J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing

1775 Expressway Drive North
Hauppauge, NY 11788
631.584.5492
Fax: 631.584.3395
www.jcbroderick.com

July 13, 2021

Mr. Steve Jacob
Nassau BOCES
George Farber Administrative Center
71 Clinton Road
Garden City, New York 11530

Re: Lead Testing in School Drinking Water
2020 Compliance 10 NYCRR Subpart 67-4

JCB#: 19-45334

Dear Mr. Jacob:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 15 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead Testing Results for Applicable Outlets
Attachment 2: Laboratory Analytical Reports
Attachment 3: Laboratory Certifications

If you have any questions, or if more information is needed, please contact our office.

Sincerely,
Paul J. Fazio
Paul J. Fazio
J C Broderick & Associates, Inc.

Attachment 1:

Lead Testing Results for Applicable Outlets



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 6/21/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/4/2021. The results are tabulated on the attached data pages for the following client designated project:

Nassau Boces, #19-45334, 195 Brookville Road, Glen Head, NY 11545

The reference number for these samples is EMSL Order #062109779. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Dominique Iaccarino, Chemistry Lab Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062109779
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 6/4/2021 04:02 PM
Collected: 6/4/2021

Project: **Nassau Boces, #19-45334, 195 Brookville Road, Glen Head, NY 11545**

Analytical Results

Client Sample Description NASS-1228 ***Collected:*** 6/4/2021 ***Lab ID:*** *062109779-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	12	3.0	µg/L	6/9/2021	AM	6/11/2021	AM

Client Sample Description NASS-1229 ***Collected:*** 6/4/2021 ***Lab ID:*** *062109779-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.9	3.0	µg/L	6/9/2021	AM	6/11/2021	AM

Client Sample Description NASS-1230 ***Collected:*** 6/4/2021 ***Lab ID:*** *062109779-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.4 J	3.0	µg/L	6/9/2021	AM	6/11/2021	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1231 ***Collected:*** 6/4/2021 ***Lab ID:*** *062109779-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.3 J	3.0	µg/L	6/9/2021	AM	6/11/2021	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1232 ***Collected:*** 6/4/2021 ***Lab ID:*** *062109779-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	6/9/2021	AM	6/11/2021	AM

Client Sample Description NASS-1233 ***Collected:*** 6/4/2021 ***Lab ID:*** *062109779-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.1 J	3.0	µg/L	6/9/2021	AM	6/11/2021	AM
Lead MDL: 1.0µg/L								

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/16/2020. The results are tabulated on the attached data pages for the following client designated project:

#19-45334, Career Preparatory High School, Nassau BOCES, 111 Cantiague Rock Rd, Westbury, NY 11590

The reference number for these samples is EMSL Order #062023892. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062023892
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 12/16/2020 05:13 PM
Collected: 12/16/2020

Project: **#19-45334, Career Preparatory High School, Nassau BOCES, 111 Cantiague Rock Rd, Westbury, NY 11590**

Analytical Results

Client Sample Description NASS-0815 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0834 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.6	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0837 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0838 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0839 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.8 J	3.0	µg/L	1/22/2021	AL	1/25/2021	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0841 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0843 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0844 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062023892
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 12/16/2020 05:13 PM
Collected: 12/16/2020

Project: **#19-45334, Career Preparatory High School, Nassau BOCES, 111 Cantiague Rock Rd, Westbury, NY 11590**

Analytical Results

Client Sample Description NASS-0844 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	1/22/2021	AL	1/25/2021	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0861 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0009*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.6	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0862 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0010*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0864 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0011*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0866 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0012*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0871 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0013*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0872 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0014*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	1/22/2021	AL	1/25/2021	AM
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062023892
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 12/16/2020 05:13 PM
Collected: 12/16/2020

Project: **#19-45334, Career Preparatory High School, Nassau BOCES, 111 Cantiague Rock Rd, Westbury, NY 11590**

Analytical Results

Client Sample Description NASS-0873 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0876 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0016*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-0877 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0017*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.5 J	3.0	µg/L	1/22/2021	AL	1/25/2021	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0889 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0018*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.7 J	3.0	µg/L	1/22/2021	AL	1/25/2021	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0892 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0019*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.7 J	3.0	µg/L	1/22/2021	AL	1/25/2021	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1253 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0020*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/22/2021	AL	1/25/2021	AM

Client Sample Description NASS-1254 ***Collected:*** 12/16/2020 ***Lab ID:*** *062023892-0021*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.4 J	3.0	µg/L	1/22/2021	AM	1/25/2021	AM
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order:	062023892
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/23/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/18/2020. The results are tabulated on the attached data pages for the following client designated project:

Nassau BOCES. Carman Road School, Carman Road,
Massapequa Park, NY 11762

The reference number for these samples is EMSL Order #062021543. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0458 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0459 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0460 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0461 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.5 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0464 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.2 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0465 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0466 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.2	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0467 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	13	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0469 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0009*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.0 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0470 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0010*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0471 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0011*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.7 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0474 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0012*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0475 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0013*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0476 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0014*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0477 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.2	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0478 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0016*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0479 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0017*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0480 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0018*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0482 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0019*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.7 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0483 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0020*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0484 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0021*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.4 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0485 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0022*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.7	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0486 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0023*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.5 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0487 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0024*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	12	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0488 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0025*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.0 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0490 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0026*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0491 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0027*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0493 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0028*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.1 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0494 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0029*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.7	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0495 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0030*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0496 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0031*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0497 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0032*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.5 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0498 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0033*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0499 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0034*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.0	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0501 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0035*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0502 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0036*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.5 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0503 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0037*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0504 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0038*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0505 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0039*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.3 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0506 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0040*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0507 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0041*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.4 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0508 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0042*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.5 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0510 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0043*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0511 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0044*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.0 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0513 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0045*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.7 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0515 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0046*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0516 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0047*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0517 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0048*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0518 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0049*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0520 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0050*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	6.2	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0521 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0051*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0522 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0052*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0523 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0053*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.2 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0525 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0054*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0526 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0055*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.2	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0528 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0056*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0529 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0057*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0529 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0057*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.6 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0530 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0058*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0531 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0059*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0532 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0060*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	84	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0533 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0061*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0534 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0062*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.7 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0535 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0063*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021543
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/18/2020 03:55 PM
Collected: 11/18/2020

Project: **Nassau BOCES. Carman Road School, Carman Road, Massapequa Park, NY 11762**

Analytical Results

Client Sample Description NASS-0536 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0064*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0537 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0065*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.0 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0538 ***Collected:*** 11/18/2020 6:08:00 AM ***Lab ID:*** *062021543-0066*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

4/26/2021

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/25/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45334, Caumsett State Park Garage, Nassau BOCES, 29 Lloyd Harbor Road, Huntington, NY 11743

The reference number for these samples is EMSL Order #062105337. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062105337
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/25/2021 10:40 AM
Collected: 3/24/2021

Project: **19-45334, Caumsett State Park Garage, Nassau BOCES, 29 Lloyd Harbor Road, Huntington, NY 11743**

Analytical Results

Client Sample Description NASS-1235 ***Collected:*** 3/24/2021 ***Lab ID:*** *062105337-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	8.1	3.0	µg/L	3/26/2021	AL	3/29/2021	AL

Client Sample Description NASS-1236 ***Collected:*** 3/24/2021 ***Lab ID:*** *062105337-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.7	3.0	µg/L	3/26/2021	AL	3/29/2021	AL

Client Sample Description NASS-1237 ***Collected:*** 3/24/2021 ***Lab ID:*** *062105337-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/26/2021	AL	3/29/2021	AL

Client Sample Description NASS-1238 ***Collected:*** 3/24/2021 ***Lab ID:*** *062105337-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/26/2021	AL	3/29/2021	AL

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com


Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/3/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45334, George Farber Administrative Center, Nassau Boces,
71 Clinton Road, Garden City, NY 11530

The reference number for these samples is EMSL Order #062104127. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:



Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-0931 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0932 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.9	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0933 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	140	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0935 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	6.0	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0936 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.6 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0937 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.3 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0938 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-0939 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.6 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0940 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0009*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.4 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0941 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0010*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.2 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0942 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0011*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.6 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0944 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0012*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0945 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0013*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.8 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0946 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0014*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-0947 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0948 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0016*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.9 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0949 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0017*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0950 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0018*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0951 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0019*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.3	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0954 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0020*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0955 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0021*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.0	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0957 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0022*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-0957 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0022*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	6.1	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0958 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0023*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.3 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0959 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0024*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0960 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0025*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	28	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0962 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0026*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.6 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0963 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0027*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	10	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0964 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0028*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-0965 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0029*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0966 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0030*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.1	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0967 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0031*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.1 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0968 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0032*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.8 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0969 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0033*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.2	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0971 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0034*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0973 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0035*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.3 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-0974 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0036*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.6 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0975 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0037*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.0 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0976 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0038*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.9 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0977 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0039*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0978 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0040*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.4 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0979 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0041*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0981 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0042*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	220	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-0982 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0043*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.7 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0983 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0044*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.7 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0984 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0045*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.2 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0985 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0046*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.9 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0986 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0047*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0987 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0048*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.8 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0988 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0049*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.7 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-0989 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0050*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	11	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0991 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0051*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.9 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0995 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0052*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0996 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0053*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	6.5	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0997 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0054*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.2 J	3.0	µg/L	3/16/2021	AM	3/17/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0998 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0055*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Client Sample Description NASS-0999 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0056*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order:	062104127
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 03:18 PM
Collected: 3/3/2021

Project: **19-45334, George Farber Administrative Center, Nassau Boces, 71 Clinton Road, Garden City, NY 11530**

Analytical Results

Client Sample Description NASS-1000 ***Collected:*** 3/3/2021 ***Lab ID:*** *062104127-0057*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.4	3.0	µg/L	3/16/2021	AM	3/17/2021	AL

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/21/2020. The results are tabulated on the attached data pages for the following client designated project:

#19-45334, Haskett Drive Complex-Building A, Nassau BOCES,
100 Haskett Drive, Syosset, NY 11791

The reference number for these samples is EMSL Order #062023633. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062023633
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 12/21/2020 10:56 AM
Collected: 12/18/2020

Project: **#19-45334, Haskett Drive Complex-Building A, Nassau BOCES, 100 Haskett Drive, Syosset, NY 11791**

Analytical Results

Client Sample Description NASS-1034 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023633-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Client Sample Description NASS-1035 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023633-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Client Sample Description NASS-1036 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023633-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Client Sample Description NASS-1037 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023633-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Client Sample Description NASS-1039 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023633-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Client Sample Description NASS-1040 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023633-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Client Sample Description NASS-1041 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023633-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order:	062023633
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/21/2020. The results are tabulated on the attached data pages for the following client designated project:

#19-45334, Haskett Drive Complex-Building C, Nassau BOCES,
100 Haskett Drive, Syosset, NY 11791

The reference number for these samples is EMSL Order #062023630. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062023630
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 12/21/2020 10:56 AM
Collected: 12/18/2020

Project: **#19-45334, Haskett Drive Complex-Building C, Nassau BOCES, 100 Haskett Drive, Syosset, NY 11791**

Analytical Results

Client Sample Description NASS-1020 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023630-0001*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/23/2020	AL

Client Sample Description NASS-1021 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023630-0002*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.5 J	3.0	µg/L	12/22/2020	AM	12/23/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1022 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023630-0003*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/23/2020	AL

Client Sample Description NASS-1023 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023630-0004*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.3	3.0	µg/L	12/22/2020	AM	12/23/2020	AL

Client Sample Description NASS-1024 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023630-0005*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.0	3.0	µg/L	12/22/2020	AM	12/23/2020	AL

Client Sample Description NASS-1025 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023630-0006*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0	µg/L	12/22/2020	AM	12/23/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1026 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023630-0007*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	16	3.0	µg/L	12/22/2020	AM	12/23/2020	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order:	062023630
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/21/2020. The results are tabulated on the attached data pages for the following client designated project:

#19-45334, Haskett Drive Complex-Building D, Nassau BOCES,
100 Haskett Drive, Syosset, NY 11791

The reference number for these samples is EMSL Order #062023632. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062023632
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 12/21/2020 10:56 AM
Collected: 12/18/2020

Project: **#19-45334, Haskett Drive Complex-Building D, Nassau BOCES, 100 Haskett Drive, Syosset, NY 11791**

Analytical Results

Client Sample Description NASS-1017 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023632-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/23/2020	AL

Client Sample Description NASS-1018 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023632-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.6	3.0	µg/L	12/22/2020	AM	12/23/2020	AL

Client Sample Description NASS-1019 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023632-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/23/2020	AL

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/21/2020. The results are tabulated on the attached data pages for the following client designated project:

#19-45334, Haskett Drive Complex-Building F, Nassau BOCES,
100 Haskett Drive, Syosset, NY 11791

The reference number for these samples is EMSL Order #062023634. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062023634
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 12/21/2020 10:56 AM
Collected: 12/18/2020

Project: **#19-45334, Haskett Drive Complex-Building F, Nassau BOCES, 100 Haskett Drive, Syosset, NY 11791**

Analytical Results

Client Sample Description NASS-1011 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023634-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	11	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Client Sample Description NASS-1012 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023634-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.9 J	3.0	µg/L	12/22/2020	AM	12/28/2020	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1013 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023634-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.9 J	3.0	µg/L	12/22/2020	AM	12/28/2020	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1014 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023634-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Client Sample Description NASS-1015 ***Collected:*** 12/18/2020 ***Lab ID:*** *062023634-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/22/2020	AM	12/28/2020	AM

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com


Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/4/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45334, Iris Wolfson High School, Nassau Boces, 21 Chestnut Street, Greenvale, NY 11548

The reference number for these samples is EMSL Order #062104129. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:



Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104129
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/4/2021 01:25 PM
Collected: 3/4/2021

Project: **19-45334, Iris Wolfson High School, Nassau Boces, 21 Chestnut Street, Greenvale, NY 11548**

Analytical Results

Client Sample Description NASS-1058 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1059 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1060 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1061 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1062 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1063 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.4 J	3.0	µg/L	3/11/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1064 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	10	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1065 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104129
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/4/2021 01:25 PM
Collected: 3/4/2021

Project: **19-45334, Iris Wolfson High School, Nassau Boces, 21 Chestnut Street, Greenvale, NY 11548**

Analytical Results

Client Sample Description NASS-1065 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.9	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1066 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0009*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.1	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1067 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0010*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.9	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1068 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0011*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	10	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1069 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0012*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	12	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1070 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0013*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.3	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1071 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0014*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.1	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1072 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104129
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/4/2021 01:25 PM
Collected: 3/4/2021

Project: **19-45334, Iris Wolfson High School, Nassau Boces, 21 Chestnut Street, Greenvale, NY 11548**

Analytical Results

Client Sample Description NASS-1072 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1074 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0016*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	3/11/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1075 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0017*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1076 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0018*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.5 J	3.0	µg/L	3/11/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1077 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0019*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1078 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0020*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

Client Sample Description NASS-1079 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0021*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/12/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104129
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/4/2021 01:25 PM
Collected: 3/4/2021

Project: **19-45334, Iris Wolfson High School, Nassau Boces, 21 Chestnut Street, Greenvale, NY 11548**

Analytical Results

Client Sample Description NASS-1080 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0022*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.5 J	3.0	µg/L	3/11/2021	AM	3/15/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1083 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0023*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.3 J	3.0	µg/L	3/11/2021	AM	3/15/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1084 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0024*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1086 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0025*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1087 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0026*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1088 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0027*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.6	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1089 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0028*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.6	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104129
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/4/2021 01:25 PM
Collected: 3/4/2021

Project: **19-45334, Iris Wolfson High School, Nassau Boces, 21 Chestnut Street, Greenvale, NY 11548**

Analytical Results

Client Sample Description NASS-1090 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0029*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.8	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1091 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0030*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	16	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1092 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0031*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1093 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0032*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1094 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0033*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1095 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0034*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.5 J	3.0	µg/L	3/11/2021	AM	3/15/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1096 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0035*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.8	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1097 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0036*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104129
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/4/2021 01:25 PM
Collected: 3/4/2021

Project: **19-45334, Iris Wolfson High School, Nassau Boces, 21 Chestnut Street, Greenvale, NY 11548**

Analytical Results

Client Sample Description NASS-1097 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0036*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.5	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1098 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0037*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.8	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1099 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0038*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.0	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1100 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0039*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Client Sample Description NASS-1101 ***Collected:*** 3/4/2021 ***Lab ID:*** *062104129-0040*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/11/2021	AM	3/15/2021	AL

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com


Attn: **Paul Fazio** 4/23/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/17/2020. The results are tabulated on the attached data pages for the following client designated project:

Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334

The reference number for these samples is EMSL Order #062021467. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:



Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0286 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0287 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0288 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0289 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0290 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0291 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0292 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0293 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0293 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0008*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0294 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0009*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0295 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0010*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0296 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0011*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0297 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0012*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0299 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0013*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0300 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0014*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0302 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0015*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0302 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0015*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0305 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0016*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0306 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0017*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0308 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0018*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0310 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0019*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0311 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0020*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/14/2020	AM	12/15/2020	DI

Client Sample Description NASS-0313 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0021*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0314 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0022*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0314 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0022*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0315 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0023*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0316 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0024*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0317 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0025*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0319 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0026*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0320 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0027*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0321 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0028*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0323 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0029*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0323 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0029*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0325 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0030*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0327 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0031*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0329 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0032*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0332 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0033*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.6 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0334 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0034*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0336 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0035*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0338 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0036*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0338 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0036*

Method	*Parameter*	*Result*		*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0	ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0344 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0037*

Method	*Parameter*	*Result*		*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0	ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0345 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0038*

Method	*Parameter*	*Result*		*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0	ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0346 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0039*

Method	*Parameter*	*Result*		*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0	ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0347 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0040*

Method	*Parameter*	*Result*		*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0	ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0348 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0041*

Method	*Parameter*	*Result*		*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0	ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0349 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0042*

Method	*Parameter*	*Result*		*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0	ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0350 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0043*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0350 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0043*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0351 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0044*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0352 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0045*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0354 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0046*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0356 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0047*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0358 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0048*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0359 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0049*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0360 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0050*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0360 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0050*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0363 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0051*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0364 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0052*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0366 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0053*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0368 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0054*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0370 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0055*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0372 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0056*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0373 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0057*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0373 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0057*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0374 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0058*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0375 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0059*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	8.7	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0376 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0060*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	81	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0377 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0061*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0378 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0062*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	39	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0379 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0063*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0380 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0064*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0380 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0064*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0381 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0065*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0382 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0066*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0383 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0067*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0384 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0068*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0385 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0069*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0386 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0070*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0387 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0071*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0387 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0071*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0388 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0072*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0389 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0073*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0390 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0074*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.9	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0391 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0075*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0393 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0076*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0394 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0077*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	13	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0395 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0078*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0395 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0078*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0396 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0079*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0397 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0080*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	34	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0398 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0081*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0399 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0082*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0400 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0083*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0402 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0084*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0406 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0085*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0406 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0085*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.3 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0407 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0086*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0409 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0087*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0411 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0088*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.8 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0413 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0089*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0414 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0090*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0416 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0091*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0418 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0092*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0419 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0093*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.3 J	3.0	µg/L	12/15/2020	AM	12/16/2020	DI
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0421 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0094*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0422 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0095*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0423 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0096*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0424 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0097*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0425 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0098*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0426 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0099*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0426 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0099*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0428 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0100*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0429 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0101*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0430 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0102*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0431 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0103*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0433 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0104*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0434 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0105*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0436 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0106*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0436 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0106*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0438 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0107*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0439 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0108*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0440 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0109*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0441 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0110*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0442 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0111*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-0444 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0112*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Client Sample Description NASS-1244 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0113*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021467
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/17/2020 12:46 PM
Collected: 11/17/2020

Project: **Jerusalem Avenue School, 2351 Jerusalem Avenue, Bellmore, NY 11710, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-1244 ***Collected:*** 11/17/2020 ***Lab ID:*** *062021467-0113*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/15/2020	AM	12/16/2020	DI

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com


Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/25/2020. The results are tabulated on the attached data pages for the following client designated project:

Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334

The reference number for these samples is EMSL Order #062022108. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:



Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0551 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0552 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0553 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0554 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0555 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0556 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0557 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0558 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0558 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0559 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0009*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0560 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0010*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0561 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0011*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0562 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0012*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0563 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0013*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0573 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0014*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0594 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0594 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0595 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0016*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0596 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0017*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0600 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0018*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0602 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0019*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0605 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0020*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.0 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0609 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0021*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.9 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0612 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0022*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.1 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0613 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0023*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0622 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0024*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0623 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0025*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0635 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0026*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.4 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0637 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0027*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.3	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0647 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0028*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.5 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0648 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0029*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0658 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0030*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0659 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0031*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0660 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0032*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0662 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0033*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0671 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0034*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.5	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0672 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0035*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	9.4	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0682 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0036*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0682 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0036*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0683 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0037*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0685 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0038*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0686 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0039*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0687 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0040*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0688 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0041*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0689 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0042*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0691 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0043*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0691 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0043*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0692 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0044*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0693 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0045*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0695 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0046*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.0	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0696 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0047*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.2	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0697 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0048*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.6	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0698 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0049*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0699 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0050*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0699 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0050*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.0 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0700 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0051*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0702 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0052*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.0 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0703 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0053*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0704 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0054*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0705 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0055*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0706 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0056*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0711 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0057*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0712 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0058*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0713 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0059*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.2 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0716 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0060*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.5	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0717 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0061*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.5	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0718 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0062*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.1	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0720 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0063*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.2 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0721 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0064*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0722 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0065*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0723 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0066*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.7	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0724 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0067*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.9 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0725 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0068*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.9	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0727 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0069*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.4	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0728 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0070*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.1 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0729 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0071*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.0 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0730 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0072*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.3 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0731 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0073*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0732 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0074*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.6	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0740 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0075*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0746 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0076*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.2 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0747 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0077*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022108
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:55 PM
Collected: 11/25/2020

Project: **Joseph M. Barry Career & Technical Education Center, 1196 Prospect Ave, Westbury, NY 11590, Nassau BOCES, #19-45334**

Analytical Results

Client Sample Description NASS-0761 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0078*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.9 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0767 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0079*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0768 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0080*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0792 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0081*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	1/5/2021	AM	1/6/2021	AL

Client Sample Description NASS-0793 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022108-0082*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	1/5/2021	AM	1/6/2021	AL
Lead MDL: 1.0µg/L								

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/23/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/20/2020. The results are tabulated on the attached data pages for the following client designated project:

LILCO House at Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11545, Nassau BOCES, 19-45334

The reference number for these samples is EMSL Order #062021700. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021700
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 02:15 PM
Collected: 11/20/2020

Project: **LILCO House at Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11545, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0249 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021700-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/25/2020	AM	11/27/2020	AL

Client Sample Description NASS-0251 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021700-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.3 J	3.0	µg/L	11/25/2020	AM	11/27/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0252 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021700-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/25/2020	AM	11/27/2020	AL

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/5/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45334, Long Island High School for the Arts, Nassau Boces,
239 Cold Spring Road, Syosset, NY 11791

The reference number for these samples is EMSL Order #062104162. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104162
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/5/2021 02:05 PM
Collected: 3/5/2021

Project: **19-45334, Long Island High School for the Arts, Nassau Boces, 239 Cold Spring Road, Syosset, NY 11791**

Analytical Results

Client Sample Description NASS-0899 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0900 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.7 J	3.0	µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0904 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0905 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.5 J	3.0	µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0906 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0907 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.4 J	3.0	µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0908 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.4	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104162
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/5/2021 02:05 PM
Collected: 3/5/2021

Project: **19-45334, Long Island High School for the Arts, Nassau Boces, 239 Cold Spring Road, Syosset, NY 11791**

Analytical Results

Client Sample Description NASS-0911 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0912 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0009*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	21	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0914 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0010*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.7	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0915 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0011*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.4	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0916 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0012*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.8	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0917 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0013*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.1 J	3.0	µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0920 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0014*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.6 J	3.0	µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062104162
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/5/2021 02:05 PM
Collected: 3/5/2021

Project: **19-45334, Long Island High School for the Arts, Nassau Boces, 239 Cold Spring Road, Syosset, NY 11791**

Analytical Results

Client Sample Description NASS-0921 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/9/2021	AM	3/15/2021	AL

Client Sample Description NASS-0922 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0016*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.0	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0923 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0017*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.2	3.0	µg/L	3/9/2021	AM	3/12/2021	AL

Client Sample Description NASS-0924 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0018*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.0 J	3.0	µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0925 ***Collected:*** 3/5/2021 ***Lab ID:*** *062104162-0019*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.6 J	3.0	µg/L	3/9/2021	AM	3/12/2021	AL
Lead MDL: 1.0µg/L								

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 6/21/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/3/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45334, North Shore Equestrian Center Barn, Nassau Boces, C.W. Post Campus, Brookville, NY 11545

The reference number for these samples is EMSL Order #062109723. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Dominique Iaccarino, Chemistry Lab Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order:	062109723
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 6/3/2021 02:03 PM
Collected: 6/3/2021

Project: **19-45334, North Shore Equestrian Center Barn, Nassau Boces, C.W. Post Campus, Brookville, NY 11545**

Analytical Results

Client Sample Description NASS-1119 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109723-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

Client Sample Description NASS-1120 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109723-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 6/21/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 6/3/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45334, Nassau Boces, C.W. Post Campus, Brookville, NY 11545

The reference number for these samples is EMSL Order #062109725. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Dominique Iaccarino, Chemistry Lab Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062109725
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 6/3/2021 02:03 PM
Collected: 6/3/2021

Project: **19-45334, Nassau Boces, C.W. Post Campus, Brookville, NY 11545**

Analytical Results

Client Sample Description NASS-1105 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109725-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

Client Sample Description NASS-1106 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109725-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

Client Sample Description NASS-1107 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109725-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

Client Sample Description NASS-1108 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109725-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

Client Sample Description NASS-1112 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109725-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

Client Sample Description NASS-1113 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109725-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	13	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

Client Sample Description NASS-1114 ***Collected:*** 6/3/2021 ***Lab ID:*** *062109725-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	14	3.0	µg/L	6/4/2021	AM	6/4/2021	AM

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order:	062109725
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com


Attn: **Paul Fazio** 4/23/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/20/2020. The results are tabulated on the attached data pages for the following client designated project:

Powell House at Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11545, Nassau BOCES, 19-45334

The reference number for these samples is EMSL Order #062021701. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:



Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order:	062021701
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 02:15 PM
Collected: 11/20/2020

Project: **Powell House at Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11545, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0247 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021701-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/25/2020	AM	11/27/2020	AL

Client Sample Description NASS-0248 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021701-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/25/2020	AM	11/27/2020	AL

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:


4/23/2021

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/3/2021. The results are tabulated on the attached data pages for the following client designated project:

19-45334, Robert E Lupinskie Center of Curriculum, Instruction and Technology, Nassau BOCES, 1 Merrick Avenue, Westbury, NY 11590

The reference number for these samples is EMSL Order #062103915. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:



Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062103915
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 3/3/2021 04:09 PM
Collected: 3/3/2021

Project: **19-45334, Robert E Lupinskie Center of Curriculum, Instruction and Technology, Nassau BOCES, 1 Merrick Avenue, Westbury, NY**

Analytical Results

Client Sample Description NASS-1199 ***Collected:*** 3/3/2021 ***Lab ID:*** *062103915-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1200 ***Collected:*** 3/3/2021 ***Lab ID:*** *062103915-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.0 J	3.0	µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1211 ***Collected:*** 3/3/2021 ***Lab ID:*** *062103915-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description NASS-1218 ***Collected:*** 3/3/2021 ***Lab ID:*** *062103915-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	3/8/2021	AM	3/9/2021	AL

Client Sample Description NASS-1222 ***Collected:*** 3/3/2021 ***Lab ID:*** *062103915-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.0 J	3.0	µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1223 ***Collected:*** 3/3/2021 ***Lab ID:*** *062103915-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.2 J	3.0	µg/L	3/8/2021	AM	3/9/2021	AL
Lead MDL: 1.0µg/L								

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com


Attn: **Paul Fazio** 4/23/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/20/2020. The results are tabulated on the attached data pages for the following client designated project:

Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334

The reference number for these samples is EMSL Order #062021777. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:



Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0001 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0002 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0003 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0004 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0005 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0007 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0008 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0009 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0009 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0010 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0009*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0011 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0010*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0013 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0011*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0014 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0012*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	37	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0015 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0013*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.4 J	3.0	µg/L	12/18/2020	AM	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0016 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0014*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	96	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0018 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0018 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0015*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0019 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0016*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0020 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0017*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0021 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0018*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0023 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0019*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0026 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0020*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0028 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0021*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0029 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0022*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0029 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0022*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0030 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0023*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0031 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0024*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0032 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0025*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0033 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0026*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0034 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0027*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0035 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0028*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0036 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0029*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0036 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0029*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0037 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0030*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0038 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0031*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0039 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0032*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0040 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0033*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.4 J	3.0	µg/L	12/18/2020	AM	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0041 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0034*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.5 J	3.0	µg/L	12/18/2020	AM	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0042 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0035*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.0 J	3.0	µg/L	12/18/2020	AM	12/22/2020	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0045 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0036*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0046 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0037*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0047 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0038*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.2	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0048 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0039*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0050 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0040*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/22/2020	AL

Client Sample Description NASS-0051 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0041*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0052 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0042*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.1 J	3.0	µg/L	12/21/2020	AL	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0053 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0043*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0053 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0043*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.2	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0054 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0044*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0055 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0045*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0056 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0046*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0057 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0047*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0059 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0048*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0060 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0049*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0061 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0050*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0061 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0050*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0062 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0051*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0063 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0052*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0064 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0053*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	5.8	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0065 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0054*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.3 J	3.0	µg/L	12/21/2020	AL	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0066 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0055*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0068 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0056*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.8 J	3.0	µg/L	12/21/2020	AL	12/22/2020	AL
Lead MDL: 1.0µg/L								

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0069 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0057*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0070 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0058*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0071 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0059*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0072 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0060*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0073 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0061*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0074 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0062*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0075 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0063*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0076 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0064*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0076 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0064*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0078 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0065*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0080 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0066*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0081 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0067*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0082 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0068*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0084 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0069*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0085 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0070*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.5	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0086 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0071*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0086 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0071*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0087 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0072*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0088 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0073*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0089 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0074*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0090 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0075*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0091 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0076*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0092 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0077*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0093 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0078*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0093 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0078*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0094 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0079*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0095 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0080*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	AL	12/22/2020	AL

Client Sample Description NASS-0096 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0081*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0097 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0082*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0098 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0083*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0099 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0084*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0101 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0085*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0101 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0085*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0103 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0086*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0104 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0087*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0105 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0088*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.6	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0106 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0089*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0107 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0090*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0108 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0091*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0109 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0092*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0109 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0092*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0110 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0093*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0111 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0094*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0112 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0095*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.9 J	3.0	µg/L	12/21/2020	DI	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0113 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0096*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.1 J	3.0	µg/L	12/21/2020	DI	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0115 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0097*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0116 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0098*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0118 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0099*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0119 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0100*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0120 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0101*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0121 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0102*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0122 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0103*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0123 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0104*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0124 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0105*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	8.2	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0125 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0106*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0125 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0106*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0126 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0107*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0127 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0108*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0128 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0109*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0129 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0110*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0130 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0111*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0131 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0112*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0132 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0113*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0132 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0113*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0133 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0114*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	8.9	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0136 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0115*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0137 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0116*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.6 J	3.0	µg/L	12/21/2020	DI	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0138 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0117*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.9	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0139 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0118*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	74	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0141 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0119*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0142 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0120*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0142 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0120*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0143 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0121*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0144 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0122*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0145 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0123*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0	µg/L	12/21/2020	DI	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0146 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0124*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0147 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0125*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0148 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0126*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0149 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0127*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0149 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0127*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0150 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0128*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.1 J	3.0	µg/L	12/21/2020	DI	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0151 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0129*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0152 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0130*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0	µg/L	12/21/2020	DI	12/22/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0153 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0131*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	110	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0154 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0132*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	58	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0155 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0133*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0156 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0134*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0157 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0135*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0158 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0136*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0159 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0137*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0160 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0138*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0161 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0139*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0162 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0140*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/22/2020	AL

Client Sample Description NASS-0163 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0141*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0163 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0141*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0164 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0142*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0165 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0143*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0166 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0144*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	7.7	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0167 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0145*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.3 J	3.0	µg/L	12/21/2020	DI	12/23/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0168 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0146*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0170 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0147*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0171 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0148*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0171 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0148*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0172 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0149*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0173 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0150*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0174 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0151*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0176 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0152*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0177 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0153*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0178 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0154*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	6.6	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0179 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0155*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0179 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0155*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	62	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0180 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0156*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0183 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0157*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0184 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0158*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0186 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0159*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0187 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0160*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0188 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0161*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0189 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0162*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0189 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0162*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	15	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0190 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0163*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	47	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0191 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0164*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0193 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0165*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	1.3 J	3.0	µg/L	12/21/2020	DI	12/23/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0194 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0166*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	14	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0195 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0167*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	120	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0197 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0168*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0199 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0169*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0199 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0169*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.3	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0200 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0170*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0201 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0171*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0202 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0172*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0203 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0173*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0204 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0174*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0205 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0175*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.0 J	3.0	µg/L	12/21/2020	DI	12/23/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0208 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0176*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0208 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0176*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0209 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0177*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0210 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0178*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0211 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0179*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	3.1	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0212 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0180*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 J	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0213 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0181*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0214 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0182*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0215 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0183*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0215 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0183*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0216 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0184*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.6	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0217 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0185*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0218 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0186*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0220 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0187*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0221 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0188*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0223 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0189*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 J	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0224 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0190*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0224 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0190*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0226 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0191*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0227 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0192*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0228 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0193*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0229 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0194*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0230 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0195*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0231 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0196*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0233 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0197*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0233 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0197*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0234 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0198*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	2.0 J	3.0	µg/L	12/21/2020	DI	12/23/2020	AL
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0235 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0199*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.0	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0237 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0200*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/21/2020	DI	12/23/2020	AL

Client Sample Description NASS-0238 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0201*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	47	3.0	µg/L	12/18/2020	AM	12/21/2020	AM

Client Sample Description NASS-0239 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0202*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	28	3.0	µg/L	12/18/2020	AM	12/21/2020	AM

Client Sample Description NASS-0240 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0203*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/21/2020	AM

Client Sample Description NASS-0241 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0204*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021777
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 04:21 PM
Collected: 11/20/2020

Project: **Rosemary Kennedy Center, 2850 N. Jerusalem Road, Wantagh, NY 11793, Nassau BOCES, 19-45334**

Analytical Results

Client Sample Description NASS-0241 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0204*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/21/2020	AM

Client Sample Description NASS-0242 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0205*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/21/2020	AM

Client Sample Description NASS-0243 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0206*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	16	3.0	µg/L	12/18/2020	AM	12/21/2020	AM

Client Sample Description NASS-0244 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0207*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.4 J	3.0	µg/L	12/18/2020	AM	12/21/2020	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-0245 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0208*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/21/2020	AM

Client Sample Description NASS-1245 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021777-0209*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	<3.0 ND	3.0	µg/L	12/18/2020	AM	12/21/2020	AM

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com


Attn: **Paul Fazio** 4/23/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/20/2020. The results are tabulated on the attached data pages for the following client designated project:

Nassau BOCES. SESSC at Rosemary Kennedy Center, 850 N. Jerusalem Road, Wantagh, NY 11793, 19-45334

The reference number for these samples is EMSL Order #062021698. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:



Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062021698
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/20/2020 02:16 PM
Collected: 11/20/2020

Project: **Nassau BOCES. SESSC at Rosemary Kennedy Center, 850 N. Jerusalem Road, Wantagh, NY 11793, 19-45334**

Analytical Results

Client Sample Description NASS-1246 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021698-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/24/2020	DI	11/25/2020	AL

Client Sample Description NASS-1247 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021698-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/24/2020	DI	11/25/2020	AL

Client Sample Description NASS-1248 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021698-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/24/2020	DI	11/25/2020	AL

Client Sample Description NASS-1251 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021698-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/24/2020	DI	11/25/2020	AL

Client Sample Description NASS-1252 ***Collected:*** 11/20/2020 ***Lab ID:*** *062021698-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	<3.0 ND	3.0	µg/L	11/24/2020	DI	11/25/2020	AL

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone: (516) 997-7251 Fax: (516) 997-7528 Email: carleplacelab@emsl.com

Attn: **Paul Fazio** 4/26/2021
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
Phone: (631) 584-5492
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 11/25/2020. The results are tabulated on the attached data pages for the following client designated project:

#19-45334, Saint Bernard's Parish, Nassau BOCES, 3100 Hempstead Turnpike, Levittown, NY 11756

The reference number for these samples is EMSL Order #062022127. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (516) 997-7251.

Approved By:

Alger Liang, Lead Laboratory Manager

NYS ELAP 11469

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:53 PM
Collected: 11/25/2020

Project: **#19-45334, Saint Bernard's Parish, Nassau BOCES, 3100 Hempstead Turnpike, Levittown, NY 11756**

Analytical Results

Client Sample Description NASS-1132 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0001*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	7.7	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1133 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0002*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	79	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1134 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0003*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	18	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1135 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0004*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	4.4	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1136 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0005*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	6.6	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1137 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0006*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	5.7	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1138 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0007*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*
200.5	Lead	23	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1139 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0008*

Method	*Parameter*	*Result*	*RL*	*Units*	*Prep Date*	*Analyst*	*Analysis Date*	*Analyst*

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order: 062022127
CustomerID: JCBR50
CustomerPO:
ProjectID:

Attn: **Paul Fazio**
J.C. Broderick & Associates
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788

Phone: (631) 584-5492
Fax:
Received: 11/25/2020 03:53 PM
Collected: 11/25/2020

Project: **#19-45334, Saint Bernard's Parish, Nassau BOCES, 3100 Hempstead Turnpike, Levittown, NY 11756**

Analytical Results

Client Sample Description NASS-1139 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0008*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	2.5 J	3.0	µg/L	12/28/2020	OR	12/29/2020	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1140 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0009*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	3.9	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1141 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0010*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	18	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1142 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0011*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	15	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1144 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0012*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	95	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

Client Sample Description NASS-1145 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0013*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	1.2 J	3.0	µg/L	12/28/2020	OR	12/29/2020	AM
Lead MDL: 1.0µg/L								

Client Sample Description NASS-1146 ***Collected:*** 11/25/2020 ***Lab ID:*** *062022127-0014*

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.5	Lead	4.9	3.0	µg/L	12/28/2020	OR	12/29/2020	AM

EMSL Analytical, Inc.
528 Mineola Avenue, Carle Place, NY 11514
Phone/Fax: (516) 997-7251 / (516) 997-7528
http://www.EMSL.com carleplacelab@emsl.com

EMSL Order:	062022127
CustomerID:	JCBR50
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - Result was below the MDL.
RL = Reporting Limit (the value below which is not defensibly quantifiable)
D = Sample was diluted

Attachment 2:

Chain of Custody
&
Laboratory Analysis



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 19-45334

Nassau BOCES

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
Brookville Outdoor Educational Center							
NASS-1228	1000A	Classroom Restroom	Bathroom Faucet	Non-Potable	6/4/2021	12	Result Below Action Level Continue O&M
NASS-1229	1000	Classroom	Water Fountain-No Chiller	Potable	6/4/2021	3.9	Result Below Action Level Continue O&M
NASS-1230	1000	Classroom	Classroom Faucet	Non-Potable	6/4/2021	2.4	Result Below Action Level Continue O&M
NASS-1231	1000B	Classroom Restroom	Bathroom Faucet	Non-Potable	6/4/2021	1.3	Result Below Action Level Continue O&M
NASS-1232	1003	Men's Restroom	Bathroom Faucet	Non-Potable	6/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1233	1002	Women's Restroom	Bathroom Faucet	Non-Potable	6/4/2021	2.1	Result Below Action Level Continue O&M
Career Preparatory High School							
NASS-0815	N/A	GYM	Water Fountain-No Chiller	Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0816	N/A	GYM	Water Fountain-No Chiller	Potable	12/16/2020	OOS	Testing Required Before Return to Service
NASS-0824	N/A	WEITHT ROOM 128	Water Cooler	Potable	12/16/2020	OOS	Testing Required Before Return to Service
NASS-0828	N/A	STUDENTS CAFETERIA	Water Cooler	Potable	12/16/2020	OOS	Testing Required Before Return to Service
NASS-0829	N/A	STUDENTS CAFETERIA	Water Cooler	Potable	12/16/2020	OOS	Testing Required Before Return to Service

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0834	N/A	CULINARY ARTS RM115	Hand Wash Only	Non-Potable	12/16/2020	5.6	Result Below Action Level Continue O&M
NASS-0837	N/A	CULINARY ARTS RM115	Hand Wash Only	Non-Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0838	N/A	CULINARY ARTS RM115	Kitchen Faucet (Cold)	Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0839	N/A	CULINARY ARTS RM115	Kitchen Faucet (Cold)	Potable	12/16/2020	2.8	Result Below Action Level Continue O&M
NASS-0840	N/A	CULINARY ARTS RM115	Ice Machine	Potable	12/16/2020	OOS	Testing Required Before Return to Service
NASS-0841	N/A	CULINARY ARTS RM115	Hand Wash Only	Non-Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0843	N/A	CULINARY ARTS RM115	Hand Wash Only	Non-Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0844	N/A	CULINARY ARTS RM115	Spray Nozzle	Non-Potable	12/16/2020	1.1	Result Below Action Level Continue O&M
NASS-0861	N/A	NURSE OFFICE 102	Nurse's Office Sink	Potable	12/16/2020	3.6	Result Below Action Level Continue O&M
NASS-0862	N/A	NURSE OFFICE 102	Bathroom Faucet	Non-Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0864	N/A	HA BY CONFERENCE RM	Water Cooler	Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0866	N/A	TEACHERS LOUNGE 113	Classroom Faucet	Non-Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0871	N/A	HA	Water Cooler	Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0872	N/A	HA	Water Cooler	Potable	12/16/2020	1.1	Result Below Action Level Continue O&M
NASS-0873	N/A	RM 218	Kitchen Faucet (Cold)	Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0874	N/A	RM 218	Water Cooler	Potable	12/16/2020	OOS	Testing Required Before Return to Service
NASS-0875	N/A	RM 218	Water Cooler	Potable	12/16/2020	OOS	Testing Required Before Return to Service
NASS-0876	N/A	HA	Water Cooler	Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0877	N/A	HA	Water Cooler	Potable	12/16/2020	1.5	Result Below Action Level Continue O&M
NASS-0889	N/A	HA BY ELEVATOR	Water Cooler	Potable	12/16/2020	2.7	Result Below Action Level Continue O&M
NASS-0892	N/A	SCIENCE RM	Bottle Fill Station	Potable	12/16/2020	1.7	Result Below Action Level Continue O&M
NASS-1253	N/A	HA	Water Cooler	Potable	12/16/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1254	N/A	HA	Water Cooler	Potable	12/16/2020	1.4	Result Below Action Level Continue O&M

Carman Road School

NASS-0458	1000D	Main Office Principal's Office	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0459	1001	Health Office	Nurse's Office Sink	Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0460	1001A	Health Office Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0461	1002	Nurse Office	Nurse's Office Sink	Potable	11/18/2020	2.5	Result Below Action Level Continue O&M
NASS-0462	1007	Kitchen	Kitchen Service Area	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0463	1007	Kitchen	Pasta Pot/Steam Kettle	Potable	6/22/2021	OOS	Testing Required Before Return to Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0464	1007	Kitchen	Kitchen Faucet (Cold)	Potable	11/18/2020	1.2	Result Below Action Level Continue O&M
NASS-0465	1007	Kitchen	Kitchen Faucet (Cold)	Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0466	1007	Kitchen	Kitchen Faucet (Cold)	Potable	11/18/2020	4.2	Result Below Action Level Continue O&M
NASS-0467	1007	Kitchen	Kitchen Faucet (Cold)	Potable	11/18/2020	13	Result Below Action Level Continue O&M
NASS-0469	1006B2	Gymnasium Volunteer Room Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	1	Result Below Action Level Continue O&M
NASS-0470	1015	Boys Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0471	1015	Boys Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	1.7	Result Below Action Level Continue O&M
NASS-0474	1018	Room 8	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0475	1017	Girls Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0476	1017	Girls Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0477	1017	Girls Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	4.2	Result Below Action Level Continue O&M
NASS-0478	1019	Room 9	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0479	1020	Room 10	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0480	1021	Room 11	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0481	1029	Corridor Room 18 to Storage Room 2	Water Cooler	Potable	6/22/2021	OOS	Testing Required Before Return to Service

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0482	1022	Room 12	Classroom Faucet	Non-Potable	11/18/2020	1.7	Result Below Action Level Continue O&M
NASS-0483	1023	Room 13	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0484	1024	Room 14	Classroom Faucet	Non-Potable	11/18/2020	1.4	Result Below Action Level Continue O&M
NASS-0485	1025	Room 15	Classroom Faucet	Non-Potable	11/18/2020	3.7	Result Below Action Level Continue O&M
NASS-0486	1026	Room 16	Classroom Faucet	Non-Potable	11/18/2020	1.5	Result Below Action Level Continue O&M
NASS-0487	1027	Room 17	Classroom Faucet	Non-Potable	11/18/2020	12	Result Below Action Level Continue O&M
NASS-0488	1028	Room 18	Classroom Faucet	Non-Potable	11/18/2020	2	Result Below Action Level Continue O&M
NASS-0489	1004	Entrance Lobby	Water Cooler	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0490	1031	Women's Restroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0491	1032	Men's Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0492	1040	Corridor Room 3 to Storage Room 1	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0493	1035	Room 7	Classroom Faucet	Non-Potable	11/18/2020	2.1	Result Below Action Level Continue O&M
NASS-0494	1035A	Room 7 Bathroom/Closet	Bathroom Faucet	Non-Potable	11/18/2020	4.7	Result Below Action Level Continue O&M
NASS-0495	1036	Room 6	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0496	1036A	Room 6 Bathroom/Closet	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0497	1037	Room 4	Classroom Faucet	Non-Potable	11/18/2020	2.5	Result Below Action Level Continue O&M
NASS-0498	1037A	Room 4 Bathroom/Closet	Bathroom Faucet	Non-Potable	11/18/2020	1.2	Result Below Action Level Continue O&M
NASS-0499	1038	Room 5	Classroom Faucet	Non-Potable	11/18/2020	4.0	Result Below Action Level Continue O&M
NASS-0500	1038A	Room 5 Bathroom/Closet	Bathroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0501	1039	Room 3	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0502	1039A	Room 3 Bathroom/Closet	Bathroom Faucet	Non-Potable	11/18/2020	2.5	Result Below Action Level Continue O&M
NASS-0503	1041	Room 1	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0504	1041A	Room 1 Changing Room/Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0505	1042A	Room 2 Changing Room/Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	2.3	Result Below Action Level Continue O&M
NASS-0506	1043A	Physical Therapy Room Changing Room/Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0507	1043	Physical Therapy Room	Classroom Faucet	Non-Potable	11/18/2020	1.4	Result Below Action Level Continue O&M
NASS-0508	1045A1	Custodial Office Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	1.5	Result Below Action Level Continue O&M
NASS-0510	1050A	Women's Faculty Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0511	1051	Faculty Room	Bathroom Faucet	Non-Potable	11/18/2020	2	Result Below Action Level Continue O&M
NASS-0513	1056	Room 20	Classroom Faucet	Non-Potable	11/18/2020	1.7	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0514	1083	Corridor Occupational Therapy to Room 20	Water Cooler	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0515	1060	Room 22	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0516	1062	Room 21	Home Economics Faucet (Cold)	Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0517	1062	Room 21	Bottle Fill Station	Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0518	1062	Room 21	Home Economics Faucet (Cold)	Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0520	1063	Room 24	Classroom Faucet	Non-Potable	11/18/2020	6.2	Result Below Action Level Continue O&M
NASS-0521	1064	Room 23	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0522	1064A	Room 23 Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0523	1065	Learning Center	Classroom Faucet	Non-Potable	11/18/2020	2.2	Result Below Action Level Continue O&M
NASS-0524	1083	Corridor Occupational Therapy to Room 20	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0525	1068	Girls Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0526	1068	Girls Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	5.2	Result Below Action Level Continue O&M
NASS-0528	1070	Boys Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0529	1071	Room 26	Classroom Faucet	Non-Potable	11/18/2020	1.6	Result Below Action Level Continue O&M
NASS-0530	1072	Room 25	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0531	1073	Room 28 / School store	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0532	1074	Room 27	Classroom Faucet	Non-Potable	11/18/2020	84	Placarded for Non-Drinking Use Until Remediated
NASS-0533	1075	Room 30	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0534	1076	Room 29	Classroom Faucet	Non-Potable	11/18/2020	1.7	Result Below Action Level Continue O&M
NASS-0535	1077	Room 32	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0536	1079	Room 34	Classroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0537	1078	Room 31	Classroom Faucet	Non-Potable	11/18/2020	1	Result Below Action Level Continue O&M
NASS-0538	1082	Bathroom	Bathroom Faucet	Non-Potable	11/18/2020	<3.0 ND	Result Below Action Level Continue O&M

Caumsett State Park Garage

NASS-1235	1006	Outdoor Education	Classroom Faucet	Non-Potable	3/24/2021	8.1	Result Below Action Level Continue O&M
NASS-1236	1007A	Nassau Boces Office/Storage	Kitchen Faucet (Cold)	Potable	3/24/2021	5.7	Result Below Action Level Continue O&M
NASS-1237	1005	Public Entry	Bottle Fill Station	Potable	3/24/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1238	1005	Public Entry	Water Cooler	Potable	3/24/2021	<3.0 ND	Result Below Action Level Continue O&M

George Farber Administrative Center

NASS-0931	0004	Room B104 Custodial Office	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0932	0004	Room B104 Custodial Office	Bathroom Faucet	Non-Potable	3/3/2021	3.9	Result Below Action Level Continue O&M
NASS-0933	1024	Human Resources Department	Water Cooler	Potable	3/3/2021	140	Removed From Service, Pending Remediation
NASS-0935	1024IB	Human Resources Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	6.0	Result Below Action Level Continue O&M
NASS-0936	1024IB	Human Resources Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	2.6	Result Below Action Level Continue O&M
NASS-0937	1024H	Human Resources Kitchen 106	Kitchen Faucet (Cold)	Potable	3/3/2021	1.3	Result Below Action Level Continue O&M
NASS-0938	1024G	Human Resources Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0939	1024G	Human Resources Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.6	Result Below Action Level Continue O&M
NASS-0940	1022	Room 105 Conference Room	Kitchen Faucet (Cold)	Potable	3/3/2021	2.4	Result Below Action Level Continue O&M
NASS-0941	1017B	General Storage Room (Formerly Arts & Education Room) Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.2	Result Below Action Level Continue O&M
NASS-0942	1017B	General Storage Room (Formerly Arts & Education Room) Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.6	Result Below Action Level Continue O&M
NASS-0944	1017A	General Storage Room (Formerly Arts & Education Room) Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.1	Result Below Action Level Continue O&M
NASS-0945	1017	General Storage Room (Formerly Arts & Education Room)	Bathroom Faucet	Non-Potable	3/3/2021	1.8	Result Below Action Level Continue O&M
NASS-0946	1009	Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0947	1009	Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0948	1007	Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.9	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0949	1007	Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0950	1001	Kitchen Room 132	Coffe Pot	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0951	1001	Kitchen Room 132	Coffe Pot	Potable	3/3/2021	4.3	Result Below Action Level Continue O&M
NASS-0954	1001	Kitchen Room 132	Kitchen Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0955	1001	Kitchen Room 132	Kitchen Faucet (Cold)	Potable	3/3/2021	4.0	Result Below Action Level Continue O&M
NASS-0957	0014	Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	6.1	Result Below Action Level Continue O&M
NASS-0958	0014	Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.3	Result Below Action Level Continue O&M
NASS-0959	0015	Administration Center Desk	Water Cooler	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0960	2000	Department Of Curriculum Instruction & Technology	Water Cooler	Potable	3/3/2021	28	Removed From Service, Pending Remediation
NASS-0962	2000H	Department Of Curriculum Instruction & Technology Men's Vestibule & Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	2.6	Result Below Action Level Continue O&M
NASS-0963	2000H	Department Of Curriculum Instruction & Technology Men's Vestibule & Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	10	Result Below Action Level Continue O&M
NASS-0964	2000G	Department Of Curriculum Instruction & Technology Room 202	Kitchen Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0965	2000J	Department Of Curriculum Instruction & Technology Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0966	2000J	Department Of Curriculum Instruction & Technology Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	3.1	Result Below Action Level Continue O&M
NASS-0967	2001I	Kitchen	Kitchen Faucet (Cold)	Potable	3/3/2021	2.1	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0968	2002B	Department Of Financial & Information Systems Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.8	Result Below Action Level Continue O&M
NASS-0969	2002B	Department Of Financial & Information Systems Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	4.2	Result Below Action Level Continue O&M
NASS-0971	2002A	Department Of Information Systems Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0973	2002A	Department Of Information Systems Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	2.3	Result Below Action Level Continue O&M
NASS-0974	2003	Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.6	Result Below Action Level Continue O&M
NASS-0975	2003	Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	2	Result Below Action Level Continue O&M
NASS-0976	2004	Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.9	Result Below Action Level Continue O&M
NASS-0977	2004	Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0978	2006	Accounting & Purchasing Department	Kitchen Faucet (Cold)	Potable	3/3/2021	1.4	Result Below Action Level Continue O&M
NASS-0979	3000	Special Education Department	Water Cooler	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0981	3000C	Special Education Department Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	220	Placarded for Non-Drinking Use Until Remediated
NASS-0982	3000C	Special Education Department Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.7	Result Below Action Level Continue O&M
NASS-0983	3000B	Special Education Department Kitchen Room 302	Kitchen Faucet (Cold)	Potable	3/3/2021	1.7	Result Below Action Level Continue O&M
NASS-0984	3000A	Special Education Department Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.2	Result Below Action Level Continue O&M
NASS-0985	3000A	Special Education Department Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	2.9	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0986	3001C	Room 315 Conference Room	Kitchen Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0987	3002C	Department Of Communication & Agency Planning Women's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.8	Result Below Action Level Continue O&M
NASS-0988	3002B	Department Of Communication & Agency Planning Mens Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.7	Result Below Action Level Continue O&M
NASS-0989	3002B	Department Of Communication & Agency Planning Mens Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	11	Result Below Action Level Continue O&M
NASS-0991	3002A	Department Of Communication & Agency Planning Ladies Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.9	Result Below Action Level Continue O&M
NASS-0993	3002A	Department Of Communication & Agency Planning Ladies Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	OOS	Testing Required Before Return to Service
NASS-0995	3004	Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	3	Result Below Action Level Continue O&M
NASS-0996	3004	Men's Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	6.5	Result Below Action Level Continue O&M
NASS-0997	3005	Ladies Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	1.2	Result Below Action Level Continue O&M
NASS-0998	3005	Ladies Bathroom	Bathroom Faucet	Non-Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0999	3007A	Board Room Kitchen	Kitchen Faucet (Cold)	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1000	3007	Board Room	Kitchen Faucet (Cold)	Potable	3/3/2021	4.4	Result Below Action Level Continue O&M

Haskett Drive Complex-Building A

NASS-1034	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1035	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1036	N/A	Kitchen	Kitchen Faucet (Cold)	Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1037	N/A	Kitchen	Kitchen Faucet (Cold)	Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1039	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1040	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1041	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M

Haskett Drive Complex-Building C

NASS-1020	N/A	Office Bathroom	Bathroom Faucet	Non-Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1021	N/A	Lunch Room	Kitchen Faucet (Cold)	Potable	12/18/2020	2.5	Result Below Action Level Continue O&M
NASS-1022	N/A	Lunch Room	Water Cooler	Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1023	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	7.3	Result Below Action Level Continue O&M
NASS-1024	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	8.0	Result Below Action Level Continue O&M
NASS-1025	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	1.1	Result Below Action Level Continue O&M
NASS-1026	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	16	Placarded for Non-Drinking Use Until Remediated

Haskett Drive Complex-Building D

NASS-1017	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1018	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	3.6	Result Below Action Level Continue O&M
NASS-1019	N/A	Office	Water Fountain-No Chiller	Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M

Haskett Drive Complex-Building F

NASS-1011	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	11	Result Below Action Level Continue O&M
NASS-1012	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	1.9	Result Below Action Level Continue O&M
NASS-1013	N/A	Office	Water Cooler	Potable	12/18/2020	1.9	Result Below Action Level Continue O&M
NASS-1014	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1015	N/A	Hallway	Water Fountain-No Chiller	Potable	12/18/2020	<3.0 ND	Result Below Action Level Continue O&M

Iris Wolfson High School

NASS-1058	N/A	Basement Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1059	N/A	Basement Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1060	N/A	Staff Restroom Unisex	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1061	N/A	Basement Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1062	N/A	Basement Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1063	N/A	Art Room B2	Classroom Faucet	Non-Potable	3/4/2021	1.4	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1064	N/A	Girl's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	10	Result Below Action Level Continue O&M
NASS-1065	N/A	Girl's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	5.9	Result Below Action Level Continue O&M
NASS-1066	N/A	Boy's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	4.1	Result Below Action Level Continue O&M
NASS-1067	N/A	Boy's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	5.9	Result Below Action Level Continue O&M
NASS-1068	N/A	Girl's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	10	Result Below Action Level Continue O&M
NASS-1069	N/A	Girl's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	12	Result Below Action Level Continue O&M
NASS-1070	N/A	Boy's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	5.3	Result Below Action Level Continue O&M
NASS-1071	N/A	Boy's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	5.1	Result Below Action Level Continue O&M
NASS-1072	N/A	Staff Restoom Men	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1074	N/A	Nurse's Office 105	Nurse's Office Sink	Potable	3/4/2021	1.1	Result Below Action Level Continue O&M
NASS-1075	N/A	Nurse's Office 105 Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1076	N/A	Principle's Office Bathroom	Bathroom Faucet	Non-Potable	3/4/2021	2.5	Result Below Action Level Continue O&M
NASS-1077	N/A	Staff Restroom Women	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1078	N/A	First Floor Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1079	N/A	First Floor Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1080	N/A	Room 104B	Kitchen Faucet (Cold)	Potable	3/4/2021	1.5	Result Below Action Level Continue O&M
NASS-1083	N/A	Second Floor Corridor	Water Cooler	Potable	3/4/2021	1.3	Result Below Action Level Continue O&M
NASS-1084	N/A	Second Floor Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1086	N/A	Staff Restroom Women	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1087	N/A	Staff Restroom Men	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1088	N/A	Boy's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	3.6	Result Below Action Level Continue O&M
NASS-1089	N/A	Boy's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	3.6	Result Below Action Level Continue O&M
NASS-1090	N/A	Girl's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	8.8	Result Below Action Level Continue O&M
NASS-1091	N/A	Girl's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	16	Placarded for Non-Drinking Use Until Remediated
NASS-1092	N/A	Student Activities 301	Ice Machine	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1093	N/A	Student Activities 301	Kitchen Faucet (Cold)	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1094	N/A	Staff Restroom Women	Bathroom Faucet	Non-Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1095	N/A	Staff Restroom Men	Bathroom Faucet	Non-Potable	3/4/2021	1.5	Result Below Action Level Continue O&M
NASS-1096	N/A	Boy's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	3.8	Result Below Action Level Continue O&M
NASS-1097	N/A	Boy's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	3.5	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1098	N/A	Girl's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	3.8	Result Below Action Level Continue O&M
NASS-1099	N/A	Girl's Restroom	Bathroom Faucet	Non-Potable	3/4/2021	5.0	Result Below Action Level Continue O&M
NASS-1100	N/A	Third Floor Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1101	N/A	Third Floor Corridor	Water Cooler	Potable	3/4/2021	<3.0 ND	Result Below Action Level Continue O&M

Jerusalem Avenue School

NASS-0286	1000A	Room 101	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0287	1001	Room 100	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0288	1002A	Room 103	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0289	1003A	Room 102	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0290	1004	Room 105	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0291	1007A	Room 107	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0292	1006A	Room 106	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0293	1008A	Room 108	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0294	1009A	Room 109	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0295	1010A	Room 111	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0296	1011	Boy's Bathroom 110	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0297	1011	Boy's Bathroom 110	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0299	1011	Boy's Bathroom 110	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0300	1011	Boy's Bathroom 110	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0302	1011	Boy's Bathroom 110	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0305	1017	Corridor Room 100 To Room 116	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0306	1013	Girl's Bathroom 113	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0308	1013	Girl's Bathroom 113	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0310	1013	Girl's Bathroom 113	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0311	1013	Girl's Bathroom 113	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0313	1013	Girl's Bathroom 113	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0314	1013	Girl's Bathroom 113	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0315	1013	Girl's Bathroom 113	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0316	1017	Corridor Room 100 To Room 116	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0317	1014A	Boiler Room Vestibule Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0319	1015A	Room 115	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0320	2023	Corridor Faculty Bath 220 To Room 200	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0321	2012	Boy's Bathroom 210	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0323	2012	Boy's Bathroom 210	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0325	2012	Boy's Bathroom 210	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0327	2012	Boy's Bathroom 210	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0329	2012	Boy's Bathroom 210	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0332	2015	Girl's Bathroom 213	Bathroom Faucet	Non-Potable	11/17/2020	1.6	Result Below Action Level Continue O&M
NASS-0334	2015	Girl's Bathroom 213	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0336	2015	Girl's Bathroom 213	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0338	2015	Girl's Bathroom 213	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0339	2015	Girl's Bathroom 213	Bathroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0340	2015	Girl's Bathroom 213	Bathroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0342	2015	Girl's Bathroom 213	Bathroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0344	2023	Corridor Faculty Bath 220 To Room 200	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0345	2022	Women's Faculty Bathroom 220	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0346	2022	Women's Faculty Bathroom 220	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0347	2022	Women's Faculty Bathroom 220	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0348	2024A2	Tech Suite Vestibule Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0349	2052	Corridor Room 246 To Tech Suite 221	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0350	2029	Room 225	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0351	2033	Room 229 Suite	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0352	2038A	Room 234	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0353	2052	Corridor Room 246 To Tech Suite 221	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0354	2040	Boy's Bathroom 236	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0356	2040	Boy's Bathroom 236	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0358	2040	Boy's Bathroom 236	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0359	2040	Boy's Bathroom 236	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0360	2040	Boy's Bathroom 236	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0363	2052	Corridor Room 246 To Tech Suite 221	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0364	2042	Girl's Bathroom 238	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0366	2042	Girl's Bathroom 238	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0368	2042	Girl's Bathroom 238	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0370	2042	Girl's Bathroom 238	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0372	2046	Art Room 242	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0373	2047	Room 243	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0374	2049	Room 245	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0375	2052	Corridor Room 246 To Tech Suite 221	Water Fountain-No Chiller	Potable	11/17/2020	8.7	Result Below Action Level Continue O&M
NASS-0376	2050A	Room 246	Classroom Faucet	Non-Potable	11/17/2020	81	Placarded for Non-Drinking Use Until Remediated
NASS-0377	2050A	Room 246	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0378	2050A	Room 246	Classroom Faucet	Non-Potable	11/17/2020	39	Placarded for Non-Drinking Use Until Remediated
NASS-0379	2050A	Room 246	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0380	1029	Women's Bathroom 126	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0381	1029	Women's Bathroom 126	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0382	1018	Room 117	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0383	1019	Health Office	Nurse's Office Sink	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0384	1019B	Health Office Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0385	1020A	Women's Bathroom 119	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0386	1020A	Women's Bathroom 119	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0387	1020A	Women's Bathroom 119	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0388	1021	Men's Bathroom 121	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0389	1021	Men's Bathroom 121	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0390	1027	Corridor Principal's Office To Room 117	Water Fountain-No Chiller	Potable	11/17/2020	8.9	Result Below Action Level Continue O&M
NASS-0391	1026B	Principal's Office Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0392	1044	Corridor Room 129 To Room 143	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0393	1032A	Room 131	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0394	1037A	Kitchen	Kitchen Faucet (Cold)	Potable	11/17/2020	13	Result Below Action Level Continue O&M
NASS-0395	1037A	Kitchen	Kitchen Faucet (Cold)	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0396	1037A	Kitchen	Kitchen Faucet (Cold)	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0397	1037A	Kitchen	Hose Bib	Non-Potable	11/17/2020	34	Placarded for Non-Drinking Use Until Remediated

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0398	1037A	Kitchen	Hose Bib	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0399	1037A	Kitchen	Kitchen Faucet (Cold)	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0400	1037A	Kitchen	Kitchen Faucet (Cold)	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0402	1037A1	Kitchen Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0404	1041B	Room 140 (Former Home Economics)	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0405	1071B	Room 173 Classroom	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0406	1070	Girl's Bathroom 172	Bathroom Faucet	Non-Potable	11/17/2020	2.3	Result Below Action Level Continue O&M
NASS-0407	1070	Girl's Bathroom 172	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0409	1070	Girl's Bathroom 172	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0411	1070	Girl's Bathroom 172	Bathroom Faucet	Non-Potable	11/17/2020	1.8	Result Below Action Level Continue O&M
NASS-0413	1073	Boys Bathroom 175	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0414	1073	Boys Bathroom 175	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0416	1073	Boys Bathroom 175	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0418	1073	Boys Bathroom 175	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0419	1082	Gym Corridor	Water Fountain-No Chiller	Potable	11/17/2020	2.3	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0421	1077A2	Custodial Vestibule 183 Office Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0422	1078A2	Gym Vestibule Boys Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0423	1078A2	Gym Vestibule Boys Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0424	1078A1A	Gym Restroom Vestibule Girls Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0425	1078A1A	Gym Restroom Vestibule Girls Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0426	1081A	Room 179 Bathroom	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0428	1080	Room 180	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0429	1080	Room 180	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0430	1047C	Room 166 Kitchenette	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0431	1047C	Room 166 Kitchenette	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0433	1065	Faculty Room 159	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0434	1064	Restroom 156 Vestibule	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0436	1064A	Restroom 156	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0438	1064A	Restroom 156	Bathroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0439	1060	Corridor Room 144 To Room 151	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0440	1057	Room 148	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0441	1055	Room 145	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0442	1054	Room 144	Classroom Faucet	Non-Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0444	1044	Corridor Room 129 To Room 143	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1244	1017	Corridor Room 100 To Room 116	Water Fountain-No Chiller	Potable	11/17/2020	<3.0 ND	Result Below Action Level Continue O&M

Joseph M. Barry Career & Technical Education Center

NASS-0551	N/A	E-133	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0552	N/A	E-125	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0553	N/A	E-124	Nurse's Office Sink	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0554	N/A	E-124	Bathroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0555	N/A	E-119	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0556	N/A	E-119	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0557	N/A	E-116	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0558	N/A	E-115	Classroom Faucet	Non-Potable	11/25/2020	1.1	Result Below Action Level Continue O&M
NASS-0559	N/A	E-115	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0560	N/A	BR NEAR E-115	Bathroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0561	N/A	E-113	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0562	N/A	E-113	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0563	N/A	E-113	Bathroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0573	N/A	E-112	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0594	N/A	HA NEAR WOMENS	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0595	N/A	HA NEAR WOMENS	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0596	N/A	E-117	Ice Machine	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0600	N/A	E-117	Pasta Pot/Steam Kettle	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0602	N/A	E-117	Kitchen Faucet (Cold)	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0605	N/A	E-117	Kitchen Faucet (Cold)	Potable	11/25/2020	2	Result Below Action Level Continue O&M
NASS-0609	N/A	E-117	Coffe Pot	Potable	11/25/2020	1.9	Result Below Action Level Continue O&M
NASS-0612	N/A	E-117	Kitchen Faucet (Cold)	Potable	11/25/2020	2.1	Result Below Action Level Continue O&M
NASS-0613	N/A	E-111	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0622	N/A	HA NEAR E-111	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0623	N/A	HA NEAR E-111	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0635	N/A	E-106	Classroom Faucet	Non-Potable	11/25/2020	2.4	Result Below Action Level Continue O&M
NASS-0637	N/A	E105	Kitchen Faucet (Cold)	Potable	11/25/2020	4.3	Result Below Action Level Continue O&M
NASS-0647	N/A	E105	Kitchen Faucet (Cold)	Potable	11/25/2020	2.5	Result Below Action Level Continue O&M
NASS-0648	N/A	E105	Coffe Pot	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0658	N/A	C231	Kitchen Faucet (Cold)	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0659	N/A	HA NEAR C231	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0660	N/A	HA NEAR C231	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0662	N/A	C230	Nurse's Office Sink	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0671	N/A	HA NEAR C223	Water Cooler	Potable	11/25/2020	3.5	Result Below Action Level Continue O&M
NASS-0672	N/A	HA NEAR C223	Water Cooler	Potable	11/25/2020	9.4	Result Below Action Level Continue O&M
NASS-0682	N/A	C217	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0683	N/A	C214	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0685	N/A	C216	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0686	N/A	C213	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0687	N/A	C213	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0688	N/A	C212	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0689	N/A	C210	Kitchen Faucet (Cold)	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0691	N/A	C201	Kitchen Faucet (Cold)	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0692	N/A	C202	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0693	N/A	C202	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0695	N/A	C207 DENTAL	Classroom Faucet	Non-Potable	11/25/2020	4.0	Result Below Action Level Continue O&M
NASS-0696	N/A	C207	Classroom Faucet	Non-Potable	11/25/2020	4.2	Result Below Action Level Continue O&M
NASS-0697	N/A	C207	Classroom Faucet	Non-Potable	11/25/2020	6.6	Result Below Action Level Continue O&M
NASS-0698	N/A	C207	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0699	N/A	C207	Classroom Faucet	Non-Potable	11/25/2020	1	Result Below Action Level Continue O&M
NASS-0700	N/A	C207	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0702	N/A	HA NEAR W316	Water Cooler	Potable	11/25/2020	1	Result Below Action Level Continue O&M
NASS-0703	N/A	HA NEAR W316	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0704	N/A	W317	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0705	N/A	W317	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0706	N/A	W317	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0711	N/A	W318	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0712	N/A	W318	Classroom Faucet	Non-Potable	11/25/2020	1.1	Result Below Action Level Continue O&M
NASS-0713	N/A	W318	Classroom Faucet	Non-Potable	11/25/2020	2.2	Result Below Action Level Continue O&M
NASS-0716	N/A	W327	Classroom Faucet	Non-Potable	11/25/2020	5.5	Result Below Action Level Continue O&M
NASS-0717	N/A	W327	Classroom Faucet	Non-Potable	11/25/2020	3.5	Result Below Action Level Continue O&M
NASS-0718	N/A	W327	Classroom Faucet	Non-Potable	11/25/2020	5.1	Result Below Action Level Continue O&M
NASS-0719	N/A	W319 TRADE	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0720	N/A	W319 TRADE	Classroom Faucet	Non-Potable	11/25/2020	1.2	Result Below Action Level Continue O&M
NASS-0721	N/A	W319 TRADE	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0722	N/A	W328 TRADE	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0723	N/A	W328 TRADE	Classroom Faucet	Non-Potable	11/25/2020	5.7	Result Below Action Level Continue O&M
NASS-0724	N/A	W328 TRADE	Classroom Faucet	Non-Potable	11/25/2020	1.9	Result Below Action Level Continue O&M
NASS-0725	N/A	W328 TRADE	Classroom Faucet	Non-Potable	11/25/2020	3.9	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0727	N/A	W320	Classroom Faucet	Non-Potable	11/25/2020	6.4	Result Below Action Level Continue O&M
NASS-0728	N/A	W320	Classroom Faucet	Non-Potable	11/25/2020	2.1	Result Below Action Level Continue O&M
NASS-0729	N/A	W320	Classroom Faucet	Non-Potable	11/25/2020	1	Result Below Action Level Continue O&M
NASS-0730	N/A	W323	Classroom Faucet	Non-Potable	11/25/2020	1.3	Result Below Action Level Continue O&M
NASS-0731	N/A	W323	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0732	N/A	W323	Classroom Faucet	Non-Potable	11/25/2020	5.6	Result Below Action Level Continue O&M
NASS-0740	N/A	W336	Classroom Faucet	Non-Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0746	N/A	HA NEAR C209	Water Cooler	Potable	11/25/2020	1.2	Result Below Action Level Continue O&M
NASS-0747	N/A	HA NEAR C209	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0761	N/A	W313	Classroom Faucet	Non-Potable	11/25/2020	1.9	Result Below Action Level Continue O&M
NASS-0763	N/A	W326	Ice Machine	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0767	N/A	HA BY W306	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0768	N/A	HA BY W306	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0769	N/A	HA BY W306	Bottle Fill Station	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0792	N/A	HA BY W323A	Water Cooler	Potable	11/25/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0793	N/A	HA BY W323A	Water Cooler	Potable	11/25/2020	1.1	Result Below Action Level Continue O&M
NASS-0800	N/A	W316	Bottle Fill Station	Potable	6/22/2021	OOS	Testing Required Before Return to Service

LILCO House at Rosemary Kennedy Center

NASS-0249	1003	Kitchen	Kitchen Faucet (Cold)	Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0251	1006	Bathroom	Bathroom Faucet	Non-Potable	11/20/2020	1.3	Result Below Action Level Continue O&M
NASS-0252	1009A	Bedroom 3 Bathroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M

Long Island High School for the Arts

NASS-0899	1057	Corridor A-8 to A-13	Water Cooler	Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0900	1060	Women's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2.7	Result Below Action Level Continue O&M
NASS-0904	1060	Women's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0905	1060	Women's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2.5	Result Below Action Level Continue O&M
NASS-0906	1061	Men's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0907	1061	Men's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2.4	Result Below Action Level Continue O&M
NASS-0908	1062A1	Nurses Office Suite Exam Room Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	3.4	Result Below Action Level Continue O&M
NASS-0911	1065G	Main Office Office 2 Now Part Of Staff Lounge	Kitchen Faucet (Cold)	Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0912	1049	Dance Studio Corridor	Water Cooler	Potable	3/5/2021	21	Removed From Service, Pending Remediation
NASS-0914	1042	Boys Bathroom/Locker Room	Bathroom Faucet	Non-Potable	3/5/2021	3.7	Result Below Action Level Continue O&M
NASS-0915	1042	Boys Bathroom/Locker Room	Bathroom Faucet	Non-Potable	3/5/2021	4.4	Result Below Action Level Continue O&M
NASS-0916	1041	Girls Bathroom/Locker Room	Bathroom Faucet	Non-Potable	3/5/2021	3.8	Result Below Action Level Continue O&M
NASS-0917	1041	Girls Bathroom/Locker Room	Bathroom Faucet	Non-Potable	3/5/2021	2.1	Result Below Action Level Continue O&M
NASS-0920	1036	Corridor Theater Lobby to Custodial Closet	Water Cooler	Potable	3/5/2021	2.6	Result Below Action Level Continue O&M
NASS-0921	1027	Room 2	Classroom Faucet	Non-Potable	3/5/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-0922	1023	Women's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	4.0	Result Below Action Level Continue O&M
NASS-0923	1023	Women's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	3.2	Result Below Action Level Continue O&M
NASS-0924	1021	Men's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	2	Result Below Action Level Continue O&M
NASS-0925	1021	Men's Bathroom	Bathroom Faucet	Non-Potable	3/5/2021	1.6	Result Below Action Level Continue O&M

North Shore Equestrian Center Barn

NASS-1119	2004	Restroom	Bathroom Faucet	Non-Potable	6/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1120	2005	Restroom	Bathroom Faucet	Non-Potable	6/3/2021	<3.0 ND	Result Below Action Level Continue O&M

North Shore Equestrian Center Indoor Arena

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1105	1003	Restroom	Bathroom Faucet	Non-Potable	6/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1106	1004	Restroom	Bathroom Faucet	Non-Potable	6/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1107	1006B	Office Bathroom	Bathroom Faucet	Non-Potable	6/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1108	1005	Restroom	Bathroom Faucet	Non-Potable	6/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1112	1008	Kitchen	Kitchen Faucet (Cold)	Potable	6/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1113	1008	Kitchen	Kitchen Faucet (Cold)	Potable	6/3/2021	13	Result Below Action Level Continue O&M
NASS-1114	1008	Kitchen	Kitchen Faucet (Cold)	Potable	6/3/2021	14	Result Below Action Level Continue O&M

Powell House at Rosemary Kennedy Center

NASS-0247	1003A	Dining Room Bathroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0248	1004	Kitchen	Kitchen Faucet (Cold)	Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M

Robert E. Lupinskie Center for Curriculum, Instruction and Technology

NASS-1199	N/A	Corridor Water Fountain	Water Cooler	Potable	3/3/2021	1.1	Result Below Action Level Continue O&M
NASS-1200	N/A	Corridor Water Fountain	Water Cooler	Potable	3/3/2021	1	Result Below Action Level Continue O&M
NASS-1211	N/A	Office Water Fountain	Water Cooler	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M
NASS-1218	N/A	Office Water Fountain	Water Cooler	Potable	3/3/2021	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1222	N/A	Employee Lounge Water Fountain	Water Cooler	Potable	3/3/2021	1	Result Below Action Level Continue O&M
NASS-1223	N/A	Employee Lounge Sink	Kitchen Faucet (Cold)	Potable	3/3/2021	1.2	Result Below Action Level Continue O&M

Rosemary Kennedy Center

NASS-0001	2000	Room 614	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0002	2002	Room 612	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0003	2003	Room 609	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0004	2004	Room 610	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0005	2005	Room 608	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0006	2006	Room 607	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0007	2008	Room 606	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0008	2010	Room 604	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0009	2011	Room 602	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0010	2013	Room 600	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0011	2014	Room 601	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0012	2018	Room 521	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0013	2020	Boys Bathroom Room 520	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0014	2020	Boys Bathroom Room 520	Bathroom Faucet	Non-Potable	11/20/2020	37	Placarded for Non-Drinking Use Until Remediated
NASS-0015	2020	Boys Bathroom Room 520	Bathroom Faucet	Non-Potable	11/20/2020	2.4	Result Below Action Level Continue O&M
NASS-0016	2020	Boys Bathroom Room 520	Bathroom Faucet	Non-Potable	11/20/2020	96	Placarded for Non-Drinking Use Until Remediated
NASS-0018	2022	Girls Bathroom Room 518	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0019	2022	Girls Bathroom Room 518	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0020	2022	Girls Bathroom Room 518	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0021	2022	Girls Bathroom Room 518	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0023	2023	Room 516	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0024	2024	Room 515 & Inner Offices	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0025	2024	Room 515 & Inner Offices	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0026	2025	Room 514	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0028	2028	Room 512	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0029	2029	Room 510	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0030	2030	Room 509	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0031	2030	Room 509	Ice Machine	Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0032	2032A	Room 508 Game Room	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0033	2033	Room 506	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0034	2034	Room 505 Home Economics Vestibule	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0035	2034	Room 505 Home Economics Vestibule	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0036	2034A	Room 505 Bathroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0037	2035	Room 505 Kitchen/Laundry Room	Home Economics Faucet (Cold)	Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0038	2035	Room 505 Kitchen/Laundry Room	Home Economics Faucet (Cold)	Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0039	2036	Women's Bathroom Room 503	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0040	2036	Women's Bathroom Room 503	Bathroom Faucet	Non-Potable	11/20/2020	1.4	Result Below Action Level Continue O&M
NASS-0041	2036	Women's Bathroom Room 503	Bathroom Faucet	Non-Potable	11/20/2020	2.5	Result Below Action Level Continue O&M
NASS-0042	2036	Women's Bathroom Room 503	Bathroom Faucet	Non-Potable	11/20/2020	1	Result Below Action Level Continue O&M
NASS-0044	2037	Room 504	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0045	2038	Room 502 School Store	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0046	2039	Boys Bathroom Room 501	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0047	2039	Boys Bathroom Room 501	Bathroom Faucet	Non-Potable	11/20/2020	4.2	Result Below Action Level Continue O&M
NASS-0048	2039	Boys Bathroom Room 501	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0050	2042	Faculty Men's Bathroom Room 400	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0051	2043	Faculty Women's Bathroom Room 402	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0052	2045	Room 404	Classroom Faucet	Non-Potable	11/20/2020	1.1	Result Below Action Level Continue O&M
NASS-0053	2046	Room 406	Classroom Faucet	Non-Potable	11/20/2020	3.2	Result Below Action Level Continue O&M
NASS-0054	2049A	Room 405 Bathroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0055	2049A	Room 405 Bathroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0056	2050	Room 410	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0057	2048	Room 408	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0059	2104	Room 103	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0060	2105	Room 105	Classroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0061	2107B	Room 107A Bathroom 2	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0062	2107	Room 107A (Space Reconstructed)	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0063	2111	Room 109	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0064	2110	Room 114	Classroom Faucet	Non-Potable	11/20/2020	5.8	Result Below Action Level Continue O&M
NASS-0065	2114	Room 116 Health Office	Nurse's Office Sink	Potable	11/19/2020	1.3	Result Below Action Level Continue O&M
NASS-0066	2114	Room 116 Health Office	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0068	2114	Room 116 Health Office	Bathroom Faucet	Non-Potable	11/19/2020	2.8	Result Below Action Level Continue O&M
NASS-0069	2112A	Room 109A Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0070	2113	Room 111	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0071	2054	Room 303	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0072	2055	Room 305	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0073	2056	Room 307	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0074	2057	Room 309	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0075	2060	Room 311	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0076	2059A	Hygiene Center Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0078	2063	Room 308	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0079	2064	Room 315	Classroom Faucet	Non-Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0080	2065	Room 317	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0081	2066	Room 310	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0082	2067	Room 312	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0084	2094	Room 200	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0085	2096	Room 201	Classroom Faucet	Non-Potable	11/19/2020	3.5	Result Below Action Level Continue O&M
NASS-0086	2095	Room 201A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0087	2093	Room 203	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0088	2091	Room 204	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0089	2091A	Room 204 Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0090	2090	Room 205	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0091	2089	Room 205A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0092	2088	Room 206	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0093	2087	Room 207	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0094	2086	Room 206A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0095	2085	Room 207A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0096	2084	Room 208	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0097	2083	Room 209	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0098	2082	Room 209A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0099	2076	Women's Bathroom Room 210B	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0101	2074	Women's Bathroom Room 210A	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0103	2075B	Room 211A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0104	2075E	Room 211 Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0105	2073	Room 212	Classroom Faucet	Non-Potable	11/19/2020	5.6	Result Below Action Level Continue O&M
NASS-0106	2072	Room 213	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0107	2071	Room 212A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0108	2070	Room 214	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0109	2069	Room 215	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0110	1016	Faculty Lounge Room 1202	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0111	1016	Faculty Lounge Room 1202	Ice Machine	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0112	1018	Men's Bathroom Room 1201	Bathroom Faucet	Non-Potable	11/19/2020	2.9	Result Below Action Level Continue O&M
NASS-0113	1018	Men's Bathroom Room 1201	Bathroom Faucet	Non-Potable	11/19/2020	1.1	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0115	1019	Women's Bathroom Room 1200	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0116	1019	Women's Bathroom Room 1200	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0118	1023	Room 1105	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0119	1025	Room 1107	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0120	1028	Bathroom Opposite 1106	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0121	1030	Room 1109	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0122	1032	Room 1111	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0123	1034	Unisex Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0124	1036A	Room 1114 Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	8.2	Result Below Action Level Continue O&M
NASS-0125	1036C	Room 1114 Sink Area	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0126	1037	Room 1113	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0127	1040	Room 914	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0128	1045	Room 910	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0129	1049	Room 906	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0130	1051	Girls Bathroom Room 904	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0131	1051	Girls Bathroom Room 904	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0132	1051	Girls Bathroom Room 904	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0133	1051	Girls Bathroom Room 904	Bathroom Faucet	Non-Potable	11/19/2020	8.9	Result Below Action Level Continue O&M
NASS-0136	1053	Boys Bathroom Room 900	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0137	1053	Boys Bathroom Room 900	Bathroom Faucet	Non-Potable	11/19/2020	2.6	Result Below Action Level Continue O&M
NASS-0138	1053	Boys Bathroom Room 900	Bathroom Faucet	Non-Potable	11/19/2020	4.9	Result Below Action Level Continue O&M
NASS-0139	1053	Boys Bathroom Room 900	Bathroom Faucet	Non-Potable	11/19/2020	74	Placarded for Non-Drinking Use Until Remediated
NASS-0141	1055	Room 1001	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0142	1055	Room 1001	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0143	1056	Kitchen Room 1000	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0144	1057	Room 1002	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0145	1058	Room 1004	Water Fountain-No Chiller	Potable	11/19/2020	1.2	Result Below Action Level Continue O&M
NASS-0146	1058	Room 1004	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0147	1060	Room 1006	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0148	1059	Room 1003	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0149	1059	Room 1003	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0150	1062	Room 1007	Classroom Faucet	Non-Potable	11/19/2020	2.1	Result Below Action Level Continue O&M
NASS-0151	1063	Room 1006A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0152	1064	Room 1008	Classroom Faucet	Non-Potable	11/19/2020	1.4	Result Below Action Level Continue O&M
NASS-0153	1064	Room 1008	Water Fountain-No Chiller	Potable	11/19/2020	110	Removed From Service, Pending Remediation
NASS-0154	1065	1000 Corridor	Water Fountain-No Chiller	Potable	11/19/2020	58	Removed From Service, Pending Remediation
NASS-0155	1066	School Store Room 701	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0156	1082	700 Corridor	Water Fountain-No Chiller	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0157	1068A	Room 703 Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0158	1070E	Room 705 Large Sink Closet	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0159	1072	Room 707	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0160	1073A	Room 707A Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0161	1074	Nurses Office Room 706	Nurse's Office Sink	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0162	1075	Medication Room	Nurse's Office Sink	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0163	1079A	Room 708A Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0164	1080	Room 711	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0165	1083C	Room 801 Conference Room Sink Closet	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0166	1085A	Room 802 Small Closet	Classroom Faucet	Non-Potable	11/19/2020	7.7	Result Below Action Level Continue O&M
NASS-0167	1086	Room 803	Classroom Faucet	Non-Potable	11/19/2020	2.3	Result Below Action Level Continue O&M
NASS-0168	1012C	Kitchen 1300 Office Vestibule	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0169	1012	Kitchen 1300	Kitchen Faucet (Cold)	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0170	1012	Kitchen 1300	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0171	1012	Kitchen 1300	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0172	1012	Kitchen 1300	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0173	1012	Kitchen 1300	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0174	1012	Kitchen 1300	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0176	1012	Kitchen 1300	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0177	1012A	Kitchen 1300 Locker Room	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0178	1012	Kitchen 1300	Pasta Pot/Steam Kettle	Potable	11/19/2020	6.6	Result Below Action Level Continue O&M
NASS-0179	1012	Kitchen 1300	Pasta Pot/Steam Kettle	Potable	11/19/2020	62	Removed From Service, Pending Remediation

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0180	1012	Kitchen 1300	Ice Machine	Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0183	1015	Room 1204 Custodial Office	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0184	1015	Room 1204 Custodial Office	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0186	1008	Women's Bathroom Room 1304	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0187	1007	Men's Bathroom Room 1306	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0188	1000	Maintenance Room/Garage	Water Fountain-No Chiller	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0189	1097	Room 1507/1509	Classroom Faucet	Non-Potable	11/19/2020	15	Result Below Action Level Continue O&M
NASS-0190	1097	Room 1507/1509	Water Fountain-No Chiller	Potable	11/19/2020	47	Removed From Service, Pending Remediation
NASS-0191	1097	Room 1507/1509	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0192	1097	Room 1507/1509	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0193	1102A	Room 1514 Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	1.3	Result Below Action Level Continue O&M
NASS-0194	1102B	Room 1514 Office	Classroom Faucet	Non-Potable	11/19/2020	14	Result Below Action Level Continue O&M
NASS-0195	1105	Men's Bathroom Room 1520	Bathroom Faucet	Non-Potable	11/19/2020	120	Placarded for Non-Drinking Use Until Remediated
NASS-0197	1106	Women's Bathroom Room 1522	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0199	1110	Room 1517	Classroom Faucet	Non-Potable	11/19/2020	3.3	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0200	1112	All Purpose Room	Water Cooler	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0201	1148	Room 1803	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0202	1147	Room 1801	Kitchen Faucet (Cold)	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0203	1150	Room 1805	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0204	1150	Room 1805	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0205	1149A1	Room 1802 Bathroom	Bathroom Faucet	Non-Potable	11/19/2020	1	Result Below Action Level Continue O&M
NASS-0208	1152	Room 1806	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0209	1154	Room Adjacent Room 1807	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0210	1153	Room 1807	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0211	1155	Room 1808/1808A	Classroom Faucet	Non-Potable	11/19/2020	3.1	Result Below Action Level Continue O&M
NASS-0212	1155	Room 1808/1808A	Classroom Faucet	Non-Potable	11/19/2020	3	Result Below Action Level Continue O&M
NASS-0213	1156	Room 1809	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0214	1133	Room 1700/1702	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0215	1133	Room 1700/1702	Water Fountain-No Chiller	Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0216	1136	Room 1704	Classroom Faucet	Non-Potable	11/19/2020	3.6	Result Below Action Level Continue O&M

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0217	1137	Room 1705/1705A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0218	1137	Room 1705/1705A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0219	1137	Room 1705/1705A	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0220	1137	Room 1705/1705A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0221	1137	Room 1705/1705A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0222	1137	Room 1705/1705A	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0223	1138	Room 1706	Classroom Faucet	Non-Potable	11/19/2020	3	Result Below Action Level Continue O&M
NASS-0224	1138	Room 1706	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0225	1138	Room 1706	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-0226	1141	Room 1708	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0227	1142	Room 1711	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0228	1142	Room 1711	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0229	1117	Girls Bathroom Room 1603	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0230	1117	Girls Bathroom Room 1603	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0231	1117	Girls Bathroom Room 1603	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-0233	1118	Boys Bathroom Room 1605	Bathroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0234	1118	Boys Bathroom Room 1605	Bathroom Faucet	Non-Potable	11/19/2020	2	Result Below Action Level Continue O&M
NASS-0235	1118	Boys Bathroom Room 1605	Bathroom Faucet	Non-Potable	11/19/2020	4.0	Result Below Action Level Continue O&M
NASS-0237	1121	Room 1608	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0238	1122	Room 1607B	Classroom Faucet	Non-Potable	11/19/2020	47	Placarded for Non-Drinking Use Until Remediated
NASS-0239	1122	Room 1607B	Water Fountain-No Chiller	Potable	11/19/2020	28	Removed From Service, Pending Remediation
NASS-0240	1124	Room 1609A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0241	1126	Room 1610	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0242	1128	Room 1611A	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0243	1129	Room 1614	Classroom Faucet	Non-Potable	11/19/2020	16	Placarded for Non-Drinking Use Until Remediated
NASS-0244	1130	Room 1613	Classroom Faucet	Non-Potable	11/19/2020	1.4	Result Below Action Level Continue O&M
NASS-0245	1130	Room 1613	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-0246	1130	Room 1613	Water Fountain-No Chiller	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-1245	2061	Room 313	Classroom Faucet	Non-Potable	11/19/2020	<3.0 ND	Result Below Action Level Continue O&M

Saint Bernard's Parish

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1132	N/A	Women's Restroom	Water Fountain-No Chiller	Potable	11/25/2020	7.7	Result Below Action Level Continue O&M
NASS-1133	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	79	Placarded for Non-Drinking Use Until Remediated
NASS-1134	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	18	Placarded for Non-Drinking Use Until Remediated
NASS-1135	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	4.4	Result Below Action Level Continue O&M
NASS-1136	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	6.6	Result Below Action Level Continue O&M
NASS-1137	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	5.7	Result Below Action Level Continue O&M
NASS-1138	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	23	Placarded for Non-Drinking Use Until Remediated
NASS-1139	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	2.5	Result Below Action Level Continue O&M
NASS-1140	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	3.9	Result Below Action Level Continue O&M
NASS-1141	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	18	Placarded for Non-Drinking Use Until Remediated
NASS-1142	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	11/25/2020	15	Result Below Action Level Continue O&M
NASS-1144	N/A	Corridor	Water Fountain-No Chiller	Potable	11/25/2020	95	Removed From Service, Pending Remediation
NASS-1145	N/A	Storage 200 Bathroom	Bathroom Faucet	Non-Potable	11/25/2020	1.2	Result Below Action Level Continue O&M
NASS-1146	N/A	Corridor	Water Fountain-No Chiller	Potable	11/25/2020	4.9	Result Below Action Level Continue O&M
NASS-1158	N/A	Kitchen	Kitchen Faucet (Cold)	Potable		OOS	Testing Required Before Return to Service

OOS= Out of Service

Outlet Number	Space ID	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result (ppb)	Remediation Actions/Current Status
NASS-1159	N/A	Kitchen	Kitchen Faucet (Cold)	Potable		OOS	Testing Required Before Return to Service
NASS-1160	N/A	Kitchen	Kitchen Faucet (Cold)	Potable		OOS	Testing Required Before Return to Service
NASS-1172	N/A	Auditorium Kitchen	Kitchen Faucet (Cold)	Potable		OOS	Testing Required Before Return to Service
NASS-1175	N/A	Corridor	Water Fountain-No Chiller	Potable		OOS	Testing Required Before Return to Service

SESSC at Rosemary Kennedy Center

NASS-1246	N/A	Kitchenette	Kitchen Faucet (Cold)	Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1247	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1248	N/A	Men's Restroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1250	N/A	O/S Women's Restroom	Water Cooler	Potable	6/22/2021	OOS	Testing Required Before Return to Service
NASS-1251	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M
NASS-1252	N/A	Women's Restroom	Bathroom Faucet	Non-Potable	11/20/2020	<3.0 ND	Result Below Action Level Continue O&M

OOS= Out of Service

Attachment 3:

Laboratory Certifications



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2022
Issued April 01, 2021

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. DANIEL CLARKE
EMSL ANALYTICAL, INC.
528 MINEOLA AVE.
CARLE PLACE, NY 11514

NY Lab Id No: 11469

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C
	SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Enterococci	SM 20, 23 9230C (Budnick 1996)
Heterotrophic Plate Count	SimPlate
	SM 20, 21-23 9215B (-04)

Metals I

Lead, Total	EPA 200.5

Miscellaneous

Asbestos	EPA 100.2

NEW YORK STATE OF OPPORTUNITY. Department of Health

Serial No.: 62991

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NELAP RECOGNIZED TNI ACCREDITATION BODY