

Lead in School Drinking Water Report

Mark Twain Elementary School



Date(s) collected: 2024-05-08

Date(s) analyzed: 2024-05-23, 2024-05-29

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389288	Main Building	Fountain/Tap Combo	D166	1 of 1	Tap	center	5
389292	Main Building	Fountain/Tap Combo	D162	1 of 1	Tap	center	3
371359	Main Building	Pot Filler	Kitchen	2 of 3	Tap	center	2
371352	Main Building	Fountain/Tap Combo	A109	1 of 1	Tap	center	1
371365	Main Building	Sink - Multi-Compartment	Kitchen	3 of 3	Tap	right	1
371366	Main Building	Fountain/Tap Combo	A107	1 of 1	Tap	center	1
389296	Main Building	Fountain/Tap Combo	C145	1 of 1	Tap	center	1
389312	Main Building	Fountain/Tap Combo	C149	1 of 1	Tap	center	1
371340	Main	Fountain/Tap	A105	1 of 1	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	Combo					
371342	Main Building	Fountain/Tap Combo	A105	1 of 1	Water Fountain	right	<1
371344	Main Building	Fountain/Tap Combo	A110	1 of 1	Tap	center	<1
371346	Main Building	Fountain/Tap Combo	A110	1 of 1	Water Fountain	right	<1
371348	Main Building	Fountain/Tap Combo	A104	1 of 1	Tap	center	<1
371350	Main Building	Fountain/Tap Combo	A104	1 of 1	Water Fountain	right	<1
371354	Main Building	Fountain/Tap Combo	A109	1 of 1	Water Fountain	right	<1
371356	Main Building	Fountain	Outside A109	1 of 1	Water Fountain	center	<1
371358	Main Building	Fountain/Tap Combo	A108	1 of 1	Tap	center	<1
371360	Main Building	Fountain/Tap Combo	A108	1 of 1	Water Fountain	right	<1
371361	Main Building	Sink - Multi-Compartment	Kitchen	3 of 3	Tap	left	<1
371362	Main Building	Fountain/Tap Combo	A102	1 of 1	Tap	center	<1
371363	Main Building	Sink - Multi-Compartment	Kitchen	3 of 3	Sprayer	left	<1
371364	Main Building	Fountain/Tap Combo	A102	1 of 1	Water Fountain	right	<1
371367	Main Building	Fountain	Multi-Purpose	1 of 2	Water Fountain	left	<1
371368	Main Building	Fountain/Tap Combo	A107	1 of 1	Water Fountain	right	<1
371369	Main Building	Fountain	Multi-Purpose	2 of 2	Water Fountain	right	<1
371370	Main Building	Fountain/Tap Combo	A101	1 of 1	Tap	center	<1
371371	Main Building	Fountain	Across From Multi	1 of 2	Water Fountain	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371372	Main Building	Fountain/Tap Combo	A101	1 of 1	Water Fountain	right	<1
371373	Main Building	Fountain	Across From Multi Purpose	2 of 2	Water Fountain	right	<1
371374	Main Building	Fountain/Tap Combo	A106	1 of 1	Tap	center	<1
371375	Main Building	Sink	B128a	1 of 1	Tap	center	<1
371376	Main Building	Fountain/Tap Combo	A106	1 of 1	Water Fountain	right	<1
371377	Main Building	Fountain	Outside Staff Lounge	1 of 2	Water Fountain	left	<1
371378	Main Building	Sink	Nurse Room	1 of 1	Tap	center	<1
371379	Main Building	Fountain	Outside Staff Lounge	2 of 2	Water Fountain	right	<1
389260	Portable 5/6	Fountain/Tap Combo	P5	1 of 1	Tap	center	<1
389261	Main Building	Sink	B123 Workroom	1 of 1	Tap	center	<1
389262	Portable 5/6	Fountain/Tap Combo	P5	1 of 1	Water Fountain	right	<1
389263	Portable 14/15	Fountain/Tap Combo	14	1 of 1	Tap	center	<1
389264	Portable 5/6	Fountain/Tap Combo	P6	1 of 1	Tap	center	<1
389265	Portable 14/15	Fountain/Tap Combo	15	1 of 1	Tap	center	<1
389266	Portable 5/6	Fountain/Tap Combo	P6	1 of 1	Water Fountain	right	<1
389267	Portable 14/15	Fountain/Tap Combo	15	1 of 1	Water Fountain	left	<1
389268	Portable	Fountain/Tap	P2	1 of 1	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	1/2	Combo					
389269	Main Building	Fountain	Outside Portable 14	1 of 1	Water Fountain	center	<1
389270	Portable 1/2	Fountain/Tap Combo	P2	1 of 1	Water Fountain	right	<1
389271	Portable 9	Fountain/Tap Combo	P9	1 of 1	Tap	center	<1
389272	Portable 1/2	Fountain/Tap Combo	P1	1 of 1	Tap	center	<1
389273	Portable 9	Fountain/Tap Combo	P9	1 of 1	Water Fountain	right	<1
389274	Main Building	Fountain/Tap Combo	D181	1 of 1	Tap	center	<1
389275	Portable 10/11	Fountain/Tap Combo	P10	1 of 1	Tap	center	<1
389276	Main Building	Fountain/Tap Combo	D181	1 of 1	Water Fountain	right	<1
389277	Portable 10/11	Fountain/Tap Combo	P10	1 of 1	Water Fountain	right	<1
389278	Main Building	Fountain/Tap Combo	D180	1 of 1	Tap	center	<1
389279	Portable 10/11	Fountain/Tap Combo	P11	1 of 1	Tap	center	<1
389280	Main Building	Fountain/Tap Combo	D180	1 of 1	Water Fountain	right	<1
389281	Portable 10/11	Fountain/Tap Combo	P11	1 of 1	Water Fountain	right	<1
389282	Main Building	Fountain/Tap Combo	Hallway Between D180 And D176	1 of 1	Tap	center	<1
389283	Portable 12/13	Fountain/Tap Combo	P12	1 of 1	Tap	center	<1
389284	Main Building	Fountain/Tap Combo	Hallway Between D180 And	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
			D176				
389285	Portable 12/13	Fountain/Tap Combo	P12	1 of 1	Water Fountain	right	<1
389286	Main Building	Fountain/Tap Combo	D170	1 of 1	Tap	center	<1
389287	Portable 12/13	Fountain/Tap Combo	P13	1 of 1	Tap	center	<1
389289	Portable 12/13	Fountain/Tap Combo	P13	1 of 1	Water Fountain	right	<1
389290	Main Building	Fountain/Tap Combo	D166	1 of 1	Water Fountain	right	<1
389291	Portable 7/8	Fountain/Tap Combo	P7	1 of 1	Tap	center	<1
389293	Portable 7/8	Fountain/Tap Combo	P8	1 of 1	Tap	center	<1
389294	Main Building	Fountain/Tap Combo	D162	1 of 1	Water Fountain	right	<1
389295	Portable 3/4	Fountain/Tap Combo	P4	1 of 1	Tap	center	<1
389297	Portable 3/4	Fountain/Tap Combo	P3	1 of 1	Tap	center	<1
389298	Main Building	Fountain/Tap Combo	C145	1 of 1	Water Fountain	right	<1
389299	Portable 3/4	Fountain/Tap Combo	P3	1 of 1	Water Fountain	right	<1
389300	Main Building	Fountain/Tap Combo	C146	1 of 1	Tap	center	<1
389301	Cafeteria	Other	Cafeteria	1 of 1	Tap	left	<1
389302	Main Building	Fountain/Tap Combo	C146	1 of 1	Water Fountain	right	<1
389303	Cafeteria	Other	Cafeteria	1 of 1	Water Bottle Filler	right	<1
389304	Main Building	Fountain/Tap Combo	C147	1 of 1	Tap	center	<1
389306	Main Building	Fountain/Tap Combo	C147	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
389308	Main Building	Fountain/Tap Combo	C148	1 of 1	Tap	center	<1
389310	Main Building	Fountain/Tap Combo	C148	1 of 1	Water Fountain	right	<1
389314	Main Building	Fountain/Tap Combo	C149	1 of 1	Water Fountain	right	<1
389316	Main Building	Fountain	Outside C149	1 of 2	Water Fountain	left	<1
389318	Main Building	Fountain	Outside C149	2 of 2	Water Fountain	right	<1
389320	Main Building	Fountain	Outside C Wing Boys Bathroom	1 of 2	Water Fountain	left	<1
389322	Main Building	Fountain	Outside C Wing Boys Bathroom	2 of 2	Water Fountain	right	<1
389324	Main Building	Fountain/Tap Combo	C150	1 of 1	Tap	center	<1
389326	Main Building	Fountain/Tap Combo	C150	1 of 1	Water Fountain	right	<1
389328	Main Building	Fountain/Tap Combo	C151	1 of 1	Tap	center	<1
389330	Main Building	Fountain/Tap Combo	C151	1 of 1	Water Fountain	right	<1
389332	Main Building	Fountain/Tap Combo	C152	1 of 1	Tap	center	<1
389334	Main Building	Fountain/Tap Combo	C152	1 of 1	Water Fountain	right	<1
389336	Main Building	Fountain/Tap Combo	C153	1 of 1	Tap	center	<1
389338	Main Building	Fountain/Tap Combo	C153	1 of 1	Water Fountain	right	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures,

multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**