



*ServiceMaster South Shore, Inc.
9 Ford Place, PO Box 399, Scituate, MA 02066
18 Jan Sebastian Drive, Unit 8, Sandwich, MA 02563
Toll Free 888-545-2700*

9/3/24

**Doug Boulanger
835 Falmouth Rd
Hyannis, Ma 02601**

Recap of Services

On Wednesday July 17th, Service Master South Shore (SMSS) was contacted by Barnstable Public Schools (BPS) regarding a suspected mold issue at Barnstable United Elementary School (BUES), discovered during their regular inspection and maintenance process at the school. The school was found to have high levels of humidity and condensation, as well as visible microbial contamination in many areas. SMSS engaged the services of Target Inspections for a microbial verification inspection, and took the following actions to remediate, as recommended in the report provided by Target Inspections:

- Installed dehumidifiers to maintain the humidity in the school at acceptable levels
- Installed HEPA 500 Air Scrubbers to begin removing any particulates from the air
- Set containment at regular intervals to prevent recontamination of areas as they are cleaned
- Removed ceiling tiles from the majority of the first floor as well as selected areas on the second floor
- Hepa vacuumed and applied an antimicrobial (Benefect Decon 30) to structure and contents in nearly all of the rooms and hallways of the first floor, as well as rooms 208, 245, and second floor hallways
- Cleaned areas that needed attention in remaining rooms on second floor
- Fogged hallways and classrooms with antimicrobial and ran air scrubbers following cleaning

Post Remediation Verification was performed by Target Inspections to confirm successful remediation.

**Steven Matthews
ServiceMaster South Shore
Project Manager
781-561-6046**