

Facility or Building Name	Hale Elementary
Did the facility test using the MDH testing	No
Facility Type (School or Child Care)	School
School ID Number or Child Care License Number	0001-03-123
Facility or Building Address	5330 13th Ave S, Minneapolis, MN 55419
Mailing Address	1225 North 7th Street, Minneapolis, MN
Contact Person	Lee Setter
Title	Manager, EH&S
Phone	612-668-0308
Email	Lee.Setter@mpls.k12.mn.us

SUMMARY	ANSWER
Total number of samples	29
Total number of fixtures sampled	29
Total number of results above 5 ppb	0
Total number of remediation actions	0
Next Scheduled Sampling Date (Month/Year)	12/2029

Unique Sample Site	Fixture Type	Location Description	Fixture Status	Sample Collection	Laboratory	Date/Time	Date/Time	Numeric Result	Unit of	Name of Laboratory Used	Remediation Action	Other	Was Remediation Successful	Additional Notes or
0001-03-123-01	Sink	120B Health Office	Active - Consumption	Initial - First Draw	24-15129	12/6/2024 03:30	12/10/2024 13:45	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-02	Drinking Fountain	RM 122 Hallway Outside Gym Left	Active - Consumption	Initial - First Draw	24-15130	12/6/2024 03:30	12/10/2024 13:51	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-03	Drinking Fountain	RM 122 Hallway Outside Gym Right	Active - Consumption	Initial - First Draw	24-15131	12/6/2024 03:31	12/10/2024 13:57	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-04	Drinking Fountain	RM 116 Hallway	Active - Consumption	Initial - First Draw	24-15132	12/6/2024 03:31	12/10/2024 14:03	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-05	Drinking Fountain	RM 108 Hallway	Active - Consumption	Initial - First Draw	24-15133	12/6/2024 03:32	12/11/2024 11:00	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-06	Drinking Fountain	RM 104 Hallway	Active - Consumption	Initial - First Draw	24-15134	12/6/2024 03:33	12/11/2024 11:06	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-07	Drinking Fountain	RM 104	Active - Consumption	Initial - First Draw	24-15135	12/6/2024 03:34	12/11/2024 11:12	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-08	Sink	Kitchen Prep Wash	Active - Consumption	Initial - First Draw	24-15136	12/6/2024 03:35	12/11/2024 11:18	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-09	Sink	Kitchen Prep	Active - Consumption	Initial - First Draw	24-15137	12/6/2024 03:35	12/11/2024 11:24	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-10	Drinking Fountain	RM 118 - Hallway (Green)	Active - Consumption	Initial - First Draw	24-15138	12/6/2024 03:36	12/11/2024 11:30	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-11	Filtered Bottle Fille	Lunch Room	Active - Consumption	Initial - First Draw	24-15139	12/6/2024 03:37	12/11/2024 11:48	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-12	Drinking Fountain	RM 115	Active - Consumption	Initial - First Draw	24-15140	12/6/2024 03:38	12/11/2024 12:06	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-13	Drinking Fountain	RM 117	Active - Consumption	Initial - First Draw	24-15141	12/6/2024 03:39	12/11/2024 12:13	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-14	Sink	RM 113B	Active - Consumption	Initial - First Draw	24-15142	12/6/2024 03:40	12/11/2024 12:19	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-15	Drinking Fountain	RM 109 Hallway	Active - Consumption	Initial - First Draw	24-15143	12/6/2024 03:42	12/11/2024 12:24	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-16	Drinking Fountain	RM 101	Active - Consumption	Initial - First Draw	24-15144	12/6/2024 03:43	12/11/2024 12:30	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-17	Drinking Fountain	RM 101A Hallway	Active - Consumption	Initial - First Draw	24-15145	12/6/2024 03:43	12/11/2024 12:37	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-18	Drinking Fountain	RM 103	Active - Consumption	Initial - First Draw	24-15146	12/6/2024 03:44	12/11/2024 12:43	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-19	Drinking Fountain	RM 205	Active - Consumption	Initial - First Draw	24-15147	12/6/2024 03:45	12/11/2024 12:48	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-20	Drinking Fountain	RM 209 Hallway	Active - Consumption	Initial - First Draw	24-15148	12/6/2024 03:46	12/11/2024 12:54	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-21	Drinking Fountain	RM 211	Active - Consumption	Initial - First Draw	24-15149	12/6/2024 03:47	12/12/2024 13:47	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-22	Drinking Fountain	RM 213	Active - Consumption	Initial - First Draw	24-15150	12/6/2024 03:48	12/12/2024 13:53	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-23	Drinking Fountain	RM 217	Active - Consumption	Initial - First Draw	24-15151	12/6/2024 03:49	12/12/2024 14:00	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-24	Drinking Fountain	RM 208	Active - Consumption	Initial - First Draw	24-15152	12/6/2024 03:51	12/12/2024 14:06	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-25	Drinking Fountain	RM 204 Common Area	Active - Consumption	Initial - First Draw	24-15153	12/6/2024 03:52	12/12/2024 14:12	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-26	Drinking Fountain	RM 216 Hallway	Active - Consumption	Initial - First Draw	24-15154	12/6/2024 03:53	12/12/2024 14:18	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-27	Drinking Fountain	RM 202 Common Area	Active - Consumption	Initial - First Draw	24-15155	12/6/2024 03:55	12/12/2024 14:24	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-28	Drinking Fountain	RM 215	Active - Consumption	Initial - First Draw	24-15156	12/6/2024 03:56	12/12/2024 14:30	ND	µg/L	Twin City Water Clinic, Inc				
0001-03-123-29	Sink	RM 214	Active - Consumption	Initial - First Draw	24-15157	12/6/2024 03:57	12/12/2024 14:36	ND	µg/L	Twin City Water Clinic, Inc				

Definitions of Reporting Fields

Field Name	Response Needed or Definition	Where does this information come
Unique Sample Site Identification Number	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	Facility
Fixture Type	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc..	Facility
Location Description	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	Facility
Fixture Status	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	Facility
Sample Collection Type	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	Facility
Laboratory Identification Number	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	Lab
Date/Time Collected	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Date/Time Analyzed	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Numeric Result	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	Lab
Unit of Measure	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	Lab
Name of Laboratory Used For Analysis	The name of the laboratory used for sample analysis.	Lab
Remediation Action	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe	Facility
Other Remediation-Please Describe	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	Facility
Was Remediation Successful (ie. Follow-up testing below 5 ppb)	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	Facility

Other Important Terms	Definitions
Consumption	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
Non-Consumption	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested.
Active	A fixture currently able to be used.
Inactive	A fixture that has been taken out of service either temporarily or permanently
First Draw	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
Flushed	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
Initial	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
Follow-up	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead.