

<b>Facility or Building Name</b>	Folwell Elementary
<b>Did the facility test using the MDH testing</b>	No
<b>Facility Type (School or Child Care)</b>	School
<b>School ID Number or Child Care License Number</b>	0001-03-222
<b>Facility or Building Address</b>	3611 20th Ave S, Minneapolis, MN
<b>Mailing Address</b>	1225 North 7th Street Minneapolis,
<b>Contact Person</b>	Lee Setter
<b>Title</b>	Manager, EH&S
<b>Phone</b>	612-668-0308
<b>Email</b>	Lee.Setter@mpls.k12.mn.us

SUMMARY	ANSWER
Total number of samples	42
Total number of fixtures sampled	42
Total number of results above 5 ppb	2
Total number of remediation actions	2
Next Scheduled Sampling Date (Month/Year)	11/2029

Fixture Type	Location Description	Fixture Status	Sample Collection	Laboratory	Date/Time	Date/Time	Numeric Result	Unit of	Name of Laboratory Used For	Remediation Action	Other	Was Remediation Successful	Additional Notes or
Drinking	B5 Choir Room - DF	Active - Consumption	Initial - First Draw	24-14128	11/15/2024 03:41	12/7/2024 13:38	8.99	µg/L	Twin City Water Clinic, Inc.	Permanantly Removed From Service		Yes	
Drinking	B9 Band Room - DF	Active - Consumption	Initial - First Draw	24-14129	11/15/2024 03:42	12/7/2024 13:47	23.2	µg/L	Twin City Water Clinic, Inc.	Permanantly Removed From Service		Yes	
sink	Eng Room 77 - Sink	Active - Consumption	Initial - First Draw	24-14130	11/15/2024 03:43	12/7/2024 13:53	ND	µg/L	Twin City Water Clinic, Inc.				
sink	Kitchen - Wash Sink	Active - Consumption	Initial - First Draw	24-14131	11/15/2024 03:44	12/7/2024 14:11	ND	µg/L	Twin City Water Clinic, Inc.				
sink	Kitchen - Prep Sink	Active - Consumption	Initial - First Draw	24-14132	11/15/2024 03:45	12/7/2024 14:30	ND	µg/L	Twin City Water Clinic, Inc.				
Sink	RM 059 Teachers Lounge - Sink	Active - Consumption	Initial - First Draw	24-14133	11/15/2024 03:46	12/7/2024 14:36	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 065 - DF Left	Active - Consumption	Initial - First Draw	24-14134	11/15/2024 03:47	12/7/2024 14:42	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 065 - DF Right	Active - Consumption	Initial - First Draw	24-14135	11/15/2024 03:48	12/7/2024 14:48	ND	µg/L	Twin City Water Clinic, Inc.				
Filtered Bottle	RM 075 Cafeteria - FBF	Active - Consumption	Initial - First Draw	24-14136	11/15/2024 03:48	12/7/2024 14:54	ND	µg/L	Twin City Water Clinic, Inc.				
sink	Hallway RM 032 - Sink	Active - Consumption	Initial - First Draw	24-14137	11/15/2024 03:49	12/7/2024 15:00	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 007 - DF Left	Active - Consumption	Initial - First Draw	24-14138	11/15/2024 03:50	12/7/2024 15:06	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 007 - DF Right	Active - Consumption	Initial - First Draw	24-14139	11/15/2024 03:50	12/7/2024 15:12	ND	µg/L	Twin City Water Clinic, Inc.				
sink	RM 108 - Sink	Active - Consumption	Initial - First Draw	24-14140	11/15/2024 03:51	12/7/2024 15:18	ND	µg/L	Twin City Water Clinic, Inc.				
sink	RM 103 - Sink	Active - Consumption	Initial - First Draw	24-14141	11/15/2024 03:51	12/7/2024 15:36	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 107 - DF Left	Active - Consumption	Initial - First Draw	24-14142	11/15/2024 03:52	12/7/2024 15:54	ND	µg/L	Twin City Water Clinic, Inc.				
Filtered Bottle	Hallway 107 - FBF Right	Active - Consumption	Initial - First Draw	24-14143	11/15/2024 03:53	12/7/2024 16:00	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 174 - DF Right	Active - Consumption	Initial - First Draw	24-14144	11/15/2024 03:54	12/7/2024 16:06	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 174 - DF Left	Active - Consumption	Initial - First Draw	24-14145	11/15/2024 03:55	12/7/2024 16:12	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 172 - DF Left	Active - Consumption	Initial - First Draw	24-14146	11/15/2024 03:55	12/7/2024 16:18	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 172 - DF Right	Active - Consumption	Initial - First Draw	24-14147	11/15/2024 03:56	12/7/2024 16:24	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 158/159 - DF Left	Active - Consumption	Initial - First Draw	24-14148	11/15/2024 03:56	12/7/2024 16:30	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 158/159 - DF Right	Active - Consumption	Initial - First Draw	24-14149	11/15/2024 03:57	12/7/2024 16:36	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway 161 - DF Left	Active - Consumption	Initial - First Draw	24-14150	11/15/2024 03:57	12/7/2024 16:42	ND	µg/L	Twin City Water Clinic, Inc.				
Filtered Bottle	Hallway 161 - FBF Right	Active - Consumption	Initial - First Draw	24-14151	11/15/2024 03:58	12/7/2024 17:00	ND	µg/L	Twin City Water Clinic, Inc.				
Sink	RM 164F - Sink	Active - Consumption	Initial - First Draw	24-14152	11/15/2024 03:58	12/7/2024 17:18	ND	µg/L	Twin City Water Clinic, Inc.				
Sink	RM 164G - Sink	Active - Consumption	Initial - First Draw	24-14153	11/15/2024 03:58	12/7/2024 17:24	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 232 - DF Left	Active - Consumption	Initial - First Draw	24-14154	11/15/2024 03:59	12/7/2024 17:30	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 232 - DF Right	Active - Consumption	Initial - First Draw	24-14155	11/15/2024 03:59	12/7/2024 17:36	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 274 - DF Left	Active - Consumption	Initial - First Draw	24-14156	11/15/2024 04:02	12/7/2024 17:42	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 274 - DF Right	Active - Consumption	Initial - First Draw	24-14157	11/15/2024 04:04	12/7/2024 17:48	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 252 - DF Left	Active - Consumption	Initial - First Draw	24-14158	11/15/2024 04:05	12/7/2024 17:54	ND	µg/L	Twin City Water Clinic, Inc.				
Filtered Bottle	Hallway RM 252 - FBF Right	Active - Consumption	Initial - First Draw	24-14159	11/15/2024 04:06	12/7/2024 18:00	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 207 - DF Left	Active - Consumption	Initial - First Draw	24-14160	11/15/2024 04:07	12/7/2024 18:06	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 207 - DF Right	Active - Consumption	Initial - First Draw	24-14161	11/15/2024 04:08	12/7/2024 12:20	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 307 - DF Left	Active - Consumption	Initial - First Draw	24-14162	11/15/2024 04:09	12/7/2024 12:43	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 307 - FBF Right	Active - Consumption	Initial - First Draw	24-14163	11/15/2024 04:11	12/7/2024 12:49	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 330 - DF Left	Active - Consumption	Initial - First Draw	24-14164	11/15/2024 04:12	12/7/2024 12:55	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 330 - DF Right	Active - Consumption	Initial - First Draw	24-14165	11/15/2024 04:20	12/7/2024 13:01	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 374 - DF Left	Active - Consumption	Initial - First Draw	24-14166	11/15/2024 04:21	12/7/2024 13:08	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 374 - DF Right	Active - Consumption	Initial - First Draw	24-14167	11/15/2024 04:22	12/7/2024 13:14	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 362 - DF Left	Active - Consumption	Initial - First Draw	24-14168	11/15/2024 04:24	12/7/2024 13:20	ND	µg/L	Twin City Water Clinic, Inc.				
Drinking	Hallway RM 362 - DF Right	Active - Consumption	Initial - First Draw	24-14169	11/15/2024 04:25	12/7/2024 13:26	ND	µg/L	Twin City Water Clinic, Inc.				

**Definitions of Reporting Fields**

Field Name	Response Needed or Definition	Where does this information come
<b>Unique Sample Site Identification Number</b>	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	<b>Facility</b>
<b>Fixture Type</b>	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc..	<b>Facility</b>
<b>Location Description</b>	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	<b>Facility</b>
<b>Fixture Status</b>	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	<b>Facility</b>
<b>Sample Collection Type</b>	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	<b>Facility</b>
<b>Laboratory Identification Number</b>	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	<b>Lab</b>
<b>Date/Time Collected</b>	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	<b>Lab</b>
<b>Date/Time Analyzed</b>	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	<b>Lab</b>
<b>Numeric Result</b>	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	<b>Lab</b>
<b>Unit of Measure</b>	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	<b>Lab</b>
<b>Name of Laboratory Used For Analysis</b>	The name of the laboratory used for sample analysis.	<b>Lab</b>
<b>Remediation Action</b>	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe	<b>Facility</b>
<b>Other Remediation-Please Describe</b>	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	<b>Facility</b>
<b>Was Remediation Successful (ie. Follow-up testing below 5 ppb)</b>	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	<b>Facility</b>

Other Important Terms	Definitions
<b>Consumption</b>	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
<b>Non-Consumption</b>	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested.
<b>Active</b>	A fixture currently able to be used.
<b>Inactive</b>	A fixture that has been taken out of service either temporarily or permanently
<b>First Draw</b>	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
<b>Flushed</b>	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
<b>Initial</b>	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
<b>Follow-up</b>	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead.