



Date: 12/15/20

Performed by: Andrew Tinklenberg

Location: Wilder-Wellstone School

RE: Radon Testing

INTRODUCTION

From December 7 – 10, 2020, radon testing was performed within Wilder-Wellstone School. The testing was performed in frequently-occupied ground contact rooms and rooms immediately above unoccupied spaces (crawl spaces and tunnels) that are in contact with the ground per the Environmental Protection Agency (EPA) and Minnesota Department of Health (MDH) guidelines.

SUMMARY OF FINDINGS

All of the areas that were tested were found to have radon gas levels below 4.0 picocuries per liter of air (pCi/L), which is the EPA and MDH action level. (Note: Duplicate (side-by-side) sampling was conducted in select areas at a rate of 10% of areas tested, and Rooms A, B, C & D were the blank samples.)

Please refer to the attached AirChek radon testing report and sample diagrams for further information concerning the radon testing, areas that were tested, and the radon levels that were found to be present. Per MDH requirements, this information will be shared with the local regulatory agency (MDH). The information will also be posted on the EH&S webpage available through the main MPS website and maintained on file by EH&S.

If you have any questions regarding this information, please feel free to contact me. Thank you,

Andrew Tinklenberg
NRPP ID# 111389 RT



Safety Specialist - Environmental Health & Safety

Minneapolis Public Schools

Environmental Health & Safety - Facilities Dept.

andrew.tinklenberg@mpls.k12.mn.us

612-668-0306 Phone

612-668-0310 EH & S General Office

612-668-0275 Fax



I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9512618	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CUSTODIAN AC101	WILDER/WELLSTONE	1	0.6
9512619	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS AC102	WILDER/WELLSTONE	1	0.6
9512620	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS AC102	WILDER/WELLSTONE	1	0.8
9512621	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS AC103	WILDER/WELLSTONE	1	0.8
9512622	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CAFETERIA AC105	WILDER/WELLSTONE	1	0.6
9512623	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	STAFF C110	WILDER/WELLSTONE	1	< 0.3
9512624	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C107	WILDER/WELLSTONE	1	< 0.3
9512625	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C105A	WILDER/WELLSTONE	1	< 0.3
9512626	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C105	WILDER/WELLSTONE	1	< 0.3
9512627	2020-12-07	7:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C103	WILDER/WELLSTONE	1	< 0.3
9512628	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C104	WILDER/WELLSTONE	1	< 0.3
9512629	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C102	WILDER/WELLSTONE	1	< 0.3
9512630	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C100/C101	WILDER/WELLSTONE	1	< 0.3
9512631	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C170	WILDER/WELLSTONE	2	0.6
9512632	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C183	WILDER/WELLSTONE	2	< 0.3
9512633	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C182	WILDER/WELLSTONE	2	< 0.3
9512634	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C179	WILDER/WELLSTONE	2	< 0.3
9512635	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C180/C181	WILDER/WELLSTONE	2	0.6
9512636	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C180/C181	WILDER/WELLSTONE	2	< 0.3
9512637	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C178	WILDER/WELLSTONE	2	0.5
9512638	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C122	WILDER/WELLSTONE	1	0.9
9512639	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C123	WILDER/WELLSTONE	1	0.6
9512640	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C121	WILDER/WELLSTONE	1	< 0.3
9512641	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C120B	WILDER/WELLSTONE	1	< 0.3
9512642	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS C120A	WILDER/WELLSTONE	1	< 0.3
9512643	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C118	WILDER/WELLSTONE	1	< 0.3
9512644	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C114	WILDER/WELLSTONE	1	0.6
9512645	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C114F	WILDER/WELLSTONE	1	< 0.3
9512646	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C114E	WILDER/WELLSTONE	1	< 0.3
9512647	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C114D	WILDER/WELLSTONE	1	< 0.3
9512648	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE C114B	WILDER/WELLSTONE	1	< 0.3
9512649	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	MULTI-PURPOSE A113/A119	WILDER/WELLSTONE	1	< 0.3
9512650	2020-12-07	8:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A115	WILDER/WELLSTONE	1	< 0.3
9512651	2020-12-07	9:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A116	WILDER/WELLSTONE	1	< 0.3
9512652	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A122	WILDER/WELLSTONE	1	0.5

I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9512653	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A121	WILDER/WELLSTONE	1	0.5
9512654	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A124	WILDER/WELLSTONE	1	0.7
9512655	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A126	WILDER/WELLSTONE	1	0.7
9512656	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A126	WILDER/WELLSTONE	1	0.7
9512657	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A128	WILDER/WELLSTONE	1	0.6
9512658	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A130	WILDER/WELLSTONE	1	0.7
9512659	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A132	WILDER/WELLSTONE	1	0.7
9512660	2020-12-07	9:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	MUSIC A14	WILDER/WELLSTONE	1	< 0.3
9512661	2020-12-07	9:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	AUDITORIUM A12	WILDER/WELLSTONE	1	< 0.3
9512662	2020-12-07	9:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A2	WILDER/WELLSTONE	1	< 0.3
9512663	2020-12-07	9:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A3	WILDER/WELLSTONE	1	< 0.3
9512664	2020-12-07	9:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A1	WILDER/WELLSTONE	1	0.5
9512665	2020-12-07	9:00 am	2020-12-10	2:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A5	WILDER/WELLSTONE	1	< 0.3
9512666	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A6	WILDER/WELLSTONE	1	< 0.3
9512667	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A116/A117	WILDER/WELLSTONE	1	< 0.3
9512668	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A116/A117	WILDER/WELLSTONE	1	< 0.3
9512669	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A109	WILDER/WELLSTONE	1	0.6
9512670	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A106	WILDER/WELLSTONE	1	0.6
9512671	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE A103	WILDER/WELLSTONE	1	0.6
9512672	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A104	WILDER/WELLSTONE	1	< 0.3
9512673	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A107	WILDER/WELLSTONE	1	< 0.3
9512674	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A108	WILDER/WELLSTONE	1	< 0.3
9512675	2020-12-07	9:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS A108	WILDER/WELLSTONE	1	< 0.3
9512676	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	STAFF AB101	WILDER/WELLSTONE	1	< 0.3
9512677	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS AB103	WILDER/WELLSTONE	1	0.6
9512678	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CAFETERIA AB104	WILDER/WELLSTONE	1	< 0.3
9512679	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE AB104A	WILDER/WELLSTONE	1	< 0.3
9512680	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE AB104B	WILDER/WELLSTONE	1	< 0.3
9512681	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS AB102	WILDER/WELLSTONE	1	0.5
9512682	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE AB105A	WILDER/WELLSTONE	1	0.8
9512683	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	STAFF B110	WILDER/WELLSTONE	1	0.6
9512684	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B114	WILDER/WELLSTONE	1	< 0.3
9512685	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B114A	WILDER/WELLSTONE	1	< 0.3
9512686	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B114B	WILDER/WELLSTONE	1	< 0.3
9512687	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B114C	WILDER/WELLSTONE	1	< 0.3

I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9512688	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B114D	WILDER/WELLSTONE	1	< 0.3
9512689	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B114E	WILDER/WELLSTONE	1	< 0.3
9512690	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B114F	WILDER/WELLSTONE	1	0.7
9512691	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B118	WILDER/WELLSTONE	1	< 0.3
9512692	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B120	WILDER/WELLSTONE	1	< 0.3
9512693	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B121	WILDER/WELLSTONE	1	< 0.3
9512694	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B121	WILDER/WELLSTONE	1	0.6
9512695	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B122	WILDER/WELLSTONE	1	0.5
9512696	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B123	WILDER/WELLSTONE	1	< 0.3
9512697	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B124	WILDER/WELLSTONE	1	< 0.3
9512698	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B127	WILDER/WELLSTONE	1	< 0.3
9512699	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B100	WILDER/WELLSTONE	1	0.8
9512700	2020-12-07	10:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B102	WILDER/WELLSTONE	1	2.9
9512701	2020-12-07	11:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B103	WILDER/WELLSTONE	1	< 0.3
9512702	2020-12-07	11:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B104	WILDER/WELLSTONE	1	< 0.3
9512703	2020-12-07	11:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B102A	WILDER/WELLSTONE	1	2.0
9512704	2020-12-07	11:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	CLASS B105	WILDER/WELLSTONE	1	2.2
9512705	2020-12-07	11:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	MEDIA CENTER B	WILDER/WELLSTONE	2	< 0.3
9512706	2020-12-07	11:00 am	2020-12-10	4:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B175	WILDER/WELLSTONE	2	0.7
9512707	2020-12-07	11:00 am	2020-12-10	4:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B170	WILDER/WELLSTONE	2	0.6
9512708	2020-12-07	11:00 am	2020-12-10	4:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B173/174	WILDER/WELLSTONE	2	< 0.3
9512709	2020-12-07	11:00 am	2020-12-10	4:00 pm	70	MPS	WILDER/WELLSTONE	OFFICE B173/174	WILDER/WELLSTONE	2	< 0.3
9512710	2020-12-07	11:00 am	2020-12-10	3:00 pm	70	MPS	WILDER/WELLSTONE	MEDIA CENTER B	WILDER/WELLSTONE	2	< 0.3
9512711	2020-12-07	11:00 am	2020-12-10	4:00 pm	70	MPS	WILDER/WELLSTONE	ROOM A	WILDER/WELLSTONE	2	< 0.3
9512712	2020-12-07	11:00 am	2020-12-10	4:00 pm	70	MPS	WILDER/WELLSTONE	ROOM B	WILDER/WELLSTONE	2	< 0.3
9512713	2020-12-07	11:00 am	2020-12-10	4:00 pm	70	MPS	WILDER/WELLSTONE	ROOM C	WILDER/WELLSTONE	2	< 0.3
9512714	2020-12-07	11:00 am	2020-12-10	4:00 pm	70	MPS	WILDER/WELLSTONE	ROOM D	WILDER/WELLSTONE	2	< 0.3