

Lead in School Drinking Water Report

Longfellow Elementary School



Date(s) collected: 2024-06-05

Date(s) analyzed: 2024-06-27, 2024-07-03

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371669	Main Building	Fountain	Teacher Lounge	1 of 1	Water Fountain	center	12
371675	Main Building	Fountain /Tap Combo	Rm 6	1 of 1	Water Fountain	left	12
371660	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	left	8
371705	Main Building	Sink	Art Storage Rm	1 of 1	Tap	center	7
371702	Main Building	Fountain /Tap Combo	Rm 23	1 of 1	Water Fountain	left	6
371703	Main Building	Sink	Music Rm	1 of 1	Tap	center	6
371664	Main Building	Pot Filler	Kitchen	2 of 2	Tap	center	5
371665	Main	Fountain	Rm 9	1 of 1	Water	left	4

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	/Tap Combo			Fountain		
371679	Main Building	Fountain /Tap Combo	Rm 5	1 of 1	Water Fountain	left	4
371682	Main Building	Fountain /Tap Combo	Rm 16	1 of 1	Water Fountain	left	4
371684	Main Building	Fountain /Tap Combo	Rm 12	1 of 1	Tap	center	4
371723	Main Building	Fountain /Tap Combo	Rm 24	1 of 1	Water Fountain	left	3
371735	Main Building	Fountain /Tap Combo	Rm 20	1 of 1	Water Fountain	left	3
371737	Main Building	Fountain /Tap Combo	Rm 21	1 of 1	Tap	center	3
371690	Main Building	Fountain /Tap Combo	Rm 10	1 of 1	Water Fountain	left	2
371693	Main Building	Fountain /Tap Combo	Rm 2	1 of 1	Water Fountain	left	2
371694	Main Building	Fountain /Tap Combo	Rm 11	1 of 1	Water Fountain	left	2
371698	Main Building	Fountain /Tap Combo	Rm 13	1 of 1	Water Fountain	left	2
371725	Main Building	Fountain /Tap Combo	Rm 25	1 of 1	Tap	center	2
371739	Main Building	Fountain /Tap Combo	Rm 21	1 of 1	Water Fountain	left	2
371661	Main	Fountain	Between	1 of 1	Water	center	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building		Rm 11 And 13		Fountain		
371668	Portable 29	Fountain /Tap Combo	P29	1 of 1	Tap	center	1
371673	Main Building	Fountain /Tap Combo	Rm 6	1 of 1	Tap	center	1
371677	Main Building	Fountain /Tap Combo	Rm 5	1 of 1	Tap	center	1
371685	Main Building	Fountain /Tap Combo	Rm 4	1 of 1	Water Fountain	left	1
371686	Main Building	Fountain /Tap Combo	Rm 12	1 of 1	Water Fountain	left	1
371689	Main Building	Fountain /Tap Combo	Rm 3	1 of 1	Water Fountain	left	1
371692	Main Building	Fountain /Tap Combo	Rm 11	1 of 1	Tap	center	1
371695	Main Building	Fountain	Between Rm 3 And 2	1 of 1	Water Fountain	center	1
371700	Main Building	Fountain /Tap Combo	Rm 23	1 of 1	Tap	center	1
371711	Main Building	Fountain	Between Rm 27 And 28	1 of 1	Water Fountain	center	1
371719	Main Building	Fountain /Tap Combo	Rm 26	1 of 1	Water Fountain	left	1
371727	Main Building	Fountain /Tap Combo	Rm 25	1 of 1	Water Fountain	left	1
371729	Main	Fountain	Rm 22	1 of 1	Tap	center	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	/Tap Combo					
371662	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	right	<1
371663	Main Building	Fountain /Tap Combo	Rm 9	1 of 1	Tap	center	<1
371666	Main Building	Fountain	Cafeteria Hallway	1 of 1	Water Fountain	center	<1
371667	Main Building	Sink	Library Workroom	1 of 1	Tap	center	<1
371670	Main Building	Fountain /Tap Combo	P29	1 of 1	Water Fountain	left	<1
371671	Main Building	Sink	Teacher Lounge Kitchen	1 of 1	Tap	center	<1
371672	Portable 19	Fountain /Tap Combo	P19	1 of 1	Tap	center	<1
371674	Portable 19	Fountain /Tap Combo	P19	1 of 1	Water Fountain	left	<1
371676	Main Building	Fountain /Tap Combo	Rm 15	1 of 1	Tap	center	<1
371678	Main Building	Fountain /Tap Combo	Rm 15	1 of 1	Water Fountain	left	<1
371680	Main Building	Fountain /Tap Combo	Rm 16	1 of 1	Tap	center	<1
371681	Main Building	Fountain	Between 5 And 4	1 of 1	Water Fountain	center	<1
371683	Main Building	Fountain /Tap	Rm 4	1 of 1	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
		Combo					
371687	Main Building	Fountain /Tap Combo	Rm 3	1 of 1	Tap	center	<1
371688	Main Building	Fountain /Tap Combo	Rm 10	1 of 1	Tap	center	<1
371691	Main Building	Fountain /Tap Combo	Rm 2	1 of 1	Tap	center	<1
371696	Main Building	Fountain /Tap Combo	Rm 13	1 of 1	Tap	center	<1
371697	Main Building	Fountain /Tap Combo	Rm 1	1 of 1	Tap	center	<1
371699	Main Building	Fountain /Tap Combo	Rm 1	1 of 1	Water Fountain	left	<1
371701	Main Building	Sink	Health Room	1 of 1	Tap	center	<1
371707	Main Building	Fountain /Tap Combo	Rm 27	1 of 1	Tap	center	<1
371709	Main Building	Fountain /Tap Combo	Rm 27	1 of 1	Water Fountain	left	<1
371713	Main Building	Fountain /Tap Combo	Rm 28	1 of 1	Tap	center	<1
371715	Main Building	Fountain /Tap Combo	Rm 28	1 of 1	Water Fountain	left	<1
371717	Main Building	Fountain /Tap Combo	Rm 26	1 of 1	Tap	center	<1
371721	Main Building	Fountain /Tap Combo	Rm 24	1 of 1	Tap	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371731	Main Building	Fountain /Tap Combo	Rm 22	1 of 1	Water Fountain	left	<1
371733	Main Building	Fountain /Tap Combo	Rm 20	1 of 1	Tap	center	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**