

Lead in School Drinking Water Report

Longfellow Elementary School - Post-remediation



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2024-10-09

Date(s) analyzed: 2024-10-28, 2024-10-29

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	389596	Main Building	Fountain/Tap Combo	Rm 9	1 of 1	Water Fountain	left	23
2	389594	Main Building	Fountain/Tap Combo	Rm 23	1 of 1	Water Fountain	left	19
3	389600	Main Building	Fountain/Tap Combo	Rm 16	1 of 1	Water Fountain	left	16
4	389580	Main Building	Sink	Art Storage Rm	1 of 1	Tap	center	13
5	389592	Main Building	Fountain/Tap Combo	Rm 5	1 of 1	Water Fountain	left	11
6	389582	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	left	6
7	389584	Main Building	Pot Filler	Kitchen	2 of 2	Tap	center	6
8	389590	Main Building	Fountain/Tap Combo	Rm 6	1 of 1	Water Fountain	left	3
9	389586	Main Building	Sink	Music Rm	1 of 1	Tap	center	<1
10	389588	Main Building	Fountain	Teacher Lounge	1 of 1	Water Fountain	center	<1
11	389598	Main Building	Fountain/Tap Combo	Rm 12	Rm 12	Tap	center	<1