

Lead in School Drinking Water Report

Virgie Robinson Elementary School



Date(s) collected: 2024-06-12

Date(s) analyzed: 2024-07-10

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371896	Main Building	Sink	Library	1 of 1	Tap	center	11
371805	Main Building	Fountain	Outside 138	1 of 1	Water Fountain	center	10
371875	Main Building	Sink	Rm 161	1 of 1	Tap	center	8
371796	Main Building	Fountain/ Tap Combo	Rm 186	1 of 1	Tap	center	5
371874	Main Building	Fountain/ Tap Combo	Rm 210	1 of 1	Tap	left	5
371886	Main Building	Fountain/ Tap Combo	Rm 212	1 of 1	Tap	left	4
371806	Main Building	Sink	Teacher Lounge Kitchen	1 of 1	Tap	center	3
371879	Main	Fountain/	Rm 164	1 of 1	Tap	center	3

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	Tap Combo					
371783	Main Building	Fountain/ Tap Combo	Rm 117	1 of 1	Tap	left	2
371784	Main Building	Pot Filler	Kitchen	2 of 2	Tap	center	2
371807	Main Building	Fountain/ Tap Combo	Rm 201	1 of 1	Tap	left	2
371810	Main Building	Fountain/ Tap Combo	Rm 121	1 of 1	Tap	center	2
371818	Main Building	Fountain/ Tap Combo	Rm 134	1 of 1	Tap	left	2
371830	Main Building	Fountain	Outside Portables	1 of 1	Water Fountain	center	2
371838	Portable 177/178	Fountain/ Tap Combo	P178	1 of 1	Water Fountain	right	2
371863	Main Building	Fountain/ Tap Combo	Rm 160	1 of 1	Tap	center	2
371870	Main Building	Fountain/ Tap Combo	Rm 208	1 of 1	Tap	left	2
371871	Main Building	Fountain/ Tap Combo	157	1 of 1	Tap	center	2
371882	Main Building	Fountain/ Tap Combo	Rm 213	1 of 1	Tap	left	2
371883	Main Building	Fountain/ Tap Combo	Rm 166	1 of 1	Tap	center	2
371887	Main	Fountain/	Rm 169	1 of 1	Tap	center	2

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building	Tap Combo					
371890	Main Building	Sink	Staff 114	1 of 1	Tap	center	2
371891	Main Building	Fountain/ Tap Combo	Rm 171	1 of 1	Tap	left	2
371892	Main Building	Fountain/ Tap Combo	Rm 217	1 of 1	Tap	left	2
371898	Main Building	Fountain/ Tap Combo	Rm 152	1 of 1	Tap	center	2
371789	Main Building	Fountain/ Tap Combo	Rm 115	1 of 1	Tap	left	1
371793	Main Building	Fountain/ Tap Combo	Rm 123	1 of 1	Tap	left	1
371797	Main Building	Fountain/ Tap Combo	Rm 127	1 of 1	Tap	center	1
371800	Main Building	Sink	Health 114	1 of 1	Tap	center	1
371801	Main Building	Fountain/ Tap Combo	Rm 138	1 of 1	Tap	left	1
371811	Main Building	Fountain/ Tap Combo	Rm 207	1 of 1	Tap	center	1
371815	Main Building	Fountain/ Tap Combo	Rm 209	1 of 1	Tap	left	1
371836	Portable 177/178	Fountain/ Tap Combo	P 178	1 of 1	Tap	center	1
371862	Main Building	Fountain/ Tap	Rm 211	1 of 1	Tap	left	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
		Combo					
371866	Main Building	Fountain/ Tap Combo	Rm 206	1 of 1	Tap	left	1
371867	Main Building	Fountain/ Tap Combo	Rm 162	1 of 1	Tap	left	1
371878	Main Building	Fountain/ Tap Combo	Rm 215	1 of 1	Tap	left	1
371895	Main Building	Fountain/ Tap Combo	Rm 168	1 of 1	Tap	center	1
371780	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	left	<1
371781	Main Building	Fountain/ Tap Combo	Rm 134	1 of 1	Water Fountain	right	<1
371782	Main Building	Sink - Multi-Compartment	Kitchen	1 of 2	Tap	right	<1
371785	Main Building	Fountain/ Tap Combo	Rm 117	1 of 1	Water Fountain	right	<1
371786	Main Building	Fountain	Gym	1 of 1	Water Fountain	center	<1
371787	Main Building	Fountain	Between 117 And 115	1 of 1	Water Fountain	center	<1
371788	Main Building	Fountain	Outside Gym	1 of 1	Water Fountain	center	<1
371790	Main Building	Fountain - Multi-Level	Cafe Hallway	1 of 2	Water Fountain	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371791	Main Building	with Bottle Filler Fountain/ Tap Combo	Rm 115	1 of 1	Water Fountain	right	<1
371792	Main Building	Fountain - Multi-Level with Bottle Filler	Cafe Hallway	2 of 2	Water Fountain	right	<1
371794	Main Building	Fountain - Multi-Level with Bottle Filler	Cafe Hallway	2 of 2	Water Bottle Filler	right	<1
371795	Main Building	Fountain/ Tap Combo	Rm 123	1 of 1	Water Fountain	right	<1
371798	Main Building	Fountain/ Tap Combo	Rm 186	1 of 1	Water Fountain	right	<1
371799	Main Building	Fountain/ Tap Combo	Rm 127	1 of 1	Water Fountain	right	<1
371802	Main Building	Fountain with Bottle Filler	Teacher Lounge	1 of 1	Water Fountain	center	<1
371803	Main Building	Fountain/ Tap Combo	Rm 138	1 of 1	Water Fountain	right	<1
371804	Main Building	Fountain with Bottle Filler	Teacher Lounge	1 of 1	Water Bottle Filler	center	<1
371808	Main Building	Fountain	Between 121 And 119	1 of 1	Water Fountain	center	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371809	Main Building	Fountain/ Tap Combo	Rm 201	1 of 1	Water Fountain in	right	<1
371812	Main Building	Fountain/ Tap Combo	Rm 121	1 of 1	Water Fountain in	right	<1
371813	Main Building	Fountain/ Tap Combo	Rm 207	1 of 1	Water Fountain in	right	<1
371814	Main Building	Fountain/ Tap Combo	Rm 119	1 of 1	Tap	left	<1
371816	Main Building	Fountain/ Tap Combo	Rm 119	1 of 1	Water Fountain in	right	<1
371817	Main Building	Fountain/ Tap Combo	Rm 209	1 of 1	Water Fountain in	right	<1
371819	Main Building	Fountain - Multi-Level	Between 211 And 209	1 of 2	Water Fountain in	left	<1
371820	Main Building	Fountain/ Tap Combo	Rm 170	1 of 1	Water Fountain in	right	<1
371822	Main Building	Fountain/ Tap Combo	Rm 175	1 of 2	Tap	left	<1
371824	Main Building	Fountain/ Tap Combo	Rm 175	1 of 2	Water Fountain in	right	<1
371826	Main Building	Fountain/ Tap Combo	Rm 175	2 of 2	Tap	center	<1
371828	Main Building	Fountain/ Tap Combo	Rm 175	2 of 2	Water Fountain in	right	<1
371832	Portable	Fountain/ Tap	P177	1 of 1	Tap	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	177/178	Combo					
371834	Portable 177/178	Fountain/ Tap Combo	P177	1 of 1	Water Fountain	right	<1
371840	Portable 179/180	Fountain/ Tap Combo	P180	1 of 1	Tap	center	<1
371842	Portable 179/180	Fountain/ Tap Combo	P180	1 of 1	Water Fountain	left	<1
371844	Portable 179/180	Fountain/ Tap Combo	P179	1 of 1	Tap	center	<1
371846	Portable 179/180	Fountain/ Tap Combo	P179	1 of 1	Water Fountain	right	<1
371860	Main Building	Fountain - Multi-Level	Between 211 And 209	2 of 2	Water Fountain	right	<1
371861	Main Building	Fountain/ Tap Combo	Rm 152	1 of 1	Water Fountain	right	<1
371864	Main Building	Fountain/ Tap Combo	Rm 211	1 of 1	Water Fountain	right	<1
371865	Main Building	Fountain/ Tap Combo	Rm 160	1 of 1	Water Fountain	right	<1
371868	Main Building	Fountain/ Tap Combo	Rm 206	1 of 1	Water Fountain	right	<1
371869	Main Building	Fountain/ Tap	Rm 162	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
		Combo			in		
371872	Main Building	Fountain/ Tap Combo	Rm 208	1 of 1	Water Founta in	right	<1
371873	Main Building	Fountain/ Tap Combo	Rm 157	1 of 1	Water Founta in	right	<1
371876	Main Building	Fountain/ Tap Combo	Rm 210	1 of 1	Water Founta in	right	<1
371877	Main Building	Fountain	Between 157 And 155	1 of 1	Water Founta in	center	<1
371880	Main Building	Fountain/ Tap Combo	Rm 215	1 of 1	Water Founta in	right	<1
371881	Main Building	Fountain/ Tap Combo	Rm 164	1 of 1	Water Founta in	right	<1
371884	Main Building	Fountain/ Tap Combo	Rm 213	1 of 1	Water Founta in	right	<1
371885	Main Building	Fountain/ Tap Combo	Rm 166	1 of 1	Water Founta in	right	<1
371888	Main Building	Fountain/ Tap Combo	Rm 212	1 of 1	Water Founta in	right	<1
371889	Main Building	Fountain/ Tap Combo	Rm 169	1 of 1	Water Founta in	right	<1
371893	Main Building	Fountain/ Tap Combo	Rm 171	1 of 1	Water Founta in	right	<1
371894	Main Building	Fountain/ Tap Combo	Rm 217	1 of 1	Water Founta in	right	<1
371897	Main Building	Fountain/ Tap	Rm 168	1 of 1	Water Founta	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
371899	Main Building	Combo Fountain/ Tap Combo	Rm 170	1 of 1	in Tap	left	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**