



December 18, 2024

Brian Arias  
Jeff-Lewis BOCES\_Watertown Central School  
District  
532 S. Massey Street  
Watertown, NY 13601

RE: Project: KNICKER BUCKER SCHOOL  
Pace Project No.: 70326671

Dear Brian Arias:

Enclosed are the analytical results for sample(s) received by the laboratory on December 10, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michelle Cohen  
michelle.cohen@pacelabs.com  
516-370-6000  
Project Manager

Enclosures

cc: Ray Filley, Jeff-Lewis BOCES\_Watertown Central School  
District  
Tiffany Oconnor, Jeff-Lewis BOCES\_Watertown Central  
School District  
Linda Shaw, Jeff-Lewis BOCES\_Watertown Central School  
District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

---

### **Pace Analytical Services, LLC - Melville, NY**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 1 DF LIBRARY		Lab ID: 70326671001	Collected: 12/04/24 06:45	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 15:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 2 R 14 FACULTY		Lab ID: 70326671002	Collected: 12/04/24 06:45	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.1	ug/L	1.0	1		12/17/24 15:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 3 RM 16		Lab ID: 70326671003	Collected: 12/04/24 06:47	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		12/17/24 15:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 4 RM 16</b>								
<b>Lab ID: 70326671004</b>								
Collected: 12/04/24 06:47								
Received: 12/10/24 07:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.9</b>	ug/L	1.0	1		12/17/24 15:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 6 RM 15		Lab ID: 70326671005	Collected: 12/04/24 06:46	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>21.7</b>	ug/L	1.0	1		12/17/24 15:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 7 RM 18		Lab ID: 70326671006	Collected: 12/04/24 06:51	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.3</b>	ug/L	1.0	1		12/17/24 15:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 8 RM 18		Lab ID: 70326671007	Collected: 12/04/24 06:51	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>8.3</b>	ug/L	1.0	1		12/17/24 16:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 10 R 17		Lab ID: 70326671008	Collected: 12/04/24 06:49	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.6</b>	ug/L	1.0	1		12/17/24 16:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 11 R 17		Lab ID: 70326671009	Collected: 12/04/24 06:49	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.8</b>	ug/L	1.0	1		12/17/24 16:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 13 R 20</b>								
<b>Lab ID: 70326671010</b>								
Collected: 12/04/24 06:55								
Received: 12/10/24 07:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	4.7	ug/L	1.0	1		12/17/24 16:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 14 R 20		Lab ID: 70326671011	Collected: 12/04/24 06:55	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.7</b>	ug/L	1.0	1		12/17/24 16:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 16 R 19		Lab ID: 70326671012	Collected: 12/04/24 06:53	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.0</b>	ug/L	1.0	1		12/17/24 16:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 17 R 19		Lab ID: 70326671013	Collected: 12/04/24 06:53	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.4</b>	ug/L	1.0	1		12/17/24 16:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 19 R 22		Lab ID: 70326671014	Collected: 12/04/24 06:57	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.9</b>	ug/L	1.0	1		12/17/24 16:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 20 R 22		Lab ID: 70326671015	Collected: 12/04/24 06:57	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.4	ug/L	1.0	1		12/17/24 16:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 22 R 21		Lab ID: 70326671016		Collected: 12/04/24 06:56	Received: 12/10/24 07:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>10.2</b>	ug/L	1.0	1		12/17/24 16:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 23 R 21</b>								
<b>Lab ID: 70326671017</b>								
Collected: 12/04/24 06:56								
Received: 12/10/24 07:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	5.5	ug/L	1.0	1		12/17/24 16:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 25 DF DISMISSAL		Lab ID: 70326671018	Collected: 12/04/24 06:58	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 16:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 26 R 24		Lab ID: 70326671019	Collected: 12/04/24 07:09	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		12/17/24 16:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 27 R 24		Lab ID: 70326671020	Collected: 12/04/24 07:09	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		12/17/24 16:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 28 R24		Lab ID: 70326671021	Collected: 12/04/24 07:09	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>8.7</b>	ug/L	1.0	1		12/17/24 16:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 29 R25		Lab ID: 70326671022		Collected: 12/04/24 07:03	Received: 12/10/24 07:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		12/17/24 16:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 30 R25		Lab ID: 70326671023	Collected: 12/04/24 07:03	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.5</b>	ug/L	1.0	1		12/17/24 16:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 31 R25		Lab ID: 70326671024	Collected: 12/04/24 07:03	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.6	ug/L	1.0	1		12/17/24 16:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 32 R26		Lab ID: 70326671025	Collected: 12/04/24 07:12	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.2</b>	ug/L	1.0	1		12/17/24 16:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 33 R26		Lab ID: 70326671026	Collected: 12/04/24 07:12	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 16:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 34 R26		Lab ID: 70326671027	Collected: 12/04/24 07:12	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		12/17/24 16:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 35 R27		Lab ID: 70326671028	Collected: 12/04/24 07:14	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		12/17/24 16:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 36 R27		Lab ID: 70326671029	Collected: 12/04/24 07:14	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		12/17/24 16:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 37 R27		Lab ID: 70326671030	Collected: 12/04/24 07:14	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.9</b>	ug/L	1.0	1		12/17/24 16:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 38 R28		Lab ID: 70326671031	Collected: 12/04/24 07:15	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.8</b>	ug/L	1.0	1		12/17/24 16:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 39 R28		Lab ID: 70326671032	Collected: 12/04/24 07:15	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 17:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 40 R28		Lab ID: 70326671033	Collected: 12/04/24 07:15	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.6</b>	ug/L	1.0	1		12/17/24 17:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 41 R29		Lab ID: 70326671034	Collected: 12/04/24 07:17	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.8</b>	ug/L	1.0	1		12/17/24 17:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 42 R29		Lab ID: 70326671035	Collected: 12/04/24 07:17	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.4</b>	ug/L	1.0	1		12/17/24 17:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 43 R29		Lab ID: 70326671036	Collected: 12/04/24 07:17	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		12/17/24 17:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 44 DF MUSIC		Lab ID: 70326671037	Collected: 12/04/24 07:18	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 17:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 45 CAFE BATH		Lab ID: 70326671038	Collected: 12/04/24 07:21	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 17:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 46 CAFE		Lab ID: 70326671039	Collected: 12/04/24 07:23	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 17:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 46A CAFE		Lab ID: 70326671040	Collected: 12/04/24 07:23	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 17:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 47 R12		Lab ID: 70326671041	Collected: 12/04/24 07:29	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	11.4	ug/L	1.0	1		12/17/24 17:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 48 R12		Lab ID: 70326671042	Collected: 12/04/24 07:29	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.0</b>	ug/L	1.0	1		12/17/24 17:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 49 R12		Lab ID: 70326671043	Collected: 12/04/24 07:29	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.5</b>	ug/L	1.0	1		12/17/24 17:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 50 R13		Lab ID: 70326671044	Collected: 12/04/24 07:27	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.3</b>	ug/L	1.0	1		12/17/24 17:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 51 R13		Lab ID: 70326671045	Collected: 12/04/24 07:27	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.5</b>	ug/L	1.0	1		12/17/24 17:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 53 R10		Lab ID: 70326671046	Collected: 12/04/24 07:35	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		12/17/24 17:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 54 R10		Lab ID: 70326671047	Collected: 12/04/24 07:35	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.8</b>	ug/L	1.0	1		12/17/24 17:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 56 R11		Lab ID: 70326671048	Collected: 12/04/24 07:32	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		12/17/24 17:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 57 R11		Lab ID: 70326671049	Collected: 12/04/24 07:32	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>9.2</b>	ug/L	1.0	1		12/17/24 17:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: 58 R11</b>								
<b>Lab ID: 70326671050</b>								
Collected: 12/04/24 07:32								
Received: 12/10/24 07:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	9.4	ug/L	1.0	1		12/17/24 17:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 59 R8		Lab ID: 70326671051	Collected: 12/04/24 07:35	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		12/17/24 17:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 60 R8		Lab ID: 70326671052	Collected: 12/04/24 07:35	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>13.2</b>	ug/L	1.0	1		12/17/24 17:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 61 R8		Lab ID: 70326671053	Collected: 12/04/24 07:35	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>11.8</b>	ug/L	1.0	1		12/17/24 17:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 62 R9		Lab ID: 70326671054	Collected: 12/04/24 06:36	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.5</b>	ug/L	1.0	1		12/17/24 18:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 63 R9		Lab ID: 70326671055	Collected: 12/04/24 06:36	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>19.9</b>	ug/L	1.0	1		12/17/24 18:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 65 R6		Lab ID: 70326671056	Collected: 12/04/24 06:43	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.8</b>	ug/L	1.0	1		12/17/24 18:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 66 R6		Lab ID: 70326671057	Collected: 12/04/24 06:43	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.8</b>	ug/L	1.0	1		12/17/24 18:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 68 R7		Lab ID: 70326671058	Collected: 12/04/24 06:41	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.3</b>	ug/L	1.0	1		12/17/24 18:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 69 R7		Lab ID: 70326671059	Collected: 12/04/24 06:41	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.3</b>	ug/L	1.0	1		12/17/24 18:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 71 PSYCH R4		Lab ID: 70326671060	Collected: 12/04/24 07:46	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>24.6</b>	ug/L	1.0	1		12/17/24 18:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 72		Lab ID: 70326671061		Collected: 12/04/24 07:48	Received: 12/10/24 07:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 18:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 74		Lab ID: 70326671062		Collected: 12/04/24 07:03	Received: 12/10/24 07:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 18:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 76		Lab ID: 70326671063	Collected: 12/04/24 07:20	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 18:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 77		Lab ID: 70326671064	Collected: 12/04/24 06:42	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.1	ug/L	1.0	1		12/17/24 18:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 79 ART		Lab ID: 70326671065		Collected: 12/04/24 07:45	Received: 12/10/24 07:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 18:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 80 ART		Lab ID: 70326671066	Collected: 12/04/24 07:45	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 18:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Sample: 72A NURSE		Lab ID: 70326671067	Collected: 12/04/24 07:48	Received: 12/10/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/24 18:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

QC Batch:	375784	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70326671001, 70326671002, 70326671003, 70326671004, 70326671005, 70326671006, 70326671007, 70326671008, 70326671009, 70326671010, 70326671011		

METHOD BLANK:	1969173	Matrix:	Water
Associated Lab Samples:	70326671001, 70326671002, 70326671003, 70326671004, 70326671005, 70326671006, 70326671007, 70326671008, 70326671009, 70326671010, 70326671011		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/17/24 15:22	

LABORATORY CONTROL SAMPLE:	1969174					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.3	101	85-115	

MATRIX SPIKE SAMPLE:	1969176						
Parameter	Units	70326667037 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	15.1	50	80.0	130	70-130	

MATRIX SPIKE SAMPLE:	1969178						
Parameter	Units	70326667038 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	29.3	50	82.0	105	70-130	

SAMPLE DUPLICATE:	1969175					
Parameter	Units	70326667037 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	15.1	15.5	3		

SAMPLE DUPLICATE:	1969177					
Parameter	Units	70326667038 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	29.3	29.8	2		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

QC Batch:	375786	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70326671012, 70326671013, 70326671014, 70326671015, 70326671016, 70326671017, 70326671018, 70326671019, 70326671020, 70326671021, 70326671022, 70326671023, 70326671024, 70326671025, 70326671026, 70326671027, 70326671028, 70326671029, 70326671030, 70326671031		

METHOD BLANK:	1969179	Matrix:	Water
Associated Lab Samples:	70326671012, 70326671013, 70326671014, 70326671015, 70326671016, 70326671017, 70326671018, 70326671019, 70326671020, 70326671021, 70326671022, 70326671023, 70326671024, 70326671025, 70326671026, 70326671027, 70326671028, 70326671029, 70326671030, 70326671031		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/17/24 16:12	

LABORATORY CONTROL SAMPLE:	1969180					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.3	101	85-115	

MATRIX SPIKE SAMPLE:	1969182						
Parameter	Units	70326671012 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.0	50	58.0	110	70-130	

MATRIX SPIKE SAMPLE:	1969184						
Parameter	Units	70326671013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.4	50	59.3	112	70-130	

SAMPLE DUPLICATE:	1969181					
Parameter	Units	70326671012 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	3.0	3.0	1		

SAMPLE DUPLICATE:	1969183					
Parameter	Units	70326671013 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	3.4	3.6	5		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

QC Batch:	375787	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70326671032, 70326671033, 70326671034, 70326671035, 70326671036, 70326671037, 70326671038, 70326671039, 70326671040, 70326671041, 70326671042, 70326671043, 70326671044, 70326671045, 70326671046, 70326671047, 70326671048, 70326671049, 70326671050, 70326671051		

METHOD BLANK:	1969185	Matrix:	Water
Associated Lab Samples:	70326671032, 70326671033, 70326671034, 70326671035, 70326671036, 70326671037, 70326671038, 70326671039, 70326671040, 70326671041, 70326671042, 70326671043, 70326671044, 70326671045, 70326671046, 70326671047, 70326671048, 70326671049, 70326671050, 70326671051		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/17/24 16:58	

LABORATORY CONTROL SAMPLE:	1969186					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.8	102	85-115	

MATRIX SPIKE SAMPLE:	1969188						
Parameter	Units	70326671032 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	62.4	124	70-130	

MATRIX SPIKE SAMPLE:	1969190						
Parameter	Units	70326671033 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.6	50	61.7	118	70-130	

SAMPLE DUPLICATE:	1969187					
Parameter	Units	70326671032 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	1969189					
Parameter	Units	70326671033 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	2.6	2.5	5		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





**QUALITY CONTROL DATA**

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

QC Batch:	375790	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70326671052, 70326671053, 70326671054, 70326671055, 70326671056, 70326671057, 70326671058, 70326671059, 70326671060, 70326671061, 70326671062, 70326671063, 70326671064, 70326671065, 70326671066, 70326671067		

METHOD BLANK:	1969193	Matrix:	Water
Associated Lab Samples:	70326671052, 70326671053, 70326671054, 70326671055, 70326671056, 70326671057, 70326671058, 70326671059, 70326671060, 70326671061, 70326671062, 70326671063, 70326671064, 70326671065, 70326671066, 70326671067		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/17/24 17:48	

LABORATORY CONTROL SAMPLE:	1969194					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE SAMPLE:	1969196						
Parameter	Units	70326671052 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	13.2	50	70.6	115	70-130	

MATRIX SPIKE SAMPLE:	1969198						
Parameter	Units	70326671053 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	11.8	50	76.3	129	70-130	

SAMPLE DUPLICATE:	1969195					
Parameter	Units	70326671052 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	13.2	13.0	2		

SAMPLE DUPLICATE:	1969197					
Parameter	Units	70326671053 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	11.8	11.6	2		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70326671001	1 DF LIBRARY	EPA 200.8	375784		
70326671002	2 R 14 FACULTY	EPA 200.8	375784		
70326671003	3 RM 16	EPA 200.8	375784		
70326671004	4 RM 16	EPA 200.8	375784		
70326671005	6 RM 15	EPA 200.8	375784		
70326671006	7 RM 18	EPA 200.8	375784		
70326671007	8 RM 18	EPA 200.8	375784		
70326671008	10 R 17	EPA 200.8	375784		
70326671009	11 R 17	EPA 200.8	375784		
70326671010	13 R 20	EPA 200.8	375784		
70326671011	14 R 20	EPA 200.8	375784		
70326671012	16 R 19	EPA 200.8	375786		
70326671013	17 R 19	EPA 200.8	375786		
70326671014	19 R 22	EPA 200.8	375786		
70326671015	20 R 22	EPA 200.8	375786		
70326671016	22 R 21	EPA 200.8	375786		
70326671017	23 R 21	EPA 200.8	375786		
70326671018	25 DF DISMISSAL	EPA 200.8	375786		
70326671019	26 R 24	EPA 200.8	375786		
70326671020	27 R 24	EPA 200.8	375786		
70326671021	28 R24	EPA 200.8	375786		
70326671022	29 R25	EPA 200.8	375786		
70326671023	30 R25	EPA 200.8	375786		
70326671024	31 R25	EPA 200.8	375786		
70326671025	32 R26	EPA 200.8	375786		
70326671026	33 R26	EPA 200.8	375786		
70326671027	34 R26	EPA 200.8	375786		
70326671028	35 R27	EPA 200.8	375786		
70326671029	36 R27	EPA 200.8	375786		
70326671030	37 R27	EPA 200.8	375786		
70326671031	38 R28	EPA 200.8	375786		
70326671032	39 R28	EPA 200.8	375787		
70326671033	40 R28	EPA 200.8	375787		
70326671034	41 R29	EPA 200.8	375787		
70326671035	42 R29	EPA 200.8	375787		
70326671036	43 R29	EPA 200.8	375787		
70326671037	44 DF MUSIC	EPA 200.8	375787		
70326671038	45 CAFE BATH	EPA 200.8	375787		
70326671039	46 CAFE	EPA 200.8	375787		
70326671040	46A CAFE	EPA 200.8	375787		
70326671041	47 R12	EPA 200.8	375787		
70326671042	48 R12	EPA 200.8	375787		
70326671043	49 R12	EPA 200.8	375787		
70326671044	50 R13	EPA 200.8	375787		
70326671045	51 R13	EPA 200.8	375787		
70326671046	53 R10	EPA 200.8	375787		
70326671047	54 R10	EPA 200.8	375787		
70326671048	56 R11	EPA 200.8	375787		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: KNICKER BUCKER SCHOOL

Pace Project No.: 70326671

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70326671049	57 R11	EPA 200.8	375787		
70326671050	58 R11	EPA 200.8	375787		
70326671051	59 R8	EPA 200.8	375787		
70326671052	60 R8	EPA 200.8	375790		
70326671053	61 R8	EPA 200.8	375790		
70326671054	62 R9	EPA 200.8	375790		
70326671055	63 R9	EPA 200.8	375790		
70326671056	65 R6	EPA 200.8	375790		
70326671057	66 R6	EPA 200.8	375790		
70326671058	68 R7	EPA 200.8	375790		
70326671059	69 R7	EPA 200.8	375790		
70326671060	71 PSYCH R4	EPA 200.8	375790		
70326671061	72	EPA 200.8	375790		
70326671062	74	EPA 200.8	375790		
70326671063	76	EPA 200.8	375790		
70326671064	77	EPA 200.8	375790		
70326671065	79 ART	EPA 200.8	375790		
70326671066	80 ART	EPA 200.8	375790		
70326671067	72A NURSE	EPA 200.8	375790		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

**CHAIN-OF-CUSTODY Analytical Request Document**  
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: Jefferson Lewis BOCES, Watertown CSD  
 Street Address: 1351 Washington Street, Watertown NY 13601

Contact/Report To: Brian Arias  
 Phone #: 315-661-4351  
 E-Mail: [barias@watertowncso.org](mailto:barias@watertowncso.org)  
 Cc E-Mail:

Customer Project #: 08215607  
 Project Name: KNICKERBOCKER SCIENCE

Invoice To: Brian Arias  
 Invoice E-Mail: [barias@watertowncso.org](mailto:barias@watertowncso.org)

Site Collection Info/Facility ID (as applicable):

Purchase Order # (if applicable):  
 Quote #:

Time Zone Collected: [ ] AK [ ] MT [ ] CT [X] ET  
 Data Deliverables:

County / State origin of sample(s): New York  
 Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):  
 [ ] 1 Day [ ] 3 day [ ] 5 day [ ] Other  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Date Results Requested: Standard 10 business day  
 Analysis:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CL2	Number & Type of Containers	Preservation non-conformance identified for sample
			(or Composite Start) Date	Time			
1 DF LIBRARY	DW	G	12/14/20	645		1	
2 R14 FACILITY				645			
3 R2M16				647			
4 R M 16				647			
6 R M 15				646			
7 R M 18				651			
8 R M 18				651			
10 R 17				649			
11 R 17				649			
13 R 20				655			

Additional Instructions from Pace\*:  
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Collected By: Thomas Rankin  
 Signature: *Thomas Rankin*

Received by/Company: (Signature) *James E. Kelly*  
 Date/Time: 12/14/20 14:45

Received by/Company: (Signature)  
 Date/Time: 12/17/20 12:00

Received by/Company: (Signature) *James E. Kelly*  
 Date/Time: 12/17/20 12:00

Received by/Company: (Signature)  
 Date/Time: 12/17/20 12:00

Tracking Number:  
 Delivered by: [ ] In-Person [ ] Courier  
 [ ] FedEx [ ] UPS [ ] Other

Page 7 of 8

WO#: 70326671



\*\* Container Size: (1) 1L (2) 500mL (3) 250mL (4) 125mL (5) 100mL (6) 40mL vial (7) Encore (8) TerraCore (9) Other  
 Identify Container Preservative Type\*\*  
 \*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) NaOH, (11) Other

Analysis Requested  
 Proj. Mgr: Randy Budhu  
 AcctNum / Client ID:  
 Table #:  
 Profile / Template:  
 Preleg / Bottle Ord. ID:



Company Name: **Jefferson Lewis BOCCES, Watertown CSD**  
 Street Address: **1351 Washington Street, Watertown NY 13601**

Customer Project #: **08215607**  
 Project Name: **Knierim-Bockker school**

Site Collection Info/Facility ID (as applicable):

Contact/Report To: **Brian Arias**  
 Phone #: **315-661-4951**  
 E-Mail: **barias@watertowncscd.org**  
 Cc E-Mail:

Invoice To: **Brian Arias**  
 Invoice E-Mail: **barias@watertowncscd.org**

Purchase Order # (if applicable):

Quote #:

County / State origin of sample(s): **New York**

Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**

**Rush (Pre-approval required):**  
 ( ) 12 Day ( ) 3 day ( ) 5 day ( ) Other: \_\_\_\_\_

**Date Results Requested:**  
 Standard 10 business day

Field Filtered (if applicable): ( ) Yes ( ) No

Analysis:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CL2	Number & Type of Containers	Plastic	Glass
			Date	Time				
28 R24	DW	G	12/4/24	709		1		
29 R25				703				
30 R25				703				
31 R25				703				
32 R26				712				
33 R26				712				
34 R26				712				
35 R27				714				
36 R27				714				
37 R27				714				

Additional Instructions from Pace®: **200.8 Drinking Water (Pb only)**

Collected By: **Thomas Rankin**  
 Printed Name: **Thomas Rankin**  
 Signature: \_\_\_\_\_

Relinquished by (Company, Signature): **James E. Cady**

Relinquished by (Company, Signature): \_\_\_\_\_

Relinquished by (Company, Signature): **James E. Cady**

Relinquished by (Company, Signature): \_\_\_\_\_

Relinquished by (Company, Signature): \_\_\_\_\_


Relinquished by (Company, Signature): \_\_\_\_\_

Relinquished by (Company, Signature): \_\_\_\_\_

Relinquished by (Company, Signature): \_\_\_\_\_

Relinquished by (Company, Signature): \_\_\_\_\_

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

Specify Container Size \*\*

Identify Container Preservative Type \*\*\*

Analysis Requested

Proj. Mgr:  
**Randy Budhu**  
 AcctNum / Client ID:  
 Table #:  
 Profile / Template:  
 Prelog / Bottle Ord. ID:

Lab Use Only

Sample Comment

Preservation non-conformance identified for sample.

\*\* Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL, (7) Encore, (8) TerraCore, (9) Other

\*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

# Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number: **1219 11145**

Date/Time: **12/19 12:00**

Delivered by: ( ) In-Person ( ) Courier

Date/Time: **12/10 7A**

( ) FedEx ( ) UPS ( ) Other

Page: of

ENV-FRM-CORQ-0019\_v01\_082123 ©

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>



4/7

LAB USE ONLY. Affix Workorder/Login Label Here

Scan QR Code for instructions



### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**Pace®** Location Requested (City/State): **Jefferson Lewis BOCES, Watertown CSD**  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747  
 Company Name: **Jefferson Lewis BOCES, Watertown CSD**  
 Street Address: **1351 Washington Street, Watertown NY 13601**  
 Contact/Report To: **Brian Arlas**  
 Phone #: **315-661-4351**  
 E-Mail: **barias@watertowncswd.org**  
 Cc E-Mail:  
 Invoice To: **Brian Arlas**  
 Invoice E-Mail: **barias@watertowncswd.org**  
 Purchase Order # (if applicable):  
 Quote #:

Customer Project #: **08215604**  
 Project Name: **KNOCKERBCKER SCHOOL**  
 Site Collection Info/Facility ID (as applicable):  
 County / State origin of sample(s): **New York**

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET [ ] ET  
 Data Deliverables:  
 [ ] Level II [ ] Level III [ ] Level IV  
 [ ] EQUIS  
 [ ] Other:  
 Rush (Pre-approval required):  
 [ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other:  
 Date Results Requested: **Standard 10 business day**  
 Field Filtered (if applicable): [ ] Yes [ ] No  
 Analysis:  
 Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Collected		Res. CL2	Number & Type of Containers	Preservation non-conformance identified for sample.
		Comp / Grab	Time			
38 R20	DW	G	7:15		1	
39 R20			7:15			
40 R28			7:15			
41 R29			7:17			
42 R29			7:17			
43 R29			7:17			
44 DF MUSIC			7:18			
45 CAFE BAH			7:21			
46 CAFE			7:23			
46A CAFE			7:23			

Additional Instructions from Pace®:  
 Collected By: **Thomas Rankin**  
 Printed Name: **Thomas Rankin**  
 Signature:  
 Received by/Company: **James E. Galt**  
 Date/Time: **12/19 11:45**  
 Received by/Company: **James E. Galt**  
 Date/Time: **12/19 12:01**  
 Received by/Company: **James E. Galt**  
 Date/Time: **12/19 7:00**  
 Received by/Company: **James E. Galt**  
 Date/Time: **12/19 7:00**



5/7

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**Pace**  
 Pace® Location Requested (City/State):  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747

**Jefferson Lewis BOCES, Watertown CSD**  
 Street Address: 1351 Washington Street, Watertown NY 13601

Contract/Report To: **Brian Atlas**  
 Phone #: 315-661-4351  
 E-Mail: barias@watertowncsd.org  
 Cc E-Mail:

Invoice To: **Brian Atlas**  
 Invoice E-Mail: barias@watertowncsd.org

Customer Project #: 08215607  
 Project Name: ANICORBACKER SCHOOL

Site Collection Info/Facility ID (as applicable):

County / State origin of sample(s): **New York**

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

**Rush (Pre-approval required):**  
 DW PWSID # or WW Permit # as applicable:  
 ( ) 12 Day ( ) 3 day ( ) 5 day ( ) Other: \_\_\_\_\_

**Date Results Requested:**  
 Standard 10 business day  
 Analysis: \_\_\_\_\_

Field Filtered (if applicable): ( ) Yes ( ) No

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End	Res. CL2	Number & Type of Containers	200.8 Drinking Water (Pb only)
			Date	Time				
47 R12	DW	G	12/4/24	725			1	X
48 R12				729				
49 R12				729				
50 R13				727				
51 R13				727				
53 R10				735				
54 R10				735				
56 R11				732				
57 R11				732				
58 R11				732				

Additional Instructions from Pace®:

Collected By: \_\_\_\_\_  
 Printed Name: Thomas Rankin  
 Signature: \_\_\_\_\_

Received by/Company: (Signature) \_\_\_\_\_  
 Date/Time: 12/9 11:45

Received by/Company: (Signature) \_\_\_\_\_  
 Date/Time: 12/9 12:00

Received by/Company: (Signature) \_\_\_\_\_  
 Date/Time: 12/10 7:00

Received by/Company: (Signature) \_\_\_\_\_  
 Date/Time: \_\_\_\_\_

Delivered by: ( ) In-Person ( ) Courier  
 ( ) FedEx ( ) UPS ( ) Other

Page: 001 of 005

**CHAIN-OF-CUSTODY Analytical Request Document**  
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Affix Workorder/Login Label Here

Company Name: **Jefferson Lewis BOCCES, Watertown CSD**  
Street Address: **1351 Washington Street, Watertown NY 13601**  
Customer Project #: **08215607**  
Project Name: **KNOCKS/BULEER SCHOOL**

Contact/Report To: **Brian Arias**  
Phone #: **315-661-4351**  
E-Mail: **barias@watertowncsd.org**  
Cc E-Mail:  
Invoice To: **Brian Arias**  
Invoice E-Mail: **barias@watertowncsd.org**

Specify Container Size \*\*  
Identify Container Preservative Type\*\*\*  
Analysis Requested

\*\* Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) Other  
\*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

County / State origin of sample(s): **New York**  
Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**  
Rush (Pre-approval required):  
DW PWSID # or WW Permit # as applicable:  
Field Filtered (if applicable): [ ] Yes [ ] No  
Date Results Requested: **Standard 10 business day**  
Analysis:

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET  
Data Deliverables:  
[ ] Level II [ ] Level III [ ] Level IV  
[ ] EQUIS  
[ ] Other:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Biosassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CL2	Composite End		Number & Type of Containers	Preservation non-conformance identified for sample
			Date	Time		Date	Time		
59	R8	G	12/24	735				1	
60	R8			735					X
61	R8			735					
62	R9			636					
63	R9			636					
65	R6			643					
66	R6			643					
68	R7			641					
69	R7			641					
71	Buch R4			746					

Additional Instructions from Pace\*:  
Collected By: **Thomas Rankin**  
Printed Name: **Thomas Rankin**  
Signature: *[Signature]*

# Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number: **1279 11:45**  
Date/Time: **12/29 11:45**

Delivered by: [ ] In-Person [ ] Courier  
[ ] FedEx [ ] UPS [ ] Other

Date/Time: **12/29 12:00**  
Date/Time: **12/29 12:00**

Received by/Company: *[Signature]*  
Received by/Company: *[Signature]*

Received by/Company: *[Signature]*  
Received by/Company: *[Signature]*

Page: **82** of **85**

LAB USE ONLY - Aftix Workorder/Login Label Here

CHAIN-OF-CUSTODY Analytical Request Document  
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: **Jefferson Lewis BOCCES\_Watertown CSD**  
Street Address: **1351 Washington Street, Watertown NY 13601**

Contact/Report To: **Brian Arias**  
Phone #: **315-661-4351**  
E-Mail: **barias@watertowncswd.org**  
Cc E-Mail:

Invoice To: **Brian Arias**  
Invoice E-Mail: **barias@watertowncswd.org**

Purchase Order # (if applicable):  
Quote #:

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [X] ET  
Data Deliverables:  
[ ] Level II [ ] Level III [ ] Level IV  
[ ] EQUIS  
[ ] Other:

Customer Project #: **0025607**  
Project Name: **Knickerbocker school**  
Site Collection Info/Facility ID (as applicable):

County / State origin of sample(s): **New York**  
Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**  
Rush (Pre-approval required):  
[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other:  
Date Results Requested: **Standard 10 business day**  
Field Filtered (if applicable): [ ] Yes [ ] No  
Analyte:

\* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Res. CL2	Number & Type of Containers	Preservation non-conformance identified for sample
			Date	Time			
73	DW	G	12/4/24	748	121	1	X
74				703			
76				720			
77				692			
79	ART			745			
80	ART			745			
72A	NURSE		12/4/24	748			

Additional Instructions from Pace\*:

Collected By: **Thomas Rankin**  
Printed Name: **Thomas Rankin**  
Signature:

# Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number: **1219 11:45**  
Date/Time: **12/9 11:45**

Delivered by: [ ] In-Person [ ] Courier  
[ ] FedEx [ ] UPS [ ] Other

Date/Time: **12/10/24 7:00**  
Date/Time: **12/10/24 7:00**

Received by/Company: **Signature: [Signature]**  
Received by/Company: **Signature: [Signature]**  
Received by/Company: **Signature: [Signature]**  
Received by/Company: **Signature: [Signature]**

Page 83 of 85





**WO#: 70326671**

Client Name:

Watertown

Project #

PM: MC1

Due Date: 12/24/24

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pac  Other

CLIENT: WATERTOWN

Tracking #:

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other Type of Ice: Wet Blue None

Thermometer Used: TH211 Correction Factor: 0.0  Samples on ice, cooling process has begun  
 Cooler Temperature (°C): 19.0 Cooler Temperature Corrected (°C): 19.0 Date/Time 5035A kits placed in freezer \_\_\_\_\_  
 Temp should be above freezing to 5.0°C

USDA Regulated Soil  N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: 12/12/24 PD

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	11.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix:	SL <u>WT</u> OIL OTHER	

Date and Initials of person checking preservation: 12/12/24 PD

All containers needing preservation have been	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13.	<input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>213624</u>			Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH > 9 Sulfide, NaOH > 12 Cyanide)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A		
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis			Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.	Positive for Res. Chlorine? Y N
KI starch test strips Lot #			
Residual chlorine strips Lot #			
SM 4500 CN samples checked for sul	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15.	Positive for Sulfide? Y N
Lead Acetate Strips Lot #			
Headspace in ALK Bottle (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.	
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A		
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A		

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

\* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.