



# IRRIGATION METER APPLICATION

FEE: \$400

Make checks payable to:  
City of Medford  
Water Meter Division  
21 James St  
Medford, MA 02155

Installation Address:

Owner's Information:

Name

Address

Home Phone #

Cell Phone #

|  |  |  |
|--|--|--|
|  |  |  |
|--|--|--|

Plumber's Information:

Company Name

Business Phone #

License #

|  |  |  |
|--|--|--|
|  |  |  |
|--|--|--|

Company Address

## Licensed Plumber Certification

I certify that:

- I will attain a plumbing permit with the Building Department.
- I will install the irrigation meter with accepted plumbing standards.
- I will properly separate all water pipes between outside irrigation and domestic usage.
- I will "T" the service to the specifications of the Water Meter Division.
- I will install shut-offs before and after the new irrigation meter.

Signed under the pains and penalties of perjury,

\_\_\_\_\_  
Signature of Licensed Plumber

### Guidelines for Basic Residential Irrigation Meter Installation and Requirements

1. A licensed plumber must obtain a permit at the Building Department and install meter to specifications.
2. A certified and tested backflow device must be furnished at customer's expense, device tested yearly.
3. All irrigation systems must comply with all local and state landscape irrigation regulations and restrictions.
4. All pipes from the service thru the irrigation meter and three feet past the backflow must be copper or brass.
5. The City of Medford Metering Division is not responsible for pressure loss or volume issues as a result of the additional meter.
6. The meter and the reading device are issued by the City and the price is included in the application fee.
7. All pipes from the irrigation meter must be properly split with no cross connections between domestic and irrigation pipes.
8. New and existing dwellings may split service connection for irrigation with backflow device that is a tee out to irrigation meter.
9. Must install shut-off valves before and after the new irrigation meter.
10. Unprotected or improperly protected cross connections are prohibited under the Medford Water Department Regulations and the Commonwealth of Massachusetts Drinking Water Regulations governing Cross Connections (310-CMR-22.22)

### Failure to Comply with these Provisions may result in termination of water service

I have read and understand the requirements outlined in this application and will comply with these provisions.

\_\_\_\_\_  
Customer Signature

\_\_\_\_\_  
Date