

Submittal #220510-1. - Lead in Potable Water Testing - Report 220510 - LEAD IN POTABLE WATER TESTING

Revision		Submittal Manager	Jessica Saccone (John W. Danforth Company)
Status	Open	Date Created	Oct 16, 2024
Issue Date	Oct 16, 2024	Spec Section	220510 - LEAD IN POTABLE WATER TESTING
Responsible Contractor	John W. Danforth Company	Received From	Mitchell Davis (John W. Danforth Company)
		Submit By	
Final Due Date	Nov 1, 2024	Lead Time	
Location		Type	Report
Approvers	Jessica Saccone (John W. Danforth Company), Owner/CM/GC		
Ball in Court	Owner/CM/GC		
Distribution			
Description	Report for Approval		
Supplier	MIS of America	Manufacturer	Special Pathogens Laboratory
Customer Submittal #		BY OTHERS	No

Submittal Workflow

Name	Sent Date	Due Date	Returned Date	Response	Attachments
General Information Attachments					Romulus Lead Test Results.pdf
Jessica Saccone		Oct 18, 2024	Oct 16, 2024	For Record Only	
Owner/CM/GC	Oct 16, 2024	Nov 1, 2024		Pending	



**SPECIAL
PATHOGENS
LABORATORY**

THE LEGIONELLA EXPERTS®
1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219
P: 412-281-5335 F: 412-281-7445
www.SpecialPathogensLab.com

OCT 1 '24 10:00

Chain of Custody: Test Request Form

SPL ID: 2410-00073

UID:

Client Information				Sampling Contact			
Account Number 2524	P.O. Number	Submitting Company M.I.S of America, Inc.		Name Jerry Meyer Jr.		Email Legionellareports@misofamerica.com	
				Phone 716-681-3758			
Sample Information							
Project Identifier (Name or Number) Romulus L5D			Sampled by: Matt Allen			Date Collected 9/30/24	
Number of Samples 11							
Samples from New York or Connecticut? ☒ Yes ☐ No		If yes, List biocide(s): N/A List biocide conc:		Case investigation? (See back for details) ☐ Yes ☒ No		QuickCheck™? (See back for details) ☐ Yes ☒ No	
Sample No.	Sample Description Specific location, source, or site	Sample Type W= Water S=Swab O=Other	Water System P = Potable NP = Non-potable	Test Codes (1 code per box)	Sample Temp (°F)	Time Collected (hr:min)	SPL USE ONLY
							Acceptable? Receipt Temp Comments
1	Rm 3 Sink	W	P	230	73	6:35 a.m./p.m.	Y N
2	Rm 3 Fountain	W	P	230	73	6:35 a.m./p.m.	Y N
3	Rm 6 Sink	W	P	230	73	6:38 a.m./p.m.	Y N
4	Rm 10 Sink	W	P	230	74	6:39 a.m./p.m.	Y N
5	Rm 11 Sink	W	P	230	72	6:41 a.m./p.m.	Y N
6	Rm 12 Sink	W	P	230	73	6:44 a.m./p.m.	Y N
7	Rm 13 Sink	W	P	230	72	6:47 a.m./p.m.	Y N
8	Rm 13 Fountain	W	P	230	72	6:48 a.m./p.m.	Y N
9	Rm 14 Sink	W	P	230	73	6:53 a.m./p.m.	Y N
10	Rm 14 Fountain	W	P	230	73	6:54 a.m./p.m.	Y N
11	Rm 15 Sink	W	P	230	72	6:57 a.m./p.m.	Y N
Relinquished by		Date	Time	Received by		Date	Time
						JH 10/1/24	



**SPECIAL
PATHOGENS
LABORATORY**

THE LEGIONELLA EXPERTS®

1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219

P: 412-281-5335 F: 412-281-7445

www.SpecialPathogensLab.com

OCT 1 '24 AM 10:03

Chain of Custody: Test Request Form

SPL ID: 2410-00073

UID:

Client Information				Sampling Contact			
Account Number 2524	P.O. Number	Submitting Company M.I.S of America, Inc.		Name Jerry Meyer Jr.		Email Legionellareports@misofamerica.com	
Phone 716-681-3758							
Sample Information							
Project Identifier (Name or Number) Romulus LSD			Sampled by: Matt Allen			Date Collected 9/30/24	
Number of Samples 11							
Samples from New York or Connecticut? ☒ Yes ☐ No		If yes, List biocide(s): N/A List biocide conc: _____		Case investigation? (See back for details) ☐ Yes ☒ No		QuickCheck™? (See back for details) ☐ Yes ☒ No	
Sample No.	Sample Description Specific location, source, or site	Sample Type W= Water Swab O= Other	Water System P= Potable NP= Non-potable	Test Codes (1 code per box)	Sample Temp ("F)	Time Collected (hr:min)	SPL USE ONLY
							Acceptable? Receipt Temp Comments
1	Rm 17 Sink	W	P	230	73	7:01 a.m./p.m.	Y N
2	Rm 22 Sink	W	P	230	73	7:06 a.m./p.m.	Y N
3	Rm 22 Fountain	W	P	230	73	7:07 a.m./p.m.	Y N
4	Rm 23 Sink	W	P	230	73	7:09 a.m./p.m.	Y N
5	Rm 23 Fountain	W	P	230	73	7:10 a.m./p.m.	Y N
6	Rm 24 Sink	W	P	230	74	7:14 a.m./p.m.	Y N
7	Rm 24 Fountain	W	P	230	74	7:14 a.m./p.m.	Y N
8	Rm 25 Sink	W	P	230	74	7:17 a.m./p.m.	Y N
9	Rm 25 Fountain	W	P	230	74	7:18 a.m./p.m.	Y N
10	Rm 26 Sink	W	P	230	73	7:20 a.m./p.m.	Y N
11	Rm 27 Sink	W	P	230	73	7:22 a.m./p.m.	Y N
Relinquished by		Date	Time	Received by		Date	Time
						JN 10/1/24	



**SPECIAL
PATHOGENS
LABORATORY**

THE LEGIONELLA EXPERTS®

1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219

P: 412-281-5335 F: 412-281-7445

www.SpecialPathogensLab.com

Chain of Custody: Test Request Form

SPL ID:

2410-00073

UID:

OCT 1 '24 AM 10:09

Client Information				Sampling Contact				
Account Number 2524	P.O. Number	Submitting Company M.I.S of America, Inc.		Name Jerry Meyer Jr.		Email Legionellareports@misofamerica.com		
Phone 716-681-3758								
Sample Information								
Project Identifier (Name or Number) Room 1 vs 2 SD		Sampled by: Matt Allen		Date Collected 9/30/24		Number of Samples 8		
Samples from New York or Connecticut? ☒ Yes ☐ No		If yes, List biocide(s): N/A List biocide conc: _____		Case investigation? (See back for details) ☐ Yes ☒ No		QuickCheck™? (See back for details) ☐ Yes ☒ No		
Sample No.	Sample Description Specific location, source, or site	Sample Type W= Water S=Swab O=Other	Water System P= Potable NP= Non-potable	Test Codes (1 code per box)	Sample Temp (°F)	Time Collected (hr:min)	SPL USE ONLY	
							Acceptable? Receipt Temp Comments	
1	Rm 27 Fountain	W	P	230	73	7:23 a.m./p.m. ☒ ☐	Y N	
2	Rm 28 Sink	W	P	230	74	7:27 a.m./p.m. ☒ ☐	Y N	
3	Rm 33 Sink	W	P	230	73	7:29 a.m./p.m. ☒ ☐	Y N	
4	Rm 34 Sink	W	P	230	74	7:31 a.m./p.m. ☒ ☐	Y N	
5	Rm 35 Sink	W	P	230	74	7:33 a.m./p.m. ☒ ☐	Y N	
6	Rm 36 Sink	W	P	230	73	7:37 a.m./p.m. ☒ ☐	Y N	
7	Rm 37 Sink	W	P	230	73	7:40 a.m./p.m. ☒ ☐	Y N	
8	Rm 38 Sink	W	P	230	73	7:42 a.m./p.m. ☒ ☐	Y N	
						a.m./p.m. ☐ ☐	Y N	
						a.m./p.m. ☐ ☐	Y N	
						a.m./p.m. ☐ ☐	Y N	
Relinquished by			Date	Time	Received by		Date	Time
					JH		10/1/24	



FINAL REPORT

M.I.S. of America Inc
4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Summary

This summary is provided for your convenience. Complete report on the following pages.

Biocide Concentration:

N/A

Lead

Location	Result	Concentration
1. Rm 3 Sink	Complete	<0.0010 mg/L
2. Rm 3 Fountain	Complete	0.0021 mg/L
3. Rm 6 Sink	Complete	<0.0010 mg/L
4. Rm 10 Sink	Complete	<0.0010 mg/L
5. Rm 11 Sink	Complete	<0.0010 mg/L
6. Rm 12 Sink	Complete	0.0019 mg/L
7. Rm 13 Sink	Complete	<0.0010 mg/L
8. Rm 13 Fountain	Complete	0.0012 mg/L
9. Rm 14 Sink	Complete	0.0031 mg/L
10. Rm 14 Fountain	Complete	0.0017 mg/L
11. Rm 15 Sink	Complete	0.0020 mg/L
1. Rm 17 Sink	Complete	0.0020 mg/L
2. Rm 22 Sink	Complete	0.0011 mg/L
3. Rm 22 Fountain	Complete	0.0022 mg/L
4. Rm 23 Sink	Complete	0.0034 mg/L
5. Rm 23 Fountain	Complete	0.0027 mg/L
6. Rm 24 Sink	Complete	<0.0010 mg/L
7. Rm 24 Fountain	Complete	0.0066 mg/L
8. Rm 25 Sink	Complete	0.0017 mg/L
9. Rm 25 Fountain	Complete	<0.0010 mg/L
10. Rm 26 Sink	Complete	0.0020 mg/L
11. Rm 27 Sink	Complete	0.0023 mg/L
1. Rm 27 Fountain	Complete	0.0096 mg/L



FINAL REPORT

M.I.S. of America Inc

4391 Walden Ave

Lancaster, NY 14086

P: (716) 681-3758

Account #: 2524

SPL Project ID: 2410-00073

Project Name: Romulus CSD

Sampled By: Matt Allen

Date Received: 10/01/2024

Date Final: 10/15/2024

Lead

Location	Result	Concentration
2. Rm 28 Sink	Complete	<0.0010 mg/L
3. Rm 33 Sink	Complete	<0.0010 mg/L
4. Rm 34 Sink	Complete	<0.0010 mg/L
5. Rm 35 Sink	Complete	<0.0010 mg/L
6. Rm 36 Sink	Complete	0.0025 mg/L
7. Rm 37 Sink	Complete	0.0044 mg/L
8. Rm 38 Sink	Complete	<0.0010 mg/L

Approved By: Brian Verdi

Janet E. Stout, Ph.D.

Laboratory Director, Special Pathogens Laboratory



FINAL REPORT

M.I.S. of America Inc

4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Location:	1. Rm 3 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.001	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:35 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	2. Rm 3 Fountain	Date Collected:	09/30/2024
Sample ID:	2410-00073.002	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:35 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0021 mg/L		
Location:	3. Rm 6 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.003	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:38 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	4. Rm 10 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.004	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:39 am
Sample Temp:	74.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		



FINAL REPORT

M.I.S. of America Inc

4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Location:	5. Rm 11 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.005	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:41 am
Sample Temp:	72.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	6. Rm 12 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.006	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:44 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0019 mg/L		
Location:	7. Rm 13 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.007	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:47 am
Sample Temp:	72.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	8. Rm 13 Fountain	Date Collected:	09/30/2024
Sample ID:	2410-00073.008	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:48 am
Sample Temp:	72.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0012 mg/L		



FINAL REPORT

M.I.S. of America Inc
4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Location:	9. Rm 14 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.009	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:53 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0031 mg/L		
Location:	10. Rm 14 Fountain	Date Collected:	09/30/2024
Sample ID:	2410-00073.010	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:54 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0017 mg/L		
Location:	11. Rm 15 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.011	Sample Type:	Water
Source Type:	Potable	Time Collected:	6:57 am
Sample Temp:	72.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0020 mg/L		
Location:	1. Rm 17 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.012	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:01 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0020 mg/L		



FINAL REPORT

M.I.S. of America Inc

4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Location:	2. Rm 22 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.013	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:06 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0011 mg/L		
Location:	3. Rm 22 Fountain	Date Collected:	09/30/2024
Sample ID:	2410-00073.014	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:07 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0022 mg/L		
Location:	4. Rm 23 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.015	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:09 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0034 mg/L		
Location:	5. Rm 23 Fountain	Date Collected:	09/30/2024
Sample ID:	2410-00073.016	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:10 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0027 mg/L		



FINAL REPORT

M.I.S. of America Inc

4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Location:	6. Rm 24 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.017	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:14 am
Sample Temp:	74.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	7. Rm 24 Fountain	Date Collected:	09/30/2024
Sample ID:	2410-00073.018	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:14 am
Sample Temp:	74.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0066 mg/L		
Location:	8. Rm 25 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.019	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:17 am
Sample Temp:	74.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0017 mg/L		
Location:	9. Rm 25 Fountain	Date Collected:	09/30/2024
Sample ID:	2410-00073.020	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:18 am
Sample Temp:	74.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		



FINAL REPORT

M.I.S. of America Inc

4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Location:	10. Rm 26 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.021	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:20 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0020 mg/L		
Location:	11. Rm 27 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.022	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:22 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0023 mg/L		
Location:	1. Rm 27 Fountain	Date Collected:	09/30/2024
Sample ID:	2410-00073.023	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:23 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0096 mg/L		
Location:	2. Rm 28 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.024	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:27 am
Sample Temp:	74.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		



FINAL REPORT

M.I.S. of America Inc

4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Location:	3. Rm 33 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.025	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:29 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	4. Rm 34 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.026	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:31 am
Sample Temp:	74.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	5. Rm 35 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.027	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:33 am
Sample Temp:	74.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		
Location:	6. Rm 36 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.028	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:37 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0025 mg/L		



FINAL REPORT

M.I.S. of America Inc
4391 Walden Ave
Lancaster, NY 14086
P: (716) 681-3758

Account #: 2524
SPL Project ID: 2410-00073
Project Name: Romulus CSD
Sampled By: Matt Allen
Date Received: 10/01/2024
Date Final: 10/15/2024

Location:	7. Rm 37 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.029	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:40 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	0.0044 mg/L		

Location:	8. Rm 38 Sink	Date Collected:	09/30/2024
Sample ID:	2410-00073.030	Sample Type:	Water
Source Type:	Potable	Time Collected:	7:42 am
Sample Temp:	73.0°F		
Test Requested:	Lead	Status:	Complete 10/15/2024
Result:	Complete		
Concentration:	<0.0010 mg/L		

Approved By: Brian Verdi

Janet E. Stout, Ph.D.
Laboratory Director, Special Pathogens Laboratory



**SPECIAL
PATHOGENS
LABORATORY**

THE LEGIONELLA EXPERTS®

1401 Forbes Ave., Suite 401 Pittsburgh, PA 15219

P: 412-281-5335 F: 412-281-7445

www.SpecialPathogensLab.com

FINAL REPORT

M.I.S. of America Inc

4391 Walden Ave

Lancaster, NY 14086

P: (716) 681-3758

Account #: 2524

SPL Project ID: 2410-00073

Project Name: Romulus CSD

Sampled By: Matt Allen

Date Received: 10/01/2024

Date Final: 10/15/2024

NOTES

Lead

Lead: Concentration in milligrams per liter (mg/L).

-Testing Performed by Pace Analytical Services LLC. Sub-contractor report available upon request.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed. This report is not to be reproduced in whole or in part without the expressed consent of SPL. Results apply to the sample as received.