

ENVIRONMENTAL LABWORKS, INC.

December 5, 2024

Mr. Kyle Harjes
Onteora Central School District
Buildings & Grounds Department
P.O. Box 300
Boiceville, NY 12412

Dear Mr. Harjes,


The following are results of the analyses performed on a sample from
**Onteora Central School District - Bennett Elementary School - Route 28,
Boiceville, NY** received at the laboratory on 11/14/24.

Date/Time Collected: 11/14/24 8:05am First Draw
Collected By: U.C.BOCES
Project ID: 11142427
Secondary ID: BE245106

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Cafeteria Ice Machine 11142427-1	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/26/24

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director

ENVIRONMENTAL LABWORKS, INC.

November 20, 2024

Mr. Kyle Harjes
Onteora Central School District
Buildings & Grounds Department
P.O. Box 300
Boiceville, NY 12412

Dear Mr. Harjes,

The following are results of the analyses performed on samples from **Onteora Central School District - Bennett Elementary School - Route 28, Boiceville, NY** received at the laboratory on 11/06/24.

Date/Time Collected: 11/06/24 7:35-7:47am First Draw
Collected By: U.C.BOCES
Project ID: 11062408
Secondary ID: BE244909-18

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
Cafeteria Fountain 11062408-1	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Cafeteria Bottle Filler 11062408-2	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Kitchen Triple Sink Left 11062408-3	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Kitchen Triple Sink Right 11062408-4	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Kitchen Single Sink 11062408-5	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Front Hall Fountain 11062408-6	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Front Hall Bottle Fill 11062408-7	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Rear Hall Bottle Fill Right 11062408-8	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Rear Hall Right Fountain 11062408-9	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24
Rear Hall Fountain Left 11062408-10	EPA 200.8 Lead	<0.0010 mg/L	0.005 mg/L	11/13/24


PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Onteora Central Schools - Bennett ES - 11062408

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,

A handwritten signature in dark ink, appearing to read "Michael F. Lupi", written in a cursive style.

for Michael F. Lupi
Technical Director