



## **WATER SAMPLING AND REPORTING SERVICES**

**COLUMBIA PUBLIC SCHOOLS  
COLUMBIA AREA CAREER CENTER  
4203 SOUTH PROVIDENCE ROAD  
COLUMBIA, MISSOURI**

Prepared for:  
**COLUMBIA PUBLIC SCHOOLS  
COLUMBIA, MISSOURI**

Prepared by:  
**GEOTECHNOLOGY, LLC, DBA UES  
ST. LOUIS, MISSOURI**

Date:  
**AUGUST 5, 2024**

Project No.:  
**J044517.01**

**SAFETY  
TEAMWORK  
RESPONSIVENESS  
INTEGRITY  
VALUE  
EXCELLENCE**



August 5, 2024

Mr. David Seamon  
District Project Manager  
Columbia Public Schools  
1818 West Worley Street  
Columbia, Missouri 65203

Re: Water Sampling and Reporting Services  
Columbia Public Schools  
Columbia Area Career Center  
4203 South Providence Road  
Columbia, Missouri  
Project No. J044517.01

Dear Mr. Seamon:

In accordance with Columbia Public Schools' (CPS) Request for Proposal No. C-24043, dated October 10, 2023, Geotechnology, LLC, dba UES, is pleased to provide this drinking water sampling report for the referenced project. Our scope of services included flushing and sampling of drinking water from potable water outlets, laboratory analysis of water samples, and a letter report.

#### **SITE AND PROJECT DESCRIPTION**

The subject property consists of the existing Columbia Public Schools Columbia Area Career Center, located west of South Providence Road and South of Peach Way in Columbia, Missouri. The purpose of the drinking water sampling was to identify potable water outlets that may require remediation in accordance with the State of Missouri's *Get the Lead out of School Drinking Water Act* (RSMo 160.077).

#### **DRINKING WATER SAMPLING**

RSMo 160.077 sets standards for lead concentrations in school drinking water, stating that each Missouri school shall provide drinking water with a lead concentration level below five (5) parts per billion (ppb). This Act requires schools to conduct the inventory, sampling, remediation, and monitoring at all potable drinking water outlets used or potentially used for drinking, food preparation, and cooking or cleaning utensils.

In general conformance with the RSMo 160.077 requirements, and the Environmental Protection Agency's (EPA) *3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities* manual, initial water flushing and sampling activities were conducted on January 15 and 16, and March 5 and 6, 2024, by Mr. Brad Lohrum, a Missouri-licensed lead risk assessor. Mr. Lohrum was assisted by Mr. Bob Haefner, a Missouri-licensed lead risk assessor, and Mr.



Jon Tuetken, an environmental scientist with UES. Copies of training certificates and lead licenses for Messrs. Lohrum and Haefner are included in Appendix A.

An inventory of potable drinking water outlets was provided to UES by CPS. UES personnel sampled the identified outlets utilizing the EPA's "first-draw" methods. The identified outlets were flushed, then allowed to sit undisturbed for a period of 8-18 hours. Following this stagnation period, the first 250 milliliters (ml) of water expelled from the outlets were collected in laboratory-provided containers. A copy of the drinking water sampling forms, which include a list of sample locations, and the times and dates of flushing and sampling activities, are included in Appendix B. A floor plan depicting approximate sample locations is included as Figure 1.

Using standard chain-of-custody procedures, the drinking water samples were submitted to Teklab, Inc. of Collinsville, Illinois, an independent, certified Missouri Department of Natural Resources (MDNR) Drinking Water and National Environmental Laboratory Accreditation Program (NELAP) accredited laboratory, for analysis of lead content via EPA Method 200.8: *Determination of Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry*.

## RESULTS

Laboratory analyses detected the presence of lead at or above 5 ppb in the following sample.

**TABLE 1**  
**DRINKING WATER OUTLETS AT OR ABOVE 5 PARTS PER BILLION**

Sample Number / Location and Fixture Type	Results
CACC-02 / Room 157 – Right Sink	5.3 ppb

UES will not be able to represent that the site contains no lead-bearing water outlets beyond those detected or observed by UES during flushing and sampling activities. Copies of the drinking water analytical results are included in Appendix C.

## RECOMMENDATIONS

Our recommendations are summarized below:

- It is our understanding that the outlet identified in Table 1 has either been removed, marked as non-potable, or has otherwise been taken out of service. Should this fixture be put back into service following remediation activities, or if a replacement fixture is to be put into service, further sampling and testing should be conducted.

\* \* \* \* \*



The following attachments are included in and complete this report:

- |            |  |
|------------|--|
| Figure 1   | - Drinking Water Sample Locations                          |
| Appendix A | - Certificates and Licenses of Environmental Professionals |
| Appendix B | - Drinking Water Sampling Forms                            |
| Appendix C | - Drinking Water Laboratory Data Sheets                    |
| Appendix D | - Limitations of Report                                    |

\* \* \* \* \*


We appreciate the opportunity to provide our professional environmental consulting services to Columbia Public Schools on this project. If you have any questions or comments, please contact me at (314) 997-7440.

Very truly yours,

**UES**


Bradley J. Lohrum  
Project Manager

BJL/MSR:bjl/jsj



#### NOTES

1. Drawing not to scale.
2. Drawing adapted from "Columbia Area Career Center Floor Plan", provided by the client, dated 06/06/2014.
3. Sample locations were identified in the field relative to building features and are approximate only.

Drawn By: BJL	Ck'd By: BJL	App'vd By: MSR
Date: 8-5-24	Date: 8-5-24	Date: 8-5-24
		
4203 South Providence Road Columbia, Missouri		
<b>DRINKING WATER SAMPLING LOCATIONS</b>		
Project Number J044517.01	<b>FIGURE 1</b>	



## **APPENDIX A**

### **CERTIFICATES AND LICENSES OF ENVIRONMENTAL PROFESSIONALS**

COLLEGE FOR  
PUBLIC HEALTH & SOCIAL JUSTICE

SAINT LOUIS UNIVERSITY

CENTER FOR ENVIRONMENTAL EDUCATION AND TRAINING

verifies that

**Bradley Lohrum**

817 S Sappington Road, Crestwood, MO 63126

has attended 8 contact hours of training and successfully passed an examination

**Lead Risk Assessor Refresher**

St. Louis, MO

Certificate # CEET 325 - 12/12/2022 - 189152

Examination Date: 12/12/2022

CEUs: 0.8

  
Christopher C. King PhD

Director, Center for Environmental  
Education and Training

Certificate expiration is 3 years from examination date for Illinois Dept. of Public Health

Center for Environmental Education and Training, 3545 Lafayette, St. Louis, MO 63104

(314) 977-8256 [shu.edu/x39753.xml](http://shu.edu/x39753.xml)

This training course has been accredited by the Illinois Department of Public Health, and by the Missouri Department of Health & Senior Services.

***STATE OF MISSOURI***  
***DEPARTMENT OF HEALTH AND SENIOR SERVICES***

**LEAD OCCUPATION LICENSE REGISTRATION**


Issued to:

**Bradley J. Lohrum**

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Risk Assessor**  
Category of License

Issuance Date: **1/20/2023**  
Expiration Date: **1/20/2025**  
License Number: **230120-300006460**



Paula F. Nickelson  
Acting Director  
Department of Health and Senior Services



# SAINT LOUIS UNIVERSITY

## CENTER FOR ENVIRONMENTAL EDUCATION AND TRAINING

verifies that

**Robert Haefner**

3951 Dover Pl, St. Louis, MO 63116

has attended 8 contact hours of training and successfully passed examination for

### Lead Risk Assessor Refresher

St. Louis, MO

Certificate # CEET 325 3/6/2023 118035  
Examination Date: 3/6/2023  
CEUs: 0.8

*Rene Dulle*

Rene Dulle, MBA, Director  
Center for Environmental Education & Training

Center for Environmental Education and Training | 3545 Lafayette Ave., St. Louis, MO 63104  
(314) 977-8256 | [slu.edu/public-health-social-justice/centers-institutes/ceet.php](http://slu.edu/public-health-social-justice/centers-institutes/ceet.php)

The training course has been accredited by the Missouri Dept. of Health and Senior Services, and by the Illinois Dept. of Public Health. Certificate expiration is 3 years from examination date for Illinois Dept. of Public Health.

**STATE OF MISSOURI**  
**DEPARTMENT OF HEALTH AND SENIOR SERVICES**

**LEAD OCCUPATION LICENSE REGISTRATION**

Issued to:

**Robert J. Haefner**

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Risk Assessor**  
**Category of License**

Issuance Date:	<b>3/28/2023</b>
Expiration Date:	<b>3/30/2025</b>
License Number:	<b>150330-300004672</b>

*Paula F. Nickelson*

Paula F. Nickelson  
Acting Director  
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102

**STATE OF MISSOURI**  
**DEPARTMENT OF HEALTH AND SENIOR SERVICES**

**Lead Abatement Contractor License**

The person, firm or corporation whose name appears on this certificate is licensed as a Lead Abatement Contractor as set forth in the Missouri Revised Statutes 701.300-701.338 and 19 CSR 30-70.180, as long as not suspended or revoked, and is hereby authorized to engage in lead-bearing substance activities.

Issued to:

**Geotechnology, LLC**

**11816 Lackland Road, Suite 150**  
**St. Louis, MO 63146**

Issuance Date: 2/8/2022  
Expiration Date: 2/8/2024  
License Number: 060208-0095



A handwritten signature in black ink, reading "Donald G. Kauerauf", is positioned above the printed name of the Director.

Donald G. Kauerauf  
Director

Department of Health and Senior Services

***STATE OF MISSOURI***  
***DEPARTMENT OF HEALTH AND SENIOR SERVICES***

**Lead Abatement Contractor License**


The person, firm or corporation whose name appears on this certificate is licensed as a Lead Abatement Contractor as set forth in the Missouri Revised Statutes 701.300-701.338 and 19 CSR 30-70.180, as long as not suspended or revoked, and is hereby authorized to engage in lead-bearing substance activities.

Issued to:

**Geotechnology LLC (UES)**

**11816 Lackland Rd Suite 150  
St. Louis, MO 63146**

Issuance Date: **2/28/2024**  
Expiration Date: **2/28/2026**  
License Number: **240229-4652**



Paula F. Nickelson  
Director  
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102



## **APPENDIX B**

### **DRINKING WATER SAMPLING FORMS**

**DRINKING WATER SAMPLING FORM**

Page 1 of 2

Project Name: Columbia Public Schools Water  
Sampling and Reporting Services  
Building Name: Columbia Area Career Center

Project Number: J044517.01  
Address: 4203 South Providence Road  
Columbia, Missouri

Sample ID	Fixture Type	Location	Flushed By - Date - Time	Sampled By - Date - Time
CACC-01	S	Room 157 - Left	RJH - 1/15/24 - 12:52	RJH - 1/15/24 - 23:38
CACC-02	S	Room 157 - Right	JFT - 1/15/24 - 12:52	JFT - 1/15/24 - 23:38
CACC-03	S	Room 162 - Left	RJH - 1/15/24 - 13:00	RJH - 1/15/24 - 23:40
CACC-04	S	Room 162- Right	JFT - 1/15/24 - 13:00	JFT - 1/15/24 - 23:40
CACC-05	S	Room 163H	KJH - 1/15/24 - 13:03	RJH - 1/15/24 - 23:42
CACC-06	BF	Hallway at Room 165 - Left	JFT - 1/15/24 - 13:05	RJH - 1/15/24 - 23:44
CACC-07	WF	Hallway at Room 165 - Left	JFT - 1/15/24 - 13:05	RJH - 1/15/24 - 23:44
CACC-08	WF	Hallway at Room 165 - Right	RJH - 1/15/24 - 13:06	JFT - 1/15/24 - 23:44
CACC-09	WF	Hallway at Room 166 - Left	JFT - 1/15/24 - 13:06	JFT - 1/15/24 - 23:45
CACC-10	WF	Hallway at Room 166 - Right	RJH - 1/15/24 - 13:06	RJH - 1/15/24 - 23:45
CACC-11	WF	Hallway at Room 164 - Left	RJH - 1/15/24 - 13:08	RJH - 1/15/24 - 23:46
CACC-12	WF	Hallway at Room 164 - Right	RJH - 1/15/24 - 13:08	JFT - 1/15/24 - 23:46
CACC-13	S	Room 171 - Dishwash	RJH - 1/15/24 - 13:12	RJH - 1/15/24 - 23:50
CACC-14	S	Room 171 - Food Prep	RJH - 1/15/24 - 13:12	RJH - 1/15/24 - 23:50
CACC-15	HW	Room 171 - East	JFT - 1/15/24 - 13:12	RJH - 1/15/24 - 23:50
CACC-16	HW	Room 171 - South	BJL - 3/5/24 - 19:52	BJL - 3/6/24 - 3:52
CACC-17	S	Room 172 - Food Prep	RJH - 1/15/24 - 13:15	JFT - 1/15/24 - 23:52
CACC-18	HW	Room 172 - Northwest	BJL - 1/15/24 - 13:15	RJH - 1/15/24 - 23:52
CACC-19	HW	Room 172 - Northeast	RJH - 1/15/24 - 13:15	JFT - 1/15/24 - 23:52
CACC-20	HW	Room 172 - Southeast	JFT - 1/15/24 - 13:15	RJH - 1/15/24 - 23:52
CACC-21	HW	Room 172F	RJH - 1/15/24 - 13:17	RJH - 1/15/24 - 23:53
CACC-22	S	Room 172F - Left	RJH - 1/15/24 - 13:17	RJH - 1/15/24 - 23:53
CACC-23	S	Room 172F - Right	RJH - 1/15/24 - 13:17	RJH - 1/15/24 - 23:53
CACC-24	S	Room 172 E	JFT - 1/15/24 - 13:17	JFT - 1/15/24 - 23:54
CACC-25	ICE	Room 172E	JFT - 1/15/24 - 13:17	JFT - 1/15/24 - 23:54

BF=Bottle Filling  
B=Bubbler

FW=Filtered Water  
ICE=Ice Machine

S=Classroom/Other Sink  
WF=Water Fountain

HW=Hand Wash

Project Name: Columbia Public Schools Water Sampling and Reporting Services  
Building Name: Columbia Area Career Center

Project Number: J044517.01

---

Address: 4203 South Providence Road

---

Columbia, Missouri

[illegible]

BF=Bottle Filling  
B=Bubbler

FW=Filtered Water  
ICE=Ice Machine

S=Classroom/Other Sink  
WF=Water Fountain



## **APPENDIX C**

### **DRINKING WATER LABORATORY DATA SHEETS**

February 09, 2024

Brad Lohrum  
Geotechnology, Inc.  
11816 Lackland Road  
St. Louis, MO 63146  
TEL: (314) 997-7440  
FAX: (314) 997-2067



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE: J044517.01**

**WorkOrder: 24011322**

Dear Brad Lohrum:

TEKLAB, INC received 60 samples on 1/19/2024 10:00:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley  
Project Manager  
(618)344-1004 ex 44  
[patrickriley@teklabinc.com](mailto:patrickriley@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

**Client:** Geotechnology, Inc.

**Work Order:** 24011322

**Client Project:** J044517.01

**Report Date:** 09-Feb-24

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended

**Client:** Geotechnology, Inc.**Work Order:** 24011322**Client Project:** J044517.01**Report Date:** 09-Feb-24**Abbr Definition**

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count ( > 200 CFU )

**Client:** Geotechnology, Inc.

**Work Order:** 24011322

**Client Project:** J044517.01

**Report Date:** 09-Feb-24

### Qualifiers

- |   |  |
|---|--|
| # - Unknown hydrocarbon                               | B - Analyte detected in associated Method Blank              |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range                           |
| H - Holding times exceeded                            | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits        | M - Manual Integration used to determine area response       |
| ND - Not Detected at the Reporting Limit              | R - RPD outside accepted recovery limits                     |
| S - Spike Recovery outside recovery limits            | T - TIC(Tentatively identified compound)                     |
| X - Value exceeds Maximum Contaminant Level           |  |



## Case Narrative

<http://www.teklabinc.com/>

**Client:** Geotechnology, Inc.

**Work Order:** 24011322

**Client Project:** J044517.01

**Report Date:** 09-Feb-24

**Cooler Receipt Temp:** NA °C

### Locations

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** jhriley@teklabinc.com

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** EHurley@teklabinc.com

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415  
**Phone** (217) 698-1004  
**Fax** (217) 698-1005  
**Email** KKlostermann@teklabinc.com

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515  
**Phone** (630) 324-6855  
**Fax**  
**Email** arenner@teklabinc.com

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214  
**Phone** (913) 541-1998  
**Fax** (913) 541-1998  
**Email** jhriley@teklabinc.com

**Client:** Geotechnology, Inc.**Work Order:** 24011322**Client Project:** J044517.01**Report Date:** 09-Feb-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



## Laboratory Results

<http://www.teklabinc.com/>

Client: Geotechnology, Inc.

Work Order: 24011322

Client Project: J044517.01

Report Date: 09-Feb-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24011322-001A	SBE-75	NELAP		1.0	1.7	µg/L	1	02/08/2024 4:37	01/15/2024 23:09
24011322-002A	SBE-76	NELAP		1.0	3.1	µg/L	1	02/08/2024 4:41	01/15/2024 23:11
24011322-003A	SBE-77	NELAP		1.0	< 1.0	µg/L	1	02/08/2024 4:45	01/15/2024 23:11
24011322-004A	SBE-78	NELAP		1.0	3.3	µg/L	1	02/08/2024 4:50	01/15/2024 23:11
24011322-005A	SBE-79	NELAP		1.0	< 1.0	µg/L	1	02/08/2024 5:29	01/15/2024 23:11
24011322-006A	CACC-01	NELAP		1.0	1.3	µg/L	1	02/08/2024 4:54	01/15/2024 23:38
24011322-007A	CACC-02	NELAP		1.0	5.3	µg/L	1	02/08/2024 5:24	01/15/2024 23:38
24011322-008A	CACC-03	NELAP		1.0	3.8	µg/L	5	02/06/2024 15:38	01/15/2024 23:40
24011322-009A	CACC-04	NELAP		1.0	3.1	µg/L	5	02/06/2024 15:03	01/15/2024 23:40
24011322-010A	CACC-05	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 20:22	01/15/2024 23:42
24011322-011A	CACC-06	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 20:25	01/15/2024 23:44
24011322-012A	CACC-07	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 20:29	01/15/2024 23:44
24011322-013A	CACC-08	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 20:33	01/15/2024 23:44
24011322-014A	CACC-09	NELAP		1.0	1.1	µg/L	1	02/07/2024 20:36	01/15/2024 23:45
24011322-015A	CACC-10	NELAP		1.0	1.1	µg/L	1	02/07/2024 20:47	01/15/2024 23:45
24011322-016A	CACC-11	NELAP		1.0	1.1	µg/L	1	02/07/2024 21:02	01/15/2024 23:46
24011322-017A	CACC-12	NELAP		1.0	1.3	µg/L	1	02/07/2024 21:06	01/15/2024 23:46
24011322-018A	CACC-13	NELAP		1.0	1.2	µg/L	1	02/07/2024 21:09	01/15/2024 23:50
24011322-019A	CACC-14	NELAP		1.0	1.4	µg/L	5	02/06/2024 15:42	01/15/2024 23:50
24011322-020A	CACC-15	NELAP		1.0	1.6	µg/L	1	02/07/2024 21:13	01/15/2024 23:50
24011322-022A	CACC-17	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 21:17	01/15/2024 23:52
24011322-023A	CACC-18	NELAP		1.0	1.7	µg/L	5	02/06/2024 15:46	01/15/2024 23:52
24011322-024A	CACC-19	NELAP		1.0	2.6	µg/L	1	02/07/2024 21:20	01/15/2024 23:52
24011322-025A	CACC-20	NELAP		1.0	1.2	µg/L	1	02/07/2024 21:24	01/15/2024 23:52
24011322-026A	CACC-21	NELAP		1.0	1.3	µg/L	1	02/07/2024 21:35	01/15/2024 23:53
24011322-027A	CACC-22	NELAP		1.0	2.3	µg/L	1	02/07/2024 21:39	01/15/2024 23:53
24011322-028A	CACC-23	NELAP		1.0	1.5	µg/L	5	02/06/2024 15:51	01/15/2024 23:53
24011322-029A	CACC-24	NELAP		1.0	< 1.0	µg/L	1	02/05/2024 15:11	01/15/2024 23:54
24011322-030A	CACC-25	NELAP		1.0	< 1.0	µg/L	1	02/05/2024 15:15	01/15/2024 23:54
24011322-031A	CACC-26	NELAP		1.0	1.6	µg/L	1	02/05/2024 11:54	01/15/2024 23:59
24011322-032A	CACC-27	NELAP		1.0	1.6	µg/L	1	02/05/2024 11:57	01/15/2024 23:59
24011322-033A	CACC-28	NELAP		1.0	3.1	µg/L	1	02/05/2024 12:01	01/16/2024 0:01
24011322-034A	CACC-29	NELAP		1.0	2.9	µg/L	1	02/05/2024 12:05	01/16/2024 0:01
24011322-035A	CACC-30	NELAP		1.0	1.5	µg/L	1	02/05/2024 12:08	01/16/2024 0:02
24011322-036A	CACC-31	NELAP		1.0	3.7	µg/L	1	02/05/2024 12:19	01/16/2024 0:03
24011322-037A	CACC-32	NELAP		1.0	< 1.0	µg/L	1	02/05/2024 12:23	01/16/2024 0:04
24011322-038A	GMS-01	NELAP		1.0	2.2	µg/L	1	02/05/2024 12:27	01/16/2024 0:26
24011322-039A	GMS-02	NELAP		1.0	1.9	µg/L	1	02/07/2024 19:12	01/16/2024 0:26
24011322-040A	GMS-03	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 19:27	01/16/2024 0:26
24011322-041A	GMS-04	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 19:30	01/16/2024 0:28
24011322-042A	GMS-05	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 19:34	01/16/2024 0:28
24011322-043A	GMS-06	NELAP		1.0	1.3	µg/L	1	02/07/2024 19:38	01/16/2024 0:29
24011322-044A	GMS-07	NELAP		1.0	< 1.0	µg/L	1	02/07/2024 19:41	01/16/2024 0:29
24011322-051A	GMS-24	NELAP		1.0	13.0	µg/L	1	02/07/2024 19:45	01/16/2024 0:37
24011322-052A	GMS-25	NELAP		1.0	20.7	µg/L	1	02/07/2024 19:56	01/16/2024 0:37
24011322-053A	GMS-26	NELAP		1.0	7.5	µg/L	1	02/07/2024 20:00	01/16/2024 0:37
24011322-054A	GMS-27	NELAP		1.0	12.7	µg/L	1	02/07/2024 20:14	01/16/2024 0:38
24011322-055A	GMS-28	NELAP		1.0	47.2	µg/L	5	02/08/2024 13:24	01/16/2024 0:40



## Laboratory Results

<http://www.teklabinc.com/>

Client: Geotechnology, Inc.

Work Order: 24011322

Client Project: J044517.01

Report Date: 09-Feb-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24011322-056A	GMS-29	NELAP		1.0	5.3	µg/L	1	02/07/2024 20:18	01/16/2024 0:40
24011322-057A	GMS-30	NELAP		1.0	1.0	µg/L	1	02/07/2024 22:30	01/16/2024 0:41
24011322-058A	GMS-31	NELAP		1.0	< 1.0	µg/L	1	02/09/2024 1:21	01/16/2024 0:42
24011322-059A	GMS-32	NELAP		1.0	1.1	µg/L	1	02/09/2024 1:24	01/16/2024 0:42
24011322-060A	GMS-33	NELAP		1.0	< 1.0	µg/L	1	02/09/2024 1:28	01/16/2024 0:43



## Receiving Check List

<http://www.teklabinc.com/>

Client: Geotechnology, Inc.

Work Order: 24011322

Client Project: J044517.01

Report Date: 09-Feb-24

Carrier: Employee

Received By: MEK

Completed by:

On:

19-Jan-24

Mary E Kemp

Reviewed by:

On:

19-Jan-24

Ellie Hopkins

Pages to follow:

Chain of custody

6

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C

NA

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice

☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☐

No ☒

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - MaryKemp - 1/19/2024 11:36:02 AM

Did not receive CACC-16 MEK 1/19/24

# CHAIN OF CUSTODY

pg. 48 of 74 Work order # 24011322

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b>	Geotechnology, LLC		
<b>Address:</b>	11816 Lackland Road		
<b>City / State / Zip</b>	St. Louis, MO 63146		
<b>Contact:</b>	Brad Lohrum	<b>Phone:</b>	(314) 997-7440
<b>E-Mail:</b>	blohrum@teamues.com	<b>Fax:</b>	

<b>Samples on:</b>	<input checked="" type="checkbox"/> ICE	<input type="checkbox"/> BLUE ICE	<input checked="" type="checkbox"/> NO ICE	NA °C	LTG#
<b>Preserved in:</b>	<input checked="" type="checkbox"/> LAB	<input type="checkbox"/> FIELD	<b>FOR LAB USE ONLY</b>		
<b>Lab Notes</b>					

Did not receive CACC-16 MEK 1/19/24

**Client Comments:**

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No  
 Are these samples known to be hazardous? ☐ Yes ☒ No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED																					
J044517.01		Brad Lohrum																									
Results Requested		Billing Instructions		# and Type of Containers										Aqueous		Drinking Water		Soil		Sludge		Special Waste		Groundwater		DW - Lead E200.8	
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)				UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER																
Lab Use Only	Sample Identification	Date/Time Sampled																									
24011322	-001 SBE-75	1/15/24 23:09		1																							
	002 SBE 76	23:11		1																							
	003 77			1																							
	004 78			1																							
	005 79			1																							
	006 CACC-01	23:38		1																							
	007 CACC-02	+		1																							
	008 03	23:40		1																							
	009 04	+		1																							
	010 05	23:42		1																							

Relinquished By		Date/Time		Received By		Date/Time	
Brad Lohrum		1/18/24		Mary Lohrum		1/18/24	
L. J. Lohrum		1/19/24 10:00				1/19/24 1000	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

BottleOrder: 80481



# CHAIN OF CUSTODY

pg. 49 of 74 Work order # 24011322-

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Geotechnology, LLC  
**Address:** 11816 Lackland Road  
**City / State / Zip:** St. Louis, MO 63146  
**Contact:** Brad Lohrum **Phone:** (314) 997-7440  
**E-Mail:** blohrum@teamues.com **Fax:**

**Samples on:** ☒ ICE ☒ BLUE ICE ☒ NO ICE °C LTG#  
**Preserved in:** ☒ LAB ☒ FIELD **FOR LAB USE ONLY**  
**Lab Notes**

**Client Comments:**

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No  
 Are these samples known to be hazardous? ☐ Yes ☒ No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED																			
J044517.01		Brad Lohrum																							
Results Requested		Billing Instructions		# and Type of Containers										Drinking Water		Soil		Sludge		Special Waste		Groundwater		DW - Lead E200.8	
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)				UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER														
Lab Use Only	Sample Identification	Date/Time Sampled																							
24011322-011	CACC - 06	1/15/24 23:44	1																						
012	CACC - 07	1	1																						
013	08	1	1																						
014	09	23:45	1																						
015	10	+	1																						
016	11	23:46	1																						
017	12	+	1																						
018	13	23:50	1																						
019	14	1	1																						
020	15	1	1																						

Relinquished By		Date/Time		Received By		Date/Time	
Brad Lohrum		1/18/24		RJ K		1/18/24	
RJ K		1/19/24 10:00		Manny Kump		1/19/24 1000	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

BottleOrder: 80481



# CHAIN OF CUSTODY

pg. 50 of 74 Work order # 24011322

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Geotechnology, LLC  
**Address:** 11816 Lackland Road  
**City / State / Zip:** St. Louis, MO 63146  
**Contact:** Brad Lohrum **Phone:** (314) 997-7440  
**E-Mail:** blohrum@teamues.com **Fax:**

**Samples on:** ☒ ICE ☒ BLUE ICE ☒ NO ICE °C LTG#  
**Preserved in:** ☒ LAB ☒ FIELD **FOR LAB USE ONLY**  
**Lab Notes**

**Client Comments:**

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No  
 Are these samples known to be hazardous? ☐ Yes ☒ No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED																			
J044517.01		Brad Lohrum																							
Results Requested		Billing Instructions		# and Type of Containers										Drinking Water		Soil		Sludge		Special Waste		Groundwater		DW - Lead E200.8	
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)				UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER														
Lab Use Only	Sample Identification	Date/Time Sampled																							
24011322-021	CACC-16	1/15/24 23:50	1																						
022	CACC-17	23:52	1																						
023	18		1																						
024	19		1																						
025	20		1																						
026	21	23:53	1																						
027	22		1																						
028	23		1																						
029	24	23:54	1																						
030	25		1																						

Relinquished By		Date/Time	Received By		Date/Time
Brad Lohrum		1/18/24	Mang Kemp		1/18/24
RJ Wf		1/19/24 10:00			1/19/24 1000

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

BottleOrder: 80481



pg. 51 of 74 Work order # 24011322

<b>Client:</b>	Geotechnology, LLC	
<b>Address:</b>	11816 Lackland Road	
<b>City / State / Zip</b>	St. Louis, MO 63146	
<b>Contact:</b>	Brad Lohrum	<b>Phone:</b> (314) 997-7440
<b>E-Mail:</b>	blohrum@teamues.com	<b>Fax:</b>

<b>Samples on:</b>	<input checked="" type="checkbox"/> ICE	<input checked="" type="checkbox"/> BLUE ICE	<input checked="" type="checkbox"/> NO ICE	_____ °C	<b>LTG#</b> _____
<b>Preserved in:</b>	<input checked="" type="checkbox"/> LAB	<input checked="" type="checkbox"/> FIELD	<b><u>FOR LAB USE ONLY</u></b>		
<b>Lab Notes</b>					
<b>Client Comments:</b>					

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
Bredley [Signature]	1/15/24	R-J [Signature]	1/18/24
R-J [Signature]	1/19/24 10:00	Mary Kemp	1/19/24 1000

BottleOrder: 80481



March 28, 2024

Brad Lohrum  
Geotechnology, Inc.  
11816 Lackland Road  
St. Louis, MO 63146  
TEL: (314) 997-7440  
FAX: (314) 997-2067



Illinois	100226
Illinois	1004652024-2
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE: J044517.01**

**WorkOrder: 24030694**

Dear Brad Lohrum:

TEKLAB, INC received 60 samples on 3/8/2024 4:11:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Shelly A. Hennessy  
Project Manager  
(618)344-1004 ex 36  
[SHennessy@teklabinc.com](mailto:SHennessy@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

**Client:** Geotechnology, Inc.

**Work Order:** 24030694

**Client Project:** J044517.01

**Report Date:** 28-Mar-24

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended

**Client:** Geotechnology, Inc.

**Work Order:** 24030694

**Client Project:** J044517.01

**Report Date:** 28-Mar-24

### Abbr Definition

\* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

**Client:** Geotechnology, Inc.

**Work Order:** 24030694

**Client Project:** J044517.01

**Report Date:** 28-Mar-24

### Qualifiers

- |   |  |
|---|--|
| # - Unknown hydrocarbon                               | B - Analyte detected in associated Method Blank              |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range                           |
| H - Holding times exceeded                            | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits        | M - Manual Integration used to determine area response       |
| ND - Not Detected at the Reporting Limit              | R - RPD outside accepted recovery limits                     |
| S - Spike Recovery outside recovery limits            | T - TIC(Tentatively identified compound)                     |
| X - Value exceeds Maximum Contaminant Level           |  |



## Case Narrative

<http://www.teklabinc.com/>

**Client:** Geotechnology, Inc.

**Work Order:** 24030694

**Client Project:** J044517.01

**Report Date:** 28-Mar-24

**Cooler Receipt Temp:** N/A °C

### Locations

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** jhriley@teklabinc.com

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** EHurley@teklabinc.com

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415  
**Phone** (217) 698-1004  
**Fax** (217) 698-1005  
**Email** KKlostermann@teklabinc.com

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515  
**Phone** (630) 324-6855  
**Fax**  
**Email** arenner@teklabinc.com

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214  
**Phone** (913) 541-1998  
**Fax** (913) 541-1998  
**Email** jhriley@teklabinc.com

**Client:** Geotechnology, Inc.**Work Order:** 24030694**Client Project:** J044517.01**Report Date:** 28-Mar-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Illinois	IEPA	1004652024-2	NELAP	4/30/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



## Laboratory Results

<http://www.teklabinc.com/>

Client: Geotechnology, Inc.

Work Order: 24030694

Client Project: J044517.01

Report Date: 28-Mar-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>									
<b>Lead</b>									
24030694-001A	SMS-05	NELAP		1.0	< 1.0	µg/L	1	03/27/2024 11:59	03/06/2024 3:32
24030694-002A	CACC-16	NELAP		1.0	1.9	µg/L	1	03/27/2024 12:03	03/06/2024 3:52
24030694-003A	JMS-05	NELAP		1.0	< 1.0	µg/L	1	03/27/2024 12:06	03/06/2024 4:12
24030694-004A	JMS-44	NELAP		1.0	< 1.0	µg/L	1	03/19/2024 9:52	03/06/2024 4:16
24030694-005A	JMS-48	NELAP		1.0	1.7	µg/L	1	03/19/2024 9:56	03/06/2024 4:18
24030694-006A	JMS-49	NELAP		1.0	< 1.0	µg/L	1	03/19/2024 9:59	03/06/2024 4:20
24030694-007A	BHS-01	NELAP		1.0	3.8	µg/L	1	03/19/2024 10:03	03/06/2024 4:46
24030694-008A	BHS-02	NELAP		1.0	1.2	µg/L	1	03/19/2024 10:07	03/06/2024 4:48
24030694-009A	BHS-03	NELAP		1.0	< 1.0	µg/L	1	03/19/2024 10:18	03/06/2024 4:51
24030694-010A	BHS-04	NELAP		1.0	1.2	µg/L	1	03/21/2024 14:06	03/06/2024 4:55
24030694-011A	BHS-05	NELAP		1.0	1.2	µg/L	1	03/19/2024 10:28	03/06/2024 5:00
24030694-012A	BHS-06	NELAP		1.0	1.4	µg/L	1	03/19/2024 10:59	03/06/2024 5:00
24030694-013A	BHS-07	NELAP		1.0	11.4	µg/L	1	03/19/2024 11:03	03/06/2024 5:06
24030694-014A	BHS-08	NELAP		1.0	5.0	µg/L	1	03/19/2024 11:08	03/06/2024 5:10
24030694-015A	BHS-09	NELAP		1.0	3.8	µg/L	1	03/19/2024 11:11	03/06/2024 5:12
24030694-016A	BHS-10	NELAP		1.0	< 1.0	µg/L	1	03/19/2024 11:16	03/06/2024 5:15
24030694-017A	BHS-11	NELAP		1.0	< 1.0	µg/L	1	03/19/2024 11:19	03/06/2024 5:15
24030694-018A	BHS-12	NELAP		1.0	< 1.0	µg/L	1	03/19/2024 11:23	03/06/2024 5:15
24030694-019A	BHS-13	NELAP		1.0	5.0	µg/L	1	03/19/2024 11:34	03/06/2024 5:17
24030694-020A	BHS-14	NELAP		1.0	13.1	µg/L	1	03/19/2024 11:49	03/06/2024 5:17
24030694-021A	BHS-15	NELAP		1.0	9.9	µg/L	1	03/19/2024 11:52	03/06/2024 5:17
24030694-022A	BHS-16	NELAP		1.0	14.4	µg/L	1	03/19/2024 11:56	03/06/2024 5:17
24030694-023A	BHS-17	NELAP		1.0	25.9	µg/L	1	03/19/2024 12:00	03/06/2024 5:17
24030694-024A	BHS-18	NELAP		1.0	5.2	µg/L	1	03/19/2024 12:03	03/06/2024 5:20
24030694-025A	BHS-19	NELAP		1.0	9.4	µg/L	1	03/21/2024 14:10	03/06/2024 5:20
24030694-026A	BHS-20	NELAP		1.0	17.1	µg/L	1	03/19/2024 12:11	03/06/2024 5:20
24030694-027A	BHS-21	NELAP		1.0	16.4	µg/L	1	03/19/2024 12:14	03/06/2024 5:20
24030694-028A	BHS-22	NELAP		1.0	14.6	µg/L	1	03/21/2024 14:13	03/06/2024 5:20
24030694-029A	BHS-23	NELAP		1.0	26.8	µg/L	1	03/19/2024 12:40	03/06/2024 5:20
24030694-030A	BHS-24	NELAP		1.0	8.1	µg/L	1	03/19/2024 12:44	03/06/2024 5:20
24030694-031A	BHS-25	NELAP		1.0	3.5	µg/L	1	03/19/2024 12:47	03/06/2024 5:25
24030694-032A	BHS-26	NELAP		1.0	< 1.0	µg/L	1	03/19/2024 12:51	03/06/2024 5:25
24030694-033A	BHS-27	NELAP		1.0	6.5	µg/L	1	03/19/2024 12:55	03/06/2024 5:27
24030694-034A	BHS-28	NELAP		1.0	9.3	µg/L	1	03/19/2024 12:58	03/06/2024 5:27
24030694-035A	BHS-29	NELAP		1.0	7.3	µg/L	1	03/19/2024 13:02	03/06/2024 5:27
24030694-036A	BHS-30	NELAP		1.0	8.1	µg/L	1	03/19/2024 13:06	03/06/2024 5:27
24030694-037A	BHS-31	NELAP		1.0	9.3	µg/L	1	03/19/2024 13:09	03/06/2024 5:27
24030694-038A	BHS-32	NELAP		1.0	5.7	µg/L	1	03/19/2024 13:24	03/06/2024 5:27
24030694-039A	BHS-33	NELAP		1.0	12.5	µg/L	1	03/19/2024 13:35	03/06/2024 5:27
24030694-040A	BHS-34	NELAP		1.0	24.1	µg/L	1	03/19/2024 13:39	03/06/2024 5:27
24030694-041A	BHS-35	NELAP		1.0	1.2	µg/L	1	03/19/2024 13:42	03/06/2024 5:33
24030694-042A	BHS-36	NELAP		1.0	1.0	µg/L	1	03/19/2024 13:46	03/06/2024 5:33
24030694-043A	BHS-37	NELAP		1.0	6.6	µg/L	1	03/19/2024 13:50	03/06/2024 5:35
24030694-044A	BHS-38	NELAP		1.0	5.1	µg/L	1	03/23/2024 3:48	03/06/2024 5:35
24030694-045A	BHS-39	NELAP		1.0	5.8	µg/L	1	03/19/2024 17:48	03/06/2024 5:35
24030694-046A	BHS-40	NELAP		1.0	6.0	µg/L	1	03/19/2024 17:51	03/06/2024 5:35
24030694-047A	BHS-41	NELAP		1.0	4.5	µg/L	1	03/19/2024 17:55	03/06/2024 5:35
24030694-048A	BHS-42	NELAP		1.0	5.9	µg/L	1	03/19/2024 18:10	03/06/2024 5:35



## Laboratory Results

<http://www.teklabinc.com/>

Client: Geotechnology, Inc.

Work Order: 24030694

Client Project: J044517.01

Report Date: 28-Mar-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24030694-049A	BHS-43	NELAP		1.0	4.6	µg/L	1	03/19/2024 18:21	03/06/2024 5:35
24030694-050A	BHS-44	NELAP		1.0	5.7	µg/L	1	03/19/2024 18:24	03/06/2024 5:35
24030694-051A	BHS-45	NELAP		1.0	5.3	µg/L	1	03/19/2024 18:28	03/06/2024 5:42
24030694-052A	BHS-46	NELAP		1.0	9.2	µg/L	1	03/19/2024 18:32	03/06/2024 5:43
24030694-053A	BHS-47	NELAP		1.0	8.3	µg/L	1	03/19/2024 18:35	03/06/2024 5:43
24030694-054A	BHS-48	NELAP		1.0	5.7	µg/L	1	03/19/2024 18:39	03/06/2024 5:43
24030694-055A	BHS-49	NELAP		1.0	9.6	µg/L	1	03/19/2024 18:43	03/06/2024 5:43
24030694-056A	BHS-50	NELAP		1.0	7.3	µg/L	1	03/19/2024 18:57	03/06/2024 5:43
24030694-057A	BHS-51	NELAP		1.0	4.7	µg/L	1	03/19/2024 19:01	03/06/2024 5:43
24030694-058A	BHS-52	NELAP		1.0	10.6	µg/L	1	03/21/2024 14:35	03/06/2024 5:43
24030694-059A	BHS-53	NELAP		1.0	9.2	µg/L	1	03/21/2024 14:46	03/06/2024 5:43
24030694-060A	BHS-54	NELAP		1.0	< 1.0	µg/L	1	03/19/2024 19:19	03/06/2024 5:48



## Receiving Check List

<http://www.teklabinc.com/>

Client: Geotechnology, Inc.

Work Order: 24030694

Client Project: J044517.01

Report Date: 28-Mar-24

Carrier: John Duarte

Received By: WAO

Completed by:

Reviewed by:

On:

On:

08-Mar-24

11-Mar-24

Nick Reed

Ellie Hopkins

Pages to follow: Chain of custody

Extra pages included

Shipping container/cooler in good condition?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	Not Present <input type="checkbox"/>	Temp °C <b>N/A</b>
Type of thermal preservation?	None <input type="checkbox"/>	Ice <input checked="" type="checkbox"/>	Blue Ice <input type="checkbox"/>	Dry Ice <input type="checkbox"/>
Chain of custody present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody signed when relinquished and received?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody agrees with sample labels?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Samples in proper container/bottle?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Sample containers intact?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Sufficient sample volume for indicated test?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
All samples received within holding time?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Reported field parameters measured:	Field <input type="checkbox"/>	Lab <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	
Container/Temp Blank temperature in compliance?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

Water – at least one vial per sample has zero headspace?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No VOA vials <input checked="" type="checkbox"/>
Water - TOX containers have zero headspace?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No TOX containers <input checked="" type="checkbox"/>
Water - pH acceptable upon receipt?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>
NPDES/CWA TCN interferences checked/treated in the field?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - ehopkins - 3/11/2024 9:56:33 AM

# CHAIN OF CUSTODY

pg. 1 of 23 Work order # 24030694

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Geotechnology, LLC  
**Address:** 11816 Lackland Road  
**City / State / Zip:** St. Louis, MO 63146  
**Contact:** Brad Lohrum **Phone:** (314) 997-7440  
**E-Mail:** blohrum@teamues.com **Fax:**

**Samples on:** ☒ ICE ☐ BLUE ICE ☒ NO ICE ☐ °C **LTG#**  
**Preserved in:** ☒ LAB ☐ FIELD **FOR LAB USE ONLY**  
**Lab Notes**

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No  
 Are these samples known to be hazardous? ☐ Yes ☒ No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section. ☐ Yes ☒ No

**Client Comments:**  

COURIER

Project Name/Number		Sample Collector's Name				MATRIX				INDICATE ANALYSIS REQUESTED																
J044517.01		Brad Lohrum				Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	DW - Lead E200.8														
Results Requested		Billing Instructions		# and Type of Containers																						
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge)																										
<input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)																										
Lab Use Only	Sample Identification		Date/Time Sampled		UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER														
1030694-001	SMS-05		3/6/24 3:32		1								X													
-002	CACC-16		3:52		1								X													
-003	JMS-05		4:12		1								X													
-004	-44		4:16		1								X													
-005	48		4:18		1								X													
-006	49		4:20		1								X													
-007	BHS 01		4:46		1								X													
-008	02		4:48		1								X													
-009	03		4:51		1								X													
-010	04		4:55		1								X													

Relinquished By	Date/Time	Received By	Date/Time
<i>Brad Lohrum</i>	3/8/24 1350	<i>John Daulton</i>	3/8/24 1350
<i>John Daulton</i>	3/8/24 1611	<i>Wherry Queen</i>	3/8/24 1611



## **APPENDIX D**

### **LIMITATIONS OF REPORT**

## **ENVIRONMENTAL SAMPLING LIMITATIONS OF REPORT**

1. The Report has been prepared on behalf of and for the exclusive use of the addressee, solely for use in documenting specific sample results. This report and the findings contained herein shall not, in whole or in part, be disseminated or conveyed to any other party, nor used by any other party in whole or in part, without the prior written consent of UES.
2. The sampling was performed in accordance with generally accepted practices of other consultants undertaking similar projects at the same time and in the same geographical area, and UES endeavored to observe that degree of care and skill ordinarily exercised by other consultants under similar circumstances and conditions. The findings and conclusions stated herein must be considered not as scientific certainties, but rather as professional opinions concerning the significance of the limited data gathered during the course of the project. UES does not and cannot represent that the site contains no hazardous waste or material, or other latent condition beyond that observed by UES.
3. In the event that information is developed relative to environmental or hazardous waste or material issues at the site and not contained in this report, such information shall be brought to UES' attention. UES will evaluate such information and, based on this evaluation, may modify the conclusions stated in this Report.
4. The conclusions and recommendations contained in this Report are based in part upon the data obtained from a limited number of water samples. The identified presence of contaminated water is limited to the extent that they could be identified by instrumentation and sampling and testing. There is a potential for contaminated water above the indicated concentrations to occur elsewhere on the site. The nature and extent of variations between these explorations may not become evident until further exploration. If variations or other latent conditions then appear evident, and/or if changes are made in regulations, it will be necessary to reevaluate the conclusions and recommendations of this report.
5. If quantitative laboratory testing was performed as part of the assessment by an outside laboratory, UES has relied upon the data provided, and has not conducted an independent evaluation of the reliability to these data.
6. Chemical analyses have been performed for specific parameters during the course of this sampling as described in the text. Do not assume that a given analyte is not present at the site simply because it was not present at the test locations. The analyte may exist on the site where tests were not performed. In addition, it should be noted that additional chemical constituents not tested for during the sampling could be present in water at the site.