

SOUTHRIDGE_LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Large community room	22436400-001SF	10/11/24	1.23
G127	22436400-002SF	10/11/24	1.2
Workroom across from "G102"	22436400-003SF	10/11/24	0.22
Health room	22436400-004NS	10/11/24	2.14
Outside S110E Left	22436400-005DW	10/11/24	ND
Outside S110E Right	22436400-006DW	10/11/24	ND
Outside S110E	22436400-007WB	10/11/24	0.202
Staff dining	22436400-008SF	10/11/24	0.441
E151 (leaking, resampled)	22436400-009CF	10/11/24	1.76
E151	22433200-009CF	11/22/24	1.84
Concession next to E151 (access restricted, handwashing only)	22436400-010KF	10/11/24	24.2
Concession next to E151 (access restricted, handwashing only)	22433200-010KF	11/22/24	16.3
E150 (leaking, resampled)	22436400-011CF	10/11/24	0.77
E150	22433200-011CF	11/22/24	0.782
S115	22436400-012KF	10/11/24	0.961
S111	22436400-013SF	10/11/24	1.65
D150 Left	22436400-014CF	10/11/24	0.681
D150 Right	22436400-015CF	10/11/24	0.779
Skybox	22436400-016KF	10/11/24	1.98
West hall Left	22436400-017DW	10/11/24	ND
West hall Right	22436400-018DW	10/11/24	0.214
D110	22436400-019SF	10/11/24	1.37
D121 Left	22436400-020CF	10/11/24	1.13
D121 Right	22436400-021CF	10/11/24	1.86
D100	22436400-022SF	10/11/24	0.26
Outside M137 Left	22436400-023DW	10/11/24	0.281
Outside M137 Right	22436400-024DW	10/11/24	ND
Outside M137	22436400-025WB	10/11/24	ND
M114	22436400-026KF	10/11/24	0.418
M114A	22436400-027CF	10/11/24	1.66
E100	22436400-028KF	10/11/24	0.375
E110	22436400-029SF	10/11/24	0.947
Library Left	22436400-030DW	10/11/24	ND
Library Right	22436400-031DW	10/11/24	ND
L112	22436400-032SF	10/11/24	1.77
L111	22436400-033SF	10/11/24	1.26
Outside auditorium Left	22436400-034DW	10/11/24	ND
Outside auditorium Right	22436400-035DW	10/11/24	0.266
A125 Left	22436400-036DW	10/11/24	ND
A125 Right	22436400-037DW	10/11/24	ND
A113	22436400-038SF	10/11/24	0.658
A113 Left	22436400-039DW	10/11/24	ND
A113 Right	22436400-040DW	10/11/24	ND
Theatre Left	22436400-041DW	10/11/24	ND
Theatre Right	22436400-042DW	10/11/24	ND
A108	22436400-043CF	10/11/24	2.36
A109	22436400-044DW	10/11/24	2.2
G110 Left	22436400-045DW	10/11/24	ND
G110 Right	22436400-046DW	10/11/24	0.275

G103 Left	22436400-047DW	10/11/24	0.547
G103 Right	22436400-048DW	10/11/24	0.224
G113	22436400-049KF	10/11/24	3.11
H101 Left	22436400-050DW	10/11/24	0.372
H101 Right	22436400-051DW	10/11/24	ND
Outside G127 Left	22436400-052DW	10/11/24	0.278
Outside G127 Right	22436400-053DW	10/11/24	ND
Outside G038 Left	22436400-054DW	10/11/24	0.449
Outside G038 Right	22436400-055DW	10/11/24	ND
G018	22436400-056CF	10/11/24	0.566
H001 Left	22436400-057KF	10/11/24	0.482
H001 Right	22436400-058KF	10/11/24	0.85
H003 Left	22436400-059DW	10/11/24	0.479
H003 Right	22433200-060DW	11/22/24	0.63
H003	22436400-061WB	10/11/24	0.415
H003 Middle	22436400-062DW	10/11/24	0.234
H003 Right	22436400-063DW	10/11/24	ND
R253	22436400-064CF	10/11/24	3.8
R252	22436400-065CF	10/11/24	3.91
R251	22436400-066CF	10/11/24	3.89
R210	22436400-067SF	10/11/24	6.23
R200B	22436400-068SF	10/11/24	0.395
Outside stair "R1" Left	22436400-069DW	10/11/24	0.448
Outside stair "R1" Right	22436400-070DW	10/11/24	ND
Outside M236 Left	22436400-071DW	10/11/24	ND
Outside M236 Right	22436400-072DW	10/11/24	ND
Outside M236	22436400-073WB	10/11/24	ND
Outside stair "C1" Left	22436400-074DW	10/11/24	0.825
Outside stair "C1" Right	22436400-075DW	10/11/24	ND
C200B	22436400-076SF	10/11/24	0.397
C221 Left	22436400-077CF	10/11/24	2.55
C221 Right	22436400-078CF	10/11/24	5.95
C210	22436400-079CF	10/11/24	3.3
C250 Left	22436400-080CF	10/11/24	2.7
C250 Right	22436400-081CF	10/11/24	0.799
H001 (kettle filler)	22433200-081KF	11/22/24	0.731