

## Whitford

LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
KITCHEN; BUBBLER	22433200-001KF24A	5/16/2024	0.318
KITCHEN; PREP SINK	22433200-002KF24A	5/16/2024	0.313
A17; BUBBLER	22433200-003CF24A	5/16/2024	9.3
A17; DRINKING FOUNTAIN	22433200-004DW24A	5/16/2024	2.79
CORRIDOR 1; DRINKING FOUNTAIN	22433200-005DW24A	5/16/2024	0.808
A HALL CENTER; DRINKING FOUNTAIN LEFT	22433200-006DW24A	5/16/2024	ND
A HALL CENTER; DRINKING FOUNTAIN RIGHT	22433200-007DW24A	5/16/2024	0.607
WKRM 3; STAFF PREP SINK	22433200-008SF24A	5/16/2024	0.515
NURSES OFFICE; NURSE PREP SINK	22433200-009NS24A	5/16/2024	0.91
A15; CLASSROOM FAUCET	22433200-010CF24A	5/16/2024	4.99
A15; CLASSROOM DRINKING FOUNTAIN	22433200-011DW24A	5/16/2024	3.41
A13; CLASSROOM FAUCET	22433200-012CF24A	5/16/2024	2.69
A13; CLASSROOM DRINKING FOUNTAIN	22433200-013DW24A	5/16/2024	2.01
A11; CLASSROOM FAUCET	22433200-014CF24A	5/16/2024	3.31
A11; CLASSROOM DRINKING FOUNTAIN	22433200-015DW24A	5/16/2024	1.62
A10; CLASSROOM FAUCET	22433200-016CF24A	5/16/2024	5.51
A10; CLASSROOM DRINKING FOUNTAIN	22433200-017DW24A	5/16/2024	1.93
A9; CLASSROOM FAUCET	22433200-018CF24A	5/16/2024	1.21
A9; CLASSROOM DRINKING FOUNTAIN	22433200-019DW24A	5/16/2024	1.89
A7; CLASSROOM FAUCET	22433200-020CF24A	5/16/2024	2.03
A7; CLASSROOM DRINKING FOUNTAIN	22433200-021DW24A	5/16/2024	0.596
A5; CLASSROOM FAUCET	22433200-022CF24A	5/16/2024	2.19
A5; CLASSROOM DRINKING FOUNTAIN	22433200-023DW24A	5/16/2024	0.927
A3; CLASSROOM FAUCET	22433200-024CF24A	5/16/2024	2.1
A3; CLASSROOM DRINKING FOUNTAIN	22433200-025DW24A	5/16/2024	1.33
A1; CLASSROOM FAUCET	22433200-026CF24A	5/16/2024	3.03
A1; CLASSROOM DRINKING FOUNTAIN	22433200-027DW24A	5/16/2024	1.67
A2; CLASSROOM FAUCET	22433200-028CF24A	5/16/2024	4.19
A2; CLASSROOM DRINKING FOUNTAIN	22433200-029DW24A	5/16/2024	4.63
A4; CLASSROOM FAUCET	22433200-030CF24A	5/16/2024	2.76
A4; CLASSROOM DRINKING FOUNTAIN	22433200-031DW24A	5/16/2024	0.517
CORRIDOR 2; DRINKING FOUNTAIN BY CUST 1	22433200-032DW24A	5/16/2024	0.528
CORRIDOR 2; DRINKING FOUNTAIN BY MECH 3	22433200-033DW24A	5/16/2024	0.755
B9; CLASSROOM FAUCET	22433200-034CF24A	5/16/2024	1.02
B9; CLASSROOM DRINKING FOUNTAIN	22433200-035DW24A	5/16/2024	1.1
B7; CLASSROOM FAUCET	22433200-036CF24A	5/16/2024	0.472
B7; CLASSROOM DRINKING FOUNTAIN	22433200-037DW24A	5/16/2024	1.5
B5; CLASSROOM FAUCET	22433200-038CF24A	5/16/2024	1.49
B5; CLASSROOM DRINKING FOUNTAIN	22433200-039DW24A	5/16/2024	1.16
B3; CLASSROOM FAUCET	22433200-040CF24A	5/16/2024	2.32
B3; CLASSROOM DRINKING FOUNTAIN	22433200-041DW24A	5/16/2024	0.611
B1; CLASSROOM FAUCET	22433200-042CF24A	5/16/2024	1.35
B1; CLASSROOM DRINKING FOUNTAIN	22433200-043DW24A	5/16/2024	1.08
B2; CLASSROOM FAUCET	22433200-044CF24A	5/16/2024	2.33
B2; CLASSROOM DRINKING FOUNTAIN	22433200-045DW24A	5/16/2024	0.997
B4; CLASSROOM FAUCET	22433200-046CF24A	5/16/2024	1.79
B4; CLASSROOM DRINKING FOUNTAIN	22433200-047DW24A	5/16/2024	1.11
B HALL CENTER; DRINKING FOUNTAIN	22433200-048DW24A	5/16/2024	0.572
B14; CLASSROOM FAUCET	22433200-049CF24A	5/16/2024	1.96
B14; CLASSROOM DRINKING FOUNTAIN	22433200-050DW24A	5/16/2024	0.722

B12; CLASSROOM FAUCET	22433200-051CF24A	5/16/2024	3.04
B12; CLASSROOM DRINKING FOUNTAIN	22433200-052DW24A	5/16/2024	1.64
B10; CLASSROOM FAUCET	22433200-053CF24A	5/16/2024	8.38
B10; CLASSROOM DRINKING FOUNTAIN	22433200-054DW24A	5/16/2024	1.7
CORRIDOR 2; DRINKING FOUNTAIN BY BOYS 3	22433200-055DW24A	5/16/2024	0.31
C7; DRINKING FOUNTAIN	22433200-056CF24A	5/16/2024	0.972
C7; CLASSROOM FAUCET	22433200-057DW24A	5/16/2024	0.494
C5; CLASSROOM DRINKING FOUNTAIN	22433200-058CF24A	5/16/2024	0.258
C5; CLASSROOM FAUCET	22433200-059DW24A	5/16/2024	0.367
C3; CLASSROOM DRINKING FOUNTAIN	22433200-060CF24A	5/16/2024	0.33
C3; CLASSROOM FAUCET	22433200-061DW24A	5/16/2024	1.89
C1; DRINKING FOUNTAIN	22433200-062CF24A	5/16/2024	3.93
C1; CLASSROOM FAUCET	22433200-063DW24A	5/16/2024	1.46
C2; CLASSROOM DRINKING FOUNTAIN	22433200-064CF24A	5/16/2024	3.57
C2; CLASSROOM FAUCET	22433200-065DW24A	5/16/2024	1.8
C4; CLASSROOM DRINKING FOUNTAIN	22433200-066CF24A	5/16/2024	1.99
C4; CLASSROOM FAUCET	22433200-067DW24A	5/16/2024	0.641
C11; CLASSROOM FAUCET SW	22433200-068CF24A	5/16/2024	1.58
C11; CLASSROOM FAUCET N	22433200-069CF24A	5/16/2024	0.932
C11; CLASSROOM DRINKING FOUNTAIN N	22433200-070DW24A	5/16/2024	0.873
C10; CLASSROOM FAUCET	22433200-071CF24A	5/16/2024	0.776
C10; CLASSROOM DRINKING FOUNTAIN	22433200-072DW24A	5/16/2024	0.611
C13; CLASSROOM DRINKING FOUNTAIN	22433200-073DW24A	5/16/2024	0.202
C9B; CLASSROOM FAUCET	22433200-074CF24A	5/16/2024	3.09
C9B; CLASSROOM DRINKING FOUNTAIN	22433200-075DW24A	5/16/2024	1.71
CORRIDOR 1; DRINKING FOUNTAIN BY CUST 3	22433200-076DW24A	5/16/2024	0.453
GIRLS LOCKER ROOM ; DRINKING FOUNTAIN	22433200-077DW24A	5/16/2024	1.69
FITNESS GYM; DRINKING FOUNTAIN	22433200-078DW24A	5/16/2024	3.07
BOYS LOCKER ROOM; DRINKING FOUNTAIN	22433200-079DW24A	5/16/2024	10.4
CAFETERIA; DRINKING FOUNTAIN	22433200-080DW24A	5/16/2024	0.237
C-12, CLASSROOM FAUCET	2233200-083CF24A	7/12/2024	1.49
C-12, CLASSROOM FAUCET	2233200-084CF24A	7/12/2024	3.19
C-12, CLASSROOM FAUCET	2233200-085CF24A	7/12/2024	4.15
C-12, CLASSROOM FAUCET	2233200-086CF24A	7/12/2024	5.77
C-12, CLASSROOM FAUCET	22433200-081CF24A	7/12/2024	3.57
C-12, CLASSROOM FAUCET	22433200-082CF24A	7/12/2024	9.61
Kitchen – Hot Pot <i>(access restricted pending mitigation)</i>	22433200-081KF	11/22/2024	19.5
Kitchen – Hot Pot <i>(post-mitigation)</i>	22433200-081KF	1/22/2025	13.7