

Sunset HS LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Main office staff room	22436500-001SF24A	6/13/2024	0.579
Nurse office	22436500-002NS24A	6/13/2024	0.976
D Hall/E Hall intersection	22436500-003DW24A	6/13/2024	0.669
Office 09	22436500-004SF24A	6/13/2024	0.526
Prep <i>(signed for no drinking)</i>	22436500-005CF24A	6/13/2024	20.4
Prep <i>(post mitigation)</i>	22436500-005CF24B	7/26/2024	4.66
C7-C9 connecting room [C8] <i>(access restricted)</i>	22436500-006CF24A	6/13/2024	133
C7-C9 connecting room [C8] <i>(access restricted- removed)</i>	22436500-006CF24B	7/26/2024	22
C9	22436500-007CF24A	6/13/2024	0.72
B Hall	22436500-008DW24A	6/13/2024	5.72
Spec ED	22436500-009CF24A	6/13/2024	4.6
Spec ED <i>(access restricted)</i>	22436500-010DW24A	6/13/2024	16.6
Spec ED <i>(access restricted- removed)</i>	22436500-010DW24B	8/7/2024	25.5
A Hall	22436500-011DW24A	6/13/2024	0.734
A4	22436500-012CF24A	6/13/2024	1.16
A14 workroom	22436500-013CF24A	6/13/2024	0.835
A Hall outside Science	22436500-014DW24A	6/13/2024	0.431
A	22436500-015CF24A	6/13/2024	0.82
A14	22436500-016CF24A	6/13/2024	1.81
A Hall outside A14	22436500-017DW24A	6/13/2024	2.19
Office 12	22436500-018SF24A	6/13/2024	0.855
A Hall, south office spaces	22436500-019SF24A	6/13/2024	2.46
Hall 1	22436500-020WB24A	6/13/2024	ND
Hall 1	22436500-021DW24A	6/13/2024	ND
Spec Ed southwest office [C2] <i>(access restricted)</i>	22436500-022SF24A	6/13/2024	16.4
Spec Ed southwest office [C2] <i>(access restricted- removed)</i>	22436500-022SF24B	7/26/2024	54.6
C Hall	22436500-023DW24A	6/13/2024	1.57
Library	22436500-024SF24A	6/13/2024	1.71
General science 1 - 9	22436500-025CF24A	6/13/2024	1.77
Library office	22436500-026SF24A	6/13/2024	0.33
K1 office	22436500-027SF24A	6/13/2024	0.284
K2	22436500-028CF24A	6/13/2024	9.24
K2	22436500-029CF24A	6/13/2024	6.91
K2 <i>(access restricted)</i>	22436500-030DW24A	6/13/2024	24.1
K2 <i>(post-mitigation)</i>	22436500-030DW24B	8/7/2024	9.39
K hall store	22436500-031CF24A	6/13/2024	9.5
K hall store	22436500-032DW24A	6/13/2024	2.08
K2 west adjacent room <i>(access restricted)</i>	22436500-033CF24A	6/13/2024	43.2
K2 west adjacent room <i>(post-mitigation)</i>	22436500-033SF24B	7/26/2024	11.7
K hall	22436500-034DW24A	6/13/2024	6.25
D Hall	22436500-035WB24A	6/13/2024	ND
D Hall	22436500-036DW24A	6/13/2024	ND
D Hall	22436500-037DW24A	6/13/2024	ND
D hall mail	22436500-038SF24A	6/13/2024	1.83
Cafe east serving room	22436500-039KF24A	6/13/2024	1.64
Cafe east serving room	22436500-040KF24A	6/13/2024	0.771
1 hall staff	22436500-041SF24A	6/13/2024	0.555
1 hall south end	22436500-042DW24A	6/13/2024	8.01
Kitchen	22436500-043KF24A	6/13/2024	1.74
Kitchen	22436500-044KF24A	6/13/2024	1.53
Kitchen	22436500-045KF24A	6/13/2024	3.34
Kitchen	22436500-046KF24A	6/13/2024	0.378
Kitchen	22436500-047KF24A	6/13/2024	0.36
Kitchen	22436500-048KF24A	6/13/2024	0.853
Kitchen	22436500-049KF24A	6/13/2024	0.644

Kitchen		22436500-050KF24A	6/13/2024	1.32
Kitchen		22436500-051KF24A	6/13/2024	0.5
Café bento		22436500-052SF24A	6/13/2024	3.9
G hall		22436500-053WB24A	6/13/2024	ND
G hall		22436500-054DW24A	6/13/2024	1.55
G4	<i>(access restricted)</i>	22436500-055CF24A	6/13/2024	15.9
G4	<i>(post-mitigation)</i>	22436500-055CF24B	7/26/2024	2.37
G hall south office		22436500-056SF24A	6/13/2024	7.91
M hall		22436500-057DW24A	6/13/2024	0.568
M hall		22436500-058DW24A	6/13/2024	0.513
Weight Room		22436500-059DW24A	6/13/2024	1.03
T6		22436500-060SF24A	6/13/2024	4.41
T6		22436500-061DW24A	6/13/2024	8.58
Girls Locker		22436500-062DW24A	6/13/2024	ND
Boys Locker		22436500-063DW24A	6/13/2024	0.338
Fitness Room		22436500-064SF24A	6/13/2024	0.209
Fitness Room		22436500-065WB24A	6/13/2024	ND
Fitness Room		22436500-066DW24A	6/13/2024	ND
3-12		22436500-067SF24A	6/13/2024	2.82
West Lobby		22436500-068WB24A	6/13/2024	0.225
West Lobby		22436500-069DW24A	6/13/2024	ND
3 Hall north		22436500-070DW24A	6/13/2024	0.24
3 – 3 Storage	<i>(access restricted)</i>	22436500-071SF24A	6/13/2024	42.7
3 – 3 Storage	<i>(access restricted)</i>	22436500-071SF24B	7/26/2024	30.9