



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Indian Hills High School, 97 Yawpo Avenue, Oakland NJ 07436
PAS Project ID : P24-12928

Matrix : Drinking Water
Report Date : 12/18/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-12928-01	1-971-K-KC-1-1A	Lead	4.21	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:19	12/12/24 17:10
P24-12928-02	1-971-K-WC-1A-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:20	12/12/24 17:15
P24-12928-03	1-10-O-NS-3-1A	Lead	3.82	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:28	12/12/24 17:19
P24-12928-04	1-10-O-NS-4-1A	Lead	4.41	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:28	12/12/24 17:24
P24-12928-05	1-10-O-NS-5-1A	Lead	3.82	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:29	12/12/24 17:28
P24-12928-06	1-10-O-NS-6-1A	Lead	5.01	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:30	12/12/24 17:32
P24-12928-07	1-10-O-NS-7-1A	Lead	4.81	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:31	12/12/24 17:59
P24-12928-08	1-087B-O-DW-11A-1A	Lead	17.2	ug/L	2	4.00	1.80	15.0 *	SM 3113 B	11/30/24 08:40	12/12/24 18:46
P24-12928-09	1-087B-C-WC-11-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:40	12/12/24 18:08
P24-12928-10	1-087B-C-BF-11-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:41	12/12/24 18:12
P24-12928-11	1-81-O-IM-12-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:41	12/12/24 18:17
P24-12928-12	1-063A-C-WC-13-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:47	12/12/24 18:21
P24-12928-13	1-063A-C-BF-13-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:47	12/12/24 18:26
P24-12928-14	1-063A-O-KC-16-1A	Lead	3.82	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:48	12/12/24 18:50
P24-12928-15	1-72-C-WC-15-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:53	12/12/24 18:55
P24-12928-16	1-72-C-BF-15-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 08:53	12/12/24 18:59
P24-12928-17	1-071A-L-WC-14-1AA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:00	12/12/24 19:04
P24-12928-18	1-071A-L-WC-14-1BA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:01	12/12/24 19:08
P24-12928-19	1-071A-L-BF-14-1BA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:01	12/12/24 19:12
P24-12928-20	1-802-O-FP-17-1A	Lead	4.81	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:09	12/12/24 19:17
P24-12928-21	1-802W-C-WC-18-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:15	12/12/24 19:21
P24-12928-22	1-802W-C-BF-18-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:15	12/12/24 19:35
P24-12928-23	1-803-O-KC-21-1A	Lead	25.1	ug/L	3	6.00	2.70	15.0 *	SM 3113 B	11/30/24 09:18	12/12/24 22:12
P24-12928-24	1-806-O-KC-19-1A	Lead	11.6	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:19	12/12/24 19:43
P24-12928-25	1-807-C-WC-20-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:22	12/12/24 19:48
P24-12928-26	1-807-C-BF-20-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:22	12/12/24 19:52
P24-12928-27	1-600-C-DW-22-1A	Lead	13.1	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:27	12/12/24 20:11
P24-12928-28	1-406W-C-WC-23-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:30	12/12/24 20:24
P24-12928-29	1-406W-C-BF-23-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:30	12/12/24 20:29
P24-12928-30	1-408-O-KC-24-1A	Lead	3.22	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:38	12/12/24 20:34
P24-12928-31	1-409-O-EC-25-1A	Lead	1.43 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:40	12/12/24 20:43
P24-12928-32	1-409-O-EC-25-1AA	Lead	3.02	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:40	12/12/24 20:47
P24-12928-33	1-409-O-EC-26-1A	Lead	1.24 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:42	12/12/24 20:52
P24-12928-34	1-409-O-EC-26-1AA	Lead	2.63	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:42	12/12/24 20:56
P24-12928-35	1-409-O-EC-27-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:44	12/12/24 21:01
P24-12928-36	1-409-O-EC-27-1AA	Lead	1.43 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:44	12/12/24 21:05
P24-12928-37	1-409-O-EC-28-1A	Lead	4.81	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:46	12/12/24 21:18
P24-12928-38	1-409-O-EC-28-1AA	Lead	5.21	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:46	12/12/24 21:23
P24-12928-39	1-409-O-EC-29-1A	Lead	1.43 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:48	12/12/24 21:27
P24-12928-40	1-409-O-EC-29-1AA	Lead	1.24 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:48	12/12/24 21:32
P24-12928-41	1-409-O-EC-30-1A	Lead	4.81	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:50	12/12/24 21:36
P24-12928-42	1-409-O-EC-30-1AA	Lead	3.42	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:50	12/12/24 21:40
P24-12928-43	1-411G-C-DW-31-1A	Lead	9.77	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 09:58	12/12/24 21:45
P24-12928-44	1-214-C-WC-32-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:00	12/12/24 21:49
P24-12928-45	1-214-C-BF-32-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:00	12/12/24 21:53
P24-12928-46	1-201-C-DW-33-1A	Lead	14.4	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:02	12/16/24 11:11
P24-12928-47	1-57-O-WC-34-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:09	12/16/24 11:53

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Indian Hills High School, 97 Yawpo Avenue, Oakland NJ 07436
PAS Project ID : P24-12928

Matrix : Drinking Water
Report Date : 12/18/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-12928-48	1-57-O-BF-34-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:09	12/16/24 11:57
P24-12928-49	1-59-O-WC-35-1A	Lead	6.04	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:11	12/16/24 12:02
P24-12928-50	1-59-K-KC-37-1A	Lead	8.12	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:22	12/16/24 12:06
P24-12928-51	1-58-K-FP-38-1A	Lead	7.29	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:24	12/16/24 12:11
P24-12928-52	1-58-K-FP-39-1A	Lead	5.63	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:25	12/16/24 12:15
P24-12928-53	1-58-K-KC-42-1A	Lead	8.74	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:28	12/16/24 12:19
P24-12928-54	1-58-K-KC-41-1A	Lead	5.42	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:28	12/16/24 12:43
P24-12928-55	1-58-K-KC-43-1A	Lead	8.74	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:29	12/16/24 12:47
P24-12928-56	1-58-K-KC-47-1A	Lead	22.5	ug/L	3	6.00	2.70	15.0 *	SM 3113 B	11/30/24 10:29	12/16/24 15:27
P24-12928-57	1-58-K-KC-46-1A	Lead	27.5	ug/L	3	6.00	2.70	15.0 *	SM 3113 B	11/30/24 10:32	12/16/24 15:32
P24-12928-58	1-58-K-KC-44-1A	Lead	3.76	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:32	12/16/24 13:01
P24-12928-59	1-58-K-KC-45-1A	Lead	11.7	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:33	12/16/24 13:05
P24-12928-60	1-58-K-KC-48-1A	Lead	1.89 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:36	12/16/24 13:10
P24-12928-61	1-58-K-KC-49-1A	Lead	1.47 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:36	12/16/24 13:15
P24-12928-62	1-58-K-IM-50-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:37	12/16/24 13:19
P24-12928-63	1-58-K-IM-50-1A	Lead	5.21	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:39	12/16/24 13:33
P24-12928-64	1-709-C-WC-51-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:50	12/16/24 13:37
P24-12928-65	1-709-C-BF-51-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:50	12/16/24 13:42
P24-12928-66	1-709-C-WC-53-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:54	12/16/24 13:46
P24-12928-67	1-709-C-BF-53-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:54	12/16/24 14:04
P24-12928-68	1-510-O-KC-54-1A	Lead	9.37	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:59	12/16/24 14:09
P24-12928-69	1-510-O-KC-54-1AA	Lead	2.09	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 10:59	12/16/24 14:22
P24-12928-70	1-310M-C-WC-55-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 11:02	12/16/24 14:26
P24-12928-71	1-310M-C-BF-55-1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 11:02	12/16/24 14:31
P24-12928-72	1-312A-C-DW-56-1A	Lead	14.1	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 11:04	12/16/24 14:35
P24-12928-73	1-111-C-DW-57-1A	Lead	5.00	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 11:10	12/16/24 14:39
P24-12928-74	1-105-O-KC-58-1A	Lead	3.76	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 11:11	12/16/24 14:44
P24-12928-75	Field Blank IHHS-11-30-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	11/30/24 11:12	12/16/24 14:48
P24-12928-76	1-95-O-DW-9-1AA	Lead	4.79	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/2/24 06:38	12/16/24 14:53
P24-12928-77	1-95-O-DW-9-1BA	Lead	11.0	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/2/24 06:39	12/16/24 14:57
P24-12928-78	1-95A-K-KC-10-1A	Lead	11.0	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/2/24 06:41	12/16/24 15:18
P24-12928-79	Field Blank IHHS-12-3-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/2/24 06:42	12/16/24 15:23

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer

