Attachment G

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-12-2024
ST JOB NUMBER	34805930
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Adult Ed (Trailers) 115 Devon Road Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	T-5	ABC	5 lb	Badger	2031	2025	Yes	A	Good
2	T-2	ABC	5 lb	Badger	2025	2025	Yes	A	Good
3	T3	ABC	5 lb	Amerex	2032	2026	Yes	A	Good
4	T4	ABC	5 lb	Badger	2033	2027	Yes	A	Good
5	T1	ABC	5 lb	Amerex	2026	2026	Yes	A	Good
6	T7	ABC	5 lb	Amerex	2029	2029	Yes	A	Good
7	T8	ABC	5 lb	Buckeye	2036	2030	Yes	A	Due 6 years done
8	T-9	ABC	5 lb	Buckeye	2026	2026	Yes	A	Good
9	T10	ABC	5 lb	Amerex	2032	2026	Yes	A	Good
10	T-11	ABC	5 lb	Badger	2029	2029	Yes	A	Good
11	T-12	ABC	5 lb	Badger	2030	2030	Yes	A	Due 6 years done
12	T13	ABC	5 lb	Buckeye	2030	2030	Yes	A	Due 6 years done
13	T18	ABC	5 lb	Amerex	2032	2026	Yes	A	Good
14	T15	ABC	5 lb	Amerex	2027	2030	Yes	A	Due 6 years done
15	T-16	ABC	5 lb	Buckeye	2030	2030	Yes	A	Due 6 years done
16	T17	ABC	5 lb	Buckeye	2026	2026	Yes	A	Good
17	T25	ABC	5 lb	Buckeye	2030	2030	Yes	B	Due 6 years done
18	T21	ABC	5 lb	Badger	2036	2030	Yes	A	Due 6 years done
19	T20	ABC	5 lb	Ansul	2032	2026	Yes	A	Good
20	T19	ABC	5 lb	Amerex	2032	2026	Yes	A	Good
21	22	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
22	T26	ABC	5 lb	Buckeye	2029	2029	Yes	A	Due 6 years done
23	T23 servicer	ABC	5 lb	Buckeye	2026	2026	Yes	A	Good
24	T23	ABC	5 lb	Badger	2031	2025	Yes	A	Good
25	T27	ABC	5 lb	Ansul	2025	2029	Yes	A	Good
26	T-24	ABC	5 lb	Other	2031	2025	Yes	A	Good
27	T29	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
28	T33	ABC	5 lb	Amerex	2032	2026	Yes	A	Good
29	T32	ABC	5 lb	Other	2034	2028	Yes	A	Good
30	T-14	ABC	5 lb	Amerex	2032	2026	Yes	A	Good
31	T6	ABC	5 lb	Buckeye	2026	2026	Yes	A	Good
32	T28	ABC	5 lb	Buckeye	2026	2026	Yes	A	Good
33	T30	ABC	5 lb	Badger	2032	2026	Yes	A	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-11-2024
ST JOB NUMBER	34846174
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Alston-Bailey Elementary 820 W 5th N St Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Custodial area	ABC	10 lb	Badger	2028	2034	Yes	A	Good
2	Kitchen	ABC	10 lb	Badger	2028	2034	Yes	A	Good
3	Kitchen	K Class		Ansul	2028				
4	Kitchen	ABC	10 lb	Amerex	2028	2034	Yes	A	Good
5	Custodial hall	ABC	10 lb	Badger	2028	2034	Yes	A	Good
6	Cafeteria near stage	ABC	10 lb	Badger	2028	2034	Yes	A	Good
7	Multipurpose room	ABC	10 lb	Badger	2028	2034	Yes	A	Good
8	Cafeteria hall in lobby by 1400D	ABC	10 lb	Badger	2028	2034	Yes	A	Good
9	Media center	ABC	10 lb	Badger	2028	2034	Yes	B	Good
10	Hall in room 1010	ABC	10 lb	Badger	2028	2034	Yes	A	Good
11	Art room 1009c kin room	ABC	10 lb	Badger	2028	2034	Yes	A	Good
12	Hall by room 1002	ABC	10 lb	Badger	2028	2034	Yes	A	Good
13	Office copier room 1605	ABC	10 lb	Badger	2028	2034	Yes	A	Good
14	Elevator equipment room 1400B	ABC	10 lb	Badger	2028	2034	Yes	A	Good
15	Hall by room 2424	ABC	10 lb	Badger	2028	2034	Yes	A	Good
16	Science lab room 2418	ABC	10 lb	Other	2028	2028	Yes	A	Good
17	Hall by room 2416	ABC	10 lb	Badger	2028	2034	Yes	A	Good
18	Hall by room 2406	ABC	10 lb	Badger	2028	2034	Yes	A	Good
19	Hall by room 1301	ABC	10 lb	Badger	2028	2034	Yes	A	Good
20	Hall by room 1206	ABC	10 lb	Badger	2029	2028	Yes	A	Good
21	Hall by room 1200G	ABC	10 lb	Other	2034	2028	Yes	A	Good
22	Hall by room 1104	ABC	10 lb	Amerex	2034	2028	Yes	A	Good
23	Hall by room 1112	ABC	10 lb	Badger	2034	2028	Yes	A	Good
24	Inside room 1003A workroom	ABC	10 lb	Badger	2028	2034	Yes	A	Good
25	1009b	ABC	10 lb	Badger	2028	2034	Yes	A	Good
26	Spare	ABC	10 lb	Amerex	2030	2030	Yes	A	Due 6 years done

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-11-2024
ST JOB NUMBER	34846189
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Alston Middle School 500 Bryon St Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Administration office	ABC	10 lb	Other	2032	2026	Yes	A	Good
2	Administration	ABC	10 lb	Amerex	2030	2030	Yes	A	Recharge done
3	Administration	ABC	10 lb	Other	2032	2026	Yes	A	Good
4	7 grade hallway	ABC	10 lb	Amerex	2027	2028	Yes	A	Good
5	Media center	ABC	10 lb	Other	2032	2026	Yes	A	Good
6	Media center	ABC	10 lb	Other	2032	2026	Yes	A	Good
7	704	ABC	10 lb	Other	2025	2025	Yes	A	Good
8	703	Water Mist	6 lit	Amerex	2028		Yes	A	Good
9	600 work room	Water	2.5 lb	Other	2027		Yes	A	Good
10	606	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
11	614	ABC	5 lb	Other	2031	2025	Yes	A	Good
12	615	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
13	202	Water Mist	6 lit	Amerex	2028		Yes	A	Good
14	201	Water Mist	6 lit	Amerex	2028		Yes	A	Good
15	Behind media center	ABC	10 lb	Badger	2032	2026	Yes	A	Good
16	712	ABC	5 lb	Other	2032	2026	Yes	A	Good
17	810	ABC	10 lb	Amerex	2035	2029	Yes	A	Good
18	813	ABC	10 lb	Badger	2032	2026	Yes	A	Good
19	900 hallway	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
20	900 hall	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
21	900 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
22	Cafeteria	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
23	Cafeteria	ABC	5 lb	Amerex	2025	2025	Yes	A	Good
24	Kitchen	K Class	6 lit	Amerex	2029		Yes	A	Due hydro done
25	Kitchen	ABC	10 lb	Ansul	2025	2025	Yes	A	Good
26	Kitchen office	ABC	10 lb	Badger	2032	2026	Yes	A	Good
27	Gym	ABC	10 lb	Amerex	2030	2030	Yes	A	Due 6 years done
28	Custodial office	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
29	Maintenance office	ABC	5 lb	Amerex	2030	2030	Yes	A	Due hydro done
30	By 113	ABC	10 lb	Amerex	2028	2028	Yes	A	Good
31	Inside 115	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
32	Outside of 102	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
33	Inside 101 B	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
34	Across from 103	ABC	10 lb	Other	2034	2028	Yes	A	Good
35	Outside of 105	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
36	Concession stand	ABC	10 lb	Other	2029	2029	Yes	A	Good
37	Gym	ABC	10 lb	Buckeye	2035	2029	Yes	A	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-13-2024
ST JOB NUMBER	34846196
TECHNICIAN	James President
CUSTOMER LOCATION	Ashley Ridge High School 9800 Delemar Highway Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	B106B	ABC	10 lb	Other	2032	2026	Yes	B	Good
2	Inside B117	ABC	10 lb	Badger	2032	2026	Yes	B	Good
3	B117A inside	CO2	10 lb	Amerex	2025	2030	Yes	B	Good
4	A102 hall	ABC	10 lb	Other	2032	2026	Yes	B	Good
5	A101E hall	ABC	10 lb	Ansul	2028	2034	Yes	D	Recharge
6	A101T hall	ABC	10 lb	Other	2032	2026	Yes	B	Good
7	A101V hall	ABC	10 lb	Other	2032	2026	Yes	B	Good
8	A108 inside	ABC	10 lb	Buckeye	2033	2027	Yes	B	Good
9	Inside 108 by first aid	ABC	10 lb	Amerex	2029	2035	Yes	B	Good
10	Inside 106A	ABC	10 lb	Other	2032	2026	Yes	B	Good
11	C103 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
12	C105 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
13	C106 inside	ABC	10 lb	Badger	2028	2034	Yes	B	Good
14	C110B work room	ABC	10 lb	Other	2032	2026	Yes	B	Good
15	C114 inside	K Class	6 lit	Buckeye	2028	2033	Yes	B	Good
16	C118 inside	CO2	10 lb	Amerex	2025	2030	Yes	B	Good
17	C120 hall	ABC	10 lb	Other	2031	2025	Yes	B	Good
18	C143 hall	ABC	5 lb	Badger	2034	2028	Yes	B	Good
19	C151 hall	ABC	10 lb	Amerex	2030	2024	Yes	D	Six years done
20	D150 inside	ABC	5 lb	Badger	2034	2028	Yes	B	Good
21	D152 inside	ABC	5 lb	Other	2034	2028	Yes	B	Good
22	C163	ABC	5 lb	Ansul	2034	2028	Yes	B	Good
23	C165 inside	K Class	6 lit	Buckeye	2025	2030	Yes	D	Hydro done
24	C165	ABC	10 lb	Buckeye	2034	2028	Yes	B	Good
25	C165	K Class	6 lit	Amerex	2025	2030	Yes	B	Good
26	Inside 110	ABC	10 lb	Other	2032	2026	Yes	B	Good
27	Inside 109	ABC	10 lb	Buckeye	2027	2033	Yes	B	Good
28	A127B	ABC	10 lb	Other	2032	2026	Yes	B	Good
29	A114 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
30	A112A prep	ABC	10 lb	Other	2032	2026	Yes	B	Good
31	A112 inside	ABC	10 lb	Kidde	2024	2030	Yes	D	Hydro done
32	D107 work room	ABC	10 lb	Badger	2029	2035	Yes	B	Good
33	D114 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
34	D118 hall	ABC	10 lb	Other	2032	2026	Yes	B	Good
35	D122 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
36	D207 work room	ABC	10 lb	Buckeye	2035	2029	Yes	B	Good
37	A221 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
38	A216	ABC	10 lb	Other	2032	2026	Yes	B	Good
39	A214 inside	ABC	10 lb	Badger	2032	2026	Yes	B	Good
40	A212A inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
41	A212 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
42	A217 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
43	Inside A217A	ABC	10 lb	Badger	2024	2030	Yes	D	Hydro done

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-13-2024
ST JOB NUMBER	34846196
TECHNICIAN	James President
CUSTOMER LOCATION	Ashley Ridge High School 9800 Delemar Highway Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
44	C219 inside	ABC	10 lb	Badger	2030	2036	Yes	B	Good
45	A219A inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
46	C203 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
47	C204 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
48	C205 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
49	C206 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
50	C210 work room	ABC	10 lb	Other	2032	2026	Yes	B	Good
51	C243 hall	ABC	10 lb	Kidde	2035	2029	Yes	B	Good
52	C244 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
53	C247 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
54	C247 hall	ABC	10 lb	Badger	2030	2024	Yes	D	Six years done
55	D008 stair	ABC	10 lb	Other	2030	2024	Yes	D	Six year's done
56	A209 inside	ABC	10 lb	Ansul	2032	2026	Yes	B	Good
57	A208	ABC	10 lb	Other	2032	2026	Yes	B	Good
58	A206 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
59	A206A inside	ABC	10 lb	Other	2031	2025	Yes	B	Good
60	A202 hall	ABC	10 lb	Other	2032	2026	Yes	B	Good
61	B206B work room	ABC	10 lb	Other	2032	2026	Yes	B	Good
62	B211 inside	K Class	2.5 gal	Amerex	2028	2033	Yes	B	Good
63	B211A	K Class	2.5 gal	Buckeye	2028	2033	Yes	B	Good
64	A201 inside	ABC	10 lb	Badger	2025	2031	Yes	B	Good
65	A201A inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
66	A201 inside	ABC	10 lb	Other	2028	2034	Yes	B	Good
67	A205 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
68	A129 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
69	Main cafeteria	ABC	10 lb	Other	2034	2028	Yes	B	Good
70	E101 hall	ABC	10 lb	Other	2032	2026	Yes	B	Good
71	G101hall	ABC	10 lb	Other	2029	2035	Yes	B	Good
72	G101A inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
73	G102 inside	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
74	G102B inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
75	G104A inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
76	G103B inside	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
77	G103 hall	ABC	10 lb	Amerex	2028	2034	Yes	B	Good
78	G115A	ABC	10 lb	Other	2032	2026	Yes	B	Good
79	E10B inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
80	E101C	ABC	10 lb	Amerex	2032	2026	Yes	B	Good
81	F102 across inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
82	F113 inside	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
83	Green house bathroom	ABC	10 lb	Other	2035	2029	Yes	B	Good
84	Green house grill area	ABC	10 lb	Other	2025	2031	Yes	B	Good
85	Green house plant sale	ABC	5 lb	Amerex	2025	2031	Yes	B	Good
86	Green house plant sale...	ABC	5 lb	Badger	2024	2030	Yes	D	Hydro done

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-13-2024
ST JOB NUMBER	34846196
TECHNICIAN	James President
CUSTOMER LOCATION	Ashley Ridge High School 9800 Delemar Highway Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
87	Green house plant sale...	ABC	5 lb	Badger	2035	2029	Yes	B	Good
88	Green house 2	ABC	5 lb	Amerex	2024	2030	Yes	D	Hydro done
89	Green house 3	ABC	10 lb	Other	2031	2025	Yes	D	Recharge done
90	Barn	ABC	10 lb	Other	2032	2026	Yes	B	Good
91	Trailer 1	ABC	5 lb	Badger	2024	2030	Yes	D	Hydro done
92	Trailer 2	ABC	5 lb	Amerex	2035	2029	Yes	B	Good
93	Trailer 3	ABC	5 lb	Amerex	2028	2034	Yes	B	Good
94	Trailer 4	ABC	5 lb	Buckeye	2026	2032	Yes	B	Good
95	Visiting concession	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
96	Visiting storage	ABC	10 lb	Amerex	2028	2034	Yes	B	Good
97	Visiting restroom inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
98	Visiting bathroom boys	ABC	10 lb	Buckeye	2034	2028	Yes	B	Good
99	Visiting ticket booth	ABC	10 lb	Ansul	2028	2034	Yes	B	Good
100	Visiting heater room jn	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
101	Visiting alarm panel room	ABC	10 lb	Other	2032	2026	Yes	B	Good
102	Home side concession	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
103	Home side ticket booth	ABC	10 lb	Other	2032	2026	Yes	B	Good
104	Home side storage	ABC	10 lb	Buckeye	2027	2033	Yes	B	Good
105	Home side girls	ABC	5 lb	Badger	2034	2028	Yes	B	Good
106	Home side boy restroom	ABC	5 lb	Buckeye	2034	2028	Yes	B	Good
107	Back home side training	ABC	10 lb	Badger	2028	2034	Yes	B	Good
108	Back home side concession	ABC	10 lb	Other	2023	2026	Yes	B	Good
109	Home back girl restroom	ABC	10 lb	Other	2032	2026	Yes	B	Good
110	Home side back box boy restroom	ABC	10 lb	Amerex	2034	2028	Yes	B	Good
111	Press box	ABC	10 lb	Badger	2035	2029	Yes	B	Good
112	Tractor shed	ABC	10 lb	Other	2032	2026	Yes	B	Good
113	Tractor shed by work bench	ABC	10 lb	Badger	2028	2034	Yes	B	Good
114	Paint shed	ABC	10 lb	Amerex	2034	2028	Yes	B	Good
115	Baseball press box	ABC	10 lb	Other	2032	2026	Yes	B	Good
116	Softball concession	ABC	10 lb	Other	2032	2026	Yes	B	Good
117	Softball storage	ABC	10 lb	Other	2032	2026	Yes	B	Good
118	Receiving	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
119	F108 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
120	Room beside F108	ABC	10 lb	Other	2032	2026	Yes	B	Good
121	Room behind kitchen	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
122	F103 inside concession	ABC	10 lb	Other	2032	2026	Yes	B	Good
123	Main gym hall	ABC	10 lb	Ansul	2035	2029	Yes	B	Good
124	Book room inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
125	Book room front exit	ABC	10 lb	Other	2032	2026	Yes	B	Good
126	F106 hall	ABC	10 lb	Buckeye	2031	2025	Yes	B	Good
127	F114B inside	BC	10 lb	Other	2032	2026	Yes	B	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-13-2024
ST JOB NUMBER	34846196
TECHNICIAN	James President
CUSTOMER LOCATION	Ashley Ridge High School 9800 Delemar Highway Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
128	F120 hall	ABC	10 lb	Other	2032	2026	Yes	B	Good
129	F126 storage	ABC	10 lb	Other	2032	2026	Yes	B	Good
130	F130 hall	ABC	10 lb	Other	2035	2029	Yes	B	Good
131	F138 inside	ABC	10 lb	Other	2032	2026	Yes	B	Good
132	F133 hall	ABC	10 lb	Other	2031	2025	Yes	B	Good
133	G110 inside	ABC	10 lb	Other	2034	2028	Yes	B	Good
134	G117 hall	ABC	10 lb	Buckeye	2034	2028	Yes	B	Good
135	K104 inside	ABC	10 lb	Other	2034	2028	Yes	B	Good
136	K111 inside	ABC	10 lb	Buckeye	2034	2028	Yes	B	Good
137	K111 hall	ABC	10 lb	Badger	2035	2029	Yes	B	Good
138	E102G	ABC	10 lb	Other	2024	2030	Yes	D	Hydro
139	Kitchen	K Class	2.5 gal	Buckeye					Replace by facilities
140	Kitchen	K Class	2.5 gal	Buckeye	2028	2033	Yes	B	Good
141	Kitchen	K Class	2.5 gal	Buckeye	2026	2031	Yes	B	Good
142	Spare	ABC	10 lb	Buckeye	2027	2033	Yes	B	Good
143	Spare	K Class		Amerex	2025	2030	Yes	F	Condemn
144	Spare	ABC	10 lb	Other	2029	2023	Yes	D	Six years
145	Spare	ABC	10 lb	Other	2032	2026	Yes	B	Good
146	Spare	ABC	10 lb	Other	2031	2025	Yes	B	Good
147	Spare	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
148	Spare	ABC	5 lb	Badger	2035	2029	Yes	B	Good
149	Spare	ABC	10 lb	Badger	2033	2027	Yes	B	Good
150	Spare	Water	6 lit	Buckeye	2028	2033	Yes	B	Good
151	Spare	Water	6 lit	Buckeye	2028	2033	Yes	B	Good
152	Spare	CO2	10 lb	Amerex	2025	2030	Yes	B	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-12-2024
ST JOB NUMBER	34065458
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Beech Hill Elementary 1001 Beech Hill Rd Summerville, SC, 294852
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Media center	ABC	5 lb	Badger	2025	2031	Yes	A	Good
2	Hall by room 26A	ABC	5 lb	Badger	2028	2030	Yes	A	Due hydro done
3	Hall by room 32	ABC	5 lb	Badger	2028	2034	Yes	A	Good
4	Room 32	ABC	10 lb	Badger	2031	2025	Yes	A	Good
5	Hall by room 33	ABC	5 lb	Other	2025	2031	Yes	A	Good
6	Hall by room 44	ABC	5 lb	Badger	2025	2031	Yes	A	Good
7	Hall by room 58	ABC	5 lb	Badger	2025	2031	Yes	A	Good
8	Hall by room 69	ABC	10 lb	Amerex	2025	2031	Yes	A	Good
9	Hall by room 72	ABC	10 lb	Amerex	2025	2031	Yes	A	Good
10	Trailer 95	ABC	5 lb	Badger	2030	2030	Yes	A	Due 6 years done
11	Trailer 94	ABC	10 lb	Kidde	2035	2029	Yes	A	Good
12	Trailer 93	ABC	5 lb	Other	2035	2029	Yes	A	Good
13	Trailer 92	ABC	5 lb	Ansul	2035	2029	Yes	A	Missing New done
14	Trailer 91	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
15	Trailer 90	ABC	5 lb	Badger	2035	2029	Yes	A	Good
16	Trailer 89	ABC	5 lb	Buckeye	2032	2026	Yes	A	Good
17	Trailer 88	ABC	5 lb	Buckeye	2032	2026	Yes	A	Good
18	Hall by room 79	ABC	5 lb	Badger	2025	2031	Yes	A	Good
19	Cafeteria	ABC	5 lb	Amerex	2025	2025	Yes	A	Good
20	Gym	ABC	5 lb	Other	2025	2031	Yes	A	Good
21	Outside electrical room behind kitchen	BC	10 lb	Amerex	2031	2025	Yes	A	Good
22	Outside mechanical room behind kitchen	ABC	10 lb	Other	2035	2029	Yes	A	Good
23	Kitchen	ABC	10 lb	Kidde	2035	2029	Yes	A	Good
24	Art room kiln	ABC	10 lb	Amerex	2030	2030	Yes	A	Due 6 years done
25	By 87	ABC	5 lb	Badger	2030	2030	Yes	A	Due hydro done
26	Kitchen	K Class			2025		Yes	A	Good
27	Hall by room 12	ABC	5 lb	Badger	2031	2025	Yes	A	Good
28	Trailer 96	ABC	5 lb	Buckeye	2030	2030	Yes	A	Due 6 years done

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-11-2024
ST JOB NUMBER	35139944
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Admin Offices 815 South Main Street Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Electric room	ABC	10 lb	Buckeye	2033	2027	Yes	A	Good
2	Storage room	ABC	10 lb	Buckeye	33	27	Yes	B	Good
3	By stage	ABC	10 lb	Buckeye	33	27	Yes	B	Good
4	135	ABC	10 lb	Buckeye	33	27	Yes	B	Good
5	101	ABC	10 lb	Ansul	34	28	Yes	B	Good
6	101	ABC	10 lb	Ansul	34	28	Yes	B	Good
7	Beside women restrooms 102	ABC	10 lb	Buckeye	33	27	Yes	B	Good
8	128	ABC	10 lb	Buckeye	33	27	Yes	B	Good
9	224	ABC	10 lb	Buckeye	33	27	Yes	B	Good
10	218 hallway	ABC	10 lb	Buckeye	33	27	Yes	B	Good
11	207	ABC	10 lb	Buckeye	33	27	Yes	B	Good
12	211	ABC	10 lb	Buckeye	33	27	Yes	B	Good
13	114 elevator room	ABC	10 lb	Buckeye	33	27	Yes	B	Good
14	118 across	ABC	10 lb	Buckeye	33	27	Yes	B	Good
15	119	ABC	10 lb	Buckeye	33	27	Yes	B	Good
16	109	ABC	10 lb	Kidde	33	27	Yes	B	Good
17	214	ABC	10 lb	Buckeye	2033	2027	Yes	B	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-26-2024
ST JOB NUMBER	34846206
TECHNICIAN	Erryl Porter
CUSTOMER LOCATION	Dubose Middle School 1005 Dubose School Rd Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Water heater room	ABC	10 lb	Badger	2033	2027	Yes	B	
2	Kitchen	K Class		Ansul	2028		Yes	B	
3	Kitchen	ABC	5 lb	Amerex	2036	2030	Yes	B	Hydro completed
4	Cafeteria	ABC	5 lb	Other	2036	2030	Yes	B	Hydro completed
5	Stage	ABC	5 lb	Badger	2025	2031	Yes	B	
6	Cafeteria	ABC	5 lb	Amerex	2030	2036	Yes	B	6yr completed
7	Cafeteria	ABC	5 lb	Badger	2036	2030	Yes	B	Hydro completed
8	By sro	ABC	5 lb	Badger	2036	2030	Yes	B	Hydro completed
9	106	ABC	5 lb	Amerex	2036	2030	Yes	B	Hydro completed
10	Hallway	ABC	5 lb	Buckeye	2032	2026	Yes	B	
11	Library	ABC	5 lb	Amerex	2032	2026	Yes	B	
12	Library	ABC	5 lb		2033	2027	Yes	B	
13	Office	ABC	10 lb	Badger	2031	2025	Yes	B	
14	Room100	ABC	5 lb	Badger	2031	2025	Yes	B	
15	Copying room	ABC	5 lb	Amerex	2031	2025	Yes	B	
16	Electric. Room	ABC	5 lb	Amerex	2030	2036	Yes	B	6yr completed
17	107	ABC	5 lb	Badger	2036	2030	Yes	B	Hydro completed
18	202	ABC	5 lb	Amerex	2033	2027	Yes	B	
19	205	ABC	5 lb	Amerex	2033	2027	Yes	B	
20	301	ABC	5 lb	Amerex	2027	2033	Yes	B	
21	301	ABC	5 lb	Amerex	2036	2030	Yes	B	Hydro completed
22	305	ABC	5 lb	Badger	2032	2026	Yes	B	
23	308	ABC	5 lb	Buckeye	2026	2032	Yes	B	
24	400	ABC	5 lb	Badger	2036	2030	Yes	B	Hydro completed
25	405	ABC	5 lb	Other	2033	2027	Yes	B	
26	406	ABC	10 lb	Badger	2027	2033	Yes	B	
27	502	ABC	5 lb	Amerex	2033	2027	Yes	B	
28	600	ABC	5 lb	Amerex	2033	2027	Yes	B	
29	605	ABC	5 lb	Amerex	2033	2027	Yes	B	
30	705	ABC	5 lb	Badger	2025	2031	Yes	B	
31	809	ABC	5 lb	Badger	2036	2030	Yes	B	Hydro completed
32	Out side custodian	ABC	5 lb	Amerex	2031	2025	Yes	B	
33	Fox den	ABC	10 lb	Amerex	2027	2033	Yes	B	
34	802	ABC	5 lb	Amerex	2031	2025	Yes	B	
35	801	ABC	10 lb	Amerex	2026	2032	Yes	B	
36	801	ABC	10 lb	Badger	2025	2031	Yes	B	
37	Electrical room e	ABC	5 lb	Badger	2031	2025	Yes	B	
38	Gym	ABC	10 lb	Badger	2031	2025	Yes	B	
39	Gym	ABC	5 lb	Buckeye	2032	2026	Yes	B	
40	Gym	ABC	5 lb	Other	2033	2027	Yes	B	
41	Gym	ABC	5 lb	Amerex	2025	2031	Yes	B	
42	Gym	ABC	5 lb	Buckeye	2032	2026	Yes	B	
43	920	ABC	5 lb	Buckeye	2026	2032	Yes	B	

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-26-2024
ST JOB NUMBER	34846206
TECHNICIAN	Erryl Porter
CUSTOMER LOCATION	Dubose Middle School 1005 Dubose School Rd Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
44	911	BC	5 lb	Badger	2030	2036		B	6yr completed
45	919	ABC	5 lb	Buckeye	2026	2032	Yes	B	
46	917	ABC	5 lb	Amerex	2031	2025	Yes	B	
47	918	ABC	5 lb	Amerex	2031	2025	Yes	B	
48	915	ABC	5 lb	Badger	2030	2036	Yes	B	6yr completed
49	916	ABC	5 lb	Badger	2030	2036	Yes	B	6yr completed
50	913	ABC	5 lb	Badger	2030	2036	Yes	B	6yr completed
51	914			Badger	2030	2036	Yes	B	6yr completed
52	911	ABC		Badger	2030	2036	Yes	B	6yr completed
53	912	ABC	5 lb	Amerex	2036	2030	Yes	B	Hydro completed
54	910	ABC	5 lb	Badger	2030	2036	Yes	B	6yr completed
55	909	ABC	5 lb	Amerex	2031	2025	Yes	B	
56	908	ABC	5 lb	Buckeye	2032	2026	Yes	B	
57	907	ABC	5 lb	Amerex	2036	2030	Yes	B	Hydro completed

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-26-2024
ST JOB NUMBER	34846227
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Eagle Nest Elementary 8640 River Oaks Dr North Charleston, SC, 29420
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	502 hall	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
2	515 hall	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
3	205 hall	ABC	10 lb	Badger	2029	2029	Yes	A	Good
4	105 hall	ABC	10 lb	Kidde	2035	2029	Yes	A	Good
5	404 hall	ABC	10 lb	Buckeye	2028	2034	Yes	A	Good
6	Maintenance room spare	ABC	10 lb	Badger	2025	2025	Yes	A	Good
7	Maintenance room spare	ABC	10 lb	Badger	2022	2026	Yes	A	Good
8	Maintenance room spare	Water Mist	6 lit	Amerex	2028		Yes	A	Good
9	Maintenance room spare	Water Mist	6 lit	Amerex	2028		Yes	A	Good
10	Maintenance room spare	Water Mist	6 lit	Amerex	2028		Yes	C	Good
11	300 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
12	116 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
13	Art room 113	ABC	10 lb	Ansul	2036	2030	Yes	A	Due hydro done
14	Media center	Water Mist		Amerex	2028		Yes	A	Good
15	415 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
16	113 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
17	109 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
18	Cafeteria	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
19	Cafeteria	ABC	10 lb	Buckeye	2033	2027	Yes	A	Good
20	Cafeteria	ABC	10 lb	Buckeye	2031	2026	Yes	A	Good
21	Cafeteria	ABC	10 lb	Badger	2026	2028	Yes	A	Good
22	Mobile 1	ABC	5 lb	Badger	2031	2025	Yes	A	Good
23	Mobile unit 2	ABC	5 lb	Badger	2031	2025	Yes	A	Good
24	Elevator	ABC	10 lb	Badger	2028	2028	Yes	A	Good
25	Spare	ABC	10 lb	Amerex	2030	2030	Yes	A	Good
26	205 custodial	ABC	10 lb	Other	2035	2029	Yes	A	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-12-2024
ST JOB NUMBER	35010069
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	East Edisto Middle School 1011 Beech Hill Road Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	107A workroom inside media center	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
2	By E100	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
3	By room 204	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
4	Across from room 217	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
5	By E200	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
6	By room 226	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
7	By room 301	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
8	Across from room 307	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
9	Across from room 312	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
10	By room 318	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
11	By room 103	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
12	Gym	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
13	Gym	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
14	By 604B	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
15	Cafeteria	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
16	Cafeteria	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
17	Kitchen	K Class	6 lit	Buckeye	2027		Yes	A	Good
18	By room 401	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
19	Across from room 407	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
20	Across from room 410	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
21	By room 416	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
22	Room 104 Art								
23	Main electrical room by gym								

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-11-2024
ST JOB NUMBER	34846248
TECHNICIAN	Erryl Porter
CUSTOMER LOCATION	Eugene Sires Elementary 301 Chandler Creek Rd Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Media center	ABC	10 lb			2028	Yes	B	
2	A128 kiln	ABC	10 lb			2028	Yes	B	
3	Hall A127	ABC	10 lb			2028	Yes	B	
4	Hall A108	ABC	10 lb			2028	Yes	B	
5	Hall A112	ABC	10 lb			2028	Yes	B	
6	Hall A104	ABC	10 lb			2028	Yes	B	
7	Hall B127	ABC	10 lb			2028	Yes	B	
8	Hall C104	ABC	10 lb			2028	Yes	B	
9	Hall D101	ABC	10 lb			2028	Yes	B	
10	Hall D108	ABC	10 lb			2028	Yes	B	
11	Hall E104	ABC	10 lb			2028	Yes	B	
12	Hall F115	ABC	10 lb			2028	Yes	B	
13	Hall F102	ABC	10 lb			2028	Yes	B	
14	Hall by restroom	ABC	10 lb			2028	Yes	B	
15	Gym	ABC	10 lb			2028	Yes	B	
16	Cafeteria	ABC	10 lb			2028	Yes	B	
17	Kitchen	ABC	10 lb			2028	Yes	B	
18	Kitchen	K Class	2.5 gal		2029		Yes	B	
19	In J115	ABC	10 lb			2028	Yes	B	
20	Office hall	ABC	10 lb			2028	Yes	B	
21	Hall by H136	ABC	10 lb			2028	Yes	B	
22	Outside electrical room	ABC	10 lb			2028	Yes	B	

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	07-11-2024
ST JOB NUMBER	34846277
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Facilities Maintenance 164 McQueen Boulevard Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Box truck 36	ABC	5 lb	Buckeye	32	26	Yes	B	Good
2	2-floor exit right	ABC	5 lb	Buckeye	26	26	Yes	B	Good
3	2-floor exit left	ABC	5 lb	Amerex	31	25	Yes	B	Good
4	Back office exit	ABC	5 lb	Buckeye	26	26	Yes	B	Good
5	Office by restroom	ABC	5 lb	Amerex	25	25	Yes	B	Good
6	Office by	ABC	5 lb	Buckeye	26	26	Yes	B	Good
7	by Freon cage 1	ABC	5 lb	Amerex	25	25	Yes	B	Good
8	Shop cold storage room	ABC	10 lb	Badger	32	26	Yes	B	Good
9	Shop outside work bench	ABC	10 lb	Buckeye	30	30	Yes	B	6-year fixed
10	Paint room	ABC	10 lb	Buckeye	30	30	Yes	B	6-year fixed
11	Shop landscape storage	ABC	10 lb	Amerex	25	25	Yes	B	Good
12	HVAC work room	ABC	10 lb	Amerex	25	25	Yes	B	Good
13	Shop by fire house	ABC	10 lb	Badger	30	30	Yes	B	6-year fixed
14	Shop middle rack	ABC	10 lb	Amerex	25	25	Yes	B	Good
15	Spare	ABC	5 lb	Amerex	25	25	Yes	B	Good
16	Spare	ABC	5 lb	Badger	25	25	Yes	B	Good
17	Spare	ABC	6 lb	Amerex	31	25	Yes	B	Good
18	Spare	ABC	5 lb	Amerex	32	26	Yes	B	Good
19	Spare	CO2	5 lb	Other	28	0	Yes	B	Good
20	Spare	ABC	5 lb	Badger	25	25	Yes	B	Good
21	Spare	ABC	5 lb	Badger	25	26	Yes	B	Good
22	Spare	ABC	20 lb	Badger	32	26	Yes	B	Good
23	Spare	ABC	2.5 lb	Buckeye	32	26	Yes	B	Good
24	Spare	Water	2.5 gal	Amerex	29	0	Yes	B	Hydrotest bring back fixed
25	Spare	ABC	10 lb	Buckeye	30	30	Yes	B	6-year fixed
26	Spare	ABC	10 lb	Badger	28	30	Yes	B	Hydrotest fixed
27	Spare	ABC	10 lb	Amerex	36	30	Yes	B	Hydrotest and fixed
28	Spare	ABC	5 lb	Kidde	30	30	Yes	B	Hydrotest fixed
29	Spare	ABC	5 lb	Amerex	36	30	Yes	B	Hydrotest fixed

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-13-2024
ST JOB NUMBER	34846285
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Flowertown Elementary School 20 King Charles Cir Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Entrance hall	ABC	10 lb	Amerex	2036	2030	Yes	A	Due 6 years done
2	Wildflower estates	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
3	Morning glory estates	ABC	10 lb	Badger	2031	2025	Yes	A	Good
4	Garden estate	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
5	Facilities office spare	ABC	10 lb	Badger	2031	2025	Yes	A	Good
6	Facilities office spare	ABC	5 lb	Badger	2025	2031	Yes	A	Good
7	Facilities office spare	ABC	5 lb	Amerex	2032	2026	Yes	A	Good
8	Facilities office spare	ABC	5 lb	Badger	2025	2026	Yes	A	Good
9	Facilities office spare	ABC	5 lb	Badger	2025	2026	Yes	A	Good
10	Facilities office spare	ABC	2.5 lb	Badger	2031	2025	Yes	A	Good
11	Wisteria estates	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
12	Classroom 55 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
13	Build a bee workshop	ABC	10 lb	Other	2035	2029	Yes	A	Good
14	Daisy estates	ABC	5 lb	Amerex	2025	2031	Yes	A	Good
15	Azalea estates	ABC	10 lb	Badger	2035	2029	Yes	A	Good
16	Lily estates	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
17	Kitchen area	ABC	5 lb	Other	2028	2025	Yes	A	Good
18	101 hall	ABC	5 lb	Other	2030	2030	Yes	A	Due hydro done
19	Soda shop corner	ABC	5 lb	Other	2026	2032	Yes	A	Good
20	Classroom 113 hall	ABC	5 lb	Other	2025	2031	Yes	A	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety* Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-27-2024
ST JOB NUMBER	34846225
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Fort Dorchester Elementary School 5201 Old GLory Ln Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Outside front office	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
2	Side of front office	ABC	10 lb	Badger	2025	2025	Yes	A	Good
3	Media room	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
4	Media room	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
5	Across 602	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
6	Across 601	ABC	10 lb	Kidde	2036	2030	Yes	A	Recharge done
7	Outside principal office	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
8	Gym	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
9	Gym	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
10	Cafeteria	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
11	Kitchen	K Class	6 lit	Ansul	2028		Yes	A	Good
12	Electrical room	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
13	Across from 5th grade girls restroom	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
14	Across 600	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
15	Outside 417	ABC	10 lb	Amerex	2035	2029	Yes	A	Good
16	Outside 413	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
17	Outside of 407	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
18	Outside 403	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
19	Outside 308	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
20	Outside 302	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
21	Outside 210	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
22	Outside 216	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
23	Outside 206	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
24	Outside 202	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
25	Outside 101	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
26	Side of 110	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
27	Outside 107	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
28	Art	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
29	Trailer 11	ABC	5 lb	Badger	2034	2028	Yes	A	Good
30	Trailer 10	ABC	5 lb	Amerex	2034	2028	Yes	A	Good
31	Trailer 9	ABC	5 lb	Badger	2034	2028	Yes	A	Good
32	Trailer 8	ABC	5 lb	Badger	2034	2028	Yes	A	Good
33	Trailer 7	ABC	5 lb	Badger	2034	2028	Yes	A	Good
34	Trailer 6	ABC	5 lb	Badger	2030	2030	Yes	A	Due 6 years done
35	Trailer 5	ABC	5 lb	Badger	2028	2028	Yes	A	Good
36	Trailer 4	ABC	5 lb	Amerex	2025	2028	Yes	A	Good
37	Trailer 3	ABC	10 lb	Badger	2034	2028	Yes	A	Good
38	Trailer 2	ABC	5 lb	Other	2034	2028	Yes	A	Good
39	Trailer 1	ABC	5 lb	Other	2034	2028	Yes	A	Good
40	Spare	ABC	10 lb	Other	2036	2030	Yes	A	Due 6 years done

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-03-2024
ST JOB NUMBER	34065498
TECHNICIAN	James President
CUSTOMER LOCATION	Fort Dorchester High School 8500 Patriot Blvd North Charleston, SC, 29420
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Spare	ABC	10 lb	Amerex	2035	2028	Yes	B	Good
2	Spare	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
3	Spare	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
4	Spare	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
5	Spare	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
6	Spare	ABC	10 lb	Badger	2035	2029	Yes	B	Good
7	Spare	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
8	Spare	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
9	Spare	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
10	Spare	ABC	10 lb	Badger	2035	2029	Yes	B	Good
11	309 receiving hall	ABC	10 lb	Badger	2024	2030	Yes	B	Hydro done
12	Kitchen	ABC	10 lb	Badger	2024	2030	Yes	B	Hydro done
13	Kitchen	K Class	2.5 gal	Badger	2024	2029	Yes	B	Hydro done
14	313 hall facility bathroom	ABC	10 lb	Amerex	2024	2030	Yes	B	Hydro done
15	Inside 411	ABC	10 lb	Kidde	2024	2030	Yes	B	Hydro done
16	Inside 415	ABC	10 lb	Amerex	2024	2030	Yes	B	Hydro done
17	Inside 413	ABC	5 lb	Badger	2031	2025	Yes	B	Good
18	415 hall	ABC	10 lb	Buckeye	2035	2029	Yes	B	Hydro done
19	C401A hall	ABC	10 lb	Buckeye	2035	2029	Yes	B	Hydro done
20	417 hall	ABC	10 lb	Amerex	2035	2029	Yes	B	Hydro done
21	Inside 417	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
22	Inside 417	K Class	2.5 gal	Badger	2024	2029	Yes	B	Hydro
23	506 hall	ABC	10 lb	Buckeye	2036	2030	Yes	B	Hydro done
24	635 hall	ABC	10 lb	Amerex	2036	2030	Yes	B	Hydro done
25	631 hall	ABC	10 lb	Amerex	2036	2030	Yes	B	Hydro done
26	516:hall	ABC	10 lb	Amerex	2034	2028	Yes	B	Good
27	Inside 826	ABC	5 lb	Buckeye	2032	2026	Yes	B	Good
28	831 hall	ABC	10 lb	Badger	2035	2029	Yes	B	Hydro done
29	Inside 824	ABC	10 lb	Amerex	2036	2030	Yes	B	Hydro done
30	Inside 824	ABC	10 lb	Other	2031	2025	Yes	B	Good
31	Inside	ABC	10 lb	Amerex	2035	2029	Yes	B	Hydro done
32	825 hall	ABC	5 lb	Buckeye	2031	2025	Yes	B	Good
33	Inside 820	ABC	10 lb	Amerex	2035	2029	Yes	B	Hydro done
34	Inside 825	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
35	Inside 823	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
36	Inside 818	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
37	333 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
38	337 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
39	Inside 337	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
40	Inside 816	ABC	10 lb	Badger	2028	2034	Yes	B	Good
41	Inside 814	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
42	Inside 812	ABC	5 lb	Badger	2025	2031	Yes	B	Good
43	809 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-03-2024
ST JOB NUMBER	34065498
TECHNICIAN	James President
CUSTOMER LOCATION	Fort Dorchester High School 8500 Patriot Blvd North Charleston, SC, 29420
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
44	119 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
45	801 hall	ABC	5 lb	Buckeye	2030	2036	Yes	B	Hydro done
46	609 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
47	601 hall	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
48	Inside learning common	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
49	615 hall	ABC	10 lb	Badger	2030	2036	Yes	B	Six years done
50	Inside 616	ABC	5 lb	Badger	2025	2031	Yes	B	Good
51	321 hall	ABC	10 lb	Buckeye	2027	2033	Yes	B	Good
52	Inside 321	ABC	5 lb	Badger	2025	2031	Yes	B	Good
53	Inside 319	ABC	5 lb	Badger	2036	2030	Yes	B	Hydro done
54	Cafe by electric room	ABC	5 lb	Buckeye	2033	2027	Yes	B	Good
55	Cafe by fountain	ABC	5 lb	Badger	2936	2030	Yes	B	Hydro done
56	Cafe on column	ABC	10 lb	Kidde	2030	2036	Yes	B	Hydro done
57	Cafe by double door	ABC	10 lb	Amerex	2025	2031	Yes	B	Good
58	Cafe adjacent exit	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
59	110 hall	ABC	10 lb	Amerex	2036	2030	Yes	B	Hydro done
60	401 hall	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
61	Front office	ABC	10 lb	Buckeye	2027	2033	Yes	B	Good
62	Office by restroom	ABC	10 lb	Buckeye	2027	2033	Yes	B	Good
63	Office hall	ABC	10 lb	Other	2033	2027	Yes	B	Good
64	Inside 108	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
65	Inside 108 right side	ABC	10 lb	Other	2030	2036	Yes	B	Hydro done
66	Inside 108 backstage	ABC	10 lb	Other	2030	2036	Yes	B	Six year done
67	Office by women restroom	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
68	207 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
69	202 hall	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
70	Inside 202	ABC	10 lb	Amerex	2029	2035	Yes	B	Hydro done
71	Inside 205	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
72	Inside 1104 k	ABC	10 lb	Amerex	2025	2031	Yes	B	Good
73	Inside JV LOCKER ROOM	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
74	Visiting JV locker rooms	ABC	10 lb	Amerex	2030	2036	Yes	B	Hydro done
75	104 hall	ABC	10 lb	Badger	2028	2034	Yes	B	Good
76	217 hall	ABC	10 lb	Amerex	2036	2030	Yes	B	Six years done
77	Big gym	ABC	10 lb	Badger	2028	2034	Yes	B	Good
78	Big gym	ABC	10 lb	Badger	2028	2034	Yes	B	Good
79	219 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
80	303 corners hall	ABC	10 lb	Badger	2028	2034	Yes	B	Good
81	302 hall	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
82	Inside 305	ABC	10 lb	Badger	2030	2036	Yes	B	Six years done
83	Big gym	ABC	10 lb	Badger	2028	2034	Yes	B	Good
84	Onside concession	ABC	5 lb	Badger	2036	2030	Yes	B	Six years done
85	Visiting concession	ABC	5 lb	Badger	2028	2034	Yes	B	Six years done
86	Home side halftime room	ABC	5 lb	Badger	2026	2032	Yes	B	Six years done

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-03-2024
ST JOB NUMBER	34065498
TECHNICIAN	James President
CUSTOMER LOCATION	Fort Dorchester High School 8500 Patriot Blvd North Charleston, SC, 29420
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
87	Visiting halftime room	ABC	10 lb	Amerex	2036	2030	Yes	B	Six years done
88	Press box	ABC	10 lb	Amerex	2036	2030	Yes	B	Hydro done
89	Press box adjacent side	ABC	10 lb	Amerex	2036	2030	Yes	B	Six years done
90	Softball concession	ABC	5 lb	Badger	2031	2037	Yes	B	Six years done
91	Baseball concession	ABC	5 lb	Amerex	2029	2035	Yes	B	Six years done
92	Tractor shed	ABC	10 lb	Amerex	2036	2030	Yes	B	Six years done
93	Tractor shed other end	ABC	10 lb	Other	2036	2030	Yes	B	Hydro done
94	233 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
95	237 hall	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
96	Inside 206	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
97	Inside 208	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
98	Inside 210	ABC	10 lb	Badger	2036	2030	Yes	B	Hydro done
99	Inside 212	ABC	10 lb	Buckeye	2036	2030	Yes	B	Hydro done
100	Inside 1125	ABC	10 lb	Ansul	2036	2030	Yes	B	Recharge done
101	1121 hall	ABC	10 lb	Kidde	2033	2027	Yes	B	Good
102	Inside 1126	ABC	10 lb	Badger	2030	2036	Yes	B	Hydro done
103	Inside 1115	ABC	10 lb	Badger	2033	2027	Yes	B	Good
104	1101 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
105	1107 hall	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
106	1102 hall	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
107	Inside 1104	ABC	10 lb	Badger	2028	2034	Yes	B	Good
108	Inside 1104	K Class	2.5 gal	Badger	2026	2031	Yes	B	Good
109	Inside 1104 by cooler	ABC	10 lb	Badger	2028	2034	Yes	B	Good
110	Inside 1104G	K Class	2.5 gal	Badger	2026	2031	Yes	B	Good
111	1104E	K Class	2.5 gal	Badger	2026	2031	Yes	B	Good
112	Inside 1101	ABC	10 lb	Badger	2028	2034	Yes	B	Good
113	Inside 1127	ABC	10 lb	Badger	2028	2034	Yes	B	Good
114	1009 hall	ABC	10 lb	Badger	2036	2030	Yes	B	Hydro done
115	Inside 1002	ABC	10 lb	Badger	2028	2034	Yes	B	Good
116	C102 by restroom	ABC	10 lb	Badger	2034	2028	Yes	B	Good
117	C106 restroom	ABC	5 lb	Ansul	2030	2036	Yes	B	Hydro done
118	Trailer 1220	ABC	5 lb	Other	2029	2035	Yes	B	Six years done
119	Inside 1219	ABC	5 lb	Ansul	2031	2025	Yes	B	Six years done
120	Trailer 1218	ABC	5 lb	Badger	2036	2030	Yes	B	Hydro done
121	Trailer 1217	ABC	5 lb	Badger	2036	2030	Yes	B	Hydro done
122	Trailer 1211	ABC	5 lb	Ansul	2036	2030	Yes	B	Hydro done
123	Trailer 1212	ABC	5 lb	Other	2031	2025	Yes	B	Good
124	Storage behind cafeteria	ABC	5 lb	Kidde	2032	2026	Yes	B	Good
125	Generator room	ABC	10 lb	Buckeye	2030	2036	Yes	B	Hydro done
126	Golf cart shed	ABC	10 lb	Badger	2036	2030	Yes	B	Hydro done

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-10-2024
ST JOB NUMBER	34846238
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Givhans Alternative 273 SC-61 Ridgeville, SC, 29472
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Kitchen	ABC	20 lb	Badger	28	28	Yes	A	Good
2	Kitchen	K Class	6 lit	Amerex	27	0	Yes	B	Good
3	Stage rides	ABC	10 lb	Badger	28	28	Yes	A	Good
4	Mechanical room outside	ABC	10 lb	Ansul	28	28	Yes	A	Good
5	97 work room	ABC	5 lb	Buckeye	31	25	Yes	A	Good
6	106	ABC	5 lb	Badger	28	28	Yes	A	Good
7	Trailer 131 left	ABC	5 lb	Other	34	28	Yes	A	Good
8	110	ABC	10 lb	Badger	31	25	Yes	A	Good
9	T120	ABC	5 lb	Badger	31	25	Yes	A	Good
10	113	ABC	10 lb	Badger	31	25	Yes	B	Good
11	114	ABC	10 lb	Amerex	28	28	Yes	A	Good
12	Media center	ABC	10 lb	Badger	28	28	Yes	A	Good
13	Trailer 121 sro	ABC	5 lb	Buckeye	33	27	Yes	A	Good
14	T119	ABC	5 lb	Buckeye	28	28	Yes	A	Good
15	T118	ABC	5 lb	Buckeye	28	28	Yes	B	Good
16	T117	ABC	5 lb	Buckeye	28	28	Yes	A	Good
17	T 126	ABC	5 lb	Buckeye	28	28	Yes	A	Good
18	T 125	ABC	10 lb	Buckeye	28	28	Yes	B	Good
19	T124	ABC	5 lb	Buckeye	2028	2028	Yes	B	Good
20	T123	ABC	5 lb	Buckeye	2028	2028	Yes	B	Good
21	T130	ABC	5 lb	Buckeye	2028	2028	Yes	B	Good
22	T129	ABC	5 lb	Buckeye	2028	2028	Yes	B	Good
23	T128	ABC	5 lb	Buckeye	2028	2028	Yes	B	Good
24	T127	ABC	5 lb	Buckeye	2028	2028	Yes	B	Good
25	Stage left	ABC	5 lb	Amerex	35	29	Yes	B	Good
26	131 right	ABC	10 lb	Badger	31	25	Yes	B	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	07-15-2024
ST JOB NUMBER	35357826
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Gregg Middle School 500 Greenwave Blvd Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Office area	ABC	10 lb	Buckeye	2031	2025	Yes	A	Good
2	Right outside of 100 hallway	ABC	10 lb	Ansul	2036	2030	Yes	A	Due 6 years done
3	Beginning of 100 hall	ABC	10 lb	Other	2028	2030	Yes	A	Due hydro done
4	By 108	ABC	5 lb	Badger	2036	2030	Yes	A	Due hydro done
5	By 112	ABC	10 lb	Ansul	2036	2030	Yes	A	Due hydro done
6	Gym	ABC	10 lb	Buckeye	2036	2030	Yes	A	Due hydro done
7	Gym	ABC	10 lb	Kidde	2028	2026	Yes	A	Good
8	Gym	ABC	10 lb	Badger	2030	2030	Yes	A	Due 6 years done
9	Gym	ABC	10 lb	Amerex	2027	2027	Yes	A	Good
10	Top of stairs in gym	ABC	10 lb	Other	2030	2030	Yes	A	Due 6 years done
11	Upstairs of gym in hallway	ABC	10 lb	Ansul	2032	2026	Yes	A	Good
12	Upstairs of gym top of stairs	ABC	10 lb	Badger	2025	2025	Yes	A	Good
13	Cafeteria	ABC	5 lb	Badger	2025	2027	Yes	A	Good
14	Cafeteria	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
15	Cafeteria	ABC	5 lb	Badger	2032	2026	Yes	A	Good
16	Kitchen	ABC	10 lb	Badger	2025	2025	Yes	A	Good
17	Kitchen	ABC	10 lb	Amerex	2027	2027	Yes	A	Good
18	Kitchen	K Class	6 lit	Badger	2029		Yes	A	Due hydro done
19	On inside electrical	ABC	10 lb	Amerex	2027	2028	Yes	A	Good
20	By 210 across from restrooms	ABC	10 lb	Ansul	2036	2030	Yes	A	Due 6 years done
21	By 205 by electrical	ABC	10 lb	Amerex	2025	2025	Yes	A	
22	By 201	ABC	5 lb	Badger	2032	2026	Yes	A	Good
23	Beginning of 300 hall across from restrooms	ABC	10 lb	Badger	2027	2027	Yes	A	Good
24	Media center	ABC	10 lb	Ansul	2036	2030	Yes	A	Due hydro done
25	Outside of media center	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
26	Across 305	ABC	5 lb	Other	2029	2029	Yes	A	Good
27	Inside 306	ABC	5 lb	Badger	2036	2030	Yes	A	Due 6 years done
28	Across 308	ABC	10 lb	Other	2034	2028	Yes	A	Good
29	Across 311	ABC	5 lb	Badger	2036	2030	Yes	A	Due hydro done
30	Across 312	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
31	700 building outside electrical	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
32	By 401	ABC	5 lb	Badger	2025	2025	Yes	A	Good
33	By 404	ABC	10 lb	Badger	2032	2026	Yes	A	Good
34	By 410	ABC	10 lb	Buckeye	2028	2028	Yes	A	Good
35	Inside 402	ABC	10 lb	Badger	2030	2030	Yes	A	Due 6 years done
36	Across 502	ABC	5 lb	Other	2030	2030	Yes	A	Due 6 years done
37	By 504	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
38	By 507	ABC	10 lb	Badger	2030	2030	Yes	A	Due 6 years done

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	07-15-2024
ST JOB NUMBER	35357826
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Gregg Middle School 500 Greenwave Blvd Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
39	Inside 501	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
40	600 building outside electrical room	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
41	By 601	ABC	5 lb	Badger	2032	2026	Yes	A	Good
42	Outside 605	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
43	Band room 601	ABC	5 lb	Badger	2036	2030	Yes	A	Due 6 years done
44	Inside 602	ABC	10 lb	Other	2025	2025	Yes	A	Good
45	Trailer LC2	ABC	10 lb	Other	2027	2027	Yes	A	Good
46	Trailer LC2	ABC	10 lb	Amerex	2036	2030	Yes	A	Due 6 years done
47	Trailer LC1	ABC	10 lb	Badger	2032	2026	Yes	A	Good
48	Trailer LC1	ABC	5 lb	Badger	2031	2025	Yes	A	Good
49	By 716	ABC	5 lb	Other	2031	2025	Yes	A	Good
50	Inside 709	ABC	10 lb	Badger	2032	2026	Yes	A	Good
51	Across 710	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
52	Inside 704	ABC	5 lb	Other	2029	2026	Yes	A	Good
53	By 702 across from restrooms	ABC	5 lb	Other	2034	2028	Yes	A	Good
54	Across from guidance director	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
55	Spare	ABC	5 lb	Buckeye	2025	2025	Yes	A	Good
56	Spare	ABC	5 lb	Buckeye	2026	2027	Yes	A	Good
57	Spare	ABC	5 lb	Other	2032	2026	Yes	A	Good
58	Spare	ABC	5 lb	Badger	2032	2026	Yes	A	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-11-2024
ST JOB NUMBER	34846200
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Pye Elementary School 9701 Patriot Blvd Ladson, SC, 29456
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Trailer	ABC	5 lb	Buckeye	2026	2026	Yes	B	Good
2	Trailer	ABC	5 lb	Buckeye	2026	2026	Yes	B	Good
3	Data room	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
4	Office hall by restroom	ABC	10 lb	Other	2035	2029	Yes	B	Good
5	604 inside	ABC	10 lb	Amerex	2032	2026	Yes	B	Good
6	Across 604 closet	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
7	Mechanical room 1	ABC	10 lb	Other	2035	2029	Yes	B	Good
8	Music storage 602	ABC	10 lb	Amerex	2030	2029	Yes	B	Hydrotest fixed
9	Pe storage	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
10	502	ABC	5 lb	Other	2035	2029	Yes	B	Good
11	Pe storage left	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
12	Kitchen	K Class	6 lit	Buckeye	2028	0	Yes	B	Good
13	Kitchen back door	ABC	10 lb	Amerex	2035	2029	Yes	B	6-year fixed
14	Dry storage	ABC	10 lb	Amerex	2023	2025	Yes	B	Good
15	Mech pump	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
16	Janitorial idf 5	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
17	Mechanical 3	ABC	10 lb	Other	2035	2029	Yes	B	Good
18	Custodial 3	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
19	Art room storage101	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
20	Art room storage 103	ABC	10 lb	Amerex	2030	2029	Yes	B	Good
21	Art room kiln	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
22	Idf2 janitorial	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
23	Main Electrical room kitchen	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
24	Kitchen janitor room	ABC	10 lb	Amerex	2027	30	Yes	B	Good
25	Room 208	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
26	Idf3 janitorial	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
27	Idf4 janitorial	ABC	10 lb	Amerex	2032	2029	Yes	B	Good
28	Room 312	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
29	Room 412	ABC	10 lb	Amerex	2029	2029	Yes	B	Good
30	Room 410	ABC	10 lb	Amerex	2029	29	Yes	B	Good
31	Custodial managers office janitorial	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
32	Mechanical #4	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
33	Around ac by kitchen	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
34	Mechanical room #5	ABC	10 lb	Other	36	30	Yes	B	Recharge fixed

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	07-30-2024
ST JOB NUMBER	35575568
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	John McKissick Museum and Alumni Center 805 South Main Street Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Outside of restrooms	ABC	10 lb	Amerex	2035	2029	Yes	A	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-13-2024
ST JOB NUMBER	34806018
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Knightsville Elementary School 847 Orangeburg Rd Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Office	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
2	Principal office	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
3	Nurse	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
4	200	ABC	5 lb	Kidde	2030	2030	Yes	A	Due hydro done
5	208	ABC	5 lb	Badger	2032	2030	Yes	A	Due 6 years done
6	225	ABC	5 lb	Other	2035	2029	Yes	A	Good
7	Room in gym multipurpose room	ABC	5 lb	Amerex	2025	2026	Yes	A	Good
8	Trailer 21	ABC	5 lb	Amerex	2032	2026	Yes	A	Good
9	Hallway across from 121	ABC	10 lb	Badger	2025	2026	Yes	A	Good
10	125	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
11	Library	ABC	10 lb	Badger	2025	2025	Yes	A	Good
12	Autumn front	ABC	10 lb	Badger	2025	2025	Yes	A	Good
13	Stage	ABC	5 lb	Kidde	2028	2029	Yes	A	Good
14	Kitchen	K Class		Buckeye	2029		Yes	A	Due hydro done
15	Kitchen	ABC	10 lb	Ansul	2035	2029	Yes	A	Good
16	Cafeteria	ABC	10 lb	Badger	2025	2025	Yes	A	Good
17	Cafeteria 2	ABC	10 lb	Buckeye	2036	2030	Yes	A	Due 6 years done
18	Trailer lc18	ABC	5 lb	Badger	2025	2025	Yes	A	Good
19	400	ABC	10 lb	Amerex	2036	2030	Yes	A	Due 6 years done
20	403	ABC	5 lb	Amerex	2031	2026	Yes	A	Good
21	Inside 408	ABC	5 lb	Amerex	2025	2025	Yes	A	Good
22	Lc17	ABC	5 lb	Buckeye	2035	2029	Yes	A	Good
23	Boiler room	ABC	5 lb	Amerex	2030	2030	Yes	A	Due hydro done
24	Shed	ABC	5 lb	Other	2035	2029	Yes	A	Recharge done
25	Shed	ABC	5 lb	Other	2029	2030	Yes	A	Due 6 years done
26	Shed	ABC	10 lb	Other	2026	2030	Yes	A	Recharge done
27	Room 200 kiln room	ABC	10 lb	Badger	2035	2029	Yes	A	Good
28	In room 104	ABC	5 lb	Badger	2032	2026	Yes	A	Good
29	T21	ABC	5 lb	Ansul	2036	2030	Yes	A	Due hydro done
30	117	ABC	5 lb	Ansul	2030	2030	Yes	A	Due hydro done
31	126	ABC	5 lb	Badger	2033	2027	Yes	A	Good
32	Inside 123	ABC	5 lb	Other	2025	2025	Yes	A	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-13-2024
ST JOB NUMBER	34846284
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Newington Elementary School 10 King Charles Cir Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Room 208 by stage	ABC	10 lb	Buckeye	2034	2026	Yes	A	Good
2	Kitchen	ABC	10 lb	Other	2026	2032	Yes	A	Good
3	Kitchen	K Class		Buckeye	2027		Yes	A	Good
4	Cafeteria	ABC	10 lb	Other	2034	2028	Yes	A	Good
5	Stage 213	ABC	10 lb	Badger	2034	2028	Yes	A	Good
6	116 hall	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
7	119 b kiln room	ABC	10 lb	Ansul	2028	2029	Yes	A	Good
8	Art room 2 kiln	ABC	10 lb	Badger	2031	2025	Yes	A	Good
9	108 hall	ABC	10 lb	Badger	2034	2028	Yes	A	Good
10	Pod 3 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
11	Cafeteria	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
12									
13	Pod 4 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
14	Pod 4 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
15	Pod 5 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
16	Pod 5 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
17	Pod 6 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
18	Pod 6 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
19	Pod 7 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
20	Pod 7 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
21	Shrimp pod	ABC	5 lb	Badger	2035	2029	Yes	A	Good
22	Pod 8 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
23	Porpoise pod	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
24	Classroom by pod 8	ABC	5 lb	Buckeye	2028	2027	Yes	A	Good
25	Pod 8 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
26	Pod 9 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
27	Pod 9 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
28	Hall by principal	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
29	Hall by assistant principal	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
30	Pod 10 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
31	Pod 10 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
32	Pod 1 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
33	Pod 1 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
34	Pod 2 boys room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
35	Pod 2 girls room	ABC	5 lb	Badger	2030	2030	Yes	A	Due 6 years done
36	Pod 3 girls room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	07-23-2024
ST JOB NUMBER	34846295
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Oakbrook Elementary School 306 Old Fort Dr Ladson, SC, 29456
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Hall h4	ABC	5 lb	Badger	2033	2030	Yes	A	Due 6 years done
2	Multipurpose	ABC	5 lb	Badger	2028	2030	Yes	A	Good
3	Teacher workroom	ABC	10 lb	Other	2028	2030	Yes	A	Due hydro done
4	Hall G2	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
5	Hall F3	ABC	5 lb	Amerex	2036	2030	Yes	A	Due 6 years done
6	Hall e1b	ABC	10 lb	Amerex	2036	2030	Yes	A	Due 6 years done
7	Media center	ABC	5 lb	Badger	2031	2025	Yes	A	Good
8	Inside d2	ABC	10 lb	Other	2032	2026	Yes	A	Good
9	Inside d1	ABC	5 lb	Badger	2025	2025	Yes	A	Good
10	111 storage	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
11	Hall by restroom	ABC	5 lb	Badger	2029	2035	Yes	A	Good
12	In 108 janitor	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
13	In 109 data	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
14	Hall out 117	ABC	5 lb	Buckeye	2036	2030	Yes	A	Due recharge done
15	In 114 kiln 112	ABC	10 lb	Other	2030	2036	Yes	A	Due hydro done
16	Trailer	ABC	5 lb	Badger	2032	2026	Yes	A	Good
17	Hall by a3	ABC	10 lb	Amerex	2025	2031	Yes	A	Good
18	Inside maintenance	ABC	10 lb	Other	2031	2025	Yes	A	Good
19	In A1	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
20	Multipurpose by a1	ABC	10 lb	Other	2031	2025	Yes	A	Good
21	Hall j8	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
22	Hall j4	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
23	Teacher lounge	ABC	5 lb	Badger	2033	2027	Yes	A	Good
24	Hall b4	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
25	Hall c2	ABC	5 lb	Buckeye	2030	2036	Yes	A	Due 6 years done
26	In c7	ABC	5 lb	Buckeye	2030	2036	Yes	A	Due hydro done
27	Trailer	ABC	10 lb	Badger	2030	2036	Yes	A	Due 6 years done
28	Cafeteria	ABC	10 lb	Amerex	2031	2025	Yes	A	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	07-16-2024
ST JOB NUMBER	34846255
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Oakbrook Middle School 286 Old Fort Dr Ladson, SC, 29456
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Main office	Water	2.5 lb	Badger	2028		Yes	A	Good
2	Media center	ABC	5 lb	Badger	2036	2030	Yes	A	Due 6 years done
3	Art 107	ABC	10 lb	Amerex	2030	2030	Yes	A	Due 6 years done
4	Teacher's lounge	ABC	10 lb	Other	2031	2025	Yes	A	Good
5	Across from 101	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
6	Across from 205	ABC	10 lb	Buckeye	2028	2025	Yes	A	Good
7	Inside 301	Water	2.5 lb	Badger	2028		Yes	A	Good
8	Inside 302	Water	2.5 lb	Badger	2028		Yes	A	Good
9	Inside 306	Water	2.5 lb	Badger	2028		Yes	A	Good
10	Inside 307	Water	2.5 lb	Badger	2028		Yes	A	Good
11	Across from 401	ABC	10 lb	Other	2031	2025	Yes	A	Good
12	Inside 406	ABC	5 lb	Amerex	2025	2025	Yes	A	Good
13	Across from 501	ABC	10 lb	Badger	2036	2030	Yes	A	Due hydro done
14	Across from 601	ABC	5 lb	Badger	2029	2029	Yes	A	Good
15	Across from 701	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
16	Inside 819 storage	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
17	Inside 817 electrical	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
18	Inside 816 janitor	ABC	5 lb	Buckeye	2035	2029	Yes	A	Good
19	Across from 800	ABC	5 lb	Other	2035	2029	Yes	A	Good
20	Inside 802	ABC	5 lb	Amerex	2036	2030	Yes	A	Due 6 years done
21	Inside 804	ABC	5 lb	Badger	2027	2030	Yes	A	Due recharge done
22	By 810	ABC	5 lb	Ansul	2029	2029	Yes	A	Good
23	Gym	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
24	Gym	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
25	903	ABC	5 lb	Badger	2025	2025	Yes	A	Good
26	Custodial trailer	ABC	5 lb	Badger	2030	2030	Yes	A	Due 6 years done
27	Band trailer	ABC	5 lb	Badger	2036	2030	Yes	A	Due 6 years done
28	Outside electrical A	ABC	10 lb	Other	2036	2030	Yes	A	Due hydro done
29	904	ABC	10 lb	Amerex	2025	2025	Yes	A	Good
30	Cafeteria	ABC	5 lb	Badger	2031	2030	Yes	A	Due 6 years done
31	Kitchen	ABC	10 lb	Amerex	2032	2026	Yes	A	Good
32	Kitchen	K Class	2.5 lb	Badger	2029		Yes	A	Due recharge done

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-11-2024
ST JOB NUMBER	34846337
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	RISE Academy (Dorchester County Adult Ed) 1325 Boonehill Road Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Construction front door	ABC	10 lb	Amerex	2027	2027	Yes	B	Good
2	Technology	CO2	15 lb	Badger	2028	0	Yes	A	Good
3	Technology	CO2	15 lb	Badger	2025	0	Yes	B	Good
4	Under construction	ABC	10 lb	Badger	33	27		B	
5	120-a	ABC	10 lb	Amerex	2027	2027	Yes	B	Good
6	130	ABC	10 lb	Amerex	27	2027	Yes	B	Good
7	112 rises	ABC	10 lb	Badger	2025	2027	Yes	B	Good
8	Adult education 125	ABC	10 lb	Amerex	27	27	Yes	B	Good
9	Multi-purpose room	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
10	106	ABC	10 lb	Amerex	2027	2027	Yes	B	Good
11	Rise 158	ABC	10 lb	Amerex	27	27	Yes	B	Good
12	133kitchen	K Class	2.5 gal	Amerex	2028	0	Yes	B	Good
13	133 kitchen	ABC	10 lb	Amerex	2034	2028	Yes	B	Good
14	Adult education 140 a	ABC	10 lb	Badger	27	27	Yes	B	Good
15	136adult education	ABC	10 lb	Badger	33	27	Yes	B	Good
16	134	ABC	10 lb	Badger	31	25	Yes	B	Good
17	Sc works back exit	ABC	10 lb	Amerex	31	26	Yes	B	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-26-2024
ST JOB NUMBER	34846336
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	River Oaks Middle School 7110, 8642 River Oaks Dr North Charleston, SC, 29420
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Outside office	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
2	Across from stairs 3	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
3	Cafeteria hall	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
4	Cafeteria entrance by 135 a	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
5	Cafeteria exit by food line	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
6	132 hall	ABC	10 lb	Buckeye	2025	2031	Yes	A	Good
7	Inside 132 by 132c kiln room	ABC	10 lb	Ansul	2036	2030	Yes	A	Due hydro done
8	203 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
9	Inside 211a prep room	ABC	10 lb	Amerex	2032	2026	Yes	A	Good
10	213 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
11	301 hall	ABC	10 lb	Amerex	2029	2029	Yes	A	Good
12	Inside 307	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
13	Inside 306	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
14	Inside 306 a prep room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
15	312 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
16	1101 Receiving	ABC	10 lb	Amerex	2027	2033	Yes	A	Good
17	Other locked door on receiving building	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
18	Mobile 1	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
19	Mobile 2	ABC	5 lb	Badger	2029	2029	Yes	A	Good
20	Mail room	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
21	101 a concession	ABC	5 lb	Badger	2031	2025	Yes	A	Good
22	Gym back exit	ABC	10 lb	Buckeye	2034	2028	Yes	A	Good
23	Gym front by boy's locker room	ABC	10 lb	Badger	2035	2029	Yes	A	Good
24	140 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
25	104 elevator room	ABC	10 lb	Badger	2033	2027	Yes	A	Good
26	149 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
27	409 hall	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
28	Inside 409 prep room	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
29	400 hall	ABC	10 lb	Badger	2029	2029	Yes	A	Good
30	Outside 416 (media center)	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
31	Inside 416 entrance	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
32	416 back	Water Mist		Amerex	2028		Yes	A	Good
33	416 outside 416 g (conference)	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
34	416 d (telecom)	Water Mist		Amerex	2028		Yes	A	Good
35	422 hall	ABC	10 lb	Buckeye	2031	2025	Yes	A	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-26-2024
ST JOB NUMBER	34846336
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	River Oaks Middle School 7110, 8642 River Oaks Dr North Charleston, SC, 29420
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
36	Inside 428 prep room	ABC	10 lb	Buckeye	2032	2026	Yes	A	Good
37	430 hall	ABC	10 lb	Amerex	2034	2028	Yes	A	Good
38	Kitchen	ABC	10 lb	Amerex	2027	2033	Yes	A	Good
39	Kitchen back exit	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
40	Kitchen back exit	K Class		Ansul	2028		Yes	A	Good
41	Kitchen by 1000C	ABC	10 lb	Amerex	2032	2026	Yes	A	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-20-2024
ST JOB NUMBER	34065523
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Rollings Middle School 1635 Beech Hill Rd Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	By room 2012	ABC	10 lb	Ansul	36	2030	Yes	B	Y6-year fixed
2	Gym	ABC	10 lb	Ansul	36	2030	Yes	B	6 y fixed
3	Hall by room 2017	ABC	10 lb	Amerex	36	2030	Yes	B	6-year fixed
4	Hall by room 1016	ABC	10 lb	Buckeye	30	2030	Yes	B	6-year fixed
5	Hall by room 1014	ABC	10 lb	Badger	35	2030	Yes	B	6-year fixed
6	In room 1010	ABC	10 lb	Buckeye	36	2030	Yes	B	6-year fixed
7	Hall by room 1002	ABC	10 lb	Amerex	30	2030	Yes	B	6-year fixed
8	In room 4013	ABC	10 lb	Amerex	30	2030	Yes	B	6-y fixed
9	In room 4012	ABC	10 lb	Buckeye	30	2030	Yes	B	6-year fixed
10	Hall by room 5016 storage	ABC	10 lb	Buckeye	30	2030	Yes	B	6-year fixed
11	In room 5028	ABC	10 lb	Amerex	30	2030	Yes	B	6-year fixed
12	In room 5033	ABC	10 lb	Amerex	30	2030	Yes	B	6-year fixed
13	Hall by room 5035	ABC	10 lb	Badger	30	2030	Yes	B	6-year fixed
14	Hall by room 2054	ABC	10 lb	Ansul	36	2030	Yes	B	6-year fixed
15	In room 2053	ABC	10 lb	Amerex	30	2030	Yes	B	6-year fixed
16	In room 2052 kiln	ABC	10 lb	Badger	36	2030	Yes	B	6-year
17	In room 2049	ABC	10 lb	Ansul	30	2030	Yes	B	6-year fixed
18	Hall by room 2047	ABC	10 lb	Badger	36	2030	Yes	B	6-year fixed
19	Hall by scene shop at 3051	ABC	10 lb	Buckeye	31	2025	Yes	B	Good
20	In room 3051 scene shop	ABC	10 lb	Buckeye	31	25	Yes	B	Good
21	End of scene shop hall 3039	ABC	10 lb	Buckeye	31	2025	Yes	B	Good
22	Hall by room 2036 elevator equipment	ABC	10 lb	Ansul	30	2030	Yes	B	6-year fixed
23	In room 2036 elevator equipment	ABC	5 lb	Kidde	30	2030	Yes	B	6-year fixed
24	In room 3030 elevator equipment	ABC	10 lb	Amerex	25	2025	Yes	B	Good
25	Cat walk by room 6011 electrical	ABC	10 lb	Kidde	31	2025	Yes	B	Good
26	Catwalk by room 6005	ABC	10 lb	Other	31	2025	Yes	B	Good
27	Hall by dining	ABC	10 lb	Other	30	2030	Yes	B	6-year fixed
28	Room 1014	ABC	10 lb	Other	2035	2029	Yes	A	Good
29	Room 1010	ABC	10 lb	Other	2036	2030	Yes	A	Good
30	Elevator room 2036	ABC	5 lb	Amerex	2036	2030	Yes	A	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-13-2024
ST JOB NUMBER	35111572
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Sand Hill Elementary School 324 Gnarly Oak Lane Summerville, SC, 29485
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	By 375 hallway	ABC	10 lb	Buckeye	28	28	Yes	B	Good
2	330 kitchen	K Class	2.5 gal	Amerex			Yes		Hydrotest
3	303 kitchen	ABC	10 lb	Badger	29	28	Yes	B	Good
4	303 kitchen	K Class		Other					Hydrotest
5	344. hallway	ABC	10 lb	Badger	28	28	Yes	B	Good
6	Across 322	ABC	10 lb	Badger	28	28	Yes	B	Good
7	401	ABC	10 lb	Buckeye	28	28	Yes	B	Good
8	541	ABC	10 lb	Badger	31	25	Yes	B	Good
9	556	ABC	10 lb	Badger	34	28	Yes	B	Good
10	565 2-floor	ABC	10 lb	Badger	28	28	Yes	B	Good
11	507	ABC	10 lb	Badger	28	28	Yes	B	Good
12	522	ABC	10 lb	Badger	28	28	Yes	B	Good
13	321 elevator room	ABC	10 lb	Badger	34	28	Yes	B	Good
14	302 lobby	ABC	10 lb	Ansul	28	28	Yes	B	Good
15	Media center	ABC	5 lb	Kidde	35	29	Yes	B	Good
16	311 by lobby	ABC	10 lb	Badger	29	28	Yes	B	Good
17	314 kil room	ABC	10 lb	Buckeye	28	28	Yes	B	Good
18	313	ABC	10 lb	Amerex	28	28	Yes	B	Good
19	hallway 202	ABC	10 lb	Amerex	28	28	Yes	B	Good
20	213	ABC	10 lb	Amerex	27	28	Yes	B	Good
21	101 hallway	ABC	10 lb	Amerex	34	28	Yes	B	Good
22	102	ABC	10 lb	Buckeye	34	28	Yes	B	Good
23	105	ABC	10 lb	Other	28	28	Yes	B	Good
24	120	ABC	10 lb	Buckeye	28	28	Yes	B	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-26-2024
ST JOB NUMBER	35112041
TECHNICIAN	Erryl Porter
CUSTOMER LOCATION	Spann Elementary School 901 John McKissick Way Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Office	ABC	10 lb		2033	2027	Yes	B	
2	In 101 Clinic	ABC	10 lb		2025	2031	Yes	B	
3	In 502 by Art storage	ABC	5 lb		2025	2031	Yes	B	
4	Cafeteria	ABC	10 lb		2030	2036	Yes	B	6yr completed
5	Cafeteria by stage	ABC	10 lb		2030	2036	Yes	B	6yr completed
6	Kitchen	K Class	2.5 gal		2028		Yes	B	
7	Kitchen	ABC	5 lb		2025	2031	Yes	B	
8	By 201	ABC	10 lb		2031	2025	Yes	B	
9	By 208	ABC	10 lb		2036	2030	Yes	B	Hydro completed
10	In 106	Water Mist	6 lit		2028		Yes	B	
11	In 107	ABC	5 lb		2031	2025	Yes	B	
12	Exit by 107	ABC	10 lb		2025	2031	Yes	B	
13	By 117	ABC	10 lb		2025	2031	Yes	B	
14	Outside the building maintenance/electrical room	ABC	5 lb		2036	2030	Yes	B	Hydro completed
15	Outside the building maintenance/electrical	ABC	5 lb		2036	2030	Yes	B	Hydro completed
16	Outside the building maintenance/electrical	ABC	10 lb		2036	2030	Yes	B	Hydro completed
17	Outside the building maintenance/electrical	ABC	10 lb		2036	2030	Yes	B	Hydro completed
18	Media Center	ABC	10 lb		2030	2036	Yes	B	6yr completed
19	Media Center	ABC	10 lb		2031	2025	Yes	B	
20	Gym	ABC	10 lb		2035	2029	Yes	B	
21	Gym	ABC	10 lb		2035	2029	Yes	B	
22	By 312	ABC	10 lb		2036	2030	Yes	B	Hydro completed
23	In electrical room by 303	ABC	5 lb		2036	2030	Yes	B	Hydro completed
24	By 302	ABC	10 lb		2025	2031	Yes	B	
25	In 401	ABC	5 lb		2031	2025	Yes	B	
26	In 402	ABC	5 lb		2031	2025	Yes	B	
27	In 403	ABC	5 lb		2031	2025	Yes	B	
28	In 404	ABC	5 lb		2031	2025	Yes	B	
29	Outside electrical room by 404	ABC	10 lb		2031	2025	Yes	B	
30	Exit by 405	ABC	10 lb		2025	2031	Yes	B	
31	In 501	Water Mist	6 lit		2028		Yes	B	
32	By 504	ABC	10 lb		2025	2031	Yes	B	
33	By 510	ABC	10 lb		2025	2031	Yes	B	
34	In 312	ABC	5 lb		2036	2030	Yes	B	Hydro completed
35	Trailer 1	ABC	10 lb		2031	2025	Yes	B	

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-26-2024
ST JOB NUMBER	35112041
TECHNICIAN	Erryl Porter
CUSTOMER LOCATION	Spann Elementary School 901 John McKissick Way Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
36	Trailer 2	ABC	10 lb		2031	2025	Yes	B	
37	Trailer 3	ABC	10 lb		2031	2025	Yes	B	
38	Trailer 10	ABC	5 lb		2030	2036	Yes	B	6yr completed
39	Trailer 11	ABC	5 lb		2035	2029	Yes	B	
40	Trailer 12	ABC	10 lb		2031	2025	Yes	B	
41	Trailer 13	ABC	5 lb		2025	2031	Yes	B	
42	Trailer 14	ABC	5 lb		2030	2036	Yes	B	6yr completed
43	Trailer 9	ABC	5 lb	Amerex	2030	2036	Yes	B	6yr completed
44	Trailer 8	ABC	5 lb		2030	2036	Yes	B	6yr completed
45	White house in rear parking lot	ABC	10 lb		2033	2027	Yes	B	
46	Family Engagement Center in rear parking lot	ABC	5 lb		2036	2030	Yes	B	Hydro completed
47	212 Special Services	ABC	5 lb		2029	2035	Yes	B	
48	801 Office of School Nutrition	ABC	10 lb		2035	2029	Yes	B	
49	House down street across from school	ABC	5 lb		2025	2031	Yes	B	

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-26-2024
ST JOB NUMBER	34846324
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Summerville Elementary School 835 S Main St Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	203	ABC	10 lb	Ansul	2036	2030	Yes	B	Hydrotest fixed
2	206 kidergarten	ABC	10 lb	Badger	2036	2030	Yes	B	Hydrotest fixed
3	Library exit	ABC	10 lb	Badger	2036	2030	Yes	B	6-year fixed
4	94	ABC	5 lb	Amerex	2036	2030	Yes	B	Good
5	112	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
6	118	ABC	10 lb	Amerex	2031	25	Yes	B	Good
7	96	ABC	10 lb	Buckeye	2026	2026	Yes	B	Good
8	99	ABC	5 lb	Badger	2025	2025	Yes	B	Good
9	100	ABC	5 lb	Badger	2030	2030	Yes	B	6-year fixed
10	Water fountain	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
11	212	ABC	5 lb	Amerex	25	25	Yes	A	Good
12	Mechanical room214	K Class	6 lit	Badger	2029	0	Yes	B	Hydrotest fixed
13	300	ABC	10 lb	Amerex	31	25	Yes	A	Good
14	307a	ABC	5 lb	Kidde	31	30	Yes	B	6-year fixed
15	313	ABC	5 lb	Buckeye	25	25	Yes	B	Good
16	Cafeteria	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
17	Cafeteria by restroom	ABC	10 lb	Badger	36	30	Yes	B	Hydrotest fixed
18	Kitchen	K Class	6 lit	Badger	28	0	Yes	B	Good
19	Kitchen	K Class	6 lit	Badger	26	0	Yes	B	Good
20	Extend day	ABC	5 lb	Amerex	34	28	Yes	A	Good
21	Gym	ABC	10 lb	Amerex	26	26	Yes	B	Good
22	Gym	ABC	10 lb	Amerex	2026	2026	Yes	B	Good
23	Marcia o' Brian	BC	10 lb	Amerex	31	25	Yes	B	Good
24	Tool shed	ABC	10 lb	Ansul	35	2029	Yes	A	Good
25	Spare	ABC	10 lb	Ansul	36	2030	Yes	B	Good
26	214	ABC	10 lb	Ansul	35	2029	Yes	B	Good
27	Spare	ABC	10 lb	Other	36	2030	Yes	B	Good
28	Spare	ABC	10 lb	Other	30	2030	Yes	B	6-year fixed
29	Spare	ABC	5 lb	Ansul	30	2030	Yes	B	Hydrotest fixed
30	Spare	ABC	5 lb	Other	26	2030	Yes	B	6-year fixed
31	In room 216	ABC	5 lb	Other	2025	25	Yes	B	Good
32	217extended day !	ABC	10 lb	Amerex	30	30	Yes	B	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-18-2024
ST JOB NUMBER	34065531
TECHNICIAN	James President
CUSTOMER LOCATION	Summerville High School 1101 Boone Hill Road Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Old weight room	ABC	10 lb	Buckeye	2031	2025	Yes	B	Good
2	Maintenance	ABC	10 lb	Badger	2027	2033	Yes	B	Good
3	Maintenance	ABC	5 lb	Badger	2032	2026	Yes	B	Good
4	Maintenance	ABC	10 lb	Badger	2033	2027	Yes	B	Recharge done
5	Athletic hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
6	Training room	ABC	5 lb	Amerex	2031	2025	Yes	B	Good
7	Kate 1 hall men room	ABC	10 lb	Badger	2035	2029	Yes	B	Good
8	Kate 1 exit 104	ABC	10 lb	Badger	2035	2029	Yes	B	Good
9	Kate 1 pastry kitchen	K Class	2.5 gal	Buckeye	2028	2033	Yes	B	Good
10	Kate l pastry's by exit	K Class	2.5 gal	Buckeye	2024	2029	Yes	B	Hydro
11	Kate 1 culinary kitchen by sink	K Class	2.5 gal	Amerex	2027	2032	Yes	B	Good
12	Kate 1 culinary by sink	ABC	10 lb	Other	2035	2029	Yes	A	Good
13	Kate1 culinary kitchen by electric panel	K Class	2.5 gal	Amerex	2027	2032	Yes	B	Good
14	Kate 1 exit by 128	ABC	5 lb	Buckeye	2030	2024	Yes	D	Six years done
15	Kate 1 by 502;hall	ABC	10 lb	Badger	2035	2029	Yes	B	Good
16	Kate 1 by electric panel	ABC	10 lb	Badger	2035	2029	Yes	B	Good
17	184 hall	ABC	10 lb	Badger	2025	2031	Yes	B	Good
18	177 hall	ABC	10 lb	Badger	2025	2031	Yes	B	Good
19	170 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
20	Inside 168	ABC	10 lb	Badger	2025	2031	Yes	B	Good
21	Trailer of books	ABC	10 lb	Amerex	2027	2033	Yes	B	Good
22	Inside 166	ABC	10 lb	Badger	2030	2024	Yes	D	Six years
23	Inside 163	Purple-K	5 lb	Badger	2025	2031	Yes	B	Good
24	163 hall	ABC	10 lb	Amerex	2026	2032	Yes	B	Good
25	159 hall	ABC	10 lb	Amerex	2027	2033	Yes	B	Good
26	265 hall	ABC	10 lb	Other	2025	2031	Yes	B	Good
27	264 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
28	Inside 136	ABC	10 lb	Badger	2026	2032	Yes	B	Good
29	138 hall	ABC	10 lb	Badger	2027	2033	Yes	B	Good
30	146 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
31	149 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
32	155 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
33	158 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
34	Career and technology 626	ABC	10 lb	Buckeye	2035	2029	Yes	D	Six years done
35	Career and technology inside 602	ABC	10 lb	Buckeye	2031	2025	Yes	A	Good
36	Career and technology inside 604	ABC	10 lb	Buckeye	2035	2029	Yes	B	Good
37	Career and technology inside 607	ABC	5 lb	Amerex	2035	2029	Yes	B	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-18-2024
ST JOB NUMBER	34065531
TECHNICIAN	James President
CUSTOMER LOCATION	Summerville High School 1101 Boone Hill Road Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
38	Career and technology 629 hall	ABC	10 lb	Badger	2036	2030	Yes	D	Six years done
39	Career and technology 630 hall	ABC	10 lb	Kidde	2036	2030	Yes	D	Six years done
40	Career and technology inside 614	ABC	5 lb	Kidde	2036	2030	Yes	D	Six years done
41	Career and technology 611 intersection hall	ABC	10 lb	Badger	2036	2030	Yes	D	Six years done
42	Career and technology inside 610	ABC	10 lb	Buckeye	2036	2030	Yes	D	Six years done
43	Career and technology inside 612	ABC	10 lb	Kidde	2031	2025	Yes	B	Good
44	JV BUILDING EQUIPMENT ROOM	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
45	ROTC HALL	ABC	10 lb	Buckeye	2036	2030	Yes	D	Six years done
46	103 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
47	Kitchen by BLODGETT HEATER	ABC	10 lb	Badger	2025	2031	Yes	B	Good
48	Kitchen by restroom	K Class	2.5 gal	Buckeye	2028	2033	Yes	B	Good
49	Kitchen by Coca Cola	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
50	Kitchen by Coca Cola	K Class	2.5 gal	Buckeye	2028	2033	Yes	B	Good
51	Cafeteria	ABC	10 lb	Buckeye	2031	2025	Yes	B	Good
52	Cafeteria by stage	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
53	Corridor by cafeteria	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
54	Auditorium right entrance	ABC	10 lb	Amerex	2026	2032	Yes	B	Good
55	Auditorium adjacent entrance	ABC	10 lb	Amerex	2032	2026	Yes	B	Good
56	Stage left	ABC	10 lb	Amerex	2035	2029	Yes	B	Good
57	Stage right	ABC	10 lb	Buckeye	2031	2025	Yes	B	Good
58	Auditorium dance studio hall	ABC	10 lb	Badger	2030	2024	Yes	D	Six years done
59	Band hall between restroom	ABC	10 lb	Amerex	2032	2026	Yes	B	Good
60	Band room inside	ABC	10 lb	Buckeye	2026	2032	Yes	B	Good
61	Choral hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
62	123 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
63	120 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
64	Inside 117	ABC	10 lb	Other	2025	2031	Yes	B	Good
65	Inside 115	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
66	115 hallelujah	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
67	Prep 115A back	ABC	10 lb	Badger	2030	2024	Yes	D	Six years done
68	Inside 113	ABC	10 lb	Badger	2025	2031	Yes	B	Good
69	Inside 111	ABC	10 lb	Badger	2025	2031	Yes	B	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-18-2024
ST JOB NUMBER	34065531
TECHNICIAN	James President
CUSTOMER LOCATION	Summerville High School 1101 Boone Hill Road Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
70	109 hall	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
71	Inside 109	ABC	10 lb	Badger	2025	2031	Yes	B	Good
72	Inside 109A prep room	ABC	10 lb	Badger	2025	2031	Yes	B	Good
73	Inside 107	ABC	10 lb	Badger	2025	2031	Yes	B	Good
74	Inside 105	ABC	10 lb	Badger	2025	2031	Yes	B	Good
75	103 hall	ABC	10 lb	Amerex	2025	2031	Yes	B	Good
76	Inside 103	ABC	10 lb	Badger	2025	2031	Yes	B	Good
77	Inside 103A prep	ABC	10 lb	Badger	2025	2031	Yes	B	Good
78	Inside 101	ABC	10 lb	Badger	2025	2031	Yes	B	Good
79	134 hall	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
80	Elevator mechanics room	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
81	Concession by canteen	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
82	Mini gym by restroom	ABC	10 lb	Badger	2025	2031	Yes	B	Good
83	Mini gym	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
84	Mini gym	ABC	10 lb	Buckeye	2032	2026	Yes	B	Good
85	Mini gym	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
86	Mini gym	ABC	5 lb	Badger	2030	2024	Yes	D	Six years done
87	Mini gym	ABC	5 lb	Badger	2031	2025	Yes	B	Good
88	Big gym	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
89	Big gym	ABC	10 lb	Amerex	2032	2026	Yes	B	Good
90	Big gym	ABC	10 lb	Badger	2033	2027	Yes	B	Good
91	Media center	ABC	10 lb	Other	2026	2032	Yes	B	Good
92	Media center corner	ABC	10 lb	Amerex	2032	2026	Yes	B	Good
93	265 hallways	ABC	10 lb	Badger	2025	2031	Yes	B	Good
94	264 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
95	259 hall	ABC	10 lb	Badger	2035	2029	Yes	B	Good
96	254B hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
97	245 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
98	253 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
99	Inside 217	ABC	5 lb	Buckeye	2026	2032		B	Good
100	Inside 215	ABC	10 lb	Badger	2025	2031	Yes	B	Good
101	215 prep	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
102	215 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
103	Inside 213	ABC	10 lb	Badger	2025	2031	Yes	B	Good
104	Inside 211	ABC	10 lb	Badger	2025	2031	Yes	B	Good
105	209 hall	ABC	10 lb	Badger	2033	2027	Yes	B	Good
106	Inside 209	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
107	Inside 209 prep	ABC	10 lb	Badger	2033	2027	Yes	B	Good
108	Inside 207	ABC	10 lb	Badger	2025	2031	Yes	B	Good
109	Inside 205	ABC	10 lb	Badger	2025	2031	Yes	B	Good
110	203 hall	ABC	10 lb	Amerex	2033	2027	Yes	B	Good
111	Inside 203	ABC	10 lb	Badger	2025	2031	Yes	B	Good
112	Inside 203 prep	ABC	10 lb	Ansul	2025	2031	Yes	B	Good

Liberty Fire Protection, Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-18-2024
ST JOB NUMBER	34065531
TECHNICIAN	James President
CUSTOMER LOCATION	Summerville High School 1101 Boone Hill Road Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
113	Inside 201	ABC	10 lb	Badger	2030	2024	Yes	D	Six years
114	Inside 220 by door	ABC	10 lb	Badger	2025	2031	Yes	B	Good
115	Inside 220 by air vent	ABC	10 lb	Buckeye	2025	2031	Yes	B	Good
116	Inside 222 by door	ABC	10 lb	Badger	2035	2029	Yes	B	Good
117	Inside 222 by air vent	ABC	10 lb	Buckeye	2029	2035	Yes	B	Good
118	222 hall	ABC	10 lb	Buckeye	2029	2035	Yes	B	Good
119	Inside 224 by exit	ABC	10 lb	Badger	2025	2031	Yes	B	Good
120	Inside 224 vent	ABC	10 lb	Amerex	2027	2033	Yes	B	Six years done
121	Inside 226 by exit	ABC	10 lb	Other	2033	2027	Yes	B	Good
122	Inside 226 by vent	ABC	10 lb	Badger	2025	2031	Yes	B	Good
123	Inside 228 exit	ABC	10 lb	Other	2025	2031	Yes	B	Good
124	Inside 228 by vent	ABC	10 lb	Badger	2025	2031	Yes	B	Good
125	Inside 229 exit	ABC	10 lb	Badger	2025	2031	Yes	B	Good
126	Inside 229 by air vent	ABC	10 lb	Badger	2025	2031	Yes	B	Good
127	229 hall	ABC	10 lb	Amerex	2025	2031	Yes	B	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-14-2024
ST JOB NUMBER	34846301
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Reeves Elementary School 1003 Dubose School Rd Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	Spare	ABC	10 lb	Kidde	2025	2025	Yes	A	Good
2	Spare	ABC	5 lb	Badger	2030	2030	Yes	A	Good
3	T14	ABC	5 lb	Buckeye	2032	2026	Yes	A	Good
4	T13	ABC	5 lb	Badger	2030	2030	Yes	A	Due hydro done
5	T12	ABC	5 lb	Buckeye	2026	2026	Yes	A	Good
6	T11	ABC	5 lb	Buckeye	2026	2026	Yes	A	Good
7	T10	ABC	5 lb	Buckeye	2036	2030	Yes	A	Due hydro done
8	T9	ABC	5 lb	Other	2028	2030	Yes	A	Due hydro done
9	T8	ABC	5 lb	Buckeye	2032	2026	Yes	A	Good
10	T7	ABC	5 lb	Buckeye	2032	2026	Yes	A	Good
11	T5	ABC	5 lb	Amerex	2031	2025	Yes	A	Good
12	T6	ABC	5 lb	Buckeye	2032	2026	Yes	A	Good
13	T4	ABC	5 lb	Buckeye	2032	2026	Yes	A	Good
14	T3	ABC	5 lb	Buckeye	2031	2025	Yes	A	Good
15	T1	ABC	5 lb	Other	2036	2030	Yes	A	Due hydro done
16	T2	ABC	5 lb	Other	2036	2030	Yes	A	Due hydro done
17	B12	ABC	5 lb	Amerex	2030	2030	Yes	A	Due hydro done
18	Music room	ABC	10 lb	Badger	2032	2026	Yes	A	Good
19	Bo8	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
20	Library	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
21	Front office	ABC	10 lb	Buckeye	2028	2028	Yes	A	Good
22	Staff only	ABC	10 lb	Amerex	2034	2028	Yes	A	Good
23	Cd2	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
24	Cd1	ABC	5 lb	Amerex	2035	2029	Yes	A	Good
25	5-b hallway	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
26	5-b computer lab	ABC	10 lb	Badger	2032	2026	Yes	A	Good
27	C07	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
28	Hallway teachers work room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
29	C-29	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
30	D23	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
31	D102	ABC	10 lb	Amerex	2031	2025	Yes	B	Good
32	E5	ABC	10 lb	Badger	2032	2026	Yes	A	Good
33	Teachers work room	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
34	E13	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
35	E104	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
36	Central supply	ABC	10 lb	Badger	2028	2028	Yes	A	Good
37	F03	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
38	Cafeteria	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
39	Cafeteria	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
40	Kitchen serving line	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
41	Kitchen	K Class		Buckeye	2027		Yes	B	Good
42	Kitchen	ABC	10 lb	Amerex	2030	2030	Yes	A	Due 6 years done

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-14-2024
ST JOB NUMBER	34846301
TECHNICIAN	Chavis Gethers
CUSTOMER LOCATION	Reeves Elementary School 1003 Dubose School Rd Summerville, SC, 29483
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
43	Multiple purpose	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
44	Multiple purpose	ABC	10 lb	Amerex	2031	2025	Yes	A	Good
45	Stage	ABC	10 lb	Kidde	2032	2026	Yes	A	Good
46	Water heater	ABC	10 lb	Badger	2033	2027	Yes	A	Good
47	Main electric room	ABC	10 lb	Ansul	2031	2025	Yes	A	Good
48	Maintenance building	ABC	10 lb	Amerex	2031	2025	Yes	A	Good

Liberty Fire Protection Inc.
A Marmic Fire & Safety® Company
7214 Peppermill Parkway
North Charleston, SC 29418

DATE	06-24-2024
ST JOB NUMBER	34846335
TECHNICIAN	Keith Swafford
CUSTOMER LOCATION	Windsor Hill Arts Infused Elementary 8600 William Moultrie Dr North Charleston, SC, 29420
FREQUENCY	Annual

Portable Fire Extinguisher Inspection Report

#	Location	Type	Size	Brand	Next Hydro	Next 6-Year	Inspected?	Class	Comment
1	9	ABC	5 lb	Amerex	33	27	Yes	B	Good
2	10	ABC	5 lb	Other	33	27	Yes	B	Good
3	8	ABC	5 lb	Amerex	33	27	Yes	B	Good
4	7	ABC	5 lb	Amerex	31	25	Yes	B	Good
5	5	ABC	5 lb	Amerex	25	25	Yes	B	Good
6	24	K Class	6 lit	Badger	25	0	Yes	B	Good
7	4	ABC	5 lb	Badger	25	25	Yes	B	Good
8	1	ABC	10 lb	Amerex	34	28	Yes	B	Good
9	2	BC	10 lb	Amerex	25	25	Yes	B	Good
10	3	ABC	10 lb	Buckeye	32	26	Yes	B	Good
11	6	ABC	5 lb	Kidde	30	30	Yes	B	Hydrotest fixed
12	18	ABC	5 lb	Badger	36	30	Yes	B	Hydrotest fixed
13	19	ABC	5 lb	Buckeye	26	26	Yes	B	Good
14	20	ABC	10 lb	Buckeye	26	26	Yes	B	Good
15	21	ABC	5 lb	Buckeye	35	29	Yes	B	Hydrotest
16	22	ABC	5 lb	Badger	31	25	Yes	B	Good
17	23	ABC	5 lb	Badger	36	30	Yes	B	Hydrotest fixed
18	17	ABC	5 lb	Ansul	30	30	Yes	B	Good
19	16	BC	10 lb	Badger	25	25	Yes	B	Good
20	15	ABC	5 lb	Other	33	27	Yes	B	Good
21	14	ABC	5 lb	Buckeye	33	27	Yes	B	Good
22	13	ABC	10 lb	Badger	33	27	Yes	B	Good
23	12	ABC	10 lb	Amerex	33	27	Yes	B	Good
24	11	ABC	5 lb	Amerex	28	25	Yes	B	Good