



**PEQUANNOCK TOWNSHIP SCHOOL
DISTRICT**

**LEAD IN DRINKING WATER
SAMPLING REPORT**

PERFORMED FOR:

**PEQUANNOCK TOWNSHIP SCHOOL DISTRICT
85 SUNSET ROAD
PEQUANNOCK, NJ 07444**

PERFORMED BY:

**WESTCHESTER ENVIRONMENTAL LLC
1248 WRIGHTS LANE
WEST CHESTER, PA 19380**

DECEMBER 2024



December 31, 2024

Mr. Dwight Anderson
Pequannock Township School District
85 Sunset Road
Pequannock, NJ 07444

Re: LEAD IN DRINKING WATER REPORT

Dear Mr. Anderson,

Please find enclosed the lead in drinking water sampling report for the 2024-2025 school year conducted at the Pequannock Township School District.

The first draw sample in the Nurse's Office at the Pequannock Township High School exceeded the action limit of 15.5 ug/L.

Thank you for giving us the opportunity to be of service. Please do not hesitate to contact us at 610-431-7545 or email cpiccininni@westchesterenvironmental.com or info@westchesterenvironmental.com.

Sincerely,

Westchester Environmental, LLC

A handwritten signature in black ink, appearing to read 'Christopher Piccininni', is written over a light blue horizontal line.

Christopher Piccininni
Environmental Specialist



TABLE OF CONTENTS

PEQUANNOCK TOWNSHIP SCHOOL DISTRICT

1.0	EXECUTIVE SUMMARY	2
2.0	INTRODUCTION	3
3.0	SAMPLING AND ANALYSES	4
4.0	SAMPLE RESULTS.....	5
5.0	DISCUSSION & RECOMMENDATIONS.....	8
6.0	DISCLAIMER	10



1.0 EXECUTIVE SUMMARY

Westchester Environmental, LLC (WCE) was contracted by Dwight Anderson of the Pequannock Township School District to conduct lead in water testing for the school district for the 2024-2025 school year.

The water sampling was performed on November 23, 2024 by Christopher Piccininni of Westchester Environmental, LLC.

The objective of the sampling was to determine the lead in water levels associated with the various buildings across the district. During this visit, first draw and flush drinking water samples were collected at predetermined locations in the following buildings:

1. Pequannock Township High School – 86 Sunset Road, Pequannock
2. Pequannock Valley Middle School – 493 Newark Pompton Turnpike, Pompton Plains
3. Hillview Elementary School – 206 Boulevard, Pompton Plains
4. North Boulevard Elementary School – 363 Boulevard, Pompton Plains
5. Stephen J. Grave Elementary School – 59 Boulevard, Pompton Plains

The first draw sample, collected on the first floor in the nurse's room at the Pequannock Township High School, exceeded the lead action level of 15.5 microgram/liter (ug/L) or 15.5 parts per billion (ppb), based on the analysis of lead content using U.S. Environmental Protection Agency (EPA) Method 200.8 for lead in drinking water.

Immediate / Short Term Action Required:

Immediately discontinue using water at the above location. If this location is going to be remediated for future use, it will need to be re-tested prior to being put in service to make sure the remedial work was successful.

-END OF SECTION-



2.0 INTRODUCTION

The objective of the sampling was to determine the lead in water levels from drinking water outlets located within the school district. The sampling was conducted in five different buildings. During this visit, first draw and flush drinking water samples were collected.

Lead in school drinking water continues to be a serious concern, with children in many schools potentially drinking water with dangerous levels of lead. Even when water entering a facility meets all federal and state public health standards for lead concentrations, older plumbing materials found in schools can contribute to elevated lead levels in the drinking water.

The New Jersey Department of Environmental Protection's (NJDEP) action level for lead in drinking water is set at 15. However, for the purposes of compliance, any concentration greater than 15 µg/L (as defined as greater than or equal to 15.5 µg/L) is considered to exceed the lead action level. If sampling exceeds the level, then the action will need to be taken.

The Environmental Protection Agency (EPA) itself states that 15 ug/L is not a health-based standard, but rather based on what is feasible for water systems to achieve. According to the EPA, given present technology and resources, this level is the lowest level to which water systems can reasonably be required to control this contaminant should it be present in drinking water.

On October 8, 2024, the EPA announced the finalization of key improvements to the Lead and Copper Rule (LCR), which introduces new regulations that will reshape how public water suppliers manage lead service lines. These changes are critical to protecting public health and will become effective in late 2027, three years after their publication.

One of the most significant changes is the reduction of the lead action level to 10 ug/L. Water systems that exceed this threshold must take immediate corrective actions, including notifying the public, implementing corrosion control treatments, and expediting lead service line replacement.

-END OF SECTION-



3.0 SAMPLING AND ANALYSES

During this sampling event, five point of entry samples, thirty-five first draw samples, thirty-four flush samples and one field blank were collected.

All the collected samples were labeled with a unique identification number and transported to Suburban Laboratory for analysis of lead in drinking water using EPA Method 200.8. Suburban Testing Labs located at 1037F MacArthur Rd, Reading, PA 19605, is a NJ certified Lead in Drinking Water testing facility.

The following guidance documents were followed for sampling:

1. New Jersey Department of Education N.J.A.C. 6A:26
2. The USEPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water as well as the Safe Drinking Water Act of 1974".

-END OF SECTION-



4.0 SAMPLE RESULTS

The tables below show the first draw concentrations of lead (microgram per liter) at sampled locations. The NJDEP establishes 15.5 ug/L as the lead action limit.

Table 1: Hillview Elementary School

Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
1 PHE-1FL-POE-Boiler Room-F	<1.00	15.5	No
2 PHE-1FL-BF-O/S Nurse Office	<1.00	15.5	No
3 PHE-1FL-NS-Nurse Office	4.18	15.5	No

Table 2: Stephen J. Gerace Elementary School

Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
4 PSJG-1FL-POE-Boiler Room-F	<1.00	15.5	No
5 PSJG-1FL-NS-Nurse	<1.00	15.5	No
6 PSJG-1FL-BF-Near Elevator	<1.00	15.5	No
7 PSJG-2FL-BF-O/S Room 211	<1.00	15.5	No
8 PSJG-1FL-S-Faculty Room	1.53	15.5	No

Table 3: North Boulevard Elementary School

Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
9 PNBE-1FL-SPOE-Electrical Room-F	1.24	15.5	No
10 PNBE-1FL-DW-O/S Media Room 2	<1.00	15.5	No
11 PNBE-1FL-NS-Nurse Office	2.68	15.5	No
12 PNBE-1FL-BF-O/S Gym	<1.00	15.5	No
13 PNBE-1FL-FS-Faculty Sink	2.06	15.5	No

Table 4: Pequannock Valley Middle School

Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
14 PVMS-1FL-POE-O/S Boiler Rm-F	<1.00	15.5	No
15 PVMS-1FL-NS-Nurse Office	1.88	15.5	No
16 PVMS-1FL-BG-O/S Media Center Stairwell	<1.00	15.5	No
17 PVMS-1FL-BF-O/S Boys RR	<1.00	15.5	No



	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
18	PVMS-1FL-FP-Kitchen-1	4.18	15.5	No
19	PVMS-1FL-FP-Kitchen-2	2.43	15.5	No
20	PVMS-1FL-FP-Kitchen-3	2.16	15.5	No
21	PVMS-1FL-BF-O/S Kitchen	<1.00	15.5	No
22	PVMS-1FL-DW-Girls Locker Room	11.5	15.5	No
23	PVMS-1FL-BF-O/S Rm 135	<1.00	15.5	No
24	PVMS-2FL-BF-O/S Boys Room	<1.00	15.5	No
25	PVMS-2FL-BF-O/S Rm 202	<1.00	15.5	No

Table 5: Pequannock Township High School

	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
26	PHS-1FL-SPOE-District Shop-F	2.04	15.5	No
27	PHS-1FL-WC-Gym-2	<1.00	15.5	No
28	PHS-1FL-IM-Trainers Rm	<1.00	15.5	No
29	PHS-1FL-HB-O/S Trainer Rm	2.55	15.5	No
30	PHS-1FL-FP-Kitchen-1	<1.00	15.5	No
31	PHS-1FL-FP-Kitchen-2	<1.00	15.5	No
32	PHS-1FL-FP-Kitchen-3	9.02	15.5	No
33	PHS-1FL-FP-Kitchen-4	<1.00	15.5	No
34	PHS-1FL-FP-Kitchen-5	<1.00	15.5	No
35	PHS-1FL-NS-Nurse Office	16.1	15.5	Yes
36	PHS-1FL-NS-Nurse Bathroom	4.05	15.5	No
37	PHS-1FL-BF-O/S Rm 507	<1.00	15.5	No
38	PHS-1FL-S-Room 507	1.96	15.5	No
39	PHS-1FL-BF-O/S Library	<1.00	15.5	No
40	PHS-1FL-BF-O/S Main Entrance	<1.00	15.5	No
41	Field Blank	<1.00	15.5	No



The table below shows the corresponding flush sample analyzed for the first draw that exceeded the action limit during the post remediation sampling.

Table 6: Pequannock Township High School Flush Draw

Building	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
1 Pequannock Township High School	PHS-1FL-NS-Nurse Office-F	8.07	15.5	No

-END OF SECTION

5.0 DISCUSSION & RECOMMENDATIONS

Lead can enter water when plumbing materials corrode, especially if the water is acidic or has low mineral content. Lead pipes, faucets, and fixtures are the most common sources of lead in drinking water.

The Safe Drinking Water Act requires the EPA to determine the level of contaminants in drinking water at which no adverse health effects are likely to occur with an adequate margin of safety. These non-enforceable health goals, based solely on possible health risks, are called maximum contaminant level goals (MCLGs). The EPA has set the maximum contaminant level goal for lead in drinking water at zero because lead is a toxic metal that can be harmful to human health even at low exposure levels. Lead is persistent, and it can bioaccumulate in the body over time.

The lead content in the samples collected was analyzed using U.S. Environmental Protection Agency (EPA) Method 200.8 for lead in drinking water.

The first draw and the corresponding flush sample that exceeded the action limit of 15.5 ug/L, are shown in the tables below:

Lead Water Exceedances:

First Draw

Building	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
1 Pequannock Township High School	PHS-1FL-NS-Nurse Office	16.1	15.5	Yes

Flush Draw

Building	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
1 Pequannock Township High School	PHS-1FL-NS-Nurse Office-F	8.07	15.5	No

Action Required:

1. Immediately discontinue using water at the above location that exceeded the NJDEP 15.5 ug/L Action Level.
2. Refer to EPA's "**3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities**" for other short term and long term suggested remediation measures and notification procedures.



3. Schedule a sampling after the point is remediated. A new first and flush sample will then be collected to determine the success or failure of the chosen remediation. If the point is decommissioned permanently, then there is no need for follow-up sampling.

-END OF SECTION-



6.0 DISCLAIMER

The type of samples collected for this assessment are referred to as grab samples. Grab samples are individual discrete samples collected at a specific time and location.

No guarantee or warranty of the findings and conclusions is implied within the intent of this report. It is limited to only those items listed in the report and is a snapshot of the conditions existing at the time of the assessment as conditions may vary with time.

WCE assumes no liability with regards to decisions made or the use of any information contained in this report, which is prepared exclusively for and is confidential to the above noted client. These services are designed to provide an analytical tool to assist the client, and the user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC

A handwritten signature in black ink, appearing to read 'Christopher Piccininni'.

Christopher Piccininni
Environmental Specialist

-END OF REPORT-

APPENDIX I

**LEAD IN DRINKING WATER SAMPLING
CHAINS-OF-CUSTODY & LAB REPORTS**



SUBURBAN TESTING LABS

Results Report

Order ID: 4K05350

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: Pequannock Township SD
85 Sunset Rd.
Pequannock, NJ 07444

Attn: Christopher Piccininni

Regulatory ID:

Sample Number: 4K05350-01	Site: PHE-1FL-POE-Boiler Room-F	Sample ID: Flush 001
Collector: CMP	Collect Date: 11/23/2024 9:28 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	12/16/24	RPV	12/16/24 17:20	RPV
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K05350-02	Site: PHE-1FL-BF-O/S Nurse Office	Sample ID: First 002
Collector: CMP	Collect Date: 11/23/2024 9:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	C4	µg/L	EPA 200.8	1.00	1	12/06/24	NDK	12/06/24 21:22	MKS
------	--------	----	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 4K05350-03	Site: PHE-1FL-NS-Nurse Office	Sample ID: First 003
Collector: CMP	Collect Date: 11/23/2024 9:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	4.18		µg/L	EPA 200.8	1.00	1	12/06/24	NDK	12/06/24 19:16	MKS
------	------	--	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 4K05350-04	Site: PSJG-1FL-POE-Boiler Room-F	Sample ID: Flush 004
Collector: CMP	Collect Date: 11/23/2024 9:04 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00		µg/L	EPA 200.8	1.00	1	12/16/24	RPV	12/16/24 17:23	RPV
------	--------	--	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 4K05350-05	Site: PSJG-1FL-NS-Nurse	Sample ID: First 005
Collector: CMP	Collect Date: 11/23/2024 9:08 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	C4	µg/L	EPA 200.8	1.00	1	12/06/24	NDK	12/06/24 21:24	MKS
------	--------	----	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 12/17/2024 7:32 pm 4K05350
 STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 4K05350-06 Site: PSJG-1FL-BF-Near Elevator Sample ID: First 006
 Collector: CMP Collect Date: 11/23/2024 9:10 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 C4 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 21:26 MKS

Sample Number: 4K05350-07 Site: PSJG-2FL-BF-O/S Room 211 Sample ID: First 007
 Collector: CMP Collect Date: 11/23/2024 9:12 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 C4 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 21:28 MKS

Sample Number: 4K05350-08 Site: PSJG-1FL-S-Faculty Room Sample ID: First 008
 Collector: CMP Collect Date: 11/23/2024 9:14 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 1.53 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/08/24 17:07 MKS

Sample Number: 4K05350-09 Site: PNBE-1FL-SPOE-Electrical Room-F Sample ID: Flush 009
 Collector: CMP Collect Date: 11/23/2024 9:20 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 1.24 µg/L EPA 200.8 1.00 1 12/16/24 RPV 12/16/24 17:27 RPV

Sample Number: 4K05350-10 Site: PNBE-1FL-DW-O/S Media Room 2 Sample ID: First 010
 Collector: CMP Collect Date: 11/23/2024 9:24 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 C4 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 21:32 MKS

Sample Number: 4K05350-11 Site: PNBE-1FL-NS-Nurse Office Sample ID: First 011
 Collector: CMP Collect Date: 11/23/2024 9:26 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 2.68 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/08/24 16:45 MKS

Sample Number: 4K05350-12 Site: PNBE-1FL-BF-O/S Gym Sample ID: First 012
 Collector: CMP Collect Date: 11/23/2024 9:28 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 C4 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 21:36 MKS

Report Generated On: 12/17/2024 7:32 pm 4K05350
 STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
 NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 4K05350-13 Site: PNBE-1FL-FS-Faculty Sink Sample ID: First 013
 Collector: CMP Collect Date: 11/23/2024 9:30 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 2.06 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 18:56 MKS

Sample Number: 4K05350-14 Site: PVMS-1FL-POE-O/S Boiler Rm-F Sample ID: Flush 014
 Collector: CMP Collect Date: 11/23/2024 8:36 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/16/24 RPV 12/16/24 17:30 RPV

Sample Number: 4K05350-15 Site: PVMS-1FL-NS-Nurse Office Sample ID: First 015
 Collector: CMP Collect Date: 11/23/2024 8:40 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 1.88 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:16 MKS

Sample Number: 4K05350-16 Site: PVMS-1FL-BG-O/S Media Center Stairw Sample ID: First 016
 Collector: CMP Collect Date: 11/23/2024 8:42 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:18 MKS

Sample Number: 4K05350-17 Site: PVMS-1FL-BF-O/S Boys RR Sample ID: First 017
 Collector: CMP Collect Date: 11/23/2024 8:44 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:20 MKS

Sample Number: 4K05350-18 Site: PVMS-1FL-FP-Kitchen-1 Sample ID: First 018
 Collector: CMP Collect Date: 11/23/2024 8:46 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 4.18 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:22 MKS

Sample Number: 4K05350-19 Site: PVMS-1FL-FP-Kitchen-2 Sample ID: First 019
 Collector: CMP Collect Date: 11/23/2024 8:48 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 2.43 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:28 MKS

Report Generated On: 12/17/2024 7:32 pm 4K05350
 STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
 NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 4K05350-20 Site: PVMS-1FL-FP-Kitchen-3 Sample ID: First 020
 Collector: CMP Collect Date: 11/23/2024 8:50 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead 2.16 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:30 MKS

Sample Number: 4K05350-21 Site: PVMS-1FL-BF-O/S Kitchen Sample ID: First 021
 Collector: CMP Collect Date: 11/23/2024 8:52 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:32 MKS

Sample Number: 4K05350-22 Site: PVMS-1FL-DW-Girls Locker Room Sample ID: First 022
 Collector: CMP Collect Date: 11/23/2024 8:54 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead 11.5 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:34 MKS

Sample Number: 4K05350-23 Site: PVMS-1FL-BF-O/S Rm 135 Sample ID: First 023
 Collector: CMP Collect Date: 11/23/2024 8:56 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:36 MKS

Sample Number: 4K05350-24 Site: PVMS-2FL-BF-O/S Boys Room Sample ID: First 024
 Collector: CMP Collect Date: 11/23/2024 8:58 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 19:02 MKS

Sample Number: 4K05350-25 Site: PVMS-2FL-BF-O/S Rm 202 Sample ID: First 025
 Collector: CMP Collect Date: 11/23/2024 9:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:38 MKS

Sample Number: 4K05350-26 Site: PHS-1FL-SPOE-District Shop-F Sample ID: Flush 026
 Collector: CMP Collect Date: 11/23/2024 7:50 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead 2.04 µg/L EPA 200.8 1.00 1 12/16/24 RPV 12/16/24 17:34 RPV

Report Generated On: 12/17/2024 7:32 pm 4K05350
 STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS



1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com

PA DEP # 06-00208
 NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 4K05350-27 Site: PHS-1FL-WC-Gym-2 Sample ID: First 027
 Collector: CMP Collect Date: 11/23/2024 7:54 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:41 MKS

Sample Number: 4K05350-28 Site: PHS-1FL-IM-Trainers Rm Sample ID: First 028
 Collector: CMP Collect Date: 11/23/2024 7:56 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:43 MKS

Sample Number: 4K05350-29 Site: PHS-1FL-HB-O/S Trainer Rm Sample ID: First 029
 Collector: CMP Collect Date: 11/23/2024 7:58 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 2.55 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:45 MKS

Sample Number: 4K05350-30 Site: PHS-1FL-FP-Kitchen-1 Sample ID: First 030
 Collector: CMP Collect Date: 11/23/2024 8:00 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:47 MKS

Sample Number: 4K05350-31 Site: PHS-1FL-FP-Kitchen-2 Sample ID: First 031
 Collector: CMP Collect Date: 11/23/2024 8:02 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 C4 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:53 MKS

Sample Number: 4K05350-32 Site: PHS-1FL-FP-Kitchen-3 Sample ID: First 032
 Collector: CMP Collect Date: 11/23/2024 8:04 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead 9.02 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/08/24 16:43 MKS

Sample Number: 4K05350-33 Site: PHS-1FL-FP-Kitchen-4 Sample ID: First 033
 Collector: CMP Collect Date: 11/23/2024 8:06 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead < 1.00 C4 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:57 MKS

Report Generated On: 12/17/2024 7:32 pm 4K05350
 STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS



1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com

PA DEP # 06-00208
 NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 4K05350-34 Site: PHS-1FL-FP-Kitchen-5 Sample ID: First 034
 Collector: CMP Collect Date: 11/23/2024 8:08 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead < 1.00 C4 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 20:59 MKS

Sample Number: 4K05350-35 Site: PHS-1FL-NS-Nurse Office Sample ID: First 035
 Collector: CMP Collect Date: 11/23/2024 8:10 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead 16.1 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 18:41 MKS

Sample Number: 4K05350-36 Site: PHS-1FL-NS-Nurse Bathroom Sample ID: First 036
 Collector: CMP Collect Date: 11/23/2024 8:12 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead 4.05 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 19:31 MKS

Sample Number: 4K05350-37 Site: PHS-1FL-BF-O/S Rm 507 Sample ID: First 037
 Collector: CMP Collect Date: 11/23/2024 8:14 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 19:33 MKS

Sample Number: 4K05350-38 Site: PHS-1FL-S-Room 507 Sample ID: First 038
 Collector: CMP Collect Date: 11/23/2024 8:16 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead 1.96 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 19:39 MKS

Sample Number: 4K05350-39 Site: PHS-1FL-BF-O/S Library Sample ID: First 039
 Collector: CMP Collect Date: 11/23/2024 8:18 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 19:41 MKS

Sample Number: 4K05350-40 Site: PHS-1FL-BF-O/S Main Entrance Sample ID: First 040
 Collector: CMP Collect Date: 11/23/2024 8:20 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals
 Lead < 1.00 µg/L EPA 200.8 1.00 1 12/06/24 NDK 12/06/24 19:43 MKS

Report Generated On: 12/17/2024 7:32 pm 4K05350
 STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS



1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com

PA DEP # 06-00208
 NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 4K05350-41	Site: Field Blank	Sample ID: First 041
Collector: CMP	Collect Date: 11/23/2024 8:22 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals										
Lead	< 1.00	µg/L	EPA 200.8	1.00		1	12/06/24	NDK	12/06/24 19:45	MKS

Data Qualifiers:

C4 The CCV for this analyte was above acceptance criteria, however the analyte was not detected in the associated sample. Data may be useable based on intended use.

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's NELAP Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle
Project Manager I

Report Generated On: 12/17/2024 7:32 pm 4K05350
STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



4K05350
Lauren Ulle



COC Pg 1

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban_testinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other


Client Name: **Westchester Environmental LLC.** Project Name: **Pequannock Township SD**
 Address: **1248 Wrights Lane** Address: **Pequannock Township School District**
West Chester, PA 19380 Address: **85 Sunset Rd., Pequannock, NJ 07444**
 Contact Name: **Chris Piccininni** Email: **cpiccininni@westchesterenviromental.com** Payment / P.O. Info:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	PHE-1FL-POE-Boiler Room	11/23/24	09:28 AM	CMP	001	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
First	PHE-1FL-BF-O/S Nurse Office	11/23/24	09:32 AM	CMP	002	Pb EPA 200.8	1	PW	G	P	H	O/S Nurse Office
First	PHE-1FL-NS-Nurse Office	11/23/24	09:34 AM	CMP	003	Pb EPA 200.8	1	PW	G	P	H	Nurse Office
Flush	PSJG-1FL-POE-Boiler Room	11/23/24	09:04 AM	CMP	004	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
First	PSJG-1FL-NS-Nurse	11/23/24	09:08 AM	CMP	005	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	PSJG-1FL-BF-Near Elevator	11/23/24	09:10 AM	CMP	006	Pb EPA 200.8	1	PW	G	P	H	Near Elevator
First	PSJG-2FL-BF-O/S Room 211	11/23/24	09:12 AM	CMP	007	Pb EPA 200.8	1	PW	G	P	H	O/S Room 211
First	PSJG-1FL-S- Faculty Room	11/23/24	09:14 AM	CMP	008	Pb EPA 200.8	1	PW	G	P	H	Faculty Room
Flush	PNBE-1FL-SPOE-Electrical Room	11/23/24	09:20 AM	CMP	009	Pb EPA 200.8	1	PW	G	P	H	Boiler room
First	PNBE-1FL-DW-O/S Media Room 2	11/23/24	09:24 AM	CMP	010	Pb EPA 200.8	1	PW	G	P	H	O/S Media Room

Comments:

Relinquished by: *[Signature]* Date: 11/27/24
 Received By: *[Signature]* Time: 8:00 AM Temp °C: Acceptable Y/N
 Relinquished by: *[Signature]* Date: 11/27/24
 Received By: *[Signature]* Time: 1:45 PM Temp °C: Acceptable Y/N
 Relinquished by: *[Signature]* Date: 11/27/24
 Received In Lab By: *[Signature]* Time: 1:55 PM Temp °C: Acceptable Y/N

Sample Conditions	Matrix Key	Sample Type Key	Bottle Type Key	Preservative Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water Soils = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water SWDA = Safe Drinking Water Act Potable Sample	G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	P = Plastic G = Glass O = Other	H = Sodium A = Ascorbic Acid H = HNO3 S = NaOH OH = NaOH NA = None Required
Number of containers match number on <input checked="" type="checkbox"/> Y/N	D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence			
All containers intact <input checked="" type="checkbox"/> Y/N				
Tests within holding times <input checked="" type="checkbox"/> Y/N				
40 ml. YCA vials free of headspace? <input checked="" type="checkbox"/> Y/N				



4K05350
Lauren Uille



COC Pg 2

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban.testinglabs.com

TAT (Check One)

Standard 24hr 48hr 72hr Other

Client Name: **Westchester Environmental LLC.** Project Name: **Pequanock Township SD**

Address: **1248 Wrights Lane** Phone: **610-431-7545**

West Chester, PA 19380

Contact Name: **Chris Piccininni** Email: **cpiccininni@westchesterenviromental.com**

Address: **Pequanock Township School District**

85 Sunset Rd., Pequanock, NJ 07444

Payment / P.O. Info:

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Mark	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	PNBE-1FL-NS-Nurse Office	11/23/24	09:26 AM	CMP	011	Pb EPA 200.8	1	PW	G	P	H	Nurse Office
First	PNBE-1FL-BF-O/S Gym	11/23/24	09:28 AM	CMP	012	Pb EPA 200.8	1	PW	G	P	H	O/S Gym
First	PNBE-1FL-FS-Faculty Sink	11/23/24	09:30 AM	CMP	013	Pb EPA 200.8	1	PW	G	P	H	Faculty Sink
Flush	PVMS-1FL-POE-O/S Boiler Rm	11/23/24	08:36 AM	CMP	014	Pb EPA 200.8	1	PW	G	P	H	O/S Boiler Rm
First	PVMS-1FL-NS-Nurse Office	11/23/24	08:40 AM	CMP	015	Pb EPA 200.8	1	PW	G	P	H	Nurse Office
First	PVMS-1FL-BG-o/s Media Center Stairwell	11/23/24	08:42 AM	CMP	016	Pb EPA 200.8	1	PW	G	P	H	O/s Media Center Stairwell
First	PVMS-1FL-BF-O/S Boys RR	11/23/24	08:44 AM	CMP	017	Pb EPA 200.8	1	PW	G	P	H	O/S Boys RR
First	PVMS-1FL-FP-Kitchen-1	11/23/24	08:46 AM	CMP	018	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	PVMS-1FL-FP-Kitchen-2	11/23/24	08:48 AM	CMP	019	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	PVMS-1FL-FP-Kitchen-3	11/23/24	08:50 AM	CMP	020	Pb EPA 200.8	1	PW	G	P	H	Kitchen

Sample Conditions	Matrix Key	Bottle Type-Key
Submitted w/ COC <input checked="" type="checkbox"/> Y / <input checked="" type="checkbox"/> N	NPAW = Non-Potable Water Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other
Not used or containers match previous COC? <input checked="" type="checkbox"/> Y / <input checked="" type="checkbox"/> N		Preservative Key H = Sodium Thiosulfate A = Ascorbic Acid C = HCl H ₂ SO ₄ O = Other
All containers intact <input checked="" type="checkbox"/> Y / <input checked="" type="checkbox"/> N	Sample Type Key / SWDA Sample Type G = Grab B HC = 8 Hour Composite 24 HC = 24 Hour Composite	S = None Required OH = NaOH NA =
Tests within holding times <input checked="" type="checkbox"/> Y / <input checked="" type="checkbox"/> N	D = Distribution E = Entry Point IR = RAW C = Check IS = Special JM = Maximum Residence	
40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y / <input checked="" type="checkbox"/> N		

Relinquished by: *[Signature]*

Received By: *[Signature]* Date: 11/27/24 Time: 8:00 AM Temp °C: Acceptable Y/N

Relinquished by: *[Signature]* Date: 11/27/24 Time: 8:00 AM Temp °C: Acceptable Y/N

Received in Lab By: *[Signature]* Date: 11/27/24 Time: 8:00 AM Temp °C: Acceptable Y/N



4K05350
Lauren Ullie



COC Pg 3

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-1EST - Fax: 610-375-4090 - suburban.testinglabs.com

TAT (Check One) Standard

24hr 48hr 72hr Other

Client Name: **Westchester Environmental LLC.** Project Name: **Pequannock Township SD**
 Address: **1248 Wrights Lane** Address: **Pequannock Township School District**
West Chester, PA 19380 Address: **85 Sunset Rd., Pequannock, NJ 07444**
 Contact Name: **Chris Piccininni** Email: **cpiccininni@westchesterenviromental.com** Phone: **610-431-7545**
 Payment / P.O. Info:

Comments:


Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Botle Quantity	Matrix	Sample Types	Botle Type	Preservative	Sample Description / Site ID
First	PVMS-1FL-BF-o/s Kitchen	11/23/24	08:52 AM	CMP	021	Pb EPA 200.8	1	PW	G	P	H	o/s Kitchen
First	PVMS-1FL-DW-Girls Locker Room	11/23/24	08:54 AM	CMP	022	Pb EPA 200.8	1	PW	G	P	H	Girls Locker Room
First	PVMS-1FL-BF-o/s Rm 135	11/23/24	08:56 AM	CMP	023	Pb EPA 200.8	1	PW	G	P	H	o/s Rm 135
First	PVMS-2FL-BF-O/S Boys Room	11/23/24	08:58 AM	CMP	024	Pb EPA 200.8	1	PW	G	P	H	O/S Boys Room
First	PVMS-2FL-BF-o/s Rm 202	11/23/24	09:00 AM	CMP	025	Pb EPA 200.8	1	PW	G	P	H	o/s Rm 202
Flush	PHS-1FL-SPOE-District Shop	11/23/24	07:50 AM	CMP	026	Pb EPA 200.8	1	PW	G	P	H	District Shop
First	PHS-1FL-WC-Gym-2	11/23/24	07:54 AM	CMP	027	Pb EPA 200.8	1	PW	G	P	H	Gym
First	PHS-1FL-IM-Trainers Rm	11/23/24	07:56 AM	CMP	028	Pb EPA 200.8	1	PW	G	P	H	Trainer's Room
First	PHS-1FL-HB-O/S Trainers Rm	11/23/24	07:58 AM	CMP	029	Pb EPA 200.8	1	PW	G	P	H	O/S Trainers Rm
First	PHS-1FL-FP-Kitchen-1	11/23/24	08:00 AM	CMP	030	Pb EPA 200.8	1	PW	G	P	H	Kitchen

Remunished by: *CP* Date: 11/27/24
 Received By: *Any Daviny* Time: 8:00 AM Temp: Acceptable Y/N
 Relinquished by: *Any Daviny* Date: 11/27/24 Temp: Acceptable Y/N
 Received in Lab By: *Y/L* Date: 11/27/24 Temp: Acceptable Y/N

Sample Conditions	Matrix Key	Botle Type Key
Submitted w/ COC <i>Y/N</i>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Presale Sample	P = Plastic G = Glass O = Other
Number of containers match number on <i>Y/N</i>	D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residual	Preservative Key H = Sodium Thiosulfate C = HCl H ₂ SO ₄ O = Other
All containers intact <i>Y/N</i>	G = Grab B HC = 8 hour Composite 24 HC = 24-hour Composite	A = Ascorbic H = HClO ₃ S = NaOH OH = NaOH NA = None Required
Tests within holding times <i>Y/N</i>		
40 mL YDA vials free of headspace? <i>Y/N</i>		



4K05350
Lauren Uille



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban.testinglabs.com

COC Pg 4

TAT (Check One)

Standard 24hr 48hr 72hr Other

Client Name: **Westchester Environmental LLC.**
 Address: **1248 Wrights Lane**
West Chester, PA 19380
 Contact Name: **Chris Piccinni**
 Phone: **610-431-7545**
 Email: **cpiccinni@westchesterenviromental.com**
 Project Name: **Pequanock Township SD**
 Address: **Pequanock Township School District**
85 Sunset Rd., Pequanock, NJ 07444
 Payment / P.O. Info:


Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	PHS-1FL-FP-Kitchen-2	11/23/24	08:02 AM	CMP	031	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	PHS-1FL-FP-Kitchen-3	11/23/24	08:04 AM	CMP	032	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	PHS-1FL-FP-Kitchen-4	11/23/24	08:06 AM	CMP	033	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	PHS-1FL-FP-Kitchen-5	11/23/24	08:08 AM	CMP	034	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	PHS-1FL-NS-Nurse Office	11/23/24	08:10 AM	CMP	035	Pb EPA 200.8	1	PW	G	P	H	Nurse Office
First	PHS-1FL-NS-Nurse Bathroom	11/23/24	08:12 AM	CMP	036	Pb EPA 200.8	1	PW	G	P	H	O/S Womens RR
First	PHS-1FL-BF-O/S Rm 507	11/23/24	08:14 AM	CMP	037	Pb EPA 200.8	1	PW	G	P	H	O/S Rm 507
First	PHS-1FL-S-Room 507	11/23/24	08:16 AM	CMP	038	Pb EPA 200.8	1	PW	G	P	H	Room 507
First	PHS-1FL-BF-O/S Library	11/23/24	08:18 AM	CMP	039	Pb EPA 200.8	1	PW	G	P	H	O/S Library
First	PHS-1FL-BF-O/S Main Entrance	11/23/24	08:20 AM	CMP	040	Pb EPA 200.8	1	PW	G	P	H	Main Entrance

Relinquished by: *[Signature]* Date: 11/27/24 Time: 8:00 AM
 Received by: *[Signature]* Temp °C: Acceptable Y/N
 Relinquished by: *[Signature]* Date: 11/27/24 Time: 1:00 PM Temp °C: Acceptable Y/N
 Received in Lab By: *[Signature]* Date: 11/27/24 Time: 1:00 PM Temp °C: Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <i>(Y/N)</i> Which in which test match number on COC? <i>(Y/N)</i> All containers intact <i>(Y/N)</i> Tests within holding times <i>(Y/N)</i> 30 ml YOA vials free of headspace? <i>(Y/N)</i>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered Sludge soil, etc. (reported as trip) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample Sample Type Key: SWDA Sample Type G = Grab BHC = 8 Hour Composite 24-HC = 24 Hour Composite	P = Plastic G = Glass O = Other H = Sodium A = Ascorbic Acid H = HMO3 S = NaOH OH = NaOH NA = None Required



4K05350
Lauren Uffe



COC Pg 5

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.	Project Name:	Pequannock Township SD
Address:	1248 Wrights Lane	Address:	Pequannock Township School District
Contact Name:	Chris Piccininni	Address:	85 Sunset Rd., Pequannock, NJ 07444
Phone:	610-431-7545	Payment / P.O. Info:	
Email:	cpiccininni@westchesterenviro.com		

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
		11/23/24	08:22 AM	CMP	041	Pb EPA 200.8	1	PW	G	P	H	Field Blank

Relinquished by: *[Signature]*
 Received By: *[Signature]*
 Relinquished by: *[Signature]*
 Received in Lab By: *[Signature]*

Date: 11/27/24
 Time: 8:00 AM
 Date: *[Signature]*
 Time: *[Signature]*
 Date: *[Signature]*
 Time: *[Signature]*
 Date: *[Signature]*
 Time: *[Signature]*

Temp °C: Acceptable Y / N
 Temp °C: Acceptable Y / N
 Temp °C: Acceptable Y / N
 Temp °C: Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y / N	NPW = Non-Probable Water Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Probable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other Preservative Key Thiosulfate Acid C = HCl O = Other H = Sodium A = Ascorbic H = HNO3 S = NaOH OH = NaOH NA = None Required	SWDA Reporting PW SID Fax Email Other Return a copy of this form with Report
Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N	Sample Type Key: SWDA Sample Type G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite		
All containers intact <input checked="" type="checkbox"/> Y / N	ID = Distribution E = Entry Point R = Raw C = Check S = Special IM = Maximum Residence		
Tests within holding times <input checked="" type="checkbox"/> Y / N			
40 mL YOA vials free of headspace? <input checked="" type="checkbox"/> Y / N			

see PH 2
(31) 450 ml P+ filter
GWSR 11-27-24



SUBURBAN TESTING LABS

Results Report

Order ID: 4K05367

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: Pequannock Township SD
85 Sunset Rd.
Pequannock, NJ 07444

Attn: Christopher Piccininni

Regulatory ID:

Sample Number: 4K05367-29
Collector: CMP

Site: PHS-1FL-NS-Nurse Office-F
Collect Date: 11/23/2024 8:11 am

Sample ID: Flush 029
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

<u>Metals</u>										
Lead	8.07	µg/L	EPA 200.8	1.00		1	12/18/24	RPV	12/18/24 17:25	RPV

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's NELAP Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle
Project Manager I


Report Generated On: 12/19/2024 2:57 pm 4K05367
STL_Results Revision #3.0 Effective: 05/29/2024

SUBURBAN TESTING LABS


1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



4K05367
Lauren Uile



TESTING LABS

COC Pg 1

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban.testinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Hold

Client Name:	Westchester Environmental LLC.	Project Name:	Pequanock Township SD
Address:	1248 Wrights Lane West Chester, PA 19380	Address:	Pequanock Township School District 85 Sunset Rd., Pequanock, NJ 07444
Contact Name:	Chris Piccinni	Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	PHE-1FL-BF-O/S Nurse Office-F	11/23/24	09:33 AM	CMP	001	Pb EPA 200.8	1	PW	G	P	H	O/S Nurse Office
Flush	PHE-1FL-NS-Nurse Office-F	11/23/24	09:35 AM	CMP	002	Pb EPA 200.8	1	PW	G	P	H	Nurse Office
Flush	PSJG-1FL-NS-Nurse-F	11/23/24	09:09 AM	CMP	003	Pb EPA 200.8	1	PW	G	P	H	Nurse
Flush	PSJG-1FL-BF-Near Elevator-F	11/23/24	09:11 AM	CMP	004	Pb EPA 200.8	1	PW	G	P	H	Near Elevator
Flush	PSJG-2FL-BF-O/S Room 211-F	11/23/24	09:13 AM	CMP	005	Pb EPA 200.8	1	PW	G	P	H	O/S Room 211
Flush	PSJG-1FL-S Faculty Room-F	11/23/24	09:15 AM	CMP	006	Pb EPA 200.8	1	PW	G	P	H	Faculty Room
Flush	PNBE-1FL-DW-O/S Media Room 2-F	11/23/24	09:25 AM	CMP	007	Pb EPA 200.8	1	PW	G	P	H	O/S Media Room
Flush	PNBE-1FL-NS-Nurse Office-F	11/23/24	09:27 AM	CMP	008	Pb EPA 200.8	1	PW	G	P	H	Nurse Office
Flush	PNBE-1FL-BF-O/S Gym-F	11/23/24	09:29 AM	CMP	009	Pb EPA 200.8	1	PW	G	P	H	O/S Gym
Flush	PNBE-1FL-FS-Faculty Sink-F	11/23/24	09:31 AM	CMP	010	Pb EPA 200.8	1	PW	G	P	H	Faculty Sink

Relinquished by:

[Signature]

Received By:

Date: 11/27/24
Time: 8:00 AM
Temp °C: Acceptable Y/N

Relinquished by:

Date: 11/27/24
Time: 11:45 AM
Temp °C: Acceptable Y/N


Received in Lab By:

Date: 11/27/24
Time: 1:50 PM
Temp °C: Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ CDC <input checked="" type="checkbox"/> N	NPW = Non-Portable Water Solid = Raw Sludges, Dewatered Sludge soil, etc. (reported as mgh) PW = Portable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Possible Sample	P = Plastic G = Glass O = Other
Number of containers match <input checked="" type="checkbox"/> N		Preservative Key H = Sodium Thiosulfate Acid C = HCl H ₂ SO ₄ NaOH NA = None O = Other Required
All containers intact <input checked="" type="checkbox"/> N	Sample Type Key G = Grab 8HC = 8 Hour Composite 24HC = 24 Hour Composite	
Tests within holding times <input checked="" type="checkbox"/> N	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	
40 ml YDA vials free of headspace? <input checked="" type="checkbox"/> N		



4K05367
Lauren Uile



COC Pg 2

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4080 - suburban_testing_labs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

* Hold *

Client Name: **Westchester Environmental LLC.** Project Name: **Pequannock Township SD**

Address: **1248 Wrights Lane** Phone: **610-431-7545** Address: **Pequannock Township School District**

West Chester, PA 19380 Email: **cpiccinini@westchesterenviromental.com** Address: **85 Sunset Rd., Pequannock, NJ 07444**

Contact Name: **Chris Piccininni** Payment / P.O. Info:

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	PVMS-1FL-NS-Nurse Office-F	11/23/24	08:41 AM	CMP	011	Pb EPA 200.8	1	PW	G	P	H	Nurse Office
Flush	PVMS-1FL-BG-o/s Media Center Stairwell-F	11/23/24	08:43 AM	CMP	012	Pb EPA 200.8	1	PW	G	P	H	O/s Media Center Stairwell
Flush	PVMS-1FL-BF-O/s Boys RR-F	11/23/24	08:45 AM	CMP	013	Pb EPA 200.8	1	PW	G	P	H	O/s Boys RR
Flush	PVMS-1FL-FP-Kitchen-1-F	11/23/24	08:47 AM	CMP	014	Pb EPA 200.8	1	PW	G	P	H	Kitchen
Flush	PVMS-1FL-FP-Kitchen-2-F	11/23/24	08:49 AM	CMP	015	Pb EPA 200.8	1	PW	G	P	H	Kitchen
Flush	PVMS-1FL-FP-Kitchen-3-F	11/23/24	08:51 AM	CMP	016	Pb EPA 200.8	1	PW	G	P	H	Kitchen
Flush	PVMS-1FL-BF-o/s Kitchen-F	11/23/24	08:53 AM	CMP	017	Pb EPA 200.8	1	PW	G	P	H	o/s Kitchen
Flush	PVMS-1FL-DW-Girls Locker Room-F	11/23/24	08:55 AM	CMP	018	Pb EPA 200.8	1	PW	G	P	H	Girls Locker Room
Flush	PVMS-1FL-BF-o/s Rm 135-F	11/23/24	08:57 AM	CMP	019	Pb EPA 200.8	1	PW	G	P	H	o/s Rm 135
Flush	PVMS-2FL-BF-O/s Boys Room-F	11/23/24	08:59 AM	CMP	020	Pb EPA 200.8	1	PW	G	P	H	O/s Boys Room

Relinquished by:

Date: 11/27/24

Time: 8:00 AM

Received By:

Date: 11/27/24

Time: 10:00 AM

Relinquished by:

Date: 11/27/24

Time: 1:40 PM

Received in Lab By:


Date: 11/27/24

Time: 1:50 PM

<p>Sample Conditions</p> <p>Submitted w/ COC <input checked="" type="checkbox"/> Y/N</p> <p>Number of containers match <input checked="" type="checkbox"/> Y/N</p> <p>All containers intact <input checked="" type="checkbox"/> Y/N</p> <p>Tests within holding times <input checked="" type="checkbox"/> Y/N</p> <p>40 ml VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N</p>	<p>Matrix Key</p> <p>NPW = Non-Potable Water</p> <p>Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)</p> <p>PW = Potable Water (not for SWDA compliance)</p> <p>SWDA = Safe Drinking Water Act</p> <p>Bubble Strips</p> <p>Sample Type Key</p> <p>G = Grab</p> <p>8 HC = 8 Hour Composite</p> <p>24 HC = 24 Hour Composite</p> <p>SWDA Sample Type</p> <p>D = Distribution</p> <p>E = Entry Point</p> <p>FR = Raw</p> <p>C = Check</p> <p>IS = Special</p> <p>M = Maximum</p> <p>Residence</p>	<p>Bottle Type Key</p> <p>P = Plastic</p> <p>G = Glass</p> <p>O = Other</p> <p>Preservative Key</p> <p>H = Sulfamic Acid</p> <p>Thiosulfate</p> <p>C = HCl</p> <p>H₂SO₄</p> <p>O = Other</p> <p>None Required</p> <p>A = Ascorbic Acid</p> <p>H = HNO₃</p> <p>S = NaOH</p> <p>OH = NaOH</p> <p>NA =</p>
--	--	---



4K05367
Lauren Uille



COC Pg 3

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban_testinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

* Hand *

Client Name:	Westchester Environmental LLC.	Project Name:	Pequannock Township SD
Address:	1248 Wrights Lane	Address:	Pequannock Township School District
Contact Name:	Chris Piccininni	Address:	85 Sunset Rd., Pequannock, NJ 07444
Phone:	610-431-7545	Payment / P.O. Info:	
Email:	cpiccininni@westchesterenviromental.com		

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	PVMS-2FL-BF-o/s Rm 202-F	11/23/24	09:01 AM	CMP	021	Pb EPA 200.8	1	PW	G	P	H	o/s Rm 202
Flush	PHS-1FL-WC-Gym-2-F	11/23/24	07:55 AM	CMP	022	Pb EPA 200.8	1	PW	G	P	H	Gym
Flush	PHS-1FL-HB-O/S Trainers Rm-F	11/23/24	07:59 AM	CMP	023	Pb EPA 200.8	1	PW	G	P	H	O/S Trainers Rm
Flush	PHS-1FL-FP-Kitchen-1-F	11/23/24	08:01 AM	CMP	024	Pb EPA 200.8	1	PW	G	P	H	Kitchen
Flush	PHS-1FL-FP-Kitchen-2-F	11/23/24	08:03 AM	CMP	025	Pb EPA 200.8	1	PW	G	P	H	Kitchen
Flush	PHS-1FL-FP-Kitchen-3-F	11/23/24	08:05 AM	CMP	026	Pb EPA 200.8	1	PW	G	P	H	Kitchen
Flush	PHS-1FL-FP-Kitchen-4-F	11/23/24	08:07 AM	CMP	027	Pb EPA 200.8	1	PW	G	P	H	Kitchen
Flush	PHS-1FL-FP-Kitchen-5-F	11/23/24	08:09 AM	CMP	028	Pb EPA 200.8	1	PW	G	P	H	Kitchen
Flush	PHS-1FL-NS-Nurse Office-F	11/23/24	08:11 AM	CMP	029	Pb EPA 200.8	1	PW	G	P	H	Nurse Office
Flush	PHS-1FL-NS-Nurse Bathroom-F	11/23/24	08:13 AM	CMP	030	Pb EPA 200.8	1	PW	G	P	H	O/S Womens RR

Relinquished by:		Date:	11/27/24
Received By:		Time:	8:00 AM
Relinquished by:		Date:	Temp °C:
Received in Lab By:		Time:	Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NFW = Non-Portable Water Solid = Raw Sludge, Dewatered Sludge, etc. (reported as mg/l) PW = Portable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other
Number of containers in each number on <input checked="" type="checkbox"/> Y/N	LD = Disinfection E = Entry Point R = Raw C = Check S = Special M = Maximum Residual	Preservative Key H = Sodium Thiocyanate Acid H2SO4 O = Other
All containers intact <input checked="" type="checkbox"/> Y/N	Sample Type Key G = Grab 8-HC = 8 Hour Composite 24-HC = 24 Hour Composite	H = Sodium Thiocyanate A = Ascorbic Acid H = HNO3 S = NaOH OR = NaOH NA = None Required
Tests written holding time <input checked="" type="checkbox"/> Y/N		
40 ml YOA vials free of headspace? <input checked="" type="checkbox"/> Y/N		



4K05367
Lauren Ulle



TESTING LABS

COC Pg 4

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban.testinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr **Other**

* Hold *

Client Name: **Westchester Environmental LLC.**
Address: **1248 Wrights Lane**
West Chester, PA 19380
Contact Name: **Chris Piccininni**
Phone: **610-431-7545**
Email: **cpiccininni@westchesterenviromental.com**
Project Name: **Pequannock Township SD**
Address: **Pequannock Township School District**
85 Sunset Rd., Pequannock, NJ 07444
Payment / P.O. Info:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	PHS-1FL-BF-O/S Rm 507-F	11/23/24	08:15 AM	CMP	031	Pb EPA 200.8	1	PW	G	P	H	O/S Rm 507
Flush	PHS-1FL-S-Room 507-F	11/23/24	08:17 AM	CMP	032	Pb EPA 200.8	1	PW	G	P	H	Room 507
Flush	PHS-1FL-BF-O/S Library-F	11/23/24	08:19 AM	CMP	033	Pb EPA 200.8	1	PW	G	P	H	O/S Library
Flush	PHS-1FL-BF-O/S Main Entrance-F	11/23/24	08:21 AM	CMP	034	Pb EPA 200.8	1	PW	G	P	H	Main Entrance

Comments:

Requisitioned by: *[Signature]*
Received By: *AMY STEVENS* Date: 11/27/24 Time: 8:00 AM Temp °C: Acceptable Y/N
Requisitioned by: *AMY STEVENS* Date: 11/27/24 Time: 1:45 PM Temp °C: Acceptable Y/N
Received in Lab By: *[Signature]* Date: 11/27/24 Time: 5:00 PM Temp °C: Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC Y/N	NPW = Non-Potable Water Solid = Raw Sludge - Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other
Tests within holding times Y/N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	Preservative Key H = Sodium Thiosulphate Acid H = HNO3 S = OR = NaOH NA = Required
40 ml. VOA vials free of headspace? Y/N	SWDA Sample Type D = Distribution E = Entry Point R = C = S = M =	

Handwritten notes:
1037F
11-27-24
1037F 1037F 1037F