

LEAD IN DRINKING WATER TESTING

At

**NORMANDY HIGH SCHOOL
6701 ST. CHARLES ROCK ROAD
ST. LOUIS, MISSOURI 63133**

Prepared for

**NORMANDY SCHOOLS COLLABORATIVE
3855 LUCAS AND HUNT ROAD
ST. LOUIS, MISSOURI 63121**

Submitted by:

**PROFESSIONAL SERVICE INDUSTRIES, INC.
11826 BORMAN DRIVE
ST. LOUIS, MISSOURI 63146**

PSI PROJECT #0029-6396

August 30, 2024





Intertek-PSI
11826 Borman Drive
St. Louis, Missouri 63146

Tel +1 314 432 8073
intertek.com/building

August 30, 2024

Normandy Schools Collaborative
3855 Lucas and Hunt Road
St. Louis, Missouri 63121

Attn: Mr. Mark Kennedy, Facilities Services
Email: mark.kennedy@normandysc.org

Re: **Report for Lead in Drinking Water Testing**
Normandy High School
6701 St. Charles Rock Road
St. Louis, Missouri 63133
PSI Project Number: 0029-6396

Dear Mr. Kennedy:

In accordance with our agreement, Professional Service Industries, Inc. (PSI), an Intertek Company, performed Lead in Drinking Water Testing at Normandy Schools Collaborative's Normandy High School located at 6701 St. Charles Rock Road in St. Louis, Missouri.

BACKGROUND

On June 30, 2022, Senate Bill 681 was signed and became effective on August 28, 2022. Section 160.077 of this Bill, "Get the Lead Out of School Drinking Water Act", requires school districts to inventory, create a plan, and to test drinking water sources for lead. PSI understands that Normandy Schools Collaborative (NSC) has requested lead in drinking water testing of drinking water outlets/high priority potable water sources at Normandy High School. According to Missouri Senate Bill 681 Section 160.077, drinking water outlets are defined as potable water fixtures that are used for drinking or food preparation, which also includes water sources used for cooking and/or for cleaning cooking and eating utensils. According to the Environmental Protection Agency (EPA), high priority potable water sources may include drinking fountains, water coolers, kitchen sinks, classroom combination sinks/drinking fountains, home economic rooms, teacher lounge sinks, nurse's office sinks, special needs classroom sinks, ice-makers, and any sink known to be or visibly used for consumption. It should be noted that in July 2024, PSI performed walkthrough evaluations to identify (inventory) these drinking water outlets/high priority potable water sources throughout the school district. Due to the passing of Missouri Senate Bill 681 Section 160.77, and the increased awareness for the potential of lead in drinking water, PSI was contacted to perform Lead in Drinking Water Testing within the facility in general accordance with Missouri Senate Bill 681 Section 160.077 and the EPA's 3T's for Reducing Lead in Drinking Water in Schools and Child Care Facilities – Revised Manual (Oct. 2018).



PURPOSE

The purpose of the lead in drinking water testing was to determine the lead concentrations in drinking water outlets/high priority potable water sources and to identify any source exceeding Missouri Senate Bill 681 Section 160.77 set action level of less than 5 parts per billion (PPB).

SCOPE OF SERVICES

PSI performed a walk-through evaluation of Normandy High School. The general evaluation consisted of a visual evaluation, identification of the drinking water outlets/high priority water sources (based on information provided from the July 2024 inventory evaluation), flushing of the water sources, and water sampling utilizing “first draw” methods.

Lead in Drinking Water Testing

The evaluation included visual observations of subject property grounds and drinking water outlets/high priority potable water source areas within the facility. The following elements were performed during the evaluation.

Lead in Drinking Water Testing

As required in Senate Bill 681 Section 160.077, PSI performed Lead in Drinking Water Testing utilizing initial “first draw” methods. A “first draw” sample is defined as the first two-hundred-fifty milliliter (250mL) sample to come out of the tap after an 8-hour period of inactivity, but no more than 18-hours. In order to successfully accomplish sampling within this time frame, PSI personnel flushed each water source the night before, and attached appropriate signage to prevent others from using the sources prior to the sampling event.

After each water source was flushed and was within the required sampling time frame, PSI arrived at the site to collect the water samples. On August 7, 2024, a total of eighty-five (85) lead in drinking water samples were collected from drinking water outlets/high priority water sources within Normandy High School.

Water samples were collected by experienced PSI environmental personnel. Following Missouri Senate Bill 681 Section 160.77 and the EPA's 3T's for Reducing Lead in Drinking Water in Schools – Revised Technical Guidance, samples were collected in laboratory supplied 250-mL sample containers and analyzed for lead concentration in accordance with EPA Method 200.8. The samples were submitted to Teklab, Inc.'s Laboratory in Collinsville, Illinois under proper chain-of-custody. Teklab, Inc., is a certified State of Missouri Department of Natural Resources (MDNR) Drinking Water (MO Certification #930) and National Environmental Laboratory Accreditation Program (NELAP) accredited laboratory.

Results were compared to Missouri Senate Bill 681 Section 160.77 “Get the Lead out of School Drinking Water Act” requirements of less than 5 parts per billion (PPB) which is equivalent to micrograms per liter (ug/L). It should be noted that 15 PPB is the set Action Level for the EPA (Primary Drinking Water Standards), and the action level in which Public Water Systems such as Missouri American Water, who supplies water to the district, must abide.



AUTHORIZATION

Authorization to perform this work was given by Mr. Willie Robinson of the Normandy Schools Collaborative signing PSI's Proposal # 0029-430663. Representatives of PSI performed the water sampling on August 7, 2024.

OBSERVATIONS AND ANALYTICAL RESULTS

August 7, 2024

On August 7, 2024, PSI representatives performed a walk-through evaluation of the facility and sampled the previously identified drinking water outlets/high priority water sources. A total of eighty-five (85) "first draw" lead in drinking water samples were collected and submitted for laboratory analysis. It should be noted that a total of ninety-four (94) water source locations were identified during the inventory; however, nine (9) water source locations did not work at the time of the sampling event. Sample locations are illustrated on the attached site map(s).

Results can be referenced in the laboratory analytical report included at the end of this report. It should be noted that the analytical sensitivity for lead in drinking water analysis identified a reporting limit of 0.001 milligrams of lead per liter (mg/L) which equates to 1.0 microgram of lead per liter (ug/L) and/or 1.0 part per billion (PPB) of lead. The following table summarizes the August 7, 2024, results:

Sample ID	Source Type	Location/Room	Floor	Time Sampled	Sample Type	Results (PPB)
NHS-WC-E3A-3-01	WC	E. Hall - 3A Hallway	3	9:32	Initial - First Draw	<1.0
NHS-BF-E3A-3-02	BF	E. Hall - 3A Hallway	3	9:33	Initial - First Draw	<1.0
NHS-WC-E3A-3-03	WC	E. Hall - 3A Hallway	3	9:35	Initial - First Draw	<1.0
NHS-BF-E3A-3-04	BF	E. Hall - 3A Hallway	3	9:36	Initial - First Draw	<1.0
NHS-WC-E3A-3-05	WC	E. Hall - 3A Hallway - L	3	9:38	Initial - First Draw	<1.0
NHS-WC-E3A-3-06	WC	E. Hall - 3A Hallway - R	3	9:39	Initial - First Draw	<1.0
NHS-BF-E3A-3-07	BF	E. Hall - 3A Hallway	3	9:40	Initial - First Draw	<1.0
NHS-WC-E2A-2-08	WC	E. Hall - 2A Hallway	2	9:48	Initial - First Draw	<1.0
NHS-BF-E2A-2-09	BF	E. Hall - 2A Hallway	2	9:49	Initial - First Draw	<1.0
NHS-WC-E2A-2-10	WC	E. Hall - 2A Hallway	2	9:50	Initial - First Draw	<1.0
NHS-BF-E2A-2-11	BF	E. Hall - 2A Hallway	2	9:51	Initial - First Draw	<1.0
NHS-WC-E2A-2-12	WC	E. Hall - 2A Hallway	2	9:52	Initial - First Draw	<1.0
NHS-WC-E2A-2-13	WC	E. Hall - 2A Hallway	2	9:57	Initial - First Draw	<1.0
NHS-BF-E2A-2-14	BF	E. Hall - 2A Hallway	2	9:58	Initial - First Draw	<1.0



Sample ID	Source Type	Location/Room	Floor	Time Sampled	Sample Type	Results (PPB)
NHS-F-176-1-15	F	E. Hall - Room 176	1	10:03	Initial - First Draw	<1.0
NHS-WC-E1A-1-16	WC	E. Hall - 1A Hallway - L	1	10:06	Initial - First Draw	<1.0
NHS-WC-E1A-1-17	WC	E. Hall - 1A Hallway - R	1	10:07	Initial - First Draw	<1.0
NHS-BF-E1A-1-18	BF	E. Hall - 1A Hallway	1	10:08	Initial - First Draw	<1.0
NHS-WC-E1A-1-19	WC	E. Hall - 1A Hallway	1	10:09	Initial - First Draw	<1.0
NHS-BF-E1A-1-20	BF	E. Hall - 1A Hallway	1	10:10	Initial - First Draw	<1.0
NHS-WC-E1B-1-21	WC	E. Hall - 1B Hallway - L	1	10:11	Initial - First Draw	<1.0
NHS-WC-E1B-1-22	WC	E. Hall - 1B Hallway - R	1	10:13	Initial - First Draw	<1.0
NHS-BF-E1B-1-23	BF	E. Hall - 1B Hallway	1	10:13	Initial - First Draw	<1.0
NHS-F-OBR-1-24	F	Connector Link Office Breakroom	1	10:16	Initial - First Draw	<1.0
NHS-WC-C3A-3-25	WC	C. Hall - 3A Hallway - L	3	10:27	Initial - First Draw	<1.0
NHS-WC-C3A-3-26	WC	C. Hall - 3A Hallway - R	3	10:28	Initial - First Draw	2.7
NHS-BF-C3A-3-27	BF	C. Hall - 3A Hallway	3	10:29	Initial - First Draw	1.7
NHS-WC-C3A-3-28	WC	C. Hall - 3A Hallway	3	10:30	Initial - First Draw	<1.0
NHS-WC-C3A-3-29	WC	C. Hall - 3A Hallway	3	10:31	Initial - First Draw	<1.0
NHS-BF-C3A-3-30	BF	C. Hall - 3A Hallway	3	10:32	Initial - First Draw	1.6
NHS-WC-C2A-2-31	WC	C. Hall - 2A Hallway - L	2	10:35	Initial - First Draw	<1.0
NHS-WC-C2A-2-32	WC	C. Hall - 2A Hallway - R	2	10:36	Initial - First Draw	2.0
NHS-BF-C2A-2-33	BF	C. Hall - 2A Hallway	2	10:37	Initial - First Draw	<1.0
NHS-WC-C2A-2-34	WC	C. Hall - 2A Hallway - L	2	10:40	Initial - First Draw	<1.0
NHS-WC-C2A-2-35	WC	C. Hall - 2A Hallway - R	2	10:41	Initial - First Draw	1.0
NHS-BF-C2A-2-36	BF	C. Hall - 2A Hallway	2	10:42	Initial - First Draw	1.7
NHS-WC-C1A-1-37	WC	C. Hall - 1A Hallway - L	1	10:46	Initial - First Draw	<1.0
NHS-WC-C1A-1-38	WC	C. Hall - 1A Hallway - R	1	10:47	Initial - First Draw	<1.0
NHS-BF-C1A-1-39	BF	C. Hall - 1A Hallway	1	10:48	Initial - First Draw	<1.0
NHS-WC-C1A-1-40	WC	C. Hall - 1A Hallway - L	1	10:49	Initial - First Draw	<1.0



Sample ID	Source Type	Location/Room	Floor	Time Sampled	Sample Type	Results (PPB)
NHS-WC-C1A-1-41	WC	C. Hall - 1A Hallway - R	1	10:50	Initial - First Draw	<1.0
NHS-BF-C1A-1-42	BF	C. Hall - 1A Hallway	1	10:51	Initial - First Draw	<1.0
NHS-WC-CAFÉ-1-43	WC	W. Hall – Cafeteria - L	1	10:55	Initial - First Draw	<1.0
NHS-WC-CAFÉ-1-44	WC	W. Hall – Cafeteria - R	1	10:56	Initial - First Draw	<1.0
NHS-BF-CAFÉ-1-45	BF	W. Hall - Cafeteria	1	10:57	Initial - First Draw	<1.0
NHS-F-211A-2-46	F	W. Hall - Room 211A	2	11:02	Initial - First Draw	2.6
NHS-F-211A-2-47	F	W. Hall - Room 211A	2	11:03	Initial - First Draw	1.7
NHS-F-211A-2-48	F	W. Hall - Room 211A	2	11:04	Initial - First Draw	1.5
NHS-F-211A-2-49	F	W. Hall - Room 211A	2	11:05	Initial - First Draw	2.3
NHS-F-211A-2-50	F	W. Hall - Room 211A	2	11:06	Initial - First Draw	2.3
NHS-SN-211A-2-51	SN	W. Hall - Room 211A	2	11:07	Initial - First Draw	<1.0
NHS-IM-207-2-52	IM	W. Hall – Room 207	2	11:11	Initial - First Draw	<1.0
NHS-KF-207-2-53	KF	W. Hall – Room 207	2	11:12	Initial - First Draw	<1.0
NHS-KF-207-2-54	KF	W. Hall – Room 207	2	11:13	Initial - First Draw	<1.0
NHS-SN-207-2-55	SN	W. Hall – Room 207	2	11:14	Initial - First Draw	<1.0
NHS-WF-207-2-56	WF	W. Hall – Room 207 – L	2	11:15	Initial - First Draw	<1.0
NHS-WF-207-2-57	WF	W. Hall – Room 207 - R	2	11:16	Initial - First Draw	2.8
NHS-F-221-2-58	F	W. Hall - Room 221	2	11:18	Initial - First Draw	<1.0
NHS-WC-W2A-2-59	WC	W. Hall - 2A Hallway	2	11:21	Initial - First Draw	<1.0
NHS-BF-W2A-2-60	BF	W. Hall - 2A Hallway	2	11:22	Initial - First Draw	<1.0
NHS-IM-112A-1-61	IM	W. Hall - Kitchen - 112A	1	11:28	Initial - First Draw	<1.0
NHS-SN-112A-1-62	SN	W. Hall - Kitchen - 112A	1	11:29	Initial - First Draw	1.2
NHS-KF-112A-1-63	KF	W. Hall - Kitchen - 112A	1	11:30	Initial - First Draw	<1.0
NHS-SN-112A-1-64	SN	W. Hall - Kitchen - 112A	1	11:31	Initial - First Draw	6.0
NHS-WF-112A-1-65	WF	W. Hall - Kitchen - 112A - L	1	11:32	Initial - First Draw	<1.0
NHS-WF-112A-1-66	WF	W. Hall - Kitchen - 112A - R	1	11:33	Initial - First Draw	<1.0



Sample ID	Source Type	Location/Room	Floor	Time Sampled	Sample Type	Results (PPB)
NHS-SN-112A-1-67	SN	W. Hall - Kitchen - 112A	1	11:34	Initial - First Draw	<1.0
NHS-F-101-1-68	F	W. Hall - Room 101	1	11:41	Initial - First Draw	1.3
NHS-WC-LR-1-69	WC	West Gym - Locker Room	1	11:44	Initial - First Draw	10.8
NHS-WC-LOBBY-2-70	WC	Viking Hall - Lobby	2	11:52	Initial - First Draw	<1.0
NHS-IM-CON-2-71	IM	V. Hall - Concession	2	11:53	Initial - First Draw	<1.0
NHS-F-CON-2-72	F	V. Hall - Concession	2	11:54	Initial - First Draw	<1.0
NHS-DF-V1A-1-73	DF	V. Hall - 1A Hallway - L	1	DNW	Initial - First Draw	DNW
NHS-DF-V1A-1-74	DF	V. Hall - 1A Hallway - R	1	DNW	Initial - First Draw	DNW
NHS-DF-V1A-1-75	DF	V. Hall - 1A Hallway - L	1	DNW	Initial - First Draw	DNW
NHS-DF-V1A-1-76	DF	V. Hall - 1A Hallway - R	1	DNW	Initial - First Draw	DNW
NHS-DF-GLR-1-77	DF	V. Hall – Girl's Locker Room - L	1	DNW	Initial - First Draw	DNW
NHS-DF-GLR-1-78	DF	V. Hall - Girl's Locker Room - R	1	DNW	Initial - First Draw	DNW
NHS-DF-GYM-1-79	DF	V. Hall - Gym	1	DNW	Initial - First Draw	DNW
NHS-DF-WLR-1-80	DF	V. Hall – Women's Locker Room - L	1	DNW	Initial - First Draw	DNW
NHS-DF-WLR-1-81	DF	V. Hall – Women's Locker Room	1	DNW	Initial - First Draw	DNW
NHS-WC-N2A-2-82	WC	N. Hall - 2A Hallway	2	12:18	Initial - First Draw	<1.0
NHS-WC-N2B-2-83	WC	N. Hall - 2B Hallway	2	12:20	Initial - First Draw	<1.0
NHS-WC-N1A-84	WC	N. Hall - 1A Hallway	1	12:22	Initial - First Draw	<1.0
NHS-F-NURSE-1-85	F	Nurse Office	1	12:23	Initial - First Draw	1.6
NHS-WC-BUS-G-86	WC	Bus Repair	G	12:27	Initial - First Draw	<1.0
NHS-WF-FH-1-87	WF	Field House	1	12:36	Initial - First Draw	5.4
NHS-WF-FH-1-88	WF	Field House	1	12:37	Initial - First Draw	3.7
NHS-F-FH-1-89	F	Field House	1	12:38	Initial - First Draw	<1.0
NHS-IM-FH-1-90	IM	Field House	1	12:39	Initial - First Draw	<1.0
NHS-DF-FH-1-91	DF	Field House	1	12:41	Initial - First Draw	<1.0



Sample ID	Source Type	Location/Room	Floor	Time Sampled	Sample Type	Results (PPB)
NHS-DF-FH-1-92	DF	Field House	1	12:42	Initial - First Draw	<1.0
NHS-DF-FIELD-1-93	DF	Football Field	1	12:45	Initial - First Draw	1.6
NHS-DF-FIELD-1-94	DF	Football Field	1	12:46	Initial - First Draw	1.9

Results that are regarded as elevated as compared to Missouri Bill 681 Section 160.77 “Get the Lead out of School Drinking Water Act” Required Action Level of 5 PPB, are bolded, italicized, and presented in larger print.

Source Type: Water Cooler = WC; BF = Bottle Filler; Drinking Fountain = DF; Faucet = F; Kitchen Faucet = KF; WF = Kitchen Washing Faucet; IM = Ice Maker; SN = Kitchen Spray Nozzle; PF = Pot Filler; CM = Coffee Maker; RL = Refrigerator Line
DNW = Does Not Work

CONCLUSIONS

On August 7, 2024, a total of eighty-five (85) “first draw” lead in drinking water samples were collected from drinking water outlets/high priority potable water sources within Normandy High School.

Water sample results collected within Normandy High School indicated concentrations met the Missouri Senate Bill 681 Section 160.77 “Get the Lead out of School Drinking Water Act” Required Action Level of less than 5 PPB with the exception of water samples NHS-SN-112A-1-64 collected from a spray nozzle in Room 112A (W. Hall Kitchen) on the 1st Floor, NHS-WC-LR-1-69 collected from a water cooler in the W. Gym Locker Room on the 1st Floor, and NHS-WF-FH-1-87 collected from a washing faucet in the Field House on the 1st Floor. Sample NHS-SN-112A-1-64 contained 6.0 PPB of lead, sample NHS-WC-LR-1-69 contained 10.8 PPB of lead, and sample NHS-WF-FH-1-87 contained 5.4 PPB of lead; therefore, were detected at concentrations over the Missouri Senate Bill 681 Section 160.77 Required Action Level.

It should be noted that the other 82 out of 85 sampled water sources appeared to have met the Missouri Senate Bill 681 Section 160.77 “Get the Lead out of School Drinking Water Act” Required Action Level of less than 5 PPB criteria for lead in water.

RECOMMENDATIONS

Based on the August 7, 2024, water sample results, it appears that the drinking water outlets/high priority potable water sources tested within Normandy Schools Collaborative’s Normandy High School located at 6701 St. Charles Rock Road in St. Louis, Missouri, meet Missouri Senate Bill 681 Section 160.77 “Get the Lead out of School Drinking Water Act” Required Action Level of less than 5 PPB with the exception of samples NHS-SN-112A-1-64 collected from a spray nozzle in Room 112A (W. Hall Kitchen) on the 1st Floor, NHS-WC-LR-1-69 collected from a water cooler in the W. Gym Locker Room on the 1st Floor, and NHS-WF-FH-1-87 collected from a washing faucet in the Field House on the 1st Floor. Therefore, PSI recommends the following:

- Follow Missouri Senate Bill 681 Section 160.77 for additional requirements (i.e., reporting procedures on school website).
- Based on these sample results, most of the water samples met the Action Level and it appears that only three (3) of the fixtures are the source of the elevated lead levels,



not the incoming water main. Therefore, PSI does not believe that adding a filter onto the incoming water main will rectify the elevated drinking water outlets in the facility.

- PSI recommends that the water sources where NHS-SN-112A-1-64, NHS-WC-LR-1-69, and NHS-WF-FH-1-87 were collected be shut off immediately (removed from service) and that School District plumbers evaluate these sources and plumbing to determine what may be different with these sources/pipes than the other ones within the facility. At a minimum, the aerators and screens to these fixtures should be removed/replaced, and these sources be re-sampled; however, PSI recommends that the entire fixture and exposed piping (if any) to these sources be removed and replaced (replacement instead of cleaning due to experience with other School Districts) back to the water shut off valve. After replacement, PSI recommends that the new aerators/screens be removed when turning the water back on for the first time (to ensure sediment does not build up due to potential grinding of the water shut off valve). After water passes through the new fixtures, the new aerators/screens should be installed. In lieu of replacing the elevated water sources, the water source locations may be permanently removed from the facility.
- The Senate Bill recommends random sampling of at least 25% of the remediated/replaced drinking water outlets until all remediated sources have been tested; however, PSI recommends that all remediated sources be retested. Once the elevated sources are replaced and/or remediated, PSI recommends immediate follow up sampling (re-test first draw and a flush sample) of the elevated water sources to determine lead concentrations prior to returning the sources for regular use.
- After the sources where samples NHS-SN-112A-1-64, NHS-WC-LR-1-69, and NHS-WF-FH-1-87 were collected have been replaced and additional follow-up sampling events determine that the lead in water Action Level have been met (less than 5.0 PPB), PSI recommends to re-sample NHS-SN-112A-1-64, NHS-WC-LR-1-69, and NHS-WF-FH-1-87 on a minimum of an annual basis (every year) utilizing “first draw” sampling procedures for at least three (3) consecutive years, or until the Missouri Department of Health and Senior Services establishes frequency sampling requirements for previous elevated sources. Once three (3) consecutive years have shown lead concentrations below 5 PPB, these sources may follow water sampling frequency testing requirements as stated in the next bulleted item below.
- Re-sample the drinking water outlets/high priority water sources throughout the facility on a minimum of every 5 years utilizing “first draw” sampling procedures.
- Properly label non-drinking water outlets/low priority water sources (bathroom faucets, custodial faucets, science classroom faucets, water fixtures not intended for drinking/consumption/food preparation, etc.) throughout the facility with appropriate signage to document and inform staff, personnel, and students that these water sources are not intended for drinking water purposes.
- If drinking water outlets/high priority water source fixtures and/or plumbing have been repaired, altered, or changed in any way since this sampling event, PSI recommends sampling the water source utilizing “first draw” procedures prior to regular use.



WARRANTY

PSI warrants that the findings contained herein have been prepared with the level of care and skill ordinarily exercised by professionals practicing in the community. The scope of work addressed readily accessible areas. No other warranties are implied or expressed.

USE BY THIRD PARTIES

This report was prepared pursuant the contract Normandy Schools Collaborative has with PSI. That contractual relationship included an exchange of information about the subject site that was unique and between PSI and Normandy Schools Collaborative and serves as the basis upon which this report was prepared. Because of the importance of the communication between PSI and Normandy Schools Collaborative reliance or any use of this report by anyone other than Normandy Schools Collaborative for whom it was prepared, is prohibited and therefore not foreseeable to PSI. Reliance or use by any such third party without explicit authorization in the report does not make said third party a third-party beneficiary to PSI's contract with Normandy Schools Collaborative. Any such unauthorized reliance on or use of this report, including any of its information or conclusions, will be at third party's risk. For the same reasons, no warranties or representations, expressed or implied in this report, are made to any such third party.

UNIDENTIFIED CONDITIONS

This Lead in Drinking Water Testing report has been developed to provide the client with information regarding apparent conditions relating to the subject property. Although PSI believes that the findings and conclusions provided in this report are reasonable, the evaluation is necessarily limited to the conditions observed and to the information available at the time of the work. Due to the nature of the work, there is a possibility that conditions may exist which could not be identified within the scope of the work or which were not apparent at the time of our site work. The evaluation is also limited to information available from the client at the time it was conducted. It is also possible that the testing methods employed at the time of the report may later be superseded by other methods. PSI does not accept responsibility for changes in the state of the art.


Please call with any questions you may have, or if PSI can be of additional service.

Respectfully submitted,
PROFESSIONAL SERVICE INDUSTRIES, INC.

Kevin C. Roberts
IH Project Manager

Greg Chambliss, RPIH
Principal Consultant

Enclosures Water Sample Location Map(s)
Laboratory Results / Certifications



LEGEND

WC = Water Cooler
 BF = Bottle Filler
 -1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
 NORMANDY HIGH SCHOOL
 6701 St. Charles Rock Road, St. Louis, Missouri 63133
 East Hall - Third Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

WC = Water Cooler
BF = Bottle Filler
-1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
East Hall - Second Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

F = Faucet

WC = Water Cooler

BF = Bottle Filler

-1 = Sample Number

● = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB

● = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB

● = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
 6701 St. Charles Rock Road, St. Louis, Missouri 63133
 East Hall - 1st Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

F = Faucet

-1 = Sample Number

● = Initial Sample Results *Below* Missouri Senate Bill

681 Section 160.077 Action Level of <5 PPB

● = Initial Sample Results *Above* Missouri Senate Bill

681 Section 160.077 Action Level of <5 PPB

● = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
 6701 St. Charles Rock Road, St. Louis, Missouri 63133
 Connector Link Building - First Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

WC = Water Cooler

BF = Bottle Filler

-1 = Sample Number

● = Initial Sample Results *Below* Missouri Senate Bill

681 Section 160.077 Action Level of <5 PPB

● = Initial Sample Results *Above* Missouri Senate Bill

681 Section 160.077 Action Level of <5 PPB

● = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
Central Hall - Third Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

WC = Water Cooler

BF = Bottle Filler

-1 = Sample Number

● = Initial Sample Results *Below* Missouri Senate Bill

681 Section 160.077 Action Level of <5 PPB

● = Initial Sample Results *Above* Missouri Senate Bill

681 Section 160.077 Action Level of <5 PPB

● = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
Central Hall - Second Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

WC = Water Cooler
BF = Bottle Filler
-1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
Central Hall - First Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

F = Faucet
WC = Water Cooler
BF = Bottle Filler
IM = Ice Maker
SN = Spray Nozzle
KF= Kitchen Faucet
WF = Washing Facet in Kitchen
-1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
West Hall - Second Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
 6701 St. Charles Rock Road, St. Louis, Missouri 63133
 West Hall - First Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

WC = Water Cooler

-1 = Sample Number

● = Initial Sample Results *Below* Missouri Senate Bill
681 Section 160.077 Action Level of <5 PPB

● = Initial Sample Results *Above* Missouri Senate Bill
681 Section 160.077 Action Level of <5 PPB

● = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
West Gym - First Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

F = Faucet
 WC = Water Cooler
 IM = Ice Maker
 -1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
 NORMANDY HIGH SCHOOL
 6701 St. Charles Rock Road, St. Louis, Missouri 63133
 Viking Hall - Second Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

DF = Drinking Fountain
-1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
Viking Hall - First Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



NORTH HALL
SECOND FLOOR


LEGEND

- WC = Water Cooler
- 1 = Sample Number
- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
North Hall - Second Floor

PSI Project No.: 0029-6396	
Lead in Drinking Water Sample Locations	
Initial Sampling Date:	Drawn, not to scale, by:
8/7/24	mksk



LEGEND

F = Faucet
 WC = Water Cooler
 -1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
 NORMANDY HIGH SCHOOL
 6701 St. Charles Rock Road, St. Louis, Missouri 63133
 North Hall - First Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

WC = Water Cooler
 -1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
 6701 St. Charles Rock Road, St. Louis, Missouri 63133
 North Hall - Ground Floor

PSI Project No.: 0029-6396


Lead in Drinking Water Sample Locations

Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk



LEGEND

F = Faucet
 DF = Drinking Fountain
 IM = Ice Maker
 WF = Washing Facet in Kitchen
 -1 = Sample Number

- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
 6701 St. Charles Rock Road, St. Louis, Missouri 63133
 Field House

PSI Project No.: 0029-6396

Lead in Drinking Water Sample Locations



Initial Sampling Date:

8/7/24

Drawn, not to scale, by:

mksk

Bleachers



Field

NHS—Football Field

DF-94

DF-93

LEGEND

- DF = Drinking Fountain
- 1 = Sample Number
- = Initial Sample Results *Below* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Initial Sample Results *Above* Missouri Senate Bill 681 Section 160.077 Action Level of <5 PPB
- = Water Source did not work at time of sampling



Normandy Schools Collaborative
NORMANDY HIGH SCHOOL
6701 St. Charles Rock Road, St. Louis, Missouri 63133
Football Field

PSI Project No.: 0029-6396	
Lead in Drinking Water Sample Locations	
Initial Sampling Date:	Drawn, not to scale, by:
8/7/24	mksk

August 19, 2024

Kevin Roberts
Professional Service Industries, Inc.
11826 Borman Dr
Maryland Heights, MO 63146
TEL: (314) 432-8073
FAX: (314) 432-5119



Illinois	100226
Illinois	1004652024-2
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Normandy - High School 0029-6396

WorkOrder: 24080813

Dear Kevin Roberts:

TEKLAB, INC received 50 samples on 8/8/2024 2:25:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 24080813

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	9
Chain of Custody	Appended

Client: Professional Service Industries, Inc.**Work Order:** 24080813**Client Project:** Normandy - High School 0029-6396**Report Date:** 19-Aug-24**Abbr Definition**

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Professional Service Industries, Inc.

Work Order: 24080813

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 24080813

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Professional Service Industries, Inc.**Work Order:** 24080813**Client Project:** Normandy - High School 0029-6396**Report Date:** 19-Aug-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Illinois	IEPA	1004652024-2	NELAP	4/30/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2025	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2025	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2025	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2025	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2026	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Mississippi	MSDH			4/30/2025	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville

Client: Professional Service Industries, Inc.

Work Order: 24080813

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24080813-001A	NHS-WC-E3A-3-01	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 10:46	08/07/2024 9:32
24080813-002A	NHS-BF-E3A-3-02	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 11:00	08/07/2024 9:33
24080813-003A	NHS-WC-E3A-3-03	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 11:03	08/07/2024 9:35
24080813-004A	NHS-BF-E3A-3-04	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 11:07	08/07/2024 9:36
24080813-005A	NHS-WC-E3A-3-05	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 11:11	08/07/2024 9:38
24080813-006A	NHS-WC-E3A-3-06	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 14:25	08/07/2024 9:39
24080813-007A	NHS-BF-E3A-3-07	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 14:36	08/07/2024 9:40
24080813-008A	NHS-WC-E2A-2-08	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 14:39	08/07/2024 9:48
24080813-009A	NHS-BF-E2A-2-09	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 14:43	08/07/2024 9:49
24080813-010A	NHS-WC-E2A-2-10	NELAP		1.0	< 1.0	µg/L	5	08/16/2024 14:20	08/07/2024 9:50
24080813-011A	NHS-BF-E2A-2-11	NELAP		1.0	< 1.0	µg/L	5	08/16/2024 14:24	08/07/2024 9:51
24080813-012A	NHS-WC-E2A-2-12	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:05	08/07/2024 9:52
24080813-013A	NHS-WC-E2A-2-13	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:09	08/07/2024 9:57
24080813-014A	NHS-BF-E2A-2-14	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:12	08/07/2024 9:58
24080813-015A	NHS-F-176-1-15	NELAP		1.0	< 1.0	µg/L	5	08/16/2024 14:27	08/07/2024 10:03
24080813-016A	NHS-WC-E1A-1-16	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:16	08/07/2024 10:06
24080813-017A	NHS-WC-E1A-1-17	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:20	08/07/2024 10:07
24080813-018A	NHS-BF-E1A-1-18	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:23	08/07/2024 10:08
24080813-019A	NHS-WC-E1A-1-19	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:27	08/07/2024 10:09
24080813-020A	NHS-BF-E1A-1-20	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:31	08/07/2024 10:10
24080813-021A	NHS-WC-E1B-1-21	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:34	08/07/2024 10:11
24080813-022A	NHS-WC-E1B-1-22	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:49	08/07/2024 10:12
24080813-023A	NHS-BF-E1B-1-23	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:53	08/07/2024 10:13
24080813-024A	NHS-F-OBR-1-24	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 15:56	08/07/2024 10:16
24080813-025A	NHS-WC-C3A-3-25	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 16:00	08/07/2024 10:27
24080813-026A	NHS-WC-C3A-3-26	NELAP		1.0	2.7	µg/L	5	08/16/2024 14:31	08/07/2024 10:28
24080813-027A	NHS-BF-C3A-3-27	NELAP		1.0	1.7	µg/L	1	08/13/2024 16:04	08/07/2024 10:29
24080813-028A	NHS-WC-C3A-3-28	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 16:15	08/07/2024 10:30
24080813-029A	NHS-WC-C3A-3-29	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 16:18	08/07/2024 10:31
24080813-030A	NHS-BF-C3A-3-30	NELAP		1.0	1.6	µg/L	1	08/13/2024 16:22	08/07/2024 10:32
24080813-031A	NHS-WC-C2A-2-31	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 16:44	08/07/2024 10:35
24080813-032A	NHS-WC-C2A-2-32	NELAP		1.0	2.0	µg/L	1	08/13/2024 16:48	08/07/2024 10:36
24080813-033A	NHS-BF-C2A-2-33	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 16:51	08/07/2024 10:37
24080813-034A	NHS-WC-C2A-2-34	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 16:55	08/07/2024 10:40
24080813-035A	NHS-WC-C2A-2-35	NELAP		1.0	1.0	µg/L	1	08/13/2024 16:59	08/07/2024 10:41
24080813-036A	NHS-BF-C3A-2-36	NELAP		1.0	1.7	µg/L	1	08/13/2024 17:02	08/07/2024 10:42
24080813-037A	NHS-WC-C1A-1-37	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:06	08/07/2024 10:46
24080813-038A	NHS-WC-C1A-1-38	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:10	08/07/2024 10:47
24080813-039A	NHS-BF-C1A-1-39	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:24	08/07/2024 10:48
24080813-040A	NHS-WC-C1A-1-40	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:28	08/07/2024 10:49
24080813-041A	NHS-WC-C1A-1-41	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:32	08/07/2024 10:50
24080813-042A	NHS-BF-C1A-1-42	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:35	08/07/2024 10:51
24080813-043A	NHS-WC-CAFÉ-1-43	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:39	08/07/2024 10:55
24080813-044A	NHS-WC-CAFÉ-1-44	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:43	08/07/2024 10:56
24080813-045A	NHS-BF-CAFÉ-1-45	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 17:46	08/07/2024 10:57
24080813-046A	NHS-F-211A-2-46	NELAP		1.0	2.6	µg/L	1	08/15/2024 16:43	08/07/2024 11:02
24080813-047A	NHA-F-211A-2-47	NELAP		1.0	1.7	µg/L	1	08/15/2024 18:22	08/07/2024 11:03
24080813-048A	NHS-F-211A-2-48	NELAP		1.0	1.5	µg/L	1	08/15/2024 18:26	08/07/2024 11:04



Laboratory Results

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 24080813

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24080813-049A	NHS-F-211A-2-49	NELAP		1.0	2.3	µg/L	5	08/16/2024 14:42	08/07/2024 11:05
24080813-050A	NHS-F-211A-2-50	NELAP		1.0	2.3	µg/L	5	08/16/2024 14:57	08/07/2024 11:06



Receiving Check List

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 24080813

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Carrier: Craig McKinney

Received By: NR

Completed by:

On:

09-Aug-24

Amber Dilallo

Reviewed by:

On:

09-Aug-24

Ellie Hopkins

Pages to follow:

Chain of custody

5

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C N/A

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice ☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

pg. 1 of 9 Work order # 24680813

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Professional Service Industries, Inc.	Samples on: ☐ ICE ☐ BLUE ICE ☒ NO ICE <u>N/A</u> °C LTG# _____
Address: 11826 Borman Dr	Preserved in: ☒ LAB ☐ FIELD <u>FOR LAB USE ONLY</u>
City / State / Zip Maryland Heights, MO 63146	Lab Notes
Contact: Kevin Roberts Phone: (314) 432-8073	Client Comments:
E-Mail: kevin.roberts@intertek.com Fax:	

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? If yes, include details of the hazard: ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

pg. 2 of 9 Work order # 24080813

Client: Professional Service Industries, Inc. Address: 11826 Borman Dr City / State / Zip Maryland Heights, MO 63146 Contact: Kevin Roberts Phone: (314) 432-8073 E-Mail: kevin.roberts@intertek.com Fax:	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE _____ °C LTG# _____ Preserved in: ☐ LAB ☐ FIELD <u>FOR LAB USE ONLY</u> Lab Notes: Client Comments:
--	--

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? If yes, include details of the hazard ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name								MATRIX						INDICATE ANALYSIS REQUESTED														
										Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater															
Results Requested ☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other _____ ☐ 3 Day (50% Surcharge)		Billing Instructions	# and Type of Containers																											
Lab Use Only		Sample Identification	Date/Time Sampled	UNPRES	HNO ₃	NaOH	H ₂ SO ₄	HCL	Meth	OTHER NaHSO ₄																				
O11	NH5-BF-E2A-2-11	8-7-24	09:51	1							X				X															
O12	NH5-WC-E2A-2-12		09:52	1							X				X															
O13	NH5-WG-E2A-2-13		09:57	1							X				X															
O14	NH5-BF-E2A-2-14		09:58	1							X				X															
O15	NH5-F-176-I-15		10:03	1							X				X															
O16	NH5-WC-EIA-1-16		10:06	1							X				X															
O17	NH5-WC-EIA-1-17		10:07	1							X				X															
O18	NH5-BF-EIA-1-18		10:08	1							X				X															
O19	NH5-WC-EIA-1-19		10:09	1							X				X															
O20	NH5-BE-EIA-1-20 ✓		10:10	1							X				X															
Relinquished By			Date/Time			Received By			Date/Time																					
Brenden Helby			8/7/24 / 13:50			Nick Reed			8/8/24 / 1235																					
			8/8/24 / 1420						8/8/24 / 1425																					

CHAIN OF CUSTODY

pg. 3 of 9 Work order # 24080813

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Professional Service Industries, Inc. Address: 11826 Borman Dr City / State / Zip: Maryland Heights, MO 63146 Contact: Kevin Roberts Phone: (314) 432-8073 E-Mail: kevin.roberts@intertek.com Fax:	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE °C LTG# Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes Client Comments:
---	--

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? If yes, include details of the hazard: ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED														
Normandy - High School 0029-6396		BH / DI																		
Results Requested ☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers UNPRES HNO3 NaOH H2SO4 HCL MeOH NaHSO4 OTHER		Aqueous Drinking Water Soil Sludge Special Waste Groundwater Lead														
Lab Use Only	Sample Identification	Date/Time Sampled																		
24080813	NHS-WC-EIB-1-21	8-7-24 10:11	1			X														
022	NHS-WC-EIB-1-22	10:12	1			X														
023	NHS-BF-EIB-1-23	10:13	1			X														
024	NHS-F-OBR-1-24	10:16	1			X														
025	NHS-WC-C3A-3-25	10:27	1			X														
026	NHS-WC-C3A-3-26	10:28	1			X														
027	NHS-BF-C3A-3-27	10:29	1			X														
028	NHS-WC-C3A-3-28	10:30	1			X														
029	NHS-WC-C3A-3-29	10:31	1			X														
030	NHS-BF-C3A-3-30	10:32	1			X														
Relinquished By		Date/Time		Received By		Date/Time														
Brenden Holbig		8/7/24 13:50		Trish Reed		8/8/24 1235														
		8/8/24 1420				8/8/24 1420														

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 92106



pg. 4 of 9 Work order # 24080813

Client: Professional Service Industries, Inc. Address: 11826 Borman Dr City / State / Zip: Maryland Heights, MO 63146 Contact: Kevin Roberts Phone: (314) 432-8073 E-Mail: kevin.roberts@intertek.com Fax:		Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE °C LTG# Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes Client Comments:																																									
<p>Are these samples known to be involved in litigation? If yes, a surcharge will apply. ☐ Yes ☒ No</p> <p>Are these samples known to be hazardous? If yes, include details of the hazard. ☐ Yes ☒ No</p> <p>Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No</p>																																											
Project Name/Number Normandy - High School 0029-6396		Sample Collector's Name BH / DI																																									
Results Requested ☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)		Billing Instructions <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="8"># and Type of Containers</th> </tr> <tr> <td>UNPRES</td> <td>HNO3</td> <td>NaOH</td> <td>H2SO4</td> <td>HCL</td> <td>MeOH</td> <td>NaHSO4</td> <td>OTHER</td> </tr> </table>		# and Type of Containers								UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER																								
# and Type of Containers																																											
UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER																																				
Lab Use Only	Sample Identification	Date/Time Sampled																																									
031	NHS-WC-C2A-2-31	8-7-24 10:35	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
032	NHS-WC-C2A-2-32	10:36	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
033	NHS-BF-C2A-2-33	10:37	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
034	NHS-WC-C2A-2-34	10:40	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
035	NHS-WC-C2A-2-35	10:41	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
036	NHS-BF-C2A-2-36	10:42	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
037	NHS-WC-CIA-1-37	10:46	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
038	NHS-WC-CIA-1-38	10:47	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
039	NHS-BF-CIA-1-39	10:48	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
040	NHS-WC-CIA-1-40	10:49	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>Aqueous</td> <td>Drinking Water</td> <td>Soil</td> <td>Sludge</td> <td>Special Waste</td> <td>Groundwater</td> <td>Lead</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>	Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead														X						X													
Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																																					
X						X																																					
Relinquished By Brenden Helbig		Date/Time 8-7-24 / 13:50 8/8/24 1420																																									
Received By</																																											

CHAIN OF CUSTODY

pg. 5 of 9 Work order # 24080813

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Professional Service Industries, Inc. Address: 11826 Borman Dr City / State / Zip: Maryland Heights, MO 63146 Contact: Kevin Roberts Phone: (314) 432-8073 E-Mail: kevin.roberts@intertek.com Fax:	Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE _____ °C LTG# _____ Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY Lab Notes Client Comments:
---	--

Are these samples known to be involved in litigation? If yes, a surcharge will apply. ☐ Yes ☒ No
 Are these samples known to be hazardous? If yes, include details of the hazard. ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED																			
Normandy - High School 0029-6396		BH / DI																							
Results Requested		Billing Instructions		# and Type of Containers										Drinking Water		Soil		Sludge		Groundwater		Special Waste		Lead	
☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other _____ ☐ 3 Day (50% Surcharge)																									
Lab Use Only		Sample Identification		Date/Time Sampled		UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER	Aqueous	Drinking Water	Soil	Sludge	Groundwater	Special Waste	Lead					
24080813	041	NHS-WC-CIA-1-41	8-7-24	10:50	1									X					X						
	042	NHS-BF-CIA-1-42		10:51	1									X					X						
	043	NHS-WC-CAFE-1-43		10:55	1									X					X						
	044	NHS-WC-CAFE-1-44		10:56	1									X					X						
	045	NHS-BF-CAFE-1-45		10:57	1									X					X						
	046	NHS-F-211A-2-46		11:02	1									X					X						
	047	NHS-F-211A-2-47		11:03	1									X					X						
	048	NHS-F-211A-2-48		11:04	1									X					X						
	049	NHS-F-211A-2-49		11:05	1									X					X						
	050	NHS-F-211A-2-50	✓	11:06	1									X					X						
Relinquished By		Date/Time		Received By		Date/Time																			
Brendan Helbig		8-7-24 / 13:50		[Signature]		8/8/24 1235																			
[Signature]		8/8/24 1435		Rick Reed		8/8/24 1425																			

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 92106



August 19, 2024

Kevin Roberts
Professional Service Industries, Inc.
11826 Borman Dr
Maryland Heights, MO 63146
TEL: (314) 432-8073
FAX: (314) 432-5119



Illinois	100226
Illinois	1004652024-2
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Normandy - High School 0029-6396

WorkOrder: 24080883

Dear Kevin Roberts:

TEKLAB, INC received 35 samples on 8/8/2024 2:25:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 24080883

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended

Client: Professional Service Industries, Inc.**Work Order:** 24080883**Client Project:** Normandy - High School 0029-6396**Report Date:** 19-Aug-24**Abbr Definition**

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: Professional Service Industries, Inc.

Work Order: 24080883

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 24080883

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: Professional Service Industries, Inc.**Work Order:** 24080883**Client Project:** Normandy - High School 0029-6396**Report Date:** 19-Aug-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Illinois	IEPA	1004652024-2	NELAP	4/30/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2025	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2025	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2025	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2025	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2026	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Mississippi	MSDH			4/30/2025	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville

Client: Professional Service Industries, Inc.

Work Order: 24080883

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24080883-001A	NHS-SN-211A-2-51	NELAP		1.0	< 1.0	µg/L	5	08/16/2024 15:00	08/07/2024 11:07
24080883-002A	NHS-IM-207-2-52	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 2:08	08/07/2024 11:11
24080883-003A	NHS-KF-207-2-53	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 2:19	08/07/2024 11:12
24080883-004A	NHS-KF-207-2-54	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 2:23	08/07/2024 11:13
24080883-005A	NHS-SN-207-2-55	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 2:27	08/07/2024 11:14
24080883-006A	NHS-WF-207-2-56	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 13:26	08/07/2024 11:15
24080883-007A	NHS-WF-207-2-57	NELAP		1.0	< 1.0	µg/L	5	08/16/2024 15:04	08/07/2024 11:16
24080883-008A	NHS-F-221-2-58	NELAP		1.0	2.8	µg/L	1	08/13/2024 13:30	08/07/2024 11:18
24080883-009A	NHS-WC-W2A-2-59	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 13:33	08/07/2024 11:21
24080883-010A	NHS-BF-W2A-2-60	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 13:37	08/07/2024 11:22
24080883-011A	NHS-IM-112A-1-61	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 13:48	08/07/2024 11:28
24080883-012A	NHS-SN-112A-1-62	NELAP		1.0	1.2	µg/L	1	08/13/2024 13:52	08/07/2024 11:29
24080883-013A	NHS-KF-112A-1-63	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 13:55	08/07/2024 11:30
24080883-014A	NHS-SN-112A-1-64	NELAP		1.0	6.0	µg/L	5	08/16/2024 15:08	08/07/2024 11:31
24080883-015A	NHS-WF-112A-1-65	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 13:59	08/07/2024 11:32
24080883-016A	NHS-WF-112A-1-66	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 14:14	08/07/2024 11:33
24080883-017A	NHS-SN-112A-1-67	NELAP		1.0	< 1.0	µg/L	5	08/16/2024 15:11	08/07/2024 11:34
24080883-018A	NHS-F-101-1-68	NELAP		1.0	1.3	µg/L	1	08/13/2024 14:17	08/07/2024 11:41
24080883-019A	NHS-WC-LR-1-69	NELAP		1.0	10.8	µg/L	5	08/16/2024 15:15	08/07/2024 11:44
24080883-020A	NHS-WC-Lobby-2-70	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 14:21	08/07/2024 11:52
24080883-021A	NHS-IM-CON-2-71	NELAP		1.0	< 1.0	µg/L	1	08/13/2024 11:14	08/07/2024 11:53
24080883-022A	NHS-F-CON-2-72	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:06	08/07/2024 11:54
24080883-023A	NHS-WC-N2A-2-82	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:10	08/07/2024 12:18
24080883-024A	NHS-WC-N2B-2-83	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:13	08/07/2024 12:20
24080883-025A	NHS-WC-N1A-84	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:17	08/07/2024 12:22
24080883-026A	NHS-F-NURSE-1-85	NELAP		1.0	1.6	µg/L	1	08/16/2024 1:21	08/07/2024 12:23
24080883-027A	NHS-WC-BUS-G-86	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:24	08/07/2024 12:27
24080883-028A	NHS-WF-FH-1-87	NELAP		1.0	5.4	µg/L	1	08/16/2024 1:28	08/07/2024 12:36
24080883-029A	NHS-WF-FH-1-88	NELAP		1.0	3.7	µg/L	1	08/16/2024 1:32	08/07/2024 12:37
24080883-030A	NHS-F-FH-1-89	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:35	08/07/2024 12:38
24080883-031A	NHS-IM-FH-1-90	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:39	08/07/2024 12:39
24080883-032A	NHS-DF-FH-1-91	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:54	08/07/2024 12:41
24080883-033A	NHS-DF-FH-1-92	NELAP		1.0	< 1.0	µg/L	1	08/16/2024 1:57	08/07/2024 12:42
24080883-034A	NHS-DF-FIELD-1-93	NELAP		1.0	1.6	µg/L	1	08/16/2024 2:01	08/07/2024 12:45
24080883-035A	NHS-DF-FIELD-1-94	NELAP		1.0	1.9	µg/L	1	08/16/2024 2:05	08/07/2024 12:46



Receiving Check List

<http://www.teklabinc.com/>

Client: Professional Service Industries, Inc.

Work Order: 24080883

Client Project: Normandy - High School 0029-6396

Report Date: 19-Aug-24

Carrier: Craig McKinney

Received By: NR

Completed by:

On:

09-Aug-24

Amber Dilallo

Reviewed by:

On:

09-Aug-24

Ellie Hopkins

Pages to follow:

Chain of custody

4

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C N/A

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice ☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

pg. 6 of 9 Work order # 24080803

Client:	Professional Service Industries, Inc.	Samples on:	☐ ICE	☐ BLUE ICE	☒ NO ICE	<u>N/A</u> °C	LTG#
Address:	11826 Borman Dr	Preserved in:	☒ LAB	☐ FIELD	<u>FOR LAB USE ONLY</u>		
City / State / Zip	Maryland Heights, MO 63146	Lab Notes					
Contact:	Kevin Roberts	Phone:	(314) 432-8073				
E-Mail:	kevin.roberts@intertek.com	Fax:					
		Client Comments:					

Are these samples known to be involved in litigation? If yes, a surcharge will apply. ☐ Yes ☒ No

Are these samples known to be hazardous? If yes, include details of the hazard. ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

[illegible]

CHAIN OF CUSTODY

pg. 7 of 9 Work order # 2408083

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

Client: Professional Service Industries, Inc.
Address: 11826 Borman Dr
City / State / Zip: Maryland Heights, MO 63146
Contact: Kevin Roberts **Phone:** (314) 432-8073
E-Mail: kevin.roberts@intertek.com **Fax:**

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE °C LTG#
Preserved in: ☐ LAB ☐ FIELD **FOR LAB USE ONLY**
Lab Notes

Client Comments:

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No
 Are these samples known to be hazardous? If yes, include details of the hazard: ☐ Yes ☒ No
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED																							
Normandy - High School 0029-6396		BH/D1																											
Results Requested		Billing Instructions	# and Type of Containers										Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead										
☒ Standard ☐ 1-2 Day (100% Surcharge) ☐ Other ☐ 3 Day (50% Surcharge)			UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER																			
Lab Use Only	Sample Identification	Date/Time Sampled																											
2408083-011	NHS-IM-112A-1-61	8/7/24 - 11:28	1															X											
012	NHS-SN-112A-1-62	- 11:29	1															X											
013	NHS-KF-112A-1-63	- 11:30	1															X											
014	NHS-SN-112A-1-64	- 11:31	1															X											
015	NHS-WF-112A-1-65	- 11:32	1															X											
016	NHS-WF-112A-1-66	- 11:33	1															X											
017	NHS-SN-112A-1-67	- 11:34	1															X											
018	NHS-F-101-1-68	- 11:41	1															X											
019	NHS-WC-LR-1-69	- 11:44	1															X											
020	NHS-WC-Lobby-2-70	- 11:52	1															X											

Relinquished By		Date/Time	Received By		Date/Time
Brenden Helbig		8-7-24 / 13:50	[Signature]		8/8/24 / 1235
[Signature]		8/8/24 1435	Arih Reed		8/8/24 1425



pg. 8 of 9 Work order # 24680883

Client: Professional Service Industries, Inc.		Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE _____ °C		LTG# _____
Address: 11826 Borman Dr		Preserved in: ☐ LAB ☐ FIELD		<u>FOR LAB USE ONLY</u>
City / State / Zip Maryland Heights, MO 63146		Lab Notes		
Contact: Kevin Roberts	Phone: (314) 432-8073			
E-Mail: kevin.roberts@intertek.com	Fax: _____	Client Comments: # 73, 74, 75, 76, 77, 78, 79, 80, and 81 did		

Are these samples known to be involved in litigation? If yes, a surcharge will apply ☐ Yes ☒ No

Are these samples known to be hazardous? If yes, include details of the hazard ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section. ☐ Yes ☒ No

Client Comments: # 73, 74, 75, 76, 77, 78, 79, 80, and 81 did not sample since they did not work.

[illegible]

State of Missouri
Department of Natural Resources

**Certificate of Approval
for Chemical Laboratory Service**

This is to certify that

Teklab, Incorporated

is hereby approved to perform the analysis of drinking water as specified on the
Certified Parameter List, which must accompany this certificate to be valid.


Certification Number 930

Date Issued December 13, 2021

Expiration Date January 31, 2025



Laboratory Certification Authority, Public Drinking Water Branch
Missouri Department of Natural Resources



Laboratory Certification Officer, Environmental Services Program
Missouri Department of Natural Resources

MISSOURI DEPARTMENT OF NATURAL RESOURCES
DRINKING WATER LABORATORY
CERTIFIED PARAMETER LIST

This is to certify that

Teklab, Incorporated

located at

5445 Horseshoe Lake Road, Collinsville, IL 62234

has been approved to perform the indicated procedures on drinking water under the Missouri Public Drinking Water Regulations (10 CSR 60-5.020). Specific method numbers or references are included in parenthesis when appropriate.

INORGANIC

EPA 335.4

Total Cyanide

EPA 353.2

Nitrate, Nitrite, Total Nitrate and Nitrite

EPA 245.1

Mercury

EPA 200.7

Barium, Beryllium, Cadmium, Chromium, Copper, Nickel

EPA 200.8

Antimony, Arsenic, Barium, Beryllium, Cadmium, Chromium, Copper, Lead, Nickel, Selenium, Thallium

SM4500F-C

Fluoride

SM4500NO2-B

Nitrite

Teklab, Incorporated

Expiration Date: January 31, 2025

Missouri Certificate No.: 930

Original Certifying State: Illinois