

DRINKING WATER NOTICE

Sebring Village PWS Did Not Meet Monitoring and Reporting Requirements

We are required to monitor your drinking water for turbidity on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

- During July 2023, we did not complete all monitoring of testing for turbidity and therefore cannot be sure of the quality of your drinking water during that time. Specifically, Sebring Village PWS failed to complete all required turbidity monitoring of the filtered water or the combined filter effluent either continuously or every four hours that the water treatment plant was in operation for turbidity for 7 days during the month of July 2023.*
- During August 2023, we did not complete all monitoring or testing for turbidity and therefore cannot be sure of the quality of your drinking water during that time. Specifically, Sebring Village PWS failed to complete all required turbidity monitoring of the filtered water or the combined filter effluent either continuously or every four hours that the water treatment plant was in operation for turbidity for 1 days during the month of August 2023.*
- During September 2023, we did not complete all monitoring or testing for turbidity and therefore cannot be sure of the quality of your drinking water during that time. Specifically, Sebring Village PWS failed to complete all required turbidity monitoring of the filtered water or the combined filter effluent either continuously or every four hours that the water treatment plant was in operation for turbidity for 5 days during the month of September 2023.*

What Should I Do?

There is nothing you need to do at this time. You do not need to boil your water or take other corrective action.

What is being done?

Turbidity sampling procedures have been modified to ensure enough turbidity samples are collected each day.

For more information, please contact LEE WILLARD at 330-821-7020 or 135 E. Ohio Ave. Sebring, OH
name of contact phone number mailing address

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.