



1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 martel@martellabs.com

Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Thursday, January 9, 2025
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 78004.

First Draw samples flushed by Martel on November 4, 2024 sampled by Martel on November 5, 2024.

Project Identification: MD HB 270

School: T. C. Martin Elementary

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.

DL2020

Page 01 of

12


Project Manager



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 1	TCMES-1-IM					11/05/2024 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 19:02 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 2	TCMES-2-FC-COMP					11/05/2024 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.87	ug/l	EPA .200.8	2	12/12/2024 19:09 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 3	TCMES-3-KK					11/05/2024 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 19:11 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 4	TCMES-4-FC-COMP					11/05/2024 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	8.48	ug/l*	EPA .200.8	2	12/12/2024 19:14 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 5	TCMES-5-FC-COMP					11/05/2024 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 19:16 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 6	TCMES-6-DF-C					11/05/2024 05:03
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 19:19 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 7	TCMES-7-BF-C					11/05/2024 05:03
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 19:21 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 8	TCMES-8-FC					11/05/2024 05:03
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 19:24 BJ	

Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 martel@martellabs.com

CHARPS

01/09/2025

P 02



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 9	TCMES-9-FC					11/05/2024 05:07
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 19:26 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 10	TCMES-10-FC					11/05/2024 05:06
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 19:29 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 11	TCMES-11-C-FC					11/05/2024 05:08
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 19:38 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 12	TCMES-12-C-FC-B					11/05/2024 05:08
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 19:43 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 13	TCMES-13-C-FC					11/05/2024 05:19
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.24	ug/l*	EPA 200.8	2	12/12/2024 19:45 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 14	TCMES-14-C-FC-B					11/05/2024 05:19
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.48	ug/l	EPA 200.8	2	12/12/2024 19:48 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 15	TCMES-15-FC					11/05/2024 05:13
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 19:50 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 16	TCMES-16-FC					11/05/2024 05:13
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 19:53 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 17	TCMES-17-C-FC		11/05/2024 05:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 19:55 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 18	TCMES-18-C-FC-B		11/05/2024 05:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 19:58 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 19	TCMES-19-C-FC		11/05/2024 05:17			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:00 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 20	TCMES-20-C-FC-B		11/05/2024 05:17			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:03 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 21	TCMES-21-C-FC		11/05/2024 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:10 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 22	TCMES-22-C-FC-B		11/05/2024 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:17 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 23	TCMES-23-C-FC		11/05/2024 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:20 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 24	TCMES-24-C-FC-B		11/05/2024 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:22 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 25	TCMES-25-C-FC					11/05/2024 05:24
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:25 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 26	TCMES-26-C-FC-B					11/05/2024 05:24
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:27 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 27	TCMES-27-C-FC					11/05/2024 05:24
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 20:29 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 28	TCMES-28-C-FC-B					11/05/2024 05:24
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:32 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 29	TCMES-29-C-FC					11/05/2024 05:26
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:34 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 30	TCMES-30-C-FC-B					11/05/2024 05:26
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:37 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 31	TCMES-31-FC					11/05/2024 05:26
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:46 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 32	TCMES-32-DF-C					11/05/2024 05:30
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:51 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 33	TCMES-33-DF-C		11/05/2024 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:54 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 34	TCMES-34-BF-C		11/05/2024 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:56 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 35	TCMES-35-C-FC		11/05/2024 05:31			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 20:59 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 36	TCMES-36-C-FC-B		11/05/2024 05:31			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 21:01 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 37	TCMES-37-C-FC		11/05/2024 05:33			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 21:04 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 38	TCMES-38-C-FC-B		11/05/2024 05:33			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 21:06 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 39	TCMES-39-C-FC		11/05/2024 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 21:09 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
78004 40	TCMES-40-C-FC-B		11/05/2024 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 21:11 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 41	TCMES-41-DF-C					11/05/2024 05:36
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 21:18 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 42	TCMES-42-DF-C					11/05/2024 05:36
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 21:26 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 43	TCMES-43-BF-C					11/05/2024 05:26
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 21:28 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 44	TCMES-44-DF					11/05/2024 05:40
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 21:31 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 46	TCMES-46-DF-C					11/05/2024 05:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 21:33 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 47	TCMES-47-DF-C					11/05/2024 05:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 21:36 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 48	TCMES-48-BF-C					11/05/2024 05:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 21:38 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
78004 49	TCMES-49-DF-C					11/05/2024 05:44
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	12/12/2024 21:41 BJ	



MARTEL NO. 78004 50 CLIENT SAMPLE IDENTIFICATION TCMES-50-DF-C Sample Date/Time 11/05/2024 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 21:43 BJ

MARTEL NO. 78004 51 CLIENT SAMPLE IDENTIFICATION TCMES-51-BF-C Sample Date/Time 11/05/2024 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 21:46 BJ

MARTEL NO. 78004 52 CLIENT SAMPLE IDENTIFICATION TCMES-52-FC Sample Date/Time 11/05/2024 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 21:55 BJ

MARTEL NO. 78004 53 CLIENT SAMPLE IDENTIFICATION TCMES-53-C-FC Sample Date/Time 11/05/2024 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.66	ug/l	EPA .200.8	2	12/12/2024 22:00 BJ

MARTEL NO. 78004 54 CLIENT SAMPLE IDENTIFICATION TCMES-54-C-FC-B Sample Date/Time 11/05/2024 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 22:03 BJ

MARTEL NO. 78004 55 CLIENT SAMPLE IDENTIFICATION TCMES-55-C-FC Sample Date/Time 11/05/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 22:05 BJ

MARTEL NO. 78004 56 CLIENT SAMPLE IDENTIFICATION TCMES-56-C-FC-B Sample Date/Time 11/05/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 22:08 BJ

MARTEL NO. 78004 2F CLIENT SAMPLE IDENTIFICATION TCMES-2F-FC-COM FLUSH Sample Date/Time 11/05/2024 05:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 22:10 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78004 3F	TCMES-3F-KK FLUSH	11/05/2024 05:53			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.16	ug/l	EPA .200.8	2	12/12/2024 22:13 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78004 4F	TCMES-4F-FC-COM FLUSH	11/05/2024 05:53			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 22:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78004 5F	TCMES-5F-FC-COM FLUSH	11/05/2024 05:53			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 22:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78004 11F	TCMES-11F-C-FC FLUSH	11/05/2024 05:53			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/12/2024 22:20 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
78004 13F	TCMES-13F-C-FC FLUSH	11/05/2024 05:53			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.16	ug/l	EPA .200.8	2	12/12/2024 22:27 BJ

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: ~~11/4/24~~ 11/5/24 5:00am
 Sampler/Relinquished By: Neverson Simms-Clark
 End Date/Time: ~~11/4/24~~ 11/5/24 5:55am
 Received at Martel by: _____
 Date/Time: ~~11/4/24~~ 11/5/24

08 T.C. Martin Elementary
First Draw
 6315 Olivers Shop Road Bryantwon, MD 20617

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78004

Martel #	Sample #	Location ID #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb)	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush	Sample Time
							Flush Date	
1	1	TCMES-1-IM	Ice Machine	IM	Room 113 - Kitchen	C	11/4	5:00
2	2	TCMES-2-FC-COMP	2 Comp Sink	FC-COMP	Room 113 - Kitchen	C	11/4	5:00
3	3	TCMES-3-KK	Kettle	KK	Room 113 - Kitchen	C	11/4	5:00
4	4	TCMES-4-FC-COMP	3 Comp Sink - Right	FC-COMP	Room 113 - Kitchen	C	11/4	5:00
5	5	TCMES-5-FC-COMP	3 Comp Sink - Left	FC-COMP	Room 113 - Kitchen	C	11/4	5:00
6	6	TCMES-6-DF-C	Water Fountain - High	DF-C	Room 112 - Cafetorium	C	11/4	5:03
7	7	TCMES-7-BF-C	Water Fountain - Low	DF-C	Room 112 - Cafetorium	C	11/4	5:03
8	8	TCMES-8-FC	Bottle Filler	BF-C	Room 112 - Cafetorium	C	11/4	5:03
9	9	TCMES-9-FC	Sink	FC	Room 102 - Work Room	C	11/4	5:07
10	10	TCMES-10-FC	Sink	FC	Room 101 - Admin Conference	C	11/4	5:06
11	11	TCMES-11-C-FC	Sink	C-FC	Room 110 - Health Office	C	11/4	5:08
12	12	TCMES-12-C-FC-B	Bubbler	C-FC-B	Room 110 - Health Office	C	11/4	5:08
13	13	TCMES-13-C-FC	Sink	C-FC	Room 110C - Exam	C	11/4	5:09
14	14	TCMES-14-C-FC-B	Bubbler	C-FC-B	Room 110C - Exam	C	11/4	5:09
15	15	TCMES-15-FC	Sink	FC	Room 111B - Media Production	C	11/4	5:13
16	16	TCMES-16-FC	Sink	FC	Room 111A - Media Office	C	11/4	5:13
17	17	TCMES-17-C-FC	Sink	C-FC	Room 153 - Pre-K	C	11/4	5:15
18	18	TCMES-18-C-FC-B	Bubbler	C-FC-B	Room 153 - Pre-K	C	11/4	5:15
19	19	TCMES-19-C-FC	Sink	C-FC	Room 154 - Pre-K	C	11/4	5:17
20	20	TCMES-20-C-FC-B	Bubbler	C-FC-B	Room 154 - Pre-K	C	11/4	5:17
21	21	TCMES-21-C-FC	Sink	C-FC	Room 155 - Pre-K	C	11/4	5:20
22	22	TCMES-22-C-FC-B	Bubbler	C-FC-B	Room 155 - Pre-K	C	11/4	5:20
23	23	TCMES-23-C-FC	Sink	C-FC	Room 156 - Pre-K	C	11/4	5:20
24	24	TCMES-24-C-FC-B	Bubbler	C-FC-B	Room 156 - Pre-K	C	11/4	5:20

08 T.C. Martin Elementary

First Draw

6315 Olivers Shop Road Bryantwon, MD 20617

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78004

							Flush	78004
25	25	TCMES-25-C-FC	Sink	C-FC	Room 158 - Pre-K	c	11/4	5:24
26	26	TCMES-26-C-FC-B	Bubbler	C-FC-B	Room 158 - Pre-K	c	11/4	5:24
27	27	TCMES-27-C-FC	Sink	C-FC	Room 159 - Pre-K	c	11/4	5:24
28	28	TCMES-28-C-FC-B	Bubbler	C-FC-B	Room 159 - Pre-K	c	11/4	5:24
29	29	TCMES-29-C-FC	Sink	C-FC	Room 160 - Co-Lab	c	11/4	5:26
30	30	TCMES-30-C-FC-B	Bubbler	C-FC-B	Room 160 - Co-Lab	c	11/4	5:26
31	31	TCMES-31-FC	Sink - Right	FC	Room 160 - Co-Lab	c	11/4	5:26
32	32	TCMES-32-DF-C	Water Fountain - High	DF-C	Corridor	c	11/4	5:30
33	33	TCMES-33-DF-C	Water Fountain - Low	DF-C	Corridor	c	11/4	5:30
34	34	TCMES-34-BF-C	Bottle Filler	BF-C	Corridor	c	11/4	5:30
35	35	TCMES-35-C-FC	Sink	C-FC	Room 181 - Achieve	c	11/4	5:31
36	36	TCMES-36-C-FC-B	Bubbler	C-FC-B	Room 181 - Achieve	c	11/4	5:31
37	37	TCMES-37-C-FC	Sink	C-FC	Room 180 - SOAR	c	11/4	5:33
38	38	TCMES-38-C-FC-B	Bubbler	C-FC-B	Room 180 - SOAR	c	11/4	5:33
39	39	TCMES-39-C-FC	Sink	C-FC	Room 169 - SOAR	c	11/4	5:34
40	40	TCMES-40-C-FC-B	Bubbler	C-FC-B	Room 169 - SOAR	c	11/4	5:34
41	41	TCMES-41-DF-C	Water Fountain - High	DF-C	Corridor	c	11/4	5:36
42	42	TCMES-42-DF-C	Water Fountain - Low	DF-C	Corridor	c	11/4	5:36
43	43	TCMES-43-BF-C	Bottle Filler	BF-C	Corridor	c	11/4	5:36
44	44	TCMES-44-DF	Water Fountain	DF	Corridor	c	11/4	5:40
45	45	TCMES-45-FC	Sink ^{In mdr room}	FC	Room 121 - Speech	c	NO SAMP	NO SAMP
46	46	TCMES-46-DF-C	Water Fountain - High	DF-C	Room 124 - Gym	c	11/4	5:42
47	47	TCMES-47-DF-C	Water Fountain - Low	DF-C	Room 124 - Gym	c	11/4	5:42
48	48	TCMES-48-BF-C	Bottle Filler	BF-C	Room 124 - Gym	c	11/4	5:42
49	49	TCMES-49-DF-C	Water Fountain - High	DF-C	Corridor	c	11/4	5:44
50	50	TCMES-50-DF-C	Water Fountain - Low	DF-C	Corridor	c	11/4	5:44
51	51	TCMES-51-BF-C	Bottle Filler	BF-C	Corridor	c	11/4	5:44
52	52	TCMES-52-FC	Sink	FC	Room 143 - Staff Lounge	c	11/4	5:46
53	53	TCMES-53-C-FC	Sink	C-FC	Room 145 - Music	c	11/4	5:48
54	54	TCMES-54-C-FC-B	Bubbler	C-FC-B	Room 145 - Music	c	11/4	5:48
55	55	TCMES-55-C-FC	Sink	C-FC	Room 146 - Instrumental Music	c	11/4	5:49
56	56	TCMES-56-C-FC-B	Bubbler	C-FC-B	Room 146 - Instrumental Music	c	11/4	5:49

08 T.C. Martin Elementary

First Draw

6315 Olivers Shop Road Bryantwon, MD 20617

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78004

							Flush	
57	2F	TCMES-2F-FC-COMP	2 Comp Sink	FC-COMP	Room 113 - Kitchen	C		FLUSH 5:53
58	3F	TCMES-3F-KK	Kettle	KK	Room 113 - Kitchen	C		FLUSH 5:53
59	4F	TCMES-4F-FC-COMP	3 Comp Sink - Right	FC-COMP	Room 113 - Kitchen	C		FLUSH 5:53
60	5F	TCMES-5F-FC-COMP	3 Comp Sink - Left	FC-COMP	Room 113 - Kitchen	C		FLUSH 5:53
61	11F	TCMES-11F-C-FC	Sink	C-FC	Room 110 - Health Office	C		FLUSH 5:55
62	13F	TCMES-13F-C-FC	Sink	C-FC	Room 110C - Exam	C		FLUSH 5:55

P 12