

Facility or Building Name	Lake Harriet Lower Elementary
Did the facility test using the MDH testing	No
Facility Type (School or Child Care)	School
School ID Number or Child Care License Number	0001-03-104
Facility or Building Address	4030 Chowen Avenue South,
Mailing Address	1225 North 7th Street Minneapolis, MN 55411
Contact Person	Lee Setter
Title	Manager, EH&S
Phone	612-668-0308
Email	Lee.Setter@mpls.k12.mn.us

SUMMARY	ANSWER
Total number of samples	33
Total number of fixtures sampled	33
Total number of results above 5 ppb	0
Total number of remediation actions	0
Next Scheduled Sampling Date (Month/Year)	12/2029

Unique Sample Site	Fixture Type	Location Description	Fixture Status	Sample Collection	Laboratory	Date/Time	Date/Time	Numeric Result	Unit of	Name of Laboratory Used	Remediation Action	Other	Was Remediation Successful	Additional Notes or
0001-03-104-01	Drinking Fountain	Media Center Hallway DF	Active - Consumption	Initial - First Draw	24-15731	12/20/2024 03:40	1/6/2025 13:19	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-02	Filtered bottle filler	RM 101 Hallway FBF	Active - Consumption	Initial - First Draw	24-15732	12/20/2024 03:42	1/6/2025 13:25	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-03	Drinking Fountain	Hallway DF by RM 124 Left	Active - Consumption	Initial - First Draw	24-15733	12/20/2024 03:43	1/6/2025 13:43	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-04	Drinking Fountain	Hallway DF by RM 124 Right	Active - Consumption	Initial - First Draw	24-15734	12/20/2024 03:43	1/6/2025 14:01	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-05	Drinking Fountain	RM 125 DF	Active - Consumption	Initial - First Draw	24-15735	12/20/2024 03:45	1/6/2025 14:07	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-06	Drinking Fountain	Lunch RM DF	Active - Consumption	Initial - First Draw	24-15736	12/20/2024 03:46	1/6/2025 14:13	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-07	Sink	Kitchen Food Wash Sink	Active - Consumption	Initial - First Draw	24-15737	12/20/2024 03:48	1/6/2025 14:18	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-08	Sink	Kitchen Dish Prep Sink	Active - Consumption	Initial - First Draw	24-15738	12/20/2024 04:05	1/6/2025 14:24	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-09	Sink	Health Office Sink	Active - Consumption	Initial - First Draw	24-15739	12/20/2024 04:06	1/6/2025 14:30	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-10	Drinking Fountain	A106 Music RM DF	Active - Consumption	Initial - First Draw	24-15740	12/20/2024 04:07	1/6/2025 14:36	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-11	Drinking Fountain	RM 106 DF	Active - Consumption	Initial - First Draw	24-15741	12/20/2024 04:15	1/6/2025 14:42	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-12	Drinking Fountain	RM 107 DF	Active - Consumption	Initial - First Draw	24-15742	12/20/2024 04:18	1/6/2025 14:48	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-13	Drinking Fountain	RM 108 DF	Active - Consumption	Initial - First Draw	24-15743	12/20/2024 04:20	1/7/2025 11:47	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-14	Drinking Fountain	RM 109 DF	Active - Consumption	Initial - First Draw	24-15744	12/20/2024 04:24	1/7/2025 11:53	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-15	Drinking Fountain	RM 110 DF	Active - Consumption	Initial - First Draw	24-15745	12/20/2024 04:25	1/7/2025 12:00	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-19	Drinking Fountain	RM 114 Restroom Right	Active - Consumption	Initial - First Draw	24-15749	12/20/2024 04:29	1/7/2025 12:06	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-20	Drinking Fountain	RM 114 Restroom Left	Active - Consumption	Initial - First Draw	24-15750	12/20/2024 04:30	1/7/2025 12:12	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-21	Filtered bottle filler	RM 201 Hallway FBF	Active - Consumption	Initial - First Draw	24-15751	12/20/2024 04:32	1/7/2025 12:18	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-22	Filtered bottle filler	RM 204 Hallway FBF	Active - Consumption	Initial - First Draw	24-15752	12/20/2024 04:33	1/7/2025 12:24	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-23	Drinking Fountain	RM A213 DF	Active - Consumption	Initial - First Draw	24-15753	12/20/2024 04:34	1/7/2025 12:30	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-24	Drinking Fountain	RM A214 DF	Active - Consumption	Initial - First Draw	24-15754	12/20/2024 04:34	1/7/2025 12:48	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-25	Drinking Fountain	RM A209 DF	Active - Consumption	Initial - First Draw	24-15755	12/20/2024 04:35	1/7/2025 13:06	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-26	Drinking Fountain	RM A208 DF	Active - Consumption	Initial - First Draw	24-15756	12/20/2024 04:37	1/7/2025 13:12	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-27	Drinking Fountain	RM A207 DF	Active - Consumption	Initial - First Draw	24-15757	12/20/2024 04:38	1/7/2025 13:18	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-28	Drinking Fountain	RM A210 RR DF	Active - Consumption	Initial - First Draw	24-15758	12/20/2024 04:40	1/7/2025 13:24	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-29	Drinking Fountain	RM A211 RR DF	Active - Consumption	Initial - First Draw	24-15759	12/20/2024 04:43	1/7/2025 13:30	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-30	Drinking Fountain	RM A205 DF	Active - Consumption	Initial - First Draw	24-15760	12/20/2024 04:44	1/7/2025 13:36	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-31	Drinking Fountain	RM A206 DF	Active - Consumption	Initial - First Draw	24-15761	12/20/2024 04:44	1/7/2025 13:42	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-32	Drinking Fountain	RM A202 DF	Active - Consumption	Initial - First Draw	24-15762	12/20/2024 04:56	1/7/2025 13:48	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-33	Drinking Fountain	RM A201 DF	Active - Consumption	Initial - First Draw	24-15763	12/20/2024 04:58	1/7/2025 13:54	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-16	Sink	RM 112 Staff Lounge Sink	Active - Consumption	Initial - First Draw	24-15843	12/23/2024 05:06	1/8/2025 11:48	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-17	Filtered bottle filler	Hallway RM 111 FBF Right	Active - Consumption	Initial - First Draw	24-15844	12/23/2024 05:09	1/8/2025 11:54	ND	µg/L	Twin City Water Clinic, Inc.				
0001-03-104-18	Drinking Fountain	Hallway RM 111 DF Left	Active - Consumption	Initial - First Draw	24-15845	12/23/2024 05:12	1/8/2025 12:00	ND	µg/L	Twin City Water Clinic, Inc.				

Definitions of Reporting Fields

Field Name	Response Needed or Definition	Where does this information come
Unique Sample Site Identification Number	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	Facility
Fixture Type	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc..	Facility
Location Description	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	Facility
Fixture Status	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	Facility
Sample Collection Type	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	Facility
Laboratory Identification Number	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	Lab
Date/Time Collected	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Date/Time Analyzed	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	Lab
Numeric Result	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	Lab
Unit of Measure	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	Lab
Name of Laboratory Used For Analysis	The name of the laboratory used for sample analysis.	Lab
Remediation Action	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe	Facility
Other Remediation-Please Describe	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	Facility
Was Remediation Successful (ie. Follow-up testing below 5 ppb)	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	Facility

Other Important Terms	Definitions
Consumption	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
Non-Consumption	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested.
Active	A fixture currently able to be used.
Inactive	A fixture that has been taken out of service either temporarily or permanently
First Draw	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
Flushed	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
Initial	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
Follow-up	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead.