

Districtwide Lead in Drinking Water Sampling and Remediation Plan

2023-2025

Rye City School District

December 2024

Enviroscience Project #25715



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779

T: 631.580.3191 • F: 631.580.3195 • W: envirohealth.org

DISTRICTWIDE LEAD IN DRINKING WATER SAMPLING AND REMEDIATION PLAN

2023-2025

DECEMBER 2024

ENVIROSCIENCE PROJECT #25715

Prepared for: RYE CITY SCHOOL DISTRICT
555 Theodore Fremd Avenue, Suite B101
Rye, NY 10580

Prepared by: ENVIROSCIENCE CONSULTANTS, LLC
2150 Smithtown Avenue
Ronkonkoma, New York 11779
(631) 580-3191

Project Manager: *Pam Chadderton*

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>
1.0	Executive Summary
2.0	Sampling Methodology
3.0	Initial Results

Appendices

Appendix A	Midland Elementary School
Appendix B	Milton Elementary School
Appendix C	Osborne Elementary School
Appendix D	Rye Middle School and High School

1.0 EXECUTIVE SUMMARY

The Rye City School District has developed their 2023-2025 Lead in Drinking Water Sampling and Remediation Plan, as required by the New York State Department of Health (Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water).

In accordance with the regulation, this Lead Remediation Plan is prepared to identify locations deemed as Applicable Drinking Water Sources and report first draw sample results, to mitigate locations where sample results exceed 5 parts per billion, to identify locations deemed as Non-Applicable Water Sources, communicate this designation to building occupants, and to develop strategies for monitoring locations deemed Non-Applicable Water Sources to insure building occupants do not consume water from these locations.

The following locations within the Rye City School District buildings have been deemed Applicable Drinking Water Sources by the administration:

- 1) Water fountains and bottle filling stations;
- 2) Kitchen water faucets and pot fillers used in food preparation;
- 3) Ice machines
- 4) Home Economics classroom sinks
- 5) Elementary Student Bathroom sinks
- 6) Nurse's Office and Faculty Room sinks

First draw samples were collected from each of these locations within the district and analyzed by a New York State Department of Health ELAP certified laboratory. The chains of custody are available upon request. For results at or below 5 ppb, no further action is required until 2025. For locations above 5 ppb, options include: second and third draw sample collection to determine source of lead, designation of the location as Non-applicable Water Source, or permanent removal of the fixture from the location. In either case, the result was communicated by Enviroscience Consultants, and the fixture was shut off by the district immediately upon receipt of results.

The following locations within the Rye City School District buildings were deemed Non-Applicable Water Sources by the administration:

- 1) Science Laboratory sinks
- 2) Art Room sinks
- 3) Technical Classroom sinks
- 4) Other Classroom sinks
- 5) Bathroom sinks
- 6) Outside spigots
- 7) Custodial Closet sinks
- 8) Mixed Valve sinks (or hot only)

In these cases, the Rye City School District staff have placed signs adjacent to the fixture to notify occupants that the water is not intended for consumption. To further support this protocol, the following management of the locations is required:

- 1) Science Laboratory sinks - communicate in writing with students that these locations are for science experiments and hand washing only, not for consumption. This is most easily accomplished by including this language in the laboratory safety paperwork distributed to students at the beginning of the Milton Elementary School024. This program should be monitored by the respective science teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 2) Art Room sinks - communicate in writing to students that these locations are for cleaning of art supplies and hand washing only, not for consumption. This is most easily accomplished by including this language in the course paperwork distributed to students at the beginning of the Milton Elementary School024. This program should be monitored by the respective art teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 3) Technical Classroom sinks - classrooms in this category often include wood shop or auto mechanics classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 4) Other classroom sinks - classrooms in this category often include elementary classrooms, where students are to hand wash after bathroom usage or activities as part

of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.

- 5) Bathroom sinks - in intermediate buildings, signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like in bathrooms, so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 6) Outside spigots - all-weather signage will be installed at each location. Further, spigots will have a special key maintained by the custodial staff to ensure that non-authorized persons do not fill sports coolers or use hoses for consumption. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 7) Custodial Closet sinks - these locations should be accessed by custodial personnel only and locked when not in use. Access to others should be restricted. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 8) Mixed Valve sinks (or hot only) – per Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water mixed valve or hot water only sources are not required to be sampled. Signage is required for these sources. Signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.

All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

2.0 SAMPLING METHODOLOGY

In accordance with the regulation, Enviroscience Consultants, LLC performed initial water sampling at the Rye City School District buildings on December 11 and 20, 2024. Samples were collected in wide-mouth 250 milliliter containers and were collected in the morning hours before the facilities opened. The water sources were not used for at least 8 hours and not more than 18 hours prior to sampling. Unique source numbers and designations were assigned to each source location. Unique sample identification numbers were assigned to each sample taken. The key to fixture type codes, source designations, and the sampling location schematics are shown below.

Code Key for Lead in Water			
Fixture Type Codes			
BF	Bottle Filler	SK	Sink
HB	Hose Bib	SL	Supply Line
IM	Ice Machine	SP	Spigot
OS	Other Source	SPY	Spray
PF	Pot Filler	SS	Slop Sink
		V	Valve
		WC	Water Cooler
		WF	Water Fountain
Source Designations			
App	Applicable	N/A	Non-applicable

3.0 Initial Results

All water source locations in each of the school buildings were assessed. Water source locations identified as drinking water sources were considered Applicable, and first draw samples were collected. Water source locations identified as non-drinking water sources were considered non-applicable and these locations were documented.

The results of the initial sampling and the use of signs warning against water use at non-applicable sources is documented in the School Water Outlet Inventory for each building.

All elevated locations should be taken off line until the remediation is completed. Any other drinking water sources in these buildings that were not functional at the time of initial sampling and have not been tested should be tested before returning to service. All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

The following is a summary of results in parts per billion (ppb) of locations in the Rye City School District where sample results were found above 5 ppb:

Midland Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen- Prep Sink	18.0	12/20/24	Removed from Service Pending Remediation

Milton Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room G-04 Bathroom Sink	11.0	12/11/24	Sign Posted

Osborne Elementary School

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room 39 Bathroom Sink	10.0	12/11/24	Sign Posted
Room 38 Bathroom Sink	21.0	12/11/24	Sign Posted

Rye Middle School and High School

SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room 111 Principal's Office Bathroom Sink	24.0	12/11/24	Sign Posted
Room 120 English Office Kitchenette	6.0	12/11/24	Removed from Service Pending Remediation

Appendix A
Midland Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Serving Line Handwash	SK	N/A		12/11/2024				Sign
1001-2	Kitchen 3 Bay	SK	N/A		12/11/2024				Sign
1001-3	Kitchen Prep	SK	App	8.0	12/20/2024	<1.0	<1.0		Removed from Service, Fixture Replacement Required
				6.0	12/11/2024				Removed from Service Pending Retest
1001-4	Kitchen Handwash	SK	N/A		12/11/2024				Sign
1001-5	Kitchen Bathroom	SK	N/A		12/11/2024				Sign
1001-6	Kitchen Custodial Closet	SS	N/A		12/11/2024				Sign
1002-1	Cafeteria	BF	App	<1.0	12/11/2024				
1002-2	Cafeteria	WF	App	<1.0	12/11/2024				
1002-3	Cafeteria Handwash	SK	N/A		12/11/2024				Sign
1002-4	Cafeteria Boy's Bathroom	SK	N/A		12/11/2024				Sign
1002-5	Cafeteria Girl's Bathroom	SK	N/A		12/11/2024				Sign
1003-1	Room 304	SK	N/A		12/11/2024				Sign
1033-2	Room 304	SPY	N/A		12/11/2024				Sign
1004-1	Unisex ADA Bsathroom	SK	N/A		12/11/2024				Sign
1005-1	Unisex Bathroom across from Room 14	SK	N/A		12/11/2024				Sign
1006-1	Boy's Bathroom by Room 1 @ A	SK	N/A		12/11/2024				Sign
1006-2	Boy's Bathroom by Room 1 @ B	SK	N/A		12/11/2024				Sign
1007-1	Custodial Closet by Room 1	SS	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1008-1	Girl's Bathroom by Room 1 @ A	SK	N/A		12/11/2024				Sign
1008-2	Girl's Bathroom by Room 1 @ B	SK	N/A		12/11/2024				Sign
1009-1	Hall by Room 129	BF	App	<1.0	12/11/2024				
1009-2	Hall by Room 129	WF	App	<1.0	12/11/2024				
1010-1	Room 126	SK	N/A		12/11/2024				Sign
1011-1	Room 124	SK	N/A		12/11/2024				Sign
1012-1	Room 123	SK	N/A		12/11/2024				Sign
1013-1	Room 122	SK	N/A		12/11/2024				Sign
1014-1	Room 121	SK	N/A		12/11/2024				Sign
1015-1	Room 120	SK	N/A		12/11/2024				Sign
1016-1	Room 119	SK	N/A		12/11/2024				Sign
1017-1	Room 118	SK	N/A		12/11/2024				Sign
1018-1	Room 117	SK	N/A		12/11/2024				Sign
1019-1	Room 116	SK	N/A		12/11/2024				Sign
1020-1	Room 115	SK	N/A		12/11/2024				Sign
1021-1	Girl's Bathroom by Room 14 @ A	SK	N/A		12/11/2024				Sign
1021-2	Girl's Bathroom by Room 14 @ B	SK	N/A		12/11/2024				Sign
1022-1	Custodial Closed by Room 14	SS	N/A		12/11/2024				Sign
1023-1	Hall by Room 107	BF	App	<1.0	12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1023-2	Hall by Room 107	WF	App	<1.0	12/11/2024				
1024-1	Faculty Room	SK	N/A		12/11/2024				Sign
1024-1	Faculty Room Bathroom	SK	N/A		12/11/2024				Sign
1025-1	Boy's Bathroom by Room 14 @A	SK	N/A		12/11/2024				Sign
1025-2	Boy's Bathroom by Room 14 @ B	SK	N/A		12/11/2024				Sign
1026-1	Music Room 105	SK	N/A		12/11/2024				Sign
1027-1	Gym Storage/Office @ A	SK	N/A		12/11/2024				Sign
1027-2	Gym Storage/Office @ B	SK	N/A		12/11/2024				Sign
1028-1	Library Office	SK	N/A		12/11/2024				Sign
1029-1	Band Room 103 @ A	SK	N/A		12/11/2024				Sign
1029-2	Band Room 103 @ B	SK	N/A		12/11/2024				Fixture Removed
1030-1	Main Office Copy Room sink	SK	N/A		12/11/2024				Sign
1030-2	Principal's Office Bathroom	SK	N/A		12/11/2024				Sign
1031-1	Hall by Main Lobby	BF	App	<1.0	12/11/2024				
1031-2	Hall by Main Lobby	WF	App	<1.0	12/11/2024				
1032-1	Girl's Bathroom by Main Lobby	SK	N/A		12/11/2024				Sign
1033-1	Boy's Bathroom by Main Lobby	SK	N/A		12/11/2024				Sign
1034-1	Hall by Room 221	BF	App	<1.0	12/11/2024				
1034-2	Hall by Room 221	WF	App	<1.0	12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1035-1	Room 224	SK	N/A		12/11/2024				Sign
1036-1	Room 222	SK	N/A		12/11/2024				Sign
1037-1	Room 221	SK	N/A		12/11/2024				Sign
1038-1	Room 220	SK	N/A		12/11/2024				Sign
1039-1	Room 219	SK	N/A		12/11/2024				Sign
1040-1	Room 218	SK	N/A		12/11/2024				Sign
1041-1	Room 217	SK	N/A		12/11/2024				Sign
1042-1	Room 216	SK	N/A		12/11/2024				Sign
1043-1	Room 215	SK	N/A		12/11/2024				Sign
1044-1	Hall by Room 215	BF	App	<1.0	12/11/2024				
1044-2	Hall by Room 215	WF	App	<1.0	12/11/2024				
1045-1	Boy's Bathroom by Room 401 @ A	SK	N/A		12/11/2024				Sign
1045-2	Boy's Bathroom by Room 401 @ B	SK	N/A		12/11/2024				Sign
1046-1	Hall by Room 401	BF	App	<1.0	12/11/2024				
1046-2	Hall by Room 401	WF	App	<1.0	12/11/2024				
1047-1	Girl's Bathroom by Room 401 @ A	SK	N/A		12/11/2024				Sign
1047-2	Girl's Bathroom by Room 401 @ B	SK	N/A		12/11/2024				Sign
1048-1	Room 401	SK	N/A		12/11/2024				Sign
1049-1	Room 409	SK	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1050-1	Art Room 406 @ A	SK	N/A		12/11/2024				Sign
1050-2	Art Room 406 @ B	SK	N/A		12/11/2024				Sign
1051-1	Custodial Closet by Room 406	SS	N/A		12/11/2024				Sign
1052-1	Kindergarten Cut Through Hall	SK	N/A		12/11/2024				Sign
1053-1	Room 40	SK	N/A		12/11/2024				Sign
1054-1	Bathroom by Room 211	SK	N/A		12/11/2024				Sign
1055-1	Room 210	SK	N/A		12/11/2024				Sign
1056-1	Room 210/209 Bathroom	SK	App	2.0	12/11/2024				
1057-1	Room 209	SK	N/A		12/11/2024				Sign
1058-1	Room 208	SK	N/A		12/11/2024				Sign
1059-1	Hall by Room 208	BF	App	<1.0	12/11/2024				
1059-2	Hall by Room 208	WF	App	<1.0	12/11/2024				
1060-1	Room 207	SK	N/A		12/11/2024				Sign
1061-1	Room 206	SK	N/A		12/11/2024				Sign
1062-1	Room 205	SK	N/A		12/11/2024				Sign
1063-1	Nurse's Office	SK	App	<1.0	12/11/2024				
1063-2	Nurse's Office Bathroom	SK	N/A		12/11/2024				Sign
1064-1	Unisex Bathroom by Nurse's Office	SK	N/A		12/11/2024				Sign

Laboratory Report

NYE Report #: 2407406-31871

December 12, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Rye City School District; Midland Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 11, 2024. New York Environmental analyzed the samples on December 12, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	11 Dec 2024
Date Received:	11 Dec 2024
Date Analyzed:	12 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241211O012	1	Kitchen Prep-SK, Initial	0.001	0.006	mg/L	H
241211O013	2	Cafeteria -BF, Initial	0.001	<0.001	mg/L	
241211O014	3	Cafeteria -WF, Initial	0.001	<0.001	mg/L	
241211O015	4	Hall by Room 129-BF, Initial	0.001	<0.001	mg/L	
241211O016	5	Hall by Room 129-WF, Initial	0.001	<0.001	mg/L	
241211O017	6	Hall by Room 107-BF, Initial	0.001	<0.001	mg/L	
241211O018	7	Hall by Room 107-WF, Initial	0.001	<0.001	mg/L	
241211O019	8	Hall by Main Lobby-BF, Initial	0.001	<0.001	mg/L	
241211O020	9	Hall by Main Lobby-WF, Initial	0.001	<0.001	mg/L	
241211O021	10	Hall by Room 221-BF, Initial	0.001	<0.001	mg/L	
241211O022	11	Hall by Room 221-WF, Initial	0.001	<0.001	mg/L	
241211O023	12	Hall by Room 215-BF, Initial	0.001	<0.001	mg/L	
241211O024	13	Hall by Room 215-WF, Initial	0.001	<0.001	mg/L	
241211O025	14	Hall by Room 401-WF, Initial	0.001	<0.001	mg/L	
241211O026	15	Hall by Room 401-WF, Initial	0.001	<0.001	mg/L	
241211O027	16	Room 210/209 Bathroom-SK, Initial	0.001	0.002	mg/L	
241211O028	17	Hall by Room 208-BF, Initial	0.001	<0.001	mg/L	
241211O029	18	Hall by Room 208-WF, Initial	0.001	<0.001	mg/L	
241211O030	19	Nurse's Office-SK, Initial	0.001	0.002	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

NYE Report #: 2407511-31938

December 23, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Rye City School District; Midland Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 20, 2024. New York Environmental analyzed the samples on December 23, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 Dec 2024
Date Received:	20 Dec 2024
Date Analyzed:	23 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241220J002	1A	Kitchen-Prep-SK, Initial	0.001	0.008	mg/L	H
241220J003	1B	Kitchen-Prep-SK, 15 Sec Flush	0.001	<0.001	mg/L	
241220J004	1C	Kitchen-Prep-SK, 60 Sec Flush	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix B
Milton Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2001-1	Hall by Room 202 - Left	WF	App	<1.0	12/11/2024				-
2001-2	Hall by Room 202 - Right	WF	App	<1.0	12/11/2024				-
2002-1	Room 201	SK	N/A		12/11/2024				Sign
2003-1	Room 202	SK	N/A		12/11/2024				Sign
2004-1	Room 203	SK	N/A		12/11/2024				Sign
2005-1	Room 204A	SK	N/A		12/11/2024				Sign
2006-1	Room 206	SK	N/A		12/11/2024				Sign
2007-1	Room 205	SK	N/A		12/11/2024				Sign
2008-1	Room 207	SK	N/A		12/11/2024				Sign
2009-1	Hall by Room 207 (Left) Bottle Filler	BF	App	<1.0	12/11/2024				-
2009-2	Hall by Room 207 (Right)	WF	App	<1.0	12/11/2024				-
2010-1	Boys Bathroom by Room 207 @ A	SK	N/A		12/11/2024				Sign
2010-2	Boys Bathroom by Room 207 @ B	SK	N/A		12/11/2024				Sign
2010-3	Boys Bathroom by Room 207 @ C	SK	N/A		12/11/2024				Sign
2011-1	Custodial Closet by Room 207	SS	N/A		12/11/2024				Sign
2012-1	Girls Bathroom by Room 207 @ A	SK	N/A		12/11/2024				Sign
2012-2	Girls Bathroom by Room 207 @ B	SK	N/A		12/11/2024				Sign
2013-1	Womens Bathroom by Room 208	SK	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2014-1	Room 208	SK	N/A		12/11/2024				Sign
2015-1	Mens Bathroom by Room 208	SK	N/A		12/11/2024				Sign
2016-1	Room 210	SK	N/A		12/11/2024				Sign
2017-1	Hall by Room 209	WF	App	<1.0	12/11/2024				-
2018-1	Room 209	SK	App	<1.0	12/11/2024				-
2019-1	Room 211	SK	N/A		12/11/2024				Sign
2020-1	Room 213	SK	N/A		12/11/2024				Sign
1001-1	Art Room 110 @ A (Left)	SK	N/A		12/11/2024				Sign
1001-2	Art Room 110 @ B (Left Middle)	SK	N/A		12/11/2024				Sign
1001-3	Art Room 110 @ C (Righ Middle)	SK	N/A		12/11/2024				Sign
1001-4	Art Room 110 @ D (Right)	SK	N/A		12/11/2024				Sign
1002-1	Media Center 114 Storage Closet	SK	N/A		12/11/2024				Sign
1004-1	Room 108	SK	N/A		12/11/2024				Sign
1005-1	Womens Bathroom by Room 108	SK	N/A		12/11/2024				Sign
1006-1	Girls Bathroom by Room 108 @ A	SK	N/A		12/11/2024				Sign
1006-2	Girls Bathroom by Room 108 @ B	SK	N/A		12/11/2024				Sign
1006-3	Girls Bathroom by Room 108 @ C	SK	N/A		12/11/2024				Sign
1007-1	Custodial Closet by Room 108	SS	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1008-1	Boys Bathroom by Room 108 @ A	SK	N/A		12/11/2024				Sign
1008-2	Boys Bathroom by Room 108 @ B	SK	N/A		12/11/2024				Sign
1008-3	Boys Bathroom by Room 108 @ C	SK	N/A		12/11/2024				Sign
1009-1	Hall by Room 107 - Left	BF	App	<1.0	12/11/2024				-
1009-2	Hall by Room 107 - Right	WF	App	<1.0	12/11/2024				-
1010-1	Room 107	SK	N/A		12/11/2024				Sign
1011-1	Room 105	SK	N/A		12/11/2024				Sign
1012-1	Room 104	SK	N/A		12/11/2024				Sign
1013-1	Room 103	SK	N/A		12/11/2024				Sign
1014-1	Room 102	SK	N/A		12/11/2024				Sign
1015-1	Room 101	SK	N/A		12/11/2024				Sign
1016-1	Hall by Room 101 - Left	WF	App	<1.0	12/11/2024				-
1016-2	Hall by Room 101 - Right	WF	App	<1.0	12/11/2024				-
0001-1	Hall by Nurses Office - Left	WF	App	<1.0	12/11/2024				-
0001-2	Hall by Nurses Office - Right	BF	App	<1.0	12/11/2024				-
0001-3	Hall by Nurses Office - Right	WF	App	<1.0	12/11/2024				-
0002-1	Womens Bathroom by Nurses Office	SK	N/A		12/11/2024				Sign
0003-1	Mens Bathroom by Nurses Office	SK	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0004-1	Nurses Office	SK	App	2.0	12/11/2024				-
0004-2	Nurses Office Storage Closet Fridge	IM	App	<1.0	12/11/2024				-
0004-3	Nurses Office Bathroom	SK	App	<1.0	12/11/2024				-
0005-1	Kitchen Handwash @ A	SK	N/A		12/11/2024				Sign
0005-2	Kitchen Prep	SK	App	2.0	12/11/2024				-
0005-3	Kitchen Handwash @ B	SK	N/A		12/11/2024				Sign
0005-4	Kitchen 3 Bay (Left)	SK	N/A		12/11/2024				Sign
0005-5	Kitchen 3 Bay (Right)	SPY	N/A		12/11/2024				Sign
0005-6	Kitchen Custodial Area	SS	N/A		12/11/2024				Sign
0005-7	Kitchen Bathroom	SK	N/A		12/11/2024				Sign
0006-2	Girls Bathroom by Kitchen @ B	SK	N/A		12/11/2024				Sign
0006-3	Girls Bathroom by Kitchen @ C	SK	N/A		12/11/2024				Sign
0007-1	Boys Bathroom by Kitchen @ A	SK	N/A		12/11/2024				Sign
0007-2	Boys Bathroom by Kitchen @ B	SK	N/A		12/11/2024				Sign
0007-3	Boys Bathroom by Kitchen @ C	SK	N/A		12/11/2024				Sign
0008-1	Room G-02	WF	App		12/11/2024				Removed from Service
0008-2	Room G-02	SK	N/A		12/11/2024				Sign
0008-3	Room G-02 Bathroom	SK	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0009-1	Main Office Bathroom	SK	N/A		12/11/2024				Sign-mixed valve
0010-1	Room G-03	WF	App		12/11/2024				Removed from Service
0010-2	Room G-03	SK	N/A		12/11/2024				Sign
0010-3	Room G-03 Bathroom	SK	App	4.0	12/11/2024				-
0011-1	Room G-04	WF	App		12/11/2024				Removed from Service
0011-2	Room G-04	SK	N/A		12/11/2024				Sign
0011-3	Room G-04 Bathroom	SK	App	11.0	12/11/2024				Sign Posted
0012-1	Boys Bathroom by Room G-04 @ A	SK	N/A		12/11/2024				Sign
0012-2	Boys Bathroom by Room G-04 @ B	SK	N/A		12/11/2024				Sign
0012-3	Boys Bathroom by Room G-04 @ C	SK	N/A		12/11/2024				Sign
0012-4	Boys Bathroom by Room G-04 @ D	SK	N/A		12/11/2024				Sign
0013-1	Custodial Closet by Room G-04	SS	N/A		12/11/2024				Sign
0014-1	Girls Bathroom by Room G-04 @ A	SK	N/A		12/11/2024				Sign
0014-2	Girls Bathroom by Room G-04 @ B	SK	N/A		12/11/2024				Sign
0015-1	Boiler Room	SS	N/A		12/11/2024				Sign
0016-1	Hall by Room ES1	WF	App	<1.0	12/11/2024				-
0017-1	Room ES1	SK	N/A		12/11/2024				Sign
0017-2	Room ES1 Bathroom	SK	App	1.0	12/11/2024				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0018-1	Faculty Room ES10	SK	App	<1.0	12/11/2024				-
0018-2	Faculty Room ES10 Mens Bathroom	SK	N/A		12/11/2024				Sign
0018-3	Faculty Room ES10 Womens Bathroom	SK	N/A		12/11/2024				Sign
0019-1	Room ES9	SK	N/A		12/11/2024				Sign

Laboratory Report

NYE Report #: 2407409-31873

December 12, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Rye City SD; Milton Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 11, 2024. New York Environmental analyzed the samples on December 12, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	11 Dec 2024
Date Received:	11 Dec 2024
Date Analyzed:	12 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241211O060	1	Hall by Room 202 - Left-WF, Initial	0.001	<0.001	mg/L	
241211O061	2	Hall by Room 202 - Right-WF, Initial	0.001	<0.001	mg/L	
241211O062	3	Hall by Room 207 (Left) Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O063	4	Hall by Room 207 (Right)-WF, Initial	0.001	<0.001	mg/L	
241211O064	5	Room 209-SK, Initial	0.001	<0.001	mg/L	
241211O065	6	Hall by Room 107 - Left-BF, Initial	0.001	<0.001	mg/L	
241211O066	7	Hall by Room 107 - Right-WF, Initial	0.001	<0.001	mg/L	
241211O067	8	Hall by Room 101 - Left-WF, Initial	0.001	<0.001	mg/L	
241211O068	9	Hall by Room 101 - Right-WF, Initial	0.001	<0.001	mg/L	
241211O069	10	Hall by Nurses Office - Left-WF, Initial	0.001	<0.001	mg/L	
241211O070	11	Hall by Nurses Office - Right -BF, Initial	0.001	<0.001	mg/L	
241211O071	12	Hall by Nurses Office - Right -WF, Initial	0.001	<0.001	mg/L	
241211O072	13	Nurses Office-SK, Initial	0.001	0.002	mg/L	
241211O073	14	Nurses Office Storage Closet Fridge-IM, Initial	0.001	<0.001	mg/L	
241211O074	15	Nurses Office Bathroom-SK, Initial	0.001	<0.001	mg/L	
241211O075	16	Kitchen Prep -SK, Initial	0.001	0.002	mg/L	
241211O076	17	Room G-03 Bathroom-SK, Initial	0.001	0.004	mg/L	
241211O077	18	Room G-04 Bathroom-SK, Initial	0.001	0.011	mg/L	H
241211O078	19	Hall by Room ES1-WF, Initial	0.001	<0.001	mg/L	
241211O079	20	Room ES1 Bathroom-SK, Initial	0.001	0.001	mg/L	
241211O080	21	Faculty Room ES10-SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Appendix C
Osborne Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen Bathroom	SK	N/A		12/11/2024				Sign
1001-2	Kitchen Handwash	SK	N/A		12/11/2024				Sign
1001-3	Kitchen Prep	SK	App	3.0	12/11/2024				-
1001-4	Kitchen Prep	SPY	App	2.0	12/11/2024				-
1001-5	Kitchen 3-Bay @ A	SK	N/A		12/11/2024				Sign
1001-6	Kitchen 3-Bay @ B	SK	N/A		12/11/2024				Sign
1002-1	Faculty Room	SK	App	2.0	12/11/2024				-
0	Faculty Room	SPY	App	1.0	12/11/2024				
1003-1	Childs Bathroom by Faculty Room	SK	App	<1.0	12/11/2024				-
1004-1	Hall by Faculty Room	BF	App	<1.0	12/11/2024				-
1004-2	Hall by Faculty Room	WF	App	<1.0	12/11/2024				-
1005-1	Childs Bathroom by Gym	SK	App	<1.0	12/11/2024				-
1006-1	Custodial Closet by Gym	SS	N/A		12/11/2024				Sign
1007-1	Gym Coach's Office	SK	N/A		12/11/2024				Sign
1008-1	Boy's Bathroom by Media Center @ A	SK	N/A		12/11/2024				Sign
1008-2	Boy's Bathroom by Media Center @ B	SK	N/A		12/11/2024				Sign
1008-3	Boy's Bathroom by Media Center @ C	SK	N/A		12/11/2024				Sign
1009-1	Custodial Closet by Media Center	SS	NA		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1010-1	Hall by Media Center	BF	App	<1.0	12/11/2024				-
1010-2	Hall by Media Center	WF	App	<1.0	12/11/2024				-
1011-1	Girl's Bathroom by Media Center @ A	SK	N/A		12/11/2024				Sign
1011-2	Girl's Bathroom by Media Center @ B	SK	N/A		12/11/2024				Sign
1011-3	Girl's Bathroom by Media Center @ C	SK	N/A		12/11/2024				Sign
1011-4	Girl's Bathroom by Media Center @ d	SK	N/A		12/11/2024				Sign
1012-1	Room 4	SK	N/A		12/11/2024				Sign
1013-1	Room 5	SK	N/A		12/11/2024				Sign
1014-1	Room 6	SK	N/A		12/11/2024				Sign
1015-1	Room 7	SK	N/A		12/11/2024				Sign
1016-1	Room 8	SK	N/A		12/11/2024				Sign
1017-1	Room 9	SK	N/A		12/11/2024				Sign
1018-1	Room 10	SK	N/A		12/11/2024				Sign
1020-1	Room 12	SK	N/A		12/11/2024				Sign
1021-1	Room 13	SK	N/A		12/11/2024				Sign
1022-1	Room 14H Special Services	SK	App	2.0	12/11/2024				-
1023-1	Faculty Bathroom by Computer Room	SK	N/A		12/11/2024				Sign
1024-1	Custodial Closet by Computer Room	SS	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1025-1	Boy's Bathroom by Computer Room @ A	SK	N/A		12/11/2024				Sign
1025-2	Boy's Bathroom by Computer Room @ B	SK	N/A		12/11/2024				Sign
1026-1	Hall by Computer Room	BF	App	<1.0	12/11/2024				-
1026-2	Hall by Computer Room	WF	App	<1.0	12/11/2024				-
1027-1	Girl's Bathroom by Computer Room @ A	SK	N/A		12/11/2024				Sign
1027-2	Girl's Bathroom by Computer Room @ B	SK	N/A		12/11/2024				Sign
1027-3	Girl's Bathroom by Computer Room @ C	SK	N/A		12/11/2024				Sign
1028-1	Room 16	SK	N/A		12/11/2024				Sign
1029-1	Room 17	SK	N/A		12/11/2024				Sign
1030-1	Room 18	SK	N/A		12/11/2024				Sign
1030-1	Room 18	SK	N/A		12/11/2024				Sign
1031-1	Room 19	SK	N/A		12/11/2024				Sign
1032-1	Room 20	SK	N/A		12/11/2024				Sign
1033-1	Room 21	SK	N/A		12/11/2024				Sign
1034-1	Room 22	SK	N/A		12/11/2024				Sign
1035-1	Room 23	SK	N/A		12/11/2024				Sign
1036-2	Boy's Bathroom by Room 29 @ B	SK	N/A		12/11/2024				Sign
1036-3	Boy's Bathroom by Room 29 @ C	SK	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1036-4	Boy's Bathroom by Room 29 @ D	SK	N/A		12/11/2024				Sign
1037-1	Custodial Closet by Room 29	SS	N/A		12/11/2024				Sign
1038-1	Hall by Room 29 Left	WF	App	<1.0	12/11/2024				-
1038-2	Hall by Room 29 Right	WF	App	<1.0	12/11/2024				-
1039-1	Girl's Bathroom by Room 29 @ A	SK	N/A		12/11/2024				Sign
1039-2	Girl's Bathroom by Room 29 @ B	SK	N/A		12/11/2024				Sign
1039-3	Girl's Bathroom by Room 29 @ C	SK	N/A		12/11/2024				Sign
1039-4	Girl's Bathroom by Room 29 @ D	SK	N/A		12/11/2024				Sign
1040-1	Room 24	SK	N/A		12/11/2024				Sign
1041-1	Room 25	SK	N/A		12/11/2024				Sign
1042-1	Room 26	SK	N/A		12/11/2024				Sign
1044-1	Room 28	SK	N/A		12/11/2024				Sign
1045-1	Room 29	SK	N/A		12/11/2024				Sign
1046-1	Hall by Room 38	BF	App	<1.0	12/11/2024				-
1046-2	Hall by Room 38	WF	App	<1.0	12/11/2024				-
1047-1	Room 34	SK	N/A		12/11/2024				Sign
1048-1	Room 35	SK	N/A		12/11/2024				Sign
1049-1	Room 35	SK	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1050-1	Room 36	SK	N/A		12/11/2024				Sign
1051-1	Room 36 Bathroom	SK	N/A		12/11/2024				Sign
1052-1	Room P2 Bathroom	SK	N/A		12/11/2024				Sign
1053-1	Room P3 Bathroom	SK	N/A		12/11/2024				Sign
1054-1	Room P4 Bathroom	SK	N/A		12/11/2024				Sign
1055-1	Room 37	SK	N/A		12/11/2024				Sign
1056-1	Hall by Room 42	BF	App	<1.0	12/11/2024				-
1056-2	Hall by Room 42	WF	App	<1.0	12/11/2024				-
1057-1	Room 41	SK	N/A		12/11/2024				Sign
1058-1	Room 40	SK	N/A		12/11/2024				Sign
1059-1	Room 39 - Left	SK	N/A		12/11/2024				Sign
1059-2	Room 39 - Right	SK	N/A		1/0/1900				
1059-3	Room 39 - Bathroom	SK	App	10.0	12/11/2024				Sign Posted
1060-1	Room 38 - Left	SK	N/A		12/11/2024				Sign
1060-2	Room 38 - Right	SK	N/A		1/0/1900				
1060-3	Room 38 Bathroom	SK	App	21.0	12/11/2024				Sign Posted
1061-1	Hall by Library	BF	App	<1.0	12/11/2024				-
1061-2	Hall by Library	WF	App	<1.0	12/11/2024				-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1062-1	Library	SK	N/A		12/11/2024				Sign
1063-1	Nurse's Office	SK	N/A		12/11/2024				Sign-Mixed Valve- Fridge has filtered water.
1063-2	Nurse's Office Bathroom	SK	N/A		12/11/2024				Sign-Mixed Valve- Fridge has filtered water.
1063-1	Nurses Office Ice Machine	IM	App	2.0	12/11/2024				-
1064-1	Bathroom by Nurse's Office	SK	N/A		12/11/2024				Sign
1065-1	Main Office Work Room	SK	App	<1.0	12/11/2024				-
1066-1	Custodial Closet by Room 3	SS	N/A		12/11/2024				Sign
1067-1	Room 3	SK	N/A		12/11/2024				Sign
1067-2	Room 3 Unit @ A	SK	N/A		12/11/2024				Sign
1067-3	Room 3 Unit @ B	SK	N/A		12/11/2024				Sign
1067-4	Room 3 Unit @ C	SK	N/A		12/11/2024				Sign
1068-1	Hall by Gym	BF	App	<1.0	12/11/2024				-
1068-2	Hall by Gym	WF	App	<1.0	12/11/2024				-
1069-1	Room 2 Unit 1 @ A	SK	N/A		12/11/2024				Sign
1069-2	Room 2 Unit 1 @ B	SK	N/A		12/11/2024				Sign
1069-3	Room 2 Unit 1 @ C	SK	N/A		12/11/2024				Sign
1069-4	Room 2 Unit 2 @ A	SK	N/A		12/11/2024				Sign
1069-5	Room 2 Unit 2 @ B	SK	N/A		12/11/2024				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1069-6	Room 2 Unit 2 @ C	SK	N/A		12/11/2024				Sign
1069-7	Room 2 Bathroom	SK	App	5.0	12/11/2024				-
1070-1	Room 1	SK	N/A		12/11/2024				Sign
1070-2	Room 1 Bathroom	SK	App	<1.0	12/11/2024				-

Laboratory Report

NYE Report #: 2407408-31872

December 12, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Rye City SD; Osborne Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 11, 2024. New York Environmental analyzed the samples on December 12, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	11 Dec 2024
Date Received:	11 Dec 2024
Date Analyzed:	12 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241211O031	1	Kitchen Prep-SK, Initial	0.001	0.003	mg/L	
241211O032	2	Kitchen Prep-SPY, Initial	0.001	0.002	mg/L	
241211O033	3	Faculty Room-SK, Initial	0.001	0.002	mg/L	
241211O034	4	Faculty Room-SPY, Initial	0.001	0.001	mg/L	
241211O035	5	Childs Bathroom by Faculty Room-SK, Initial	0.001	<0.001	mg/L	
241211O036	6	Hall by Faculty Room-BF, Initial	0.001	<0.001	mg/L	
241211O037	7	Hall by Faculty Room-WF, Initial	0.001	<0.001	mg/L	
241211O038	8	Childs Bathroom by Gym-SK, Initial	0.001	<0.001	mg/L	
241211O039	9	Hall by Media Center-BF, Initial	0.001	<0.001	mg/L	
241211O040	10	Hall by Media Center-WF, Initial	0.001	<0.001	mg/L	
241211O041	11	Room 14H Special Services-SK, Initial	0.001	0.002	mg/L	
241211O042	12	Hall by Computer Room-BF, Initial	0.001	<0.001	mg/L	
241211O043	13	Hall by Computer Room-WF, Initial	0.001	<0.001	mg/L	
241211O044	14	Hall by Room 29 Left-WF, Initial	0.001	<0.001	mg/L	
241211O045	15	Hall by Room 29 Right-WF, Initial	0.001	<0.001	mg/L	
241211O046	16	Hall by Room 38-BF, Initial	0.001	<0.001	mg/L	
241211O047	17	Hall by Room 38-WF, Initial	0.001	<0.001	mg/L	
241211O048	18	Hall by Room 42-BF, Initial	0.001	<0.001	mg/L	
241211O049	19	Hall by Room 42-WF, Initial	0.001	<0.001	mg/L	
241211O050	20	Room 39 Bathroom-SK, Initial	0.001	0.010	mg/L	H
241211O051	21	Room 38 Bathroom-SK, Initial	0.001	0.021	mg/L	H
241211O052	22	Hall by Library-BF, Initial	0.001	<0.001	mg/L	
241211O053	23	Hall by Library-WF, Initial	0.001	<0.001	mg/L	
241211O054	24	Nurse's Office Refrigerator-IM, Initial	0.001	0.002	mg/L	
241211O055	25	Main Office Work Room-SK, Initial	0.001	<0.001	mg/L	
241211O056	26	Hall by Gym-BF, Initial	0.001	<0.001	mg/L	



Date Collected:	11 Dec 2024
Date Received:	11 Dec 2024
Date Analyzed:	12 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
241211O057	27	Hall by Gym-WF, Initial	0.001	<0.001	mg/L	
241211O058	28	Room 2 Bathroom-SK, Initial	0.001	0.005	mg/L	
241211O059	29	Room 1 Bathroom-SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix D
Rye Middle School and High School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Custodial Office Bathroom	SK	N/A		12/11/2024				
1002-1	Bathroom by Boiler Room	SK	N/A		12/11/2024				
1003-1	Custodial Closet by Boiler Room	SS	N/A		12/11/2024				
1004-1	Room 111 Principal's Office Kitchenette	SK	App	3.0	12/11/2024				
1005-1	Hall by Room 111 Principal's Office	WF	App	<1.0	12/11/2024				
1006-1	Assistant Principal's Office Bathroom	SK	App	4.0	12/11/2024				
1007-1	Boys Bathroom by Assistant Principal's Office @ A	SK	N/A		12/11/2024				
1007-2	Boys Bathroom by Assistant Principal's Office @ B	SK	N/A		12/11/2024				
1008-1	Girls Bathroom by Assistant Principal's Office @ A	SK	N/A		12/11/2024				
1008-2	Girls Bathroom by Assistant Principal's Office @ B	SK	N/A		12/11/2024				
1008-3	Girls Bathroom by Assistant Principal's Office @ C	SK	N/A		12/11/2024				
1009-1	Faculty Women's Bathroom by Auditorium #1	SK	N/A		12/11/2024				
1009-2	Faculty Women's Bathroom by Auditorium #2	SK	N/A		12/11/2024				
1010-1	Faculty Men's Bathroom by Auditorium #1	SK	N/A		12/11/2024				
1010-2	Faculty Men's Bathroom by Auditorium #2	SK	N/A		12/11/2024				
1011-1	Hall by Room 102	WF	App	<1.0	12/11/2024				
1011-2	Hall by Room 102	BF	App	<1.0	12/11/2024				
1012-1	Room 118 Nurses Office	SK	App	3.0	12/11/2024				
1012-2	Room 118 Nurses Office Bathroom	SK	N/A		12/11/2024				
1014-1	Media Center/Library Office	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1015-1	Hall by Room 192 Nurses Office	WF	App	<1.0	12/11/2024				
1015-2	Hall by Room 192 Nurses Office Bottle Filler	BF	App	<1.0	12/11/2024				
1016-1	Room 192 Nurses Office	SK	App	3.0	12/11/2024				
1017-1	Women's Bathroom 188 @ A	SK	N/A		12/11/2024				
1017-2	Women's Bathroom 188 @ B	SK	N/A		12/11/2024				
1017-3	Women's Bathroom 188 @ C	SK	N/A		12/11/2024				
1018-1	Auditorium Stage Wood Shop	SS	N/A		12/11/2024				
1019-1	Band Room 185	SK	App	2.0	12/11/2024				
1021-1	Hall by Boys Bathroom by Gym	WF	App	<1.0	12/11/2024				
1021-2	Hall by Boys Bathroom by Gym Bottle Filler	BF	App	<1.0	12/11/2024				
1022-1	Hall by Girls Bathroom by Gym	WF	App	<1.0	12/11/2024				
1022-2	Hall by Girls Bathroom by Gym Bottle Filler	BF	App	<1.0	12/11/2024				
1023-1	Girls Bathroom by Gym @ A	SK	N/A		12/11/2024				
1023-2	Girls Bathroom by Gym @ B	SK	N/A		12/11/2024				
1023-3	Girls Bathroom by Gym @ C	SK	N/A		12/11/2024				
1024-1	Women's Bathroom by Room 412 @ A	SK	N/A		12/11/2024				
1024-2	Women's Bathroom by Room 412 @ B	SK	N/A		12/11/2024				
1025-1	Custodial Closet 418	SS	N/A		12/11/2024				
1026-1	Men's Bathroom by Room 412 @ A	SK	N/A		12/11/2024				
1026-2	Men's Bathroom by Room 412 @ B	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1027-1	Work Room Faculty Bathroom 412	SK	N/A		12/11/2024				
1028-1	Hall by Room 411	WF	App	<1.0	12/11/2024				
1028-2	Hall by Room 411 Bottle Filler	BF	App	<1.0	12/11/2024				
1029-1	Science Room 411 Teacher's Station	SK	N/A		12/11/2024				
1029-2	Science Room 411 @ A	SK	N/A		12/11/2024				
1029-3	Science Room 411 @ B	SK	N/A		12/11/2024				
1029-4	Science Room 411 @ C	SK	N/A		12/11/2024				
1029-5	Science Room 411 @ D	SK	N/A		12/11/2024				
1029-6	Science Room 411 @ E	SK	N/A		12/11/2024				
1029-7	Science Room 411 @ F	SK	N/A		12/11/2024				
1029-8	Science Room 411 @ G	SK	N/A		12/11/2024				
1029-9	Science Room 411 @ H	SK	N/A		12/11/2024				
1029-10	Science Room 411 @ I	SK	N/A		12/11/2024				
1029-11	Science Room 411 @ J	SK	N/A		12/11/2024				
1029-12	Science Room 411 @ K	SK	N/A		12/11/2024				
1029-13	Science Room 411 @ L	SK	N/A		12/11/2024				
1029-14	Science Room 411 Fume Hood	SP	N/A		12/11/2024				
1030-1	Prep Room 409 @ A (by Room 411)	SK	N/A		12/11/2024				
1030-2	Prep Room 409 @ B (by Room 407)	SK	N/A		12/11/2024				
1031-1	Science Room 407 Teacher's Station	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1031-2	Science Room 407 @ A	SK	N/A		12/11/2024				
1031-3	Science Room 407 @ B	SK	N/A		12/11/2024				
1031-5	Science Room 407 @ D	SK	N/A		12/11/2024				
1031-6	Science Room 407 @ E	SK	N/A		12/11/2024				
1031-7	Science Room 407 @ F	SK	N/A		12/11/2024				
1031-8	Science Room 407 @ G	SK	N/A		12/11/2024				
1031-9	Science Room 407 @ H	SK	N/A		12/11/2024				
1031-10	Science Room 407 @ I	SK	N/A		12/11/2024				
1031-11	Science Room 407 @ J	SK	N/A		12/11/2024				
1031-12	Science Room 407 @ K	SK	N/A		12/11/2024				
1031-13	Science Room 407 @ L	SK	N/A		12/11/2024				
1031-14	Science Room 407 Fume Hood	SP	N/A		12/11/2024				
1032-1	Science Room 410 Teacher's Station	SK	N/A		12/11/2024				
1032-2	Science Room 410 @ A	SK	N/A		12/11/2024				
1032-3	Science Room 410 @ B	SK	N/A		12/11/2024				
1032-4	Science Room 410 @ C	SK	N/A		12/11/2024				
1032-5	Science Room 410 @ D	SK	N/A		12/11/2024				
1032-6	Science Room 410 @ E	SK	N/A		12/11/2024				
1032-7	Science Room 410 @ F	SK	N/A		12/11/2024				
1032-8	Science Room 410 @ G	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1032-9	Science Room 410 @ H	SK	N/A		12/11/2024				
1032-10	Science Room 410 @ I	SK	N/A		12/11/2024				
1032-11	Science Room 410 @ J	SK	N/A		12/11/2024				
1032-12	Science Room 410 @ K	SK	N/A		12/11/2024				
1032-13	Science Room 410 @ L	SK	N/A		12/11/2024				
1032-14	Science Room 410 Fume Hood	SP	N/A		12/11/2024				
1033-1	Prep Room 408 @ A (by Room 410)	SK	N/A		12/11/2024				
1033-2	Prep Room 408 @ B (by Room 406)	SK	N/A		12/11/2024				
1034-1	Science Room 406 Teacher's Station	SK	N/A		12/11/2024				
1034-2	Science Room 406 @ A	SK	N/A		12/11/2024				
1034-3	Science Room 406 @ B	SK	N/A		12/11/2024				
1034-4	Science Room 406 @ C	SK	N/A		12/11/2024				
1034-5	Science Room 406 @ D	SK	N/A		12/11/2024				
1034-6	Science Room 406 @ E	SK	N/A		12/11/2024				
1034-7	Science Room 406 @ F	SK	N/A		12/11/2024				
1034-8	Science Room 406 @ G	SK	N/A		12/11/2024				
1034-9	Science Room 406 @ H	SK	N/A		12/11/2024				
1034-10	Science Room 406 @ I	SK	N/A		12/11/2024				
1034-11	Science Room 406 @ J	SK	N/A		12/11/2024				
1034-12	Science Room 406 @ K	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1034-13	Science Room 406 @ L	SK	N/A		12/11/2024				
1035-1	Hall by Room 406	WF	App	<1.0	12/11/2024				
1035-2	Hall by Room 406 Bottle Filler	BF	App	<1.0	12/11/2024				
1036-1	Science Room 405 Teacher's Station	SK	N/A		12/11/2024				
1036-2	Science Room 405 @ A	SK	N/A		12/11/2024				
1036-3	Science Room 405 @ B	SK	N/A		12/11/2024				
1036-4	Science Room 405 @ C	SK	N/A		12/11/2024				
1036-5	Science Room 405 @ D	SK	N/A		12/11/2024				
1036-6	Science Room 405 @ E	SK	N/A		12/11/2024				
1036-7	Science Room 405 @ F	SK	N/A		12/11/2024				
1036-8	Science Room 405 @ G	SK	N/A		12/11/2024				
1036-9	Science Room 405 @ H	SK	N/A		12/11/2024				
1036-10	Science Room 405 @ I	SK	N/A		12/11/2024				
1036-11	Science Room 405 @ J	SK	N/A		12/11/2024				
1036-12	Science Room 405 @ K	SK	N/A		12/11/2024				
1036-13	Science Room 405 @ L	SK	N/A		12/11/2024				
1036-14	Science Room 405 Fume Hood	SP	N/A		12/11/2024				
1037-1	Prep Room 403 @ A (by Room 405)	SK	N/A		12/11/2024				
1037-2	Prep Room 403 @ B (by Room 401)	SK	N/A		12/11/2024				
1038-1	Science Room 401 Teacher's Station	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1038-2	Science Room 401 @ A	SK	N/A		12/11/2024				
1038-3	Science Room 401 @ B	SK	N/A		12/11/2024				
1038-4	Science Room 401 @ C	SK	N/A		12/11/2024				
1038-6	Science Room 401 @ E	SK	N/A		12/11/2024				
1038-7	Science Room 401 @ F	SK	N/A		12/11/2024				
1038-8	Science Room 401 @ G	SK	N/A		12/11/2024				
1038-9	Science Room 401 @ H	SK	N/A		12/11/2024				
1038-10	Science Room 401 @ I	SK	N/A		12/11/2024				
1038-11	Science Room 401 @ J	SK	N/A		12/11/2024				
1038-12	Science Room 401 @ K	SK	N/A		12/11/2024				
1038-13	Science Room 401 @ L	SK	N/A		12/11/2024				
1038-14	Science Room 401 Fume Hood	SP	N/A		12/11/2024				
1039-1	Gym Vestibule by Boys Locker Room @ A	BF	App	<1.0	12/11/2024				
1039-2	Gym Vestibule by Boys Locker Room @ B	BF	App	<1.0	12/11/2024				
1040-1	Auxiliary Gym Men's Bathroom	SK	N/A		12/11/2024				
1041-1	Auxiliary Gym Women's Bathroom	SK	N/A		12/11/2024				
1042-1	Auxiliary Gym Office	IM	App	<1.0	12/11/2024				
1043-1	Boys Locker Room Storage Closet Bathroom	SK	N/A		12/11/2024				
1043-2	Boys Locker Room Custodial Closet	SS	N/A		12/11/2024				
1043-3	Boys Locker Room Bathroom @ A	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1043-4	Boys Locker Room Bathroom @ B	SK	N/A		12/11/2024				
1043-5	Boys Locker Room Bathroom @ C	SK	N/A		12/11/2024				
1043-6	Boys Locker Room (Right)	WF	App	<1.0	12/11/2024				
1043-7	Boys Locker Room (Right) Bottle Filler	BF	App	<1.0	12/11/2024				
1043-8	Boys Locker Room (Left)	WF	App	<1.0	12/11/2024				
1043-9	Boys Locker Room PE Office 173A Bathroom	SK	N/A		12/11/2024				
1044-1	Hall by Room 178	WF	App	<1.0	12/11/2024				
1044-2	Hall by Room 178 Bottle Filler	BF	App	<1.0	12/11/2024				
1045-1	Tutoring Center Room 178 Women's Bathroom	SK	N/A		12/11/2024				
1046-1	Tutoring Center Room 178 Men's Bathroom	SK	N/A		12/11/2024				
1047-1	Art Room 171 @ A	SK	N/A		12/11/2024				
1047-2	Art Room 171 @ B	SK	N/A		12/11/2024				
1047-3	Art Room 171 @ C	SK	N/A		12/11/2024				
1047-4	Art Room 171 @ D	SK	N/A		12/11/2024				
1048-1	Art Room 169 @ A	SK	N/A		12/11/2024				
1048-2	Art Room 169 @ B	SK	N/A		12/11/2024				
1048-3	Art Room 169 @ C	SK	N/A		12/11/2024				
1048-4	Art Room 169 @ D	SK	N/A		12/11/2024				
1049-1	Room 167A @ A	SK	N/A		12/11/2024				
1049-2	Room 167A @ B	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1050-1	Room 167 Dark Room #1	SK	N/A		12/11/2024				
1050-2	Room 167 Dark Room #2 Trough @ A	SP	N/A		12/11/2024				
1050-3	Room 167 Dark Room #2 Trough @ B	SP	N/A		12/11/2024				
1051-1	Room 165 @ A	SK	N/A		12/11/2024				
1051-2	Room 165 @ B	SK	N/A		12/11/2024				
1051-3	Room 165 @ C	SK	N/A		12/11/2024				
1051-4	Room 165 @ D	SK	N/A		12/11/2024				
1052-1	Room 163 @ A	SK	N/A		12/11/2024				
1052-2	Room 163 @ B	SK	N/A		12/11/2024				
1052-3	Room 163 @ C	SK	N/A		12/11/2024				
1053-1	Science Room 142 Teacher's Station	SK	N/A		12/11/2024				
1053-2	Science Room 142 @ A	SK	N/A		12/11/2024				
1053-3	Science Room 142 @ B	SK	N/A		12/11/2024				
1053-4	Science Room 142 @ C	SK	N/A		12/11/2024				
1053-5	Science Room 142 @ D	SK	N/A		12/11/2024				
1053-6	Science Room 142 @ E	SK	N/A		12/11/2024				
1053-7	Science Room 142 @ F	SK	N/A		12/11/2024				
1053-8	Science Room 142 @ G	SK	N/A		12/11/2024				
1053-9	Science Room 142 @ H	SK	N/A		12/11/2024				
1053-10	Science Room 142 @ I	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1053-11	Science Room 142 @ J	SK	N/A		12/11/2024				
1053-12	Science Room 142 @ K	SK	N/A		12/11/2024				
1053-13	Science Room 142 @ L	SK	N/A		12/11/2024				
1054-1	Art Room 162 @ A	SK	N/A		12/11/2024				
1054-2	Art Room 162 @ B	SK	N/A		12/11/2024				
1055-1	Technology Room 161	SK	N/A		12/11/2024				
1056-1	Women's Bathroom by Room 143	SK	N/A		12/11/2024				
1057-1	Hall by Room 143	WF	App	<1.0	12/11/2024				
1057-2	Hall by Room 143 Bottle Filler	BF	App	<1.0	12/11/2024				
1058-1	Men's Bathroom by Room 143	SK	N/A		12/11/2024				
1059-1	Room 145 Middle School Teacher's Lounge	SK	App	2.0	12/11/2024				
1060-1	Girls Bathroom by Room 136 @ A	SK	N/A		12/11/2024				
1060-2	Girls Bathroom by Room 136 @ B	SK	N/A		12/11/2024				
1060-3	Girls Bathroom by Room 136 @ C	SK	N/A		12/11/2024				
1060-4	Girls Bathroom by Room 136 @ D	SK	N/A		12/11/2024				
1061-1	Hall by Middle School Gym	WF	App	<1.0	12/11/2024				
1061-2	Hall by Middle School Gym Bottle Filler	BF	App	<1.0	12/11/2024				
1062-1	Middle School Café Custodial Closet	SS	N/A		12/11/2024				
1062-2	Middle School Café	SK	N/A		12/11/2024				
1062-3	Middle School Café	WF	App	<1.0	12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1062-4	Middle School Café Bottle Filler	BF	App	<1.0	12/11/2024				
1063-1	Middle School Kitchen 1 Bay	SK	App	1.0	12/11/2024				
1063-3	Middle School Kitchen Handwash	SK	N/A		12/11/2024				
1063-4	Middle School Kitchen Bathroom	SK	N/A		12/11/2024				
1064-1	Girls Bathroom by Middle School Café	SK	N/A		12/11/2024				
1065-1	Boys Bathroom by Middle School Café	SK	N/A		12/11/2024				
1066-1	Custodial Closet by Middle School Gym	SS	N/A		12/11/2024				
1067-1	Middle School Room 130 Nurses Office	SK	App	4.0	12/11/2024				
1067-2	Middle School Room 130 Nurses Office Bathroom	SK	N/A		12/11/2024				
1068-1	Middle School Boys Locker Room Coaches Bathroom	SK	App	<1.0	12/11/2024				
1068-2	Middle School Boys Locker Room Bathroom @ A	SK	N/A		12/11/2024				
1068-3	Middle School Boys Locker Room Bathroom @ B	SK	N/A		12/11/2024				
1068-4	Middle School Boys Locker Room	WF	App	<1.0	12/11/2024				
1068-5	Middle School Boys Locker Room Bottle Filler	BF	App	<1.0	12/11/2024				
1069-1	Hall by Room 125A	WF	App		12/11/2024				
1069-2	Hall by Room 125A Bathroom	BF	App		12/11/2024				
1070-1	Hall by Room 150	WF	App	<1.0	12/11/2024				
1070-2	Hall by Room 152	BF	App	<1.0	12/11/2024				
1071-1	Custodial Closet by Room 152	SS	N/A		12/11/2024				
2001-1	High School Kitchen Handwash @ A	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2001-2	High School Kitchen Ice Machine	IM	App	<1.0	12/11/2024				
2001-3	High School Kitchen Handwash @ B	SK	N/A		12/11/2024				
2001-4	High School Kitchen Island by Stove	SK	App	3.0	12/11/2024				
2001-7	High School Kitchen Custodian Bucket Filler	SS	N/A		12/11/2024				
2001-9	High School Kitchen 3 Bay @ A	SK	N/A		12/11/2024				
2001-9	High School Kitchen 3 Bay @ A	SPY	N/A		12/11/2024				
2001-10	High School Kitchen 3 Bay @ B	SK	N/A		12/11/2024				
2001-11	High School Kitchen Island by Windows	SK	App	1.0	12/11/2024				
2002-1	Hall by Room 204	WF	App	<1.0	12/11/2024				
2002-2	Hall by Room 204 Bottle Filler	BF	App	<1.0	12/11/2024				
2003-1	Room 204 Faculty Room	SK	App	5.0	12/11/2024				
2004-1	Custodial Closet by Room 202	SS	N/A		12/11/2024				
2005-1	Men's Bathroom 251 @ A	SK	N/A		12/11/2024				
2005-2	Men's Bathroom 251 @ B	SK	N/A		12/11/2024				
2005-3	Men's Bathroom 251 @ C	SK	N/A		12/11/2024				
2006-1	Unisex ADA Bathroom by Room 200	SK	N/A		12/11/2024				
2007-1	Room 200 @ A	SK	N/A		12/11/2024				
2007-2	Room 200 @ B	SK	N/A		12/11/2024				
2007-3	Room 200 @ C	SK	N/A		12/11/2024				
2008-1	Room 250	SK	App	3.0	12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2009-1	Boys Bathroom by Room 246 @ A	SK	N/A		12/11/2024				
2009-2	Boys Bathroom by Room 246 @ B	SK	N/A		12/11/2024				
2010-1	Girls Bathroom by Room 246 @ A	SK	N/A		12/11/2024				
2010-2	Girls Bathroom by Room 246 @ B	SK	N/A		12/11/2024				
2010-3	Girls Bathroom by Room 246 @ C	SK	N/A		12/11/2024				
2011-1	Unisex ADA Bathroom by Room 246	SK	N/A		12/11/2024				
2012-1	Hall by Room 246	WF	App	<1.0	12/11/2024				
2012-2	Hall by Room 246 Bottle Filler	BF	App	<1.0	12/11/2024				
2013-1	Custodial Closet by Room 246A	SS	N/A		12/11/2024				
2014-1	Women's Bathroom by Room 461 @ A	SK	N/A		12/11/2024				
2014-2	Women's Bathroom by Room 461 @ B	SK	N/A		12/11/2024				
2015-1	Custodial Closet 468	SS	N/A		12/11/2024				
2016-1	Men's Bathroom by Room 461 @ A	SK	N/A		12/11/2024				
2016-2	Men's Bathroom by Room 461 @ B	SK	N/A		12/11/2024				
2017-1	Hall by Room 461	WF	App	<1.0	12/11/2024				
2017-2	Hall by Room 461 Bottle Filler	BF	App	<1.0	12/11/2024				
2018-1	Science Room 461 Teacher's Station	SK	N/A		12/11/2024				
2018-2	Science Room 461 @ A	SK	N/A		12/11/2024				
2018-3	Science Room 461 @ B	SK	N/A		12/11/2024				
2018-4	Science Room 461 @ C	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2018-5	Science Room 461 @ D	SK	N/A		12/11/2024				
2018-6	Science Room 461 @ E	SK	N/A		12/11/2024				
2018-7	Science Room 461 @ F	SK	N/A		12/11/2024				
2018-8	Science Room 461 @ G	SK	N/A		12/11/2024				
2018-9	Science Room 461 @ H	SK	N/A		12/11/2024				
2018-10	Science Room 461 @ I	SK	N/A		12/11/2024				
2018-11	Science Room 461 @ J	SK	N/A		12/11/2024				
2018-12	Science Room 461 @ K	SK	N/A		12/11/2024				
2018-13	Science Room 461 @ L	SK	N/A		12/11/2024				
2018-14	Science Room 461 Fume Hood	SP	N/A		12/11/2024				
2019-1	Prep Room 459 @ A (by Room 461)	SK	N/A		12/11/2024				
2019-2	Prep Room 459 @ B (by Room 457)	SK	N/A		12/11/2024				
2020-1	Science Room 457 Teacher's Station	SK	N/A		12/11/2024				
2020-2	Science Room 457 @ A	SK	N/A		12/11/2024				
2020-3	Science Room 457 @ B	SK	N/A		12/11/2024				
2020-4	Science Room 457 @ C	SK	N/A		12/11/2024				
2020-5	Science Room 457 @ D	SK	N/A		12/11/2024				
2020-6	Science Room 457 @ E	SK	N/A		12/11/2024				
2020-7	Science Room 457 @ F	SK	N/A		12/11/2024				
2020-8	Science Room 457 @ G	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2020-9	Science Room 457 @ H	SK	N/A		12/11/2024				
2020-10	Science Room 457 @ I	SK	N/A		12/11/2024				
2020-11	Science Room 457 @ J	SK	N/A		12/11/2024				
2020-12	Science Room 457 @ K	SK	N/A		12/11/2024				
2020-13	Science Room 457 @ L	SK	N/A		12/11/2024				
2020-14	Science Room 457 Fume Hood	SP	N/A		12/11/2024				
2021-1	Science Room 460 Teacher's Station	SK	N/A		12/11/2024				
2021-2	Science Room 460 @ A	SK	N/A		12/11/2024				
2021-3	Science Room 460 @ B	SK	N/A		12/11/2024				
2021-4	Science Room 460 @ C	SK	N/A		12/11/2024				
2021-5	Science Room 460 @ D	SK	N/A		12/11/2024				
2021-6	Science Room 460 @ E	SK	N/A		12/11/2024				
2021-7	Science Room 460 @ F	SK	N/A		12/11/2024				
2021-8	Science Room 460 @ G	SK	N/A		12/11/2024				
2021-9	Science Room 460 @ H	SK	N/A		12/11/2024				
2021-10	Science Room 460 @ I	SK	N/A		12/11/2024				
2021-11	Science Room 460 @ J	SK	N/A		12/11/2024				
2021-12	Science Room 460 @ K	SK	N/A		12/11/2024				
2021-13	Science Room 460 @ L	SK	N/A		12/11/2024				
2021-14	Science Room 460 Fume Hood	SP	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2022-1	Prep Room 458 @ A (by Room 460)	SK	N/A		12/11/2024				
2022-2	Prep Room 458 @ B (by Room 456)	SK	N/A		12/11/2024				
2023-1	Science Room 456 Teacher's Station	SK	N/A		12/11/2024				
2023-2	Science Room 456 @ A	SK	N/A		12/11/2024				
2023-3	Science Room 456 @ B	SK	N/A		12/11/2024				
2023-4	Science Room 456 @ C	SK	N/A		12/11/2024				
2023-5	Science Room 456 @ D	SK	N/A		12/11/2024				
2023-6	Science Room 456 @ E	SK	N/A		12/11/2024				
2023-7	Science Room 456 @ F	SK	N/A		12/11/2024				
2023-8	Science Room 456 @ G	SK	N/A		12/11/2024				
2023-9	Science Room 456 @ H	SK	N/A		12/11/2024				
2023-10	Science Room 456 @ I	SK	N/A		12/11/2024				
2023-11	Science Room 456 @ J	SK	N/A		12/11/2024				
2023-12	Science Room 456 @ K	SK	N/A		12/11/2024				
2023-13	Science Room 456 @ L	SK	N/A		12/11/2024				
2023-14	Science Room 456 Fume Hood	SP	N/A		12/11/2024				
2024-1	Science Room 455 Teacher's Station	SK	N/A		12/11/2024				
2024-2	Science Room 455 @ A	SK	N/A		12/11/2024				
2024-3	Science Room 455 @ B	SK	N/A		12/11/2024				
2024-4	Science Room 455 @ C	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2024-5	Science Room 455 @ D	SK	N/A		12/11/2024				
2024-6	Science Room 455 @ E	SK	N/A		12/11/2024				
2024-7	Science Room 455 @ F	SK	N/A		12/11/2024				
2024-8	Science Room 455 @ G	SK	N/A		12/11/2024				
2024-9	Science Room 455 @ H	SK	N/A		12/11/2024				
2024-10	Science Room 455 @ I	SK	N/A		12/11/2024				
2024-11	Science Room 455 @ J	SK	N/A		12/11/2024				
2024-12	Science Room 455 @ K	SK	N/A		12/11/2024				
2024-13	Science Room 455 @ L	SK	N/A		12/11/2024				
2024-14	Science Room 455 Fume Hood	SP	N/A		12/11/2024				
2025-1	Prep Room 453 @ A (by Room 455)	SK	N/A		12/11/2024				
2025-2	Prep Room 453 @ B (by Room 451)	SK	N/A		12/11/2024				
2026-1	Science Room 451 Teacher's Station	SK	N/A		12/11/2024				
2026-2	Science Room 451 @ A	SK	N/A		12/11/2024				
2026-3	Science Room 451 @ B	SK	N/A		12/11/2024				
2026-4	Science Room 451 @ C	SK	N/A		12/11/2024				
2026-5	Science Room 451 @ D	SK	N/A		12/11/2024				
2026-6	Science Room 451 @ E	SK	N/A		12/11/2024				
2026-7	Science Room 451 @ F	SK	N/A		12/11/2024				
2026-8	Science Room 451 @ G	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2026-9	Science Room 451 @ H	SK	N/A		12/11/2024				
2026-10	Science Room 451 @ I	SK	N/A		12/11/2024				
2026-11	Science Room 451 @ J	SK	N/A		12/11/2024				
2026-12	Science Room 451 @ K	SK	N/A		12/11/2024				
2026-13	Science Room 451 @ L	SK	N/A		12/11/2024				
2026-14	Science Room 451 Fume Hood	SP	N/A		12/11/2024				
2027-1	Hall by Room 456	WF	App	<1.0	12/11/2024				
2027-2	Hall by Room 456 Bottle Filler	BF	App	<1.0	12/11/2024				
2028-1	High School Girls Locker Room Coaches Office Bathroom	SK	N/A		12/11/2024				
2028-2	High School Girls Locker Room Bathroom @ A	SK	N/A		12/11/2024				
2028-3	High School Girls Locker Room Bathroom @ B	SK	N/A		12/11/2024				
2028-4	High School Girls Locker Room Bathroom @ C	SK	N/A		12/11/2024				
2028-5	High School Girls Locker Room (Left)	WF	App	<1.0	12/11/2024				
2028-6	High School Girls Locker Room (Right)	WF	App	<1.0	12/11/2024				
2028-7	High School Girls Locker Room (Right) Bottle Filler	BF	App	<1.0	12/11/2024				
2029-1	Hall by Room 233	WF	App	<1.0	12/11/2024				
2029-2	Hall by Room 233 Bottle Filler	BF	App	<1.0	12/11/2024				
2030-1	Custodial Closet by Room 233	SS	N/A		12/11/2024				
2031-1	Science Room 231 Teacher's Station	SK	N/A		12/11/2024				
2031-2	Science Room 231 @ A	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2031-3	Science Room 231 @ B	SK	N/A		12/11/2024				
2031-4	Science Room 231 @ C	SK	N/A		12/11/2024				
2031-5	Science Room 231 @ D	SK	N/A		12/11/2024				
2031-6	Science Room 231 @ E	SK	N/A		12/11/2024				
2031-7	Science Room 231 @ F	SK	N/A		12/11/2024				
2031-8	Science Room 231 @ G	SK	N/A		12/11/2024				
2031-9	Science Room 231 @ H	SK	N/A		12/11/2024				
2031-10	Science Room 231 @ I	SK	N/A		12/11/2024				
2031-11	Science Room 231 @ J	SK	N/A		12/11/2024				
2031-12	Science Room 231 @ K	SK	N/A		12/11/2024				
2031-13	Science Room 231 @ L	SK	N/A		12/11/2024				
2031-14	Science Room 231 Fume Hood	SP	N/A		12/11/2024				
2032-1	Prep Room by Room 231	SK	N/A		12/11/2024				
2032-2	Prep Room by Room 231 Fume Hood	SP	N/A		12/11/2024				
2033-1	Science Room 229 Teacher's Station	SK	N/A		12/11/2024				
2033-2	Science Room 229 @ A	SK	N/A		12/11/2024				
2033-3	Science Room 229 @ B	SK	N/A		12/11/2024				
2033-4	Science Room 229 @ C	SK	N/A		12/11/2024				
2033-5	Science Room 229 @ D	SK	N/A		12/11/2024				
2033-6	Science Room 229 @ E	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2033-7	Science Room 229 @ F	SK	N/A		12/11/2024				
2033-8	Science Room 229 @ G	SK	N/A		12/11/2024				
2033-9	Science Room 229 @ H	SK	N/A		12/11/2024				
2033-10	Science Room 229 @ I	SK	N/A		12/11/2024				
2033-11	Science Room 229 @ J	SK	N/A		12/11/2024				
2033-12	Science Room 229 @ K	SK	N/A		12/11/2024				
2033-13	Science Room 229 @ L	SK	N/A		12/11/2024				
2034-1	Hall by Room 227	WF	App	<1.0	12/11/2024				
2034-2	Hall by Room 227 Bottle Filler	BF	App	<1.0	12/11/2024				
2035-1	Men's Faculty Bathroom by Room 218	SK	N/A		12/11/2024				
2036-1	Custodial Closet by Room 218	SS	N/A		12/11/2024				
2037-1	Science Room 218 Teacher's Station @ A	SK	N/A		12/11/2024				
2037-2	Science Room 218 Teacher's Station @ B	SK	N/A		12/11/2024				
2037-3	Science Room 218 POD 1 @ A	SK	N/A		12/11/2024				
2037-4	Science Room 218 POD 1 @ B	SK	N/A		12/11/2024				
2037-5	Science Room 218 POD 2 @ A	SK	N/A		12/11/2024				
2037-6	Science Room 218 POD 2 @ B	SK	N/A		12/11/2024				
2037-7	Science Room 218 POD 3 @ A	SK	N/A		12/11/2024				
2037-8	Science Room 218 POD 3 @ B	SK	N/A		12/11/2024				
2037-9	Science Room 218 POD 4 @ A	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2037-10	Science Room 218 POD 4 @ B	SK	N/A		12/11/2024				
2037-11	Science Room 218 POD 5 @ A	SK	N/A		12/11/2024				
2037-12	Science Room 218 POD 5 @ B	SK	N/A		12/11/2024				
2037-13	Science Room 218 POD 6 @ A	SK	N/A		12/11/2024				
2037-14	Science Room 218 POD 6 @ B	SK	N/A		12/11/2024				
2038-1	Science Room 220 Teacher's Station @ A	SK	N/A		12/11/2024				
2038-2	Science Room 220 Teacher's Station @ B	SK	N/A		12/11/2024				
2038-3	Science Room 220 POD 1 @ A	SK	N/A		12/11/2024				
2038-4	Science Room 220 POD 1 @ B	SK	N/A		12/11/2024				
2038-5	Science Room 220 POD 2 @ A	SK	N/A		12/11/2024				
2038-6	Science Room 220 POD 2 @ B	SK	N/A		12/11/2024				
2038-7	Science Room 220 POD 3 @ A	SK	N/A		12/11/2024				
2038-8	Science Room 220 POD 3 @ B	SK	N/A		12/11/2024				
2038-9	Science Room 220 POD 4 @ A	SK	N/A		12/11/2024				
2038-10	Science Room 220 POD 4 @ B	SK	N/A		12/11/2024				
2038-11	Science Room 220 POD 5 @ A	SK	N/A		12/11/2024				
2038-12	Science Room 220 POD 5 @ B	SK	N/A		12/11/2024				
2038-13	Science Room 220 POD 6 @ A	SK	N/A		12/11/2024				
2038-14	Science Room 220 POD 6 @ B	SK	N/A		12/11/2024				
2039-1	Science Room 222 Teacher's Station @ A	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2039-2	Science Room 222 Teacher's Station @ B	SK	N/A		12/11/2024				
2039-3	Science Room 222 Counter 1 @ A	SK	N/A		12/11/2024				
2039-4	Science Room 222 Counter 1 @ B	SK	N/A		12/11/2024				
2039-5	Science Room 222 Counter 2 @ A	SK	N/A		12/11/2024				
2039-6	Science Room 222 Counter 2 @ B	SK	N/A		12/11/2024				
2040-1	Room 230 Counter 1 @ A	SK	N/A		12/11/2024				
2040-2	Room 230 Counter 1 @ B	SK	N/A		12/11/2024				
2040-3	Room 230 Counter 2 @ A	SK	N/A		12/11/2024				
2040-4	Room 230 Counter 2 @ B	SK	N/A		12/11/2024				
2041-1	Women's Faculty Bathroom by Room 221	SK	N/A		12/11/2024				
2042-1	Boys Bathroom by Room 221 @ A	SK	N/A		12/11/2024				
2042-2	Boys Bathroom by Room 221 @ B	SK	N/A		12/11/2024				
2042-3	Boys Bathroom by Room 221 @ C	SK	N/A		12/11/2024				
2042-4	Boys Bathroom by Room 221 @ D	SK	N/A		12/11/2024				
2043-1	Science Room 214 Teacher's Station	SK	N/A		12/11/2024				
2043-2	Science Room 214 POD 1 @ A	SK	N/A		12/11/2024				
2043-3	Science Room 214 POD 1 @ B	SK	N/A		12/11/2024				
2043-4	Science Room 214 POD 2 @ A	SK	N/A		12/11/2024				
2043-5	Science Room 214 POD 2 @ B	SK	N/A		12/11/2024				
2043-6	Science Room 214 POD 3 @ A	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2043-7	Science Room 214 POD 3 @ B	SK	N/A		12/11/2024				
2043-8	Science Room 214 POD 4 @ A	SK	N/A		12/11/2024				
2043-9	Science Room 214 POD 4 @ B	SK	N/A		12/11/2024				
2043-10	Science Room 214 POD 5 @ A	SK	N/A		12/11/2024				
2043-11	Science Room 214 POD 5 @ B	SK	N/A		12/11/2024				
2043-12	Science Room 214 POD 6 @ A	SK	N/A		12/11/2024				
2043-13	Science Room 214 POD 6 @ B	SK	N/A		12/11/2024				
2044-1	Hall by Room 214	WF	App	<1.0	12/11/2024				
2045-1	Room 216 Counter 1	SK	N/A		12/11/2024				
2045-2	Room 216 Counter 2	SK	N/A		12/11/2024				
2046-1	Custodial Closet by Room 217	SS	N/A		12/11/2024				
2047-1	Custodial Closet 217	SS	N/A		12/11/2024				
2048-1	Women's Bathroom by Custodial Closet 217 @ A	SK	N/A		12/11/2024				
2048-2	Women's Bathroom by Custodial Closet 217 @ B	SK	N/A		12/11/2024				
2048-3	Women's Bathroom by Custodial Closet 217 @ C	SK	N/A		12/11/2024				
2048-4	Women's Bathroom by Custodial Closet 217 @ D	SK	N/A		12/11/2024				
2049-1	Unisex ADA Bathroom by Room 212	SK	N/A		12/11/2024				
2050-1	Room 212	SK	N/A		12/11/2024				
2051-1	Room 208 @ A	SK	N/A		12/11/2024				
2051-2	Room 208 @ B	SK	N/A		12/11/2024				

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2051-3	Room 208 @ C	SK	N/A		12/11/2024				
3001-1	Kitchen Staff Bathroom	SK	N/A		12/11/2024				
0001-1	Boiler Room	SS	N/A		12/11/2024				
0002-1	Weight Room	WF	App	2.0	12/11/2024				
0003-1	Custodial Closet by Weight Room	SS	N/A		12/11/2024				
0004-1	Middle School Girl's Locker Room PE office Bathroom	SK	App	1.0	12/11/2024				
0004-2	Middle School Basement Boys Locker Room Bathroom @ A	SK	App	<1.0	12/11/2024				
0004-3	Middle School Basement Boys Locker Room Bathroom @ B	SK	N/A		12/11/2024				
0004-4	Middle School Basement Boys Locker Room	WF	App	<1.0	12/11/2024				
0004-5	Middle School Basement Boys Locker Room Bottle Filler	BF	App	<1.0	12/11/2024				
	Field House-Ice Machine	IM	App	<1.0	12/20/2024				

Laboratory Report

NYE Report #: 2407410-31874

December 13, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Rye City SD; Rye High School And Middle School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 11, 2024. New York Environmental analyzed the samples on December 12, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	11 Dec 2024
Date Received:	11 Dec 2024
Date Analyzed:	12 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241211O081	1	High School Kitchen Ice Machine-IM, Initial	0.001	<0.001	mg/L	
241211O082	2	High School Kitchen Island by Stove-SK, Initial	0.001	0.003	mg/L	
241211O083	3	High School Kitchen Island by Windows-SK, Initial	0.001	0.001	mg/L	
241211O084	4	Room 111 Principal's Office Kitchenette-SK, Initial	0.001	0.003	mg/L	
241211O085	5	Room 111 Principal's Office Bathroom-SK, Initial	0.001	0.026	mg/L	H
241211O086	6	Hall by Room 111 Principal's Office-WF, Initial	0.001	<0.001	mg/L	
241211O087	7	Assistant Principal's Office Bathroom-SK, Initial	0.001	0.004	mg/L	
241211O088	8	Hall by Room 102-WF, Initial	0.001	<0.001	mg/L	
241211O089	9	Hall by Room 102-BF, Initial	0.001	<0.001	mg/L	
241211O090	10	Room 118 Nurses Office-SK, Initial	0.001	0.003	mg/L	
241211O091	11	Room 120 English Office Kitchenette-SK, Initial	0.001	0.006	mg/L	H
241211O092	12	Room 192 Nurses Office -SK, Initial	0.001	<0.001	mg/L	
241211O093	13	Hall by Room 192 Nurses Office-WF, Initial	0.001	0.003	mg/L	
241211O094	14	Band Room 185-SK, Initial	0.001	0.002	mg/L	
241211O095	15	Hall by Boys Bathroom by Gym-WF, Initial	0.001	<0.001	mg/L	
241211O096	16	Hall by Boys Bathroom by Gym Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O097	17	Hall by Girls Bathroom by Gym -WF, Initial	0.001	<0.001	mg/L	
241211O098	18	Hall by Girls Bathroom by Gym Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O099	19	Hall by Room 411-WF, Initial	0.001	<0.001	mg/L	
241211O100	20	Hall by Room 411 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O101	21	Hall by Room 406-WF, Initial	0.001	<0.001	mg/L	
241211O102	22	Hall by Room 406 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O103	23	Hall by Room 461-WF, Initial	0.001	<0.001	mg/L	
241211O104	24	Hall by Room 461 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O105	25	Hall by Room 456 -WF, Initial	0.001	<0.001	mg/L	
241211O106	26	Hall by Room 456 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	



Date Collected:	11 Dec 2024
Date Received:	11 Dec 2024
Date Analyzed:	12 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
241211O107	27	Gym Vestibule by Boys Locker Room @ A-BF, Initial	0.001	<0.001	mg/L	
241211O108	28	Gym Vestibule by Boys Locker Room @ B-BF, Initial	0.001	<0.001	mg/L	
241211O109	29	Auxiliary Gym Office-IM, Initial	0.001	<0.001	mg/L	
241211O110	30	Boys Locker Room (Left)-WF, Initial	0.001	<0.001	mg/L	
241211O111	31	Boys Locker Room (Right)-WF, Initial	0.001	<0.001	mg/L	
241211O112	32	Boys Locker Room (Right) Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O113	33	Hall by Room 178-WF, Initial	0.001	<0.001	mg/L	
241211O114	34	Hall by Room 178 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O115	35	Hall by Room 150-WF, Initial	0.001	<0.001	mg/L	
241211O116	36	Hall by Room 150-BF, Initial	0.001	<0.001	mg/L	
241211O117	37	Room 150A I Lab-WF, Initial	0.001	<0.001	mg/L	
241211O118	38	Room 150A I lab-BF, Initial	0.001	<0.001	mg/L	
241211O119	39	Hall by Room 143-WF, Initial	0.001	<0.001	mg/L	
241211O120	40	Hall by Room 143 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O121	41	Room 145 Middle School Teacher's Lounge-SK, Initial	0.001	0.002	mg/L	
241211O122	42	Hall by Middle School Gym-WF, Initial	0.001	<0.001	mg/L	
241211O123	43	Hall by Middle School Gym Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O124	44	Middle School Room 130 Nurses Office-SK, Initial	0.001	0.004	mg/L	
241211O125	45	Middle School Boys Locker Room Coaches Bathroom-SK, Initial	0.001	<0.001	mg/L	
241211O126	46	Middle School Boys Locker Room-WF, Initial	0.001	<0.001	mg/L	
241211O127	47	Middle School Boys Locker Room Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O128	48	Middle School Girl's Locker Room PE office Bathroom-SK, Initial	0.001	0.001	mg/L	
241211O129	49	Middle School Basement Boys Locker Room-WF, Initial	0.001	<0.001	mg/L	
241211O130	50	Middle School Basement Boys Locker Room Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O131	51	Middle School Café-WF, Initial	0.001	<0.001	mg/L	
241211O132	52	Middle School Café Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O133	53	Middle School Kitchen 1 Bay-SK, Initial	0.001	0.001	mg/L	



Date Collected:	11 Dec 2024
Date Received:	11 Dec 2024
Date Analyzed:	12 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
241211O134	54	Hall by Room 204-WF, Initial	0.001	<0.001	mg/L	
241211O135	55	Hall by Room 204 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O136	56	Room 204 Faculty Room-SK, Initial	0.001	0.005	mg/L	
241211O137	57	Room 250 Faculty Lounge-SK, Initial	0.001	0.003	mg/L	
241211O138	58	Hall by Room 246 -WF, Initial	0.001	<0.001	mg/L	
241211O139	59	Hall by Room 246 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O140	60	High School Girls Locker Room (Left)-WF, Initial	0.001	<0.001	mg/L	
241211O141	61	High School Girls Locker Room (Right)-WF, Initial	0.001	<0.001	mg/L	
241211O142	62	High School Girls Locker Room (Right) Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O143	63	Hall by Room 233-WF, Initial	0.001	<0.001	mg/L	
241211O144	64	Hall by Room 233 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O145	65	Hall by Room 227-WF, Initial	0.001	<0.001	mg/L	
241211O146	66	Hall by Room 227 Bottle Filler-BF, Initial	0.001	<0.001	mg/L	
241211O147	67	Hall by Room 214-WF, Initial	0.001	<0.001	mg/L	
241211O148	68	Weight Room -WF, Initial	0.001	0.002	mg/L	
241211O149	69	Hall by Room 192 Nurses Office Bottle Filler-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

NYE Report #: 2407510-31937

December 23, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Rye City School District; High School Field House

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on December 20, 2024. New York Environmental analyzed the samples on December 23, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 Dec 2024
Date Received:	20 Dec 2024
Date Analyzed:	23 Dec 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
241220J001	1	Field House-Ice Machine-IM, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation