School District of University City
Lead in Drinking Water
Table for Tracking Elevated Sources
9/23/24

School	Sample Location	Initial Results (PPB)	Plan for Elevated Source (Remediate & Re-Test, Signage, or Permanently Remove)	1st Follow Up Date	1st Follow Up Results (PPB) First Draw (R) / Flush (F)	2nd Follow Up Date	2nd Follow Up Results (PPB) First Draw (2R) / Flush (2F)	Comments on Completion
Barbara Jordan	BJ-PF-165-1-34	170	Re-Test	9/13/2024	R = <1.0 / F = <1.0			Perform Annual Sampling
Flynn Park	FP-F-107A-1-9	37.5	Re-Test	9/13/2024	R = <1.0 / F = <1.0			Perform Annual Sampling
	FP-SN-107A-1-10	22.3	Does Not Exist - Taken out of Service					Water Source Does not Exist (Taken out of Service)
	FP-F-BOI-LL-13	36.3	Signage					Signage Installed
High School	HS-F-328-3-24	11.8	Re-Test	9/13/2024	R = 2.5 / F = 1.5			Perform Annual Sampling
	HS-F-004B-G-73	6.1	Re-Test	9/13/2024	R = 2.0 / F = <1.0			Perform Annual Sampling
	HS-KF-006A-G-77	6.4	Re-Test	9/13/2024	R = <1.0 / F = <1.0			Perform Annual Sampling
Jackson Park	JP-F-201-1-7	23.4	Re-Test	9/13/2024	R = <1.0 / F = <1.0			Perform Annual Sampling
	JP-F-103-G-18	26.7	Re-Test	9/13/2024	R = 2.5 / F = <1.0			Perform Annual Sampling
Brittany Woods	BW-DF-259-2-7	17.3	Permanantly Remove					Permanently Removed
	BW-F-245A-2-11	7,340	Signage					Signage Installed
	BW-F-125-1-50	34.6	Signage					Signage Installed