



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Randolph BOE (9176) Transition House, 573 Millbrook Avenue, Randolph NJ 07869

PAS Project ID : P25-00261

Matrix : Drinking Water
Report Date : 1/20/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-00261-01	RTRANS-1-S01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/27/24 12:29	1/10/25 19:35
P25-00261-02	RTRANS-1-S02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/27/24 12:30	1/10/25 19:39
P25-00261-03	RTRANS-12-27-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/27/24 12:30	1/10/25 19:55

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer

