

Facility Name:  
Station ID Number:

Richmond Middle School  
SCH-20825  
Testing Lead in Drinking Water

Outlet Type:	BF: Bathroom Faucet	CF: Classroom Faucet	DF: Drinking Fountain	IM: Ice Machine	KF: Kitchen Faucet	NS: Nurse's Sink	O: Other	R: Refrigerator
--------------	---------------------	----------------------	-----------------------	-----------------	--------------------	------------------	----------	-----------------

Station ID	Outlet	Outlet	Floor	Location / Room Number	Sample Date	Sample Time	Sample Result	Notes
20825	1	DF	G	Gym Hall Corridor 149 Bubbler	12/11/2024	6:00 AM	< 0.001	
20825	2	CF	G	Rm 806 (011) Classroom Sink #2	12/11/2024	6:01 AM	< 0.001	
20825	3	CF	G	Rm 804 (017) Classroom Sink #1	12/11/2024	6:02 AM	< 0.001	
20825	4	CF	G	Rm 804 (017) Classroom Sink #2	12/11/2024	6:03 AM	< 0.001	
20825	5	O	G	Rm 804/806 (013) Prep Room Sin	12/11/2024	6:04 AM	< 0.001	
20825	6	DF	G	8th Gr Hall Corridor 007 Bubbler	12/11/2024	6:05 AM	< 0.001	
20825	7	CF	G	Rm 800 (031) Classroom Sink	12/11/2024	6:06 AM	< 0.001	
20825	8	CF	G	Rm 800 (028) Classroom Sink	12/11/2024	6:07 AM	< 0.001	
20825	9	DF	1	Music Hall Corridor 117 Bubbler	12/11/2024	6:08 AM	< 0.001	
20825	10	CF	1	Rm 715 (172) Classroom Sink #1	12/11/2024	6:09 AM	< 0.001	Living Arts
20825	11	CF	1	Rm 715 (172) Classroom Sink #2	12/11/2024	6:10 AM	< 0.001	Living Arts
20825	12	CF	1	Rm 715 (172) Classroom Sink #3	12/11/2024	6:11 AM	< 0.001	Living Arts
20825		CF	1	Rm 715 (172) Classroom Sink #4			N/A	Sink removed/Dish washer installed
20825	13	CF	1	Rm 715 (172) Classroom Sink #5	12/11/2024	6:13 AM	< 0.001	Living Arts
20825	14	CF	1	Rm 715 (172) Classroom Sink #6	12/11/2024	6:14 AM	< 0.001	Living Arts
20825	15	CF	1	Rm 713 (169) Classroom Sink #1	12/11/2024	6:15 AM	< 0.001	Art Room
20825	16	CF	1	Rm 713 (169) Classroom Sink #2	12/11/2024	6:16 AM	< 0.001	Art Room
20825	17	CF	1	Rm 713 (169) Classroom Sink #3	12/11/2024	6:17 AM	< 0.001	Art Room
20825	18	CF	1	Rm 713 (169) Classroom Sink #4	12/11/2024	6:18 AM	< 0.001	Art Room
20825	19	CF	1	Rm 713 (169) Classroom Sink #5	12/11/2024	6:19 AM	< 0.001	Art Room
20825	20	CF	1	Rm 713 (169) Classroom Sink #6	12/11/2024	6:20 AM	< 0.001	Art Room
20825	21	NS	1	Rm 71 (162) Nurse Sink #1	12/11/2024	6:21 AM	< 0.001	Counter Sink
20825	22	NS	1	Rm 71 (162) Nurse Sink #2	12/11/2024	6:22 AM	< 0.001	Hand Sink
20825	23	NS	1	Rm 71 (162b) Nurse Sink #3	12/11/2024	6:23 AM	< 0.001	Hand Sink
20825	24	O	1	Rm 73 (142) Staff Room Sink	12/11/2024	6:24 AM	< 0.001	
20825	25	CF	1	Rm 702 (135) Classroom Sink #1	12/11/2024	6:25 AM	< 0.001	
20825	26	CF	1	Rm 702 (135) Classroom Sink #2	12/11/2024	6:26 AM	< 0.001	
20825	27	O	1	Rm 702A (131) Prep Room Sink	12/11/2024	6:27 AM	0.0016	
20825	28	CF	1	Rm 704 (129) Classroom Sink #1	12/11/2024	6:28 AM	< 0.001	
20825	29	CF	1	Rm 704 (129) Classroom Sink #2	12/11/2024	6:29 AM	< 0.001	
20825	30	DF	1	7th Gr Hall Corridor 125 Bubbler	12/11/2024	6:30 AM	< 0.001	
20825	31	O	1	Rm 729 (141A) Workroom Sink	12/11/2024	6:31 AM	< 0.001	
20825	32	DF	1	Hall Corridor 180 Bubbler	12/11/2024	6:32 AM	< 0.001	
20825	33	KF	1	Room 728a(145) Kitchen Sink #1	12/11/2024	6:33 AM	0.0081	Hand Sink
20825	34	KF	1	Room 728a(145) Kitchen Sink #2	12/11/2024	6:34 AM	< 0.001	Hand Sink
20825	35	KF	1	Room 728a(145) Kitchen Sink #3	12/11/2024	6:35 AM	< 0.001	Produce Sink
20825	36	O	2	Rm 604 (209) Staff Room Sink	12/11/2024	6:36 AM	< 0.001	
20825	37	CF	2	Rm 602 (219) Classroom Sink #1	12/11/2024	6:37 AM	< 0.001	
20825		CF	2	Rm 602 (219) Classroom Sink #2			N/A	Sink out of order on 12/11/2024, No faucet at time of testing
20825	38	DF	2	6th Gr Hall Corridor 216 Bubbler	12/11/2024	6:38 AM	< 0.001	