

ERROL HASSELL_LOCATION (FACILITIES REPIPE PROJECT)	SAMPLE ID	DATE	LEAD RESULT (ppb)	FLUSH TEST LEAD RESULT (ppb)	POST- MITIGATION SAMPLE DATE	POST- MITIGATION SAMPLE (ppb)
Classroom M100	EHES-001CFA	12/23/2024	ND	-	-	-
Classroom M100	EHES-002DWA	12/23/2024	1	-	-	-
Classroom M102	EHES-003CFA	12/23/2024	12.3	3.3	-	-
Classroom M102	EHES-004DWA	12/23/2024	12.8	3.3	-	-
Classroom M104	EHES-005CFA	12/23/2024	4.2	-	-	-
Classroom 104	EHES-006DWA	12/23/2024	2	-	-	-
Classroom M106	EHES-007CFA	12/23/2024	1.3	-	-	-
Classroom M106	EHES-008DWA	12/23/2024	1	-	-	-
M Classrooms Hallway	EHES-009DWA	12/23/2024	ND	-	-	-
M Hall Boys Restroom (Left)	EHES-010BFA	12/23/2024	2.9	-	-	-
M Hall Boys Restroom (Right)	EHES-011BFA	12/23/2024	7.3	-	-	-
M Hall Girls Restroom (Left)	EHES-012BFA	12/23/2024	2.1	-	-	-
M Hall Girls Restroom (Right)	EHES-013BFA	12/23/2024	10.8	-	-	-
Classroom B110	EHES-014CFA	12/23/2024	49.2	ND	1/17/2025	3.5
Classroom B110	EHES-015DWA	12/23/2024	1.2	-	-	-
Classroom B108	EHES-016CFA	12/23/2024	3	-	-	-
Classroom B108	EHES-017DWA	12/23/2024	1.7	-	-	-
Classroom B106	EHES-018CFA	12/23/2024	2.6	-	-	-
Classroom B106	EHES-019DWA	12/23/2024	1.5	-	-	-
Classroom B120	EHES-020CFA	12/23/2024	5.6	-	-	-
Classroom B120	EHES-021DWA	12/23/2024	2.2	-	-	-
Classroom B122	EHES-022CFA	12/23/2024	2.9	-	-	-
Classroom B122	EHES-023DWA	12/23/2024	ND	-	-	-
Classroom B124	EHES-024CFA	12/23/2024	4.5	-	-	-
Classroom B124	EHES-025DWA	12/23/2024	2.4	-	-	-
B Hall Staff Restroom (Left)	EHES-026BFA	12/23/2024	3.5	-	-	-
B Hall Staff Restroom (Right)	EHES-027BFA	12/23/2024	5.9	-	-	-
B Hall Girls Restroom (Left)	EHES-028BFA	12/23/2024	1.9	-	-	-
B Hall Girls Restroom (Right)	EHES-029BFA	12/23/2024	1.3	-	-	-
B Hall Boys Restroom (Left)	EHES-030BFA	12/23/2024	2.6	-	-	-
B Hall Boys Restroom (Right)	EHES-031BFA	12/23/2024	1.6	-	-	-