



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)668-9078 Fax – (732)358-0168
Cert # 00407A Cert # 00430E
Asb # 01200

05/22/2023

Re: 612 Amboy Ave Perth Amboy NJ 08861

To whom it may concern,

We have sampled the drinking water at the above property for lead. Please note the Federal Action for Copper is 1,300 ug/l (ppb) and for lead is 15 ug/l (ppb).

All results were found to be above/below the action level

Feel Free to contact us with any questions.

Matitia Charbit
732-668-9078



30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 913942
Sampling Date : 05/15/2023
Date Received : 05/17/2023
Date Analyzed : 05/18/2023
Date Reported : 05/19/2023

Client Project : 612 AMBOY AVE PERTH AMBOY NJ **Collected By :** MATITIA CHARBIT

WSSN :

Project Location : 612 AMBOY AVE PERTH AMBOY NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8441431	1	TEACHER LUNCH RM IMMEDIATE	NA		0.0028	0.0020	Below
8441432	2	TEACHER LUNCH RM AFTER RUN	NA		<0.0020	0.0020	Below
8441433	3	BOYS BATHRM 2ND FL IMMEDIATE	NA		<0.0020	0.0020	Below
8441434	4	BOYS BATHRM 2ND FL AFTER RUN	NA		<0.0020	0.0020	Below
8441435	5	PRINCIPAL OFFICE IMMEDIATE	NA		0.0033	0.0020	Below
8441436	6	PRINCIPAL OFFICE AFTER RUN	NA		<0.0020	0.0020	Below
8441437	7	GIRLS BATH 2ND FL IMMEDIATE	NA		<0.0020	0.0020	Below
8441438	8	GIRLS BATH 2ND FL AFTER RUN	NA		<0.0020	0.0020	Below
8441439	9	FOUNTAIN RECTORY BLDG IMMEDIATE	NA		<0.0020	0.0020	Below
8441440	10	FOUNTAIN RECTORY BLDG AFTER RUN	NA		<0.0020	0.0020	Below
8441441	11	BASEMENT BATHRM IMMEDIATE	NA		<0.0020	0.0020	Below
8441442	12	BASEMENT BATHRM AFTER RUN	NA		<0.0020	0.0020	Below
8441443	13	KITCHEN IMMEDIATE	NA		<0.0020	0.0020	Below
8441444	14	KITCHEN AFTER RUN	NA		0.0026	0.0020	Below
8441445	15	NURSE RM IMMEDIATE	NA		<0.0020	0.0020	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 05/19/2023

AAT Project: 913942

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8441446	16	NURSE RM AFTER RUN	NA		0.0029	0.0020	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed.
 Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 913942
Sampling Date : 05/15/2023
Date Received : 05/17/2023
Date Analyzed : 05/18/2023
Date Reported : 05/19/2023

Client Project : 612 AMBOY AVE PERTH AMBOY | **Collected By :** MATITIA CHARBIT
Project Location : 612 AMBOY AVE PERTH AMBOY NJ

WSSN :

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
8441431	1	TEACHER LUNCH RM IMMEDIATE	NA		0.1251	Below
8441432	2	TEACHER LUNCH RM AFTER RUN	NA		0.0906	Below
8441433	3	BOYS BATHRM 2ND FL IMMEDIATE	NA		0.0282	Below
8441434	4	BOYS BATHRM 2ND FL AFTER RUN	NA		0.0184	Below
8441435	5	PRINCIPAL OFFICE IMMEDIATE	NA		0.1749	Below
8441436	6	PRINCIPAL OFFICE AFTER RUN	NA		0.0119	Below
8441437	7	GIRLS BATH 2ND FL IMMEDIATE	NA		0.0117	Below
8441438	8	GIRLS BATH 2ND FL AFTER RUN	NA		0.0105	Below
8441439	9	STAIN RECTORY BLDG IMMEDIATE	NA		0.2026	Below
8441440	10	STAIN RECTORY BLDG AFTER RUN	NA		0.1020	Below
8441441	11	BASEMENT BATHRM IMMEDIATE	NA		0.2158	Below
8441442	12	BASEMENT BATHRM AFTER RUN	NA		0.0490	Below
8441443	13	KITCHEN IMMEDIATE	NA		0.0221	Below
8441444	14	KITCHEN AFTER RUN	NA		0.0250	Below
8441445	15	NURSE RM IMMEDIATE	NA		0.0255	Below
8441446	16	NURSE RM AFTER RUN	NA		0.1414	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit. The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results

relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.

All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 05/19/2023

AAT Project: 913942



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

AAT Project : 913942
Client Project : 612 AMBOY AVE PERTH AMBC
Date Reported : 05/19/2023

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
Phone : 732-668-9078

Project Location : 612 AMBOY AVE PERTH AMBOY NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
8441431	1	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441432	2	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441433	3	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441434	4	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441435	5	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441436	6	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441437	7	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441438	8	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441439	9	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441440	10	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441441	11	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441442	12	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441443	13	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441444	14	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441445	15	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise
8441446	16	Pb/Cu in Drinking Water	05/18/2023	Joseph Kenwabikise

Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



AAA LEAD PROFESSIONALS
 6 WHITE DOVE CT
 LAKEWOOD NJ 08701
 732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT
			✓

CHAIN OF CUSTODY

ADDRESS: 612 AMBOY AVE PERTH AMBOY NJ

Lead & Copper in water testing

8/14/23

SAMPLE	ROOM	PLACE	AREA	
1	TEACHER LUNCH ROOM	IMMEDIATE		
2		AFTER RUN		
3	BOYS BATHROOM SEC FLOOR	IMMEDIATE		
4		AFTER RUN		
5	PRINCIPAL OFFICE	IMMEDIATE		
6		AFTER RUN		
7	GIRLS BATH SEC FLOOR	IMMEDIATE		
8		AFTER RUN		
9	FOUNTAIN RECTORY BLDG	IMMEDIATE		
10		AFTER RUN		
11	BASEMENT BATHROOM	IMMEDIATE		
12		AFTER RUN		
13	KITCHEN	IMMEDIATE		
14		AFTER RUN		
15	NURSE ROOM	IMMEDIATE		
16		AFTER RUN		

TAKEN AND RELINQUISHED BY:
 MATITIA CHARBIT

Signature

DATE: 5/15/23

913942

DM 5-17 10a