ENVIRONMENTAL SERVICES
A Mainline Company

181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:
Manville School District

Performed For:
Manville School District
Mark Manderski
1100 Brooks Blvd, Manville, NJ, 08835

Prepared By:
LEW Environmental Services, LLC.
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website http://www.LEWCorp.com

Inspection Date: 10/27/2024
Project Number: 2347

Table of Contents

Contact Information 3
Introduction 4
Sampling Methodology 4
Drinking Water Results 5
Recommendations 5
Additional Recommendations 6

Appendices

Appendix A Exceedances
Appendix B Recommendations
Appendix C All results
Appendix D Floor Plan(S)
Appendix E Laboratory Data

Contact Information

Education Agency

Client Contact:	Mark Manderski3
Client Name:	Manville School District3
Street Address	1100 Brooks Blvd3, Manville3, NJ, 08835
Phone Number:	(908) 623-00583

Sampler(s)

Site Assessor(s):	Marvin Ayumbi
Signature:	
Date:	October 27, 2024

Firm

Organization:	LEW Environmental Services, LLC.
Certification #:	NJDCA 00015 E
Street:	181 US Hwy 46
City, State & Zip:	Mine Hill, NJ 07803
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	Environmental Hazard Services, LLC
Street:	7469 Whitepine Road
City, State & Zip:	Richmond, VA 23237
NJDEP Certification #	VA008
Phone Number:	800-347-4010

Introduction

LEW Environmental Services, LLC. was contracted by Manville School District to test for the presence of lead in drinking water in four schools in the district.

Sampling Methodology

LEW Environmental Services, LLC. followed NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.

Drinking Water Results

On October 27, 2024, LEW Environmental Services, LLC. collected the following number of water samples:

Manville High School
- 25 first draw samples
- 0 samples above the 15ppb action level

Roosevelt School
- 5 first draw samples
- 0 samples above the 15ppb action level

Weston Elementary School
- 10 first draw samples
- 0 samples above the 15ppb action level

Alexander Batcho Intermediate School
- 23 first draw samples collected
- 0 samples above the 15ppb action level

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix E.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

School	Sample Location	Reason for not testing.
ABIS	WC-Room 108	Removed
ABIS	DW-Room 106	Removed
ABIS	FP-Kitchen	Not found
ABIS	DW-Gym Hall	Not Functional
Manville High School	DW-Trainer's Office	Not found
Weston Elementary School	DW-Main Hallway	Removed
Roosevelt School	WC-2nd Floor Hall	Out of order
None		

Recommendations

Those outlets where the first draw sample tested below 15ppb are not considered to be elevated and no mitigation is necessary.

A complete list of recommendations per outlet can be found in Appendix B.

Additional Recommendations

1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sample.
3) Comply with all requirements set forth in NJAC 6A:26.

Appendix A Exceedances

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Manville High School	10/3/2024	11/5/2024	No actionable sample results		
Roosevelt School	10/3/2024	11/5/2024	No actionable sample results		
Weston Elementary School	10/3/2024	11/5/2024	No actionable sample results		
Alexander Batcho Intermediate School	10/3/2024	10/17/2024	No actionable sample results		

Appendix B Recommendations

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Manville High School	10/3/2024	11/5/2024	No actionable sample results		
Roosevelt School	10/3/2024	11/5/2024	No actionable sample results		
Weston Elementary School	10/3/2024	11/5/2024	No actionable sample results		
Alexander Batcho Intermediate School	10/3/2024	10/17/2024	No actionable sample results		

Appendix C All Results

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentr
Manville High School	10/27/2024	11/7/2024	1	MHS-TL	1.13
Manville High School	10/27/2024	11/7/2024	2	MHS-NS-1	3.88
Manville High School	10/27/2024	11/7/2024	3	MHS-NS-2	1.67
Manville High School	10/27/2024	11/7/2024	4	MHS-WC	<1.00
Manville High School	10/27/2024	11/7/2024	4A	MHS-BF	<1.00
Manville High School	10/27/2024	11/7/2024	5	MHS-WC-2	<1.00
Manville High School	10/27/2024	11/7/2024	5A	MHS-BF-2	<1.00
Manville High School	10/27/2024	11/7/2024	6	MHS-FP-1	<1.00
Manville High School	10/27/2024	11/7/2024	7	NHS-FP-2	2.90
Manville High School	10/27/2024	11/7/2024	8	MHS-WC	<1.00
Manville High School	10/27/2024	11/7/2024	8A	MHS-BF	<1.00
Manville High School	10/27/2024	11/7/2024	9	MHS-WC	<1.00
Manville High School	10/27/2024	11/7/2024	9A	MHS-BF	<1.00
Manville High School	10/27/2024	11/7/2024	9B	MHS-WC	<1.00
Manville High School	10/27/2024	11/7/2024	9C	MHS-BF	<1.00
Manville High School	10/27/2024	11/7/2024	10	MHS-WC	<1.00
Manville High School	10/27/2024	11/7/2024	10A	MHS-BF	<1.00
Manville High School	10/27/2024	11/7/2024	11	MHS-IM	<1.00
Manville High School	10/27/2024	11/7/2024	13	MHS-DW	<1.00
Manville High School	10/27/2024	11/7/2024	14	MHS-WC	<1.00
Manville High School	10/27/2024	11/7/2024	14A	MHS-BF	<1.00
Manville High School	10/27/2024	11/7/2024	14B	MHS-WC	<1.00
Manville High School	10/27/2024	11/7/2024	14C	MHS-BF	<1.00
Manville High School	10/27/2024	11/7/2024	15	MHS-WC	<1.00
Manville High School	10/27/2024	11/7/2024	15A	MHS-BF	<1.00
Manville High School	10/27/2024	11/7/2024	16	MHS-SR	<1.00
Roosevelt School	10/27/2024	11/4/2024	1	R-WC	<1.00
Roosevelt School	10/27/2024	11/4/2024	1A	R-BF	<1.00
Roosevelt School	10/27/2024	11/4/2024	2	R-TL	<1.00
Roosevelt School	10/27/2024	11/4/2024	3	R-NS	1.25
Roosevelt School	10/27/2024	11/4/2024	4A	R-BF	<1.00
Roosevelt School	10/27/2024	11/4/2024	5	R-SR	<1.00
Weston Elementary School	10/27/2024	11/4/2024	1	W-WC-1	<1.00
Weston Elementary School	10/27/2024	11/4/2024	2	W-WC-2	<1.00
Weston Elementary School	10/27/2024	11/4/2024	2A	W-BF	<1.00
Weston Elementary School	10/27/2024	11/4/2024	3	W-FP	<1.00
Weston Elementary School	10/27/2024	11/4/2024	4	W-WC	<1.00
Weston Elementary School	10/27/2024	11/4/2024	4A	W-BF	<1.00
Weston Elementary School	10/27/2024	11/4/2024	5	W-TL	1.50
Weston Elementary School	10/27/2024	11/4/2024	6	W-DW	<1.00
Weston Elementary School	10/27/2024	11/4/2024	6A	W-BF	<1.00
Weston Elementary School	10/27/2024	11/4/2024	8	W-NS	1.79
Weston Elementary School	10/27/2024	11/4/2024	9	W-SR	<1.00
ABIS	10/27/2024	11/6/2024	2	ABIS-WC-1	<1.00
ABIS	10/27/2024	11/6/2024	2A	ABIS-BF-1	<1.00
ABIS	10/27/2024	11/6/2024	3	ABIS-WC-2	<1.00
ABIS	10/27/2024	11/6/2024	3A	ABIS-BF-2	<1.00
ABIS	10/27/2024	11/6/2024	3B	ABIS-WC	<1.00
ABIS	10/27/2024	11/6/2024	3C	ABIS-BF	<1.00
ABIS	10/27/2024	11/6/2024	3D	ABIS-WC	<1.00
ABIS	10/27/2024	11/6/2024	3E	ABIS-BF	<1.00
ABIS	10/27/2024	11/6/2024	5	ABIS-WC-1	<1.00
ABIS	10/27/2024	11/6/2024	5A	ABIS-BF-1	<1.00
ABIS	10/27/2024	11/6/2024	6	ABIS-WC-2	<1.00

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentr
ABIS	10/27/2024	11/6/2024	12B	ABIS-WC-2	<1.00
ABIS	10/27/2024	11/6/2024	12C	ABIS-BF-2	<1.00
ABIS	10/27/2024	11/6/2024	13	ABIS-NS	<1.00
ABIS	10/27/2024	11/6/2024	14	ABIS-WC	<1.00
ABIS	10/27/2024	11/6/2024	14A	ABIS-BF	<1.00
ABIS	10/27/2024	11/6/2024	15	ABIS-DW	<1.00
ABIS	10/27/2024	11/6/2024	16	ABIS-SR	<1.00

Appendix D Floor Plan(s)

Appendix E Laboratory Data

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 24-10-06514

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Received Date: 10/31/2024
Reported Date: 11/07/2024
Sampled By: Marvin Ayumbi
Tech Certification #:

Project/Test Address: 2347; Manville High School; 1100 Brooks Blvd; Manville, NJ 08835

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-10-06514-001	1	10/27/2024	MHS-TL	1.13	11/07/2024	
24-10-06514-002	2	10/27/2024	MHS-NS-1	3.88	11/07/2024	
24-10-06514-003	3	10/27/2024	MHS-NS-2	1.67	11/07/2024	
24-10-06514-004	4	10/27/2024	MHS-WC	<1.00	11/07/2024	
24-10-06514-005	4A	10/27/2024	MHS-BF	<1.00	11/07/2024	
24-10-06514-006	5	10/27/2024	MHS-WC-2	<1.00	11/07/2024	
24-10-06514-007	5A	10/27/2024	MHS-BF-2	<1.00	11/07/2024	
24-10-06514-008	6	10/27/2024	MHS-FP-1	<1.00	11/07/2024	
24-10-06514-009	7	10/27/2024	NHS-FP-2	2.90	11/07/2024	
24-10-06514-010	8	10/27/2024	MHS-WC	<1.00	11/07/2024	
24-10-06514-011	8A	10/27/2024	MHS-BF	<1.00	11/07/2024	
24-10-06514-012	9	10/27/2024	MHS-WC	<1.00	11/07/2024	
24-10-06514-013	9A	10/27/2024	MHS-BF	<1.00	11/07/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327 Report Number: 24-10-06514

Project/Test Address: 2347; Manville High School; 1100 Brooks Blvd; Manville, NJ 08835

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-10-06514-014	9B	10/27/2024	MHS-WC	<1.00	11/07/2024	
24-10-06514-015	9C	10/27/2024	MHS-BF	<1.00	11/07/2024	
24-10-06514-016	10	10/27/2024	MHS-WC	<1.00	11/07/2024	
24-10-06514-017	10A	10/27/2024	MHS-BF	<1.00	11/07/2024	
24-10-06514-018	11	10/27/2024	MHS-IM	<1.00	11/07/2024	
24-10-06514-019	13	10/27/2024	MHS-DW	<1.00	11/07/2024	
24-10-06514-020	14	10/27/2024	MHS-WC	<1.00	11/07/2024	
24-10-06514-021	14A	10/27/2024	MHS-BF	<1.00	11/07/2024	
24-10-06514-022	14B	10/27/2024	MHS-WC	<1.00	11/07/2024	
24-10-06514-023	14C	10/27/2024	MHS-BF	<1.00	11/07/2024	
24-10-06514-024	15	10/27/2024	MHS-WC	<1.00	11/07/2024	
24-10-06514-025	15A	10/27/2024	MHS-BF	<1.00	11/07/2024	
24-10-06514-026	16	10/27/2024	MHS-SR	<1.00	11/07/2024	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory: Candace Mason

Candace Mason
QA Chemist

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart ® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

24-10-06514

Due Date:
11/07/2024
(Thursday)
AE

Client Name: LEW Environmental Services Account #: 201327

Address: 181 US Hwy 46

City/State/Zip: Mine Hill NJ 07803 Phone: 908-654-8069

Email Address: labresults@lewenvironmental.com

Project Name/ Number: Manville High School / 2347

Collection Address: 1100 Brooks Blvd City/State/Zip: Manville NJ 08835
(Required) (Required)

Approx. Age Of Property: 1957 Collected By: Marvin Ayumbi

Water Source: (Check One) Public X or Well _____ Well Tag # (if applicable): _____

Turn-Around Time ____ 5 Days ____ 3 Days ____ 2 Days ____ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	1	MHS - TL	10/27/24	AM / PM	✓	
2	2	MHS - NS-1		AM / PM	✓	
3	3	MHS - NS-2		AM / PM	✓	
4	4	MHS - WC		AM / PM	✓	
5	4A	MHS - BF		AM / PM	✓	
6	5	MHS - WC-2		AM / PM	✓	
7	5A	MHS - BF-2		AM / PM	✓	
8	6	MHS - FP-1		AM / PM	✓	
9	7	MHS - FP-2		AM / PM	✓	
10	8	MHS - WC		AM / PM	✓	
11	8A	MHS - BF		AM / PM	✓	
12	9	MHS - WC		AM / PM	✓	
13	9A	MHS - BF		AM / PM	✓	
14	9B	MHS - WC		AM / PM	✓	
15	9C	MHS - BF	10/27/24	AM / PM	✓	

Released by: Marvin Ayumbi	Signature:	Date/Time: 10/28/24
Received by: Ava Swart	Signature: A Swart	Date/Time: 10/31/24

1:01 pm

Client Name: _____ Account #_____ Page 2 of _____

Project Name: _____

Lab I.D. #: _____-_____-_____

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
16	10	MHS - WC	10/27/24	AM / PM		
17	10A	MHS - BF		AM / PM		
18	11	MHS - IM		AM / PM		
19	13	MHS - DW		AM / PM		
20	14	MHS - WC		AM / PM		
21	14A	MHS - BF		AM / PM		
22	14B	MHS - WC		AM / PM		
23	14C	MHS - BF		AM / PM		
24	15	MHS - WC		AM / PM		
25	15A	MHS - BF		AM / PM		
26	16	MHS - SR	10/27/24	AM / PM		
27				AM / PM		
28				AM / PM		
29				AM / PM		
30				AM / PM		
31				AM / PM		
32				AM / PM		
33				AM / PM		
34				AM / PM		
35				AM / PM		
36				AM / PM		
37				AM / PM		
38				AM / PM		
39				AM / PM		
40				AM / PM		
41				AM / PM		
42				AM / PM		
43				AM / PM		
44				AM / PM		
45				AM / PM		
46				AM / PM		
47				AM / PM		
48				AM / PM		
49				AM / PM		
50				AM / PM		

Released by:	Signature:	Date/Time:
Received by: A Swart	Signature: A Swart	Date/Time: 10/31/24 1:01 PM

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 24-10-06517

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Received Date: 10/31/2024
Reported Date: 11/06/2024
Sampled By: Marvin Ayumbi
Tech Certification #:

Project/Test Address: 2347; Roosevelt Elementary; 410 Brooks Blvd; Manville, NJ 08835

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-10-06517-001	1	10/27/2024	R-WC	<1.00	11/04/2024	
24-10-06517-002	1A	10/27/2024	R-BF	<1.00	11/04/2024	
24-10-06517-003	2	10/27/2024	R-TL	<1.00	11/04/2024	
24-10-06517-004	3	10/27/2024	R-NS	1.25	11/04/2024	
24-10-06517-005	4A	10/27/2024	R-BF	<1.00	11/04/2024	
24-10-06517-006	5	10/27/2024	R-SR	<1.00	11/04/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327 Report Number: 24-10-06517

Project/Test Address: 2347; Roosevelt Elementary; 410 Brooks Blvd; Manville, NJ 08835

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory: Melissa Kanode

Melissa Kanode
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

24-10-06517

Due Date:
11/07/2024
(Thursday)
AE

ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart ® Lead Chain-of-Custody Form

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC
Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

Client Name: LEW Environmental Services Account #: 201327

Address: 181 US Hwy 46

City/State/Zip: Mine Hill NJ 07803 Phone: 908-654-8069

Email Address: labresults@lewenvironmental.com

Project Name/ Number: Roosevelt Elementary / 2347

Collection Address: 410 Brooks Blvd (Required) City/State/Zip: Manville NJ 08835 (Required)

Approx. Age Of Property: 1929 Collected By: Marvin Ayumbi

Water Source: (Check One) Public X or Well _____ Well Tag # (if applicable): _____

Turn-Around Time ____ 5 Days ____ 3 Days ____ 2 Days ____ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte Pb	Analyte Cu
1	1	R - WC	10/27/24	AM / PM	✓	
2	1A	R - BF	↓	AM / PM	✓	
3	2	R - TL	↓	AM / PM	✓	
4	3	R - NS	↓	AM / PM	✓	
5	4A	R - BF	↓	AM / PM	✓	
6	5	R - SR	10/27/24	AM / PM	✓	
7				AM / PM		
8				AM / PM		
9				AM / PM		
10				AM / PM		
11				AM / PM		
12				AM / PM		
13				AM / PM		
14				AM / PM		
15				AM / PM		

Released by: Marvin Ayumbi Signature: [signature] Date/Time: 10/28/24

Received by: A Swart Signature: A Swart Date/Time: 10/31/24

1:21

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 24-10-06518

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Received Date: 10/31/2024
Reported Date: 11/06/2024
Sampled By: Marvin Ayumbi
Tech Certification #:

Project/Test Address: 2347; Weston Elementary; 600 Newark Ave; Manville, NJ 08835

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-10-06518-001	1	10/27/2024	W-WC-1	<1.00	11/04/2024	
24-10-06518-002	2	10/27/2024	W-WC-2	<1.00	11/04/2024	
24-10-06518-003	2A	10/27/2024	W-BF	<1.00	11/04/2024	
24-10-06518-004	3	10/27/2024	W-FP	<1.00	11/04/2024	
24-10-06518-005	4	10/27/2024	W-WC	<1.00	11/04/2024	
24-10-06518-006	4A	10/27/2024	W-BF	<1.00	11/04/2024	
24-10-06518-007	5	10/27/2024	W-TL	1.50	11/04/2024	
24-10-06518-008	6	10/27/2024	W-DW	<1.00	11/04/2024	
24-10-06518-009	6A	10/27/2024	W-BF	<1.00	11/04/2024	
24-10-06518-010	8	10/27/2024	W-NS	1.79	11/04/2024	
24-10-06518-011	9	10/27/2024	W-SR	<1.00	11/04/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327 Report Number: 24-10-06518

Project/Test Address: 2347; Weston Elementary; 600 Newark Ave; Manville, NJ 08835

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory: Melissa Kanode

Melissa Kanode
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

24-10-06518

ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart ® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Due Date:
11/07/2024
(Thursday)
AE

Client Name: LEW Environmental Services Account #: 201327

Address: 181 US Hwy 46

City/State/Zip: Mine Hill NJ 07803 Phone: 908-654-8069

Email Address: labresults@lewenvironmental.com

Project Name/ Number: Weston Elementary /2347

Collection Address: 600 Newark Ave (Required) City/State/Zip: Manville NJ 08835 (Required)

Approx. Age Of Property: 1968 Collected By: Marvin Ayumbi

Water Source: (Check One) Public X or Well _____ Well Tag # (if applicable): _____

Turn-Around Time ____ 5 Days ____ 3 Days ____ 2 Days ____ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte Pb	Analyte Cu
1	1	W-WC-1	10/27/24	AM / PM	✓	
2	2	W-WC-2		AM / PM	✓	
3	2A	W-BF		AM / PM	✓	
4	3	W-FP		AM / PM	✓	
5	4	W-WC		AM / PM	✓	
6	4A	W-BF		AM / PM	✓	
7	5	W-TL		AM / PM	✓	
8	6	W-DW		AM / PM	✓	
9	6A	W-BF		AM / PM	✓	
10	8	W-NS		AM / PM	✓	
11	9	W-SR	10/27/24	AM / PM	✓	
12				AM / PM		
13				AM / PM		
14				AM / PM		
15				AM / PM		

Released by: Marvin Ayumbi Signature: [signature] Date/Time: 10/28/24

Received by: A Swart Signature: A Swart Date/Time: 10/31/24 1:23 PM

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 24-10-06574

Client: LEW Corp
181 US Hwy 46
Mine Hill, NJ 07803

Received Date: 10/31/2024
Reported Date: 11/07/2024
Sampled By: Marvin Ayumbi
Tech Certification #:

Project/Test Address: 2347; ABIS; 100 North 13th Ave; Manville, NJ 08835

Client Number:
201327

Laboratory Results

Fax Number:
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-10-06574-001	2	10/27/2024	ABIS-WC-1	<1.00	11/06/2024	
24-10-06574-002	2A	10/27/2024	ABIS-BF-1	<1.00	11/06/2024	
24-10-06574-003	3	10/27/2024	ABIS-WC-2	<1.00	11/06/2024	
24-10-06574-004	3A	10/27/2024	ABIS-BF-2	<1.00	11/06/2024	
24-10-06574-005	3B	10/27/2024	ABIS-WC	<1.00	11/06/2024	
24-10-06574-006	3C	10/27/2024	ABIS-BF	<1.00	11/06/2024	
24-10-06574-007	3D	10/27/2024	ABIS-WC	<1.00	11/06/2024	
24-10-06574-008	3E	10/27/2024	ABIS-BF	<1.00	11/06/2024	
24-10-06574-009	5	10/27/2024	ABIS-WC-1	<1.00	11/06/2024	
24-10-06574-010	5A	10/27/2024	ABIS-BF-1	<1.00	11/06/2024	
24-10-06574-011	6	10/27/2024	ABIS-WC-2	<1.00	11/06/2024	
24-10-06574-012	6A	10/27/2024	ABIS-BF-2	<1.00	11/06/2024	
24-10-06574-013	7	10/27/2024	ABIS-FP	1.92	11/06/2024	

Environmental Hazards Services, L.L.C

Client Number: 201327 Report Number: 24-10-06574

Project/Test Address: 2347; ABIS; 100 North 13th Ave; Manville, NJ 08835

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
24-10-06574-014	10	10/27/2024	ABIS-DW	<1.00	11/06/2024	
24-10-06574-015	11	10/27/2024	ABIS-TL	<1.00	11/06/2024	
24-10-06574-016	12	10/27/2024	ABIS-WC-1	<1.00	11/06/2024	
24-10-06574-017	12A	10/27/2024	ABIS-BF-1	<1.00	11/06/2024	
24-10-06574-018	12B	10/27/2024	ABIS-WC-2	<1.00	11/06/2024	
24-10-06574-019	12C	10/27/2024	ABIS-BF-2	<1.00	11/06/2024	
24-10-06574-020	13	10/27/2024	ABIS-NS	<1.00	11/06/2024	
24-10-06574-021	14	10/27/2024	ABIS-WC	<1.00	11/06/2024	
24-10-06574-022	14A	10/27/2024	ABIS-BF	<1.00	11/06/2024	
24-10-06574-023	15	10/27/2024	ABIS-DW	<1.00	11/06/2024	
24-10-06574-024	16	10/27/2024	ABIS-SR	<1.00	11/06/2024	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NJ VA008

Reviewed By Authorized Signatory: Melissa Kanode

Melissa Kanode
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

24-10-06574

ENVIRONMENTAL HAZARDS SERVICES, LLC

WaterSmart ® Lead Chain-of-Custody Form

Richmond, VA - Phone: (800) 347-4010 FAX: (804) 275-4907
www.leadlab.com

EHS Laboratories
ENVIRONMENTAL HAZARDS SERVICES, LLC

Due Date:
11/07/2024
(Thursday)
AE

Client Name: LEW Environmental Services Account #: 20132.7

Address: 181 US HWY 46

City/State/Zip: Mine Hill NJ 07803 Phone: 908-654-8069

Email Address: labresults@lewenvironmental.com

Project Name/ Number: ABIS / 2347

Collection Address: 100 North 18th Ave (Required) City/State/Zip: Manville NJ 08835 (Required)

Approx. Age Of Property: 1970 Collected By: Marvin Ayumbi

Water Source: (Check One) Public X or Well _____ Well Tag # (if applicable): _____

Turn-Around Time ____ 5 Days ____ 3 Days ____ 2 Days ____ 1 Day

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
1	2	ABIS-WC-1	10/27/24	AM / PM	✓	
2	2A	ABIS-BF-1		AM / PM	✓	
3	3	ABIS-WC-2		AM / PM	✓	
4	3A	ABIS-BF-2		AM / PM	✓	
5	3B	ABIS-WC		AM / PM	✓	
6	3C	ABIS-BF		AM / PM	✓	
7	3D	ABIS-WC		AM / PM	✓	
8	3E	ABIS-BF		AM / PM	✓	
9	5	ABIS-WC-1		AM / PM	✓	
10	5A	ABIS-BF-1		AM / PM	✓	
11	6	ABIS-WC-2		AM / PM	✓	
12	6A	ABIS-BF-2		AM / PM	✓	
13	7	ABIS-FP		AM / PM	✓	
14	10	ABIS-DW		AM / PM	✓	
15	11	ABIS-TL	10/27/24	AM / PM	✓	

Released by: Marvin Ayumbi	Signature:	Date/Time: 10/28/24	
Received by: A Smart	Signature: A Smart	Date/Time: 10/31/24	

2:20

Client Name: _____ Account #_____ Page 2 of 2

Project Name: _____

Lab I.D. #: _____-_____-_____

No.	Client Sample ID	Collection Location (Ex: Kitchen Sink)	Collection Date	Collection Time	Analyte	
					Pb	Cu
16	12	ABIS – WC-1	10/27/24	AM / PM	✓	
17	12A	ABIS – BF-1		AM / PM	✓	
18	12B	ABIS – WC-2		AM / PM	✓	
19	12C	ABIS – BF-2		AM / PM	✓	
20	13	ABIS – KS		AM / PM	✓	
21	14	ABIS – WC		AM / PM	✓	
22	14A	ABIS – BF		AM / PM	✓	
23	15	ABIS – DW		AM / PM	✓	
24	16	ABIS – SR	10/27/24	AM / PM	✓	
25				AM / PM		
26				AM / PM		
27				AM / PM		
28				AM / PM		
29				AM / PM		
30				AM / PM		
31				AM / PM		
32				AM / PM		
33				AM / PM		
34				AM / PM		
35				AM / PM		
36				AM / PM		
37				AM / PM		
38				AM / PM		
39				AM / PM		
40				AM / PM		
41				AM / PM		
42				AM / PM		
43				AM / PM		
44				AM / PM		
45				AM / PM		
46				AM / PM		
47				AM / PM		
48				AM / PM		
49				AM / PM		
50				AM / PM		

Released by:		Signature:	Date/Time:
Received by:	A Swait	Signature: A Swait	Date/Time: 10/31/24

2:20