



Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Monday, January 27, 2025
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 78006.
First Draw samples flushed by Martel on November 6, 2024 sampled by Martel on November 7, 2024.
Project Identification: MD HB 270
School: Paul Barnhart Elementary School

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



Certificate of Analysis

MARTEL NO. 78006 1 CLIENT SAMPLE IDENTIFICATION PBES-1-FC Sample Date/Time 11/07/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:21 BJ

MARTEL NO. 78006 2 CLIENT SAMPLE IDENTIFICATION PBES-2-FC Sample Date/Time 11/07/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:31 BJ

MARTEL NO. 78006 3 CLIENT SAMPLE IDENTIFICATION PBES-3-FC Sample Date/Time 11/07/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.64	ug/l	EPA .200.8	2	01/07/2025 18:34 BJ

MARTEL NO. 78006 4 CLIENT SAMPLE IDENTIFICATION PBES-4-DC Sample Date/Time 11/07/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:37 BJ

MARTEL NO. 78006 5 CLIENT SAMPLE IDENTIFICATION PBES-5-IM Sample Date/Time 11/07/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:39 BJ

MARTEL NO. 78006 6 CLIENT SAMPLE IDENTIFICATION PBES-6-FC Sample Date/Time 11/07/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:36 BJ

MARTEL NO. 78006 7 CLIENT SAMPLE IDENTIFICATION PBES-7-FC Sample Date/Time 11/07/2024 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:39 BJ

MARTEL NO. 78006 8 CLIENT SAMPLE IDENTIFICATION PBES-8-FC Sample Date/Time 11/07/2024 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.89	ug/l*	EPA .200.8	2	12/16/2024 18:42 BJ



Certificate of Analysis

MARTEL NO. 78006 9 CLIENT SAMPLE IDENTIFICATION PBES-9-DB Sample Date/Time 11/07/2024 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:45 BJ

MARTEL NO. 78006 10 CLIENT SAMPLE IDENTIFICATION PBES-10-DC Sample Date/Time 11/07/2024 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:47 BJ

MARTEL NO. 78006 11 CLIENT SAMPLE IDENTIFICATION PBES-11-DC Sample Date/Time 11/07/2024 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:50 BJ

MARTEL NO. 78006 12 CLIENT SAMPLE IDENTIFICATION PBES-12-FC Sample Date/Time 11/07/2024 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.40	ug/l	EPA .200.8	2	12/16/2024 18:52 BJ

MARTEL NO. 78006 13 CLIENT SAMPLE IDENTIFICATION PBES-13-DB Sample Date/Time 11/07/2024 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:55 BJ

MARTEL NO. 78006 28 CLIENT SAMPLE IDENTIFICATION PBES-28-FC Sample Date/Time 11/07/2024 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:41 BJ

MARTEL NO. 78006 29 CLIENT SAMPLE IDENTIFICATION PBES-29-FC Sample Date/Time 11/07/2024 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.11	ug/l*	EPA .200.8	2	12/16/2024 18:57 BJ

MARTEL NO. 78006 30 CLIENT SAMPLE IDENTIFICATION PBES-30-FC Sample Date/Time 11/07/2024 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.10	ug/l	EPA .200.8	2	12/16/2024 18:15 BJ



Certificate of Analysis

MARTEL NO. 78006 31 CLIENT SAMPLE IDENTIFICATION PBES-31-DB Sample Date/Time 11/07/2024 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:18 BJ

MARTEL NO. 78006 32 CLIENT SAMPLE IDENTIFICATION PBES-32-FC Sample Date/Time 11/07/2024 06:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 18:20 BJ

MARTEL NO. 78006 33 CLIENT SAMPLE IDENTIFICATION PBES-33-DB Sample Date/Time 11/07/2024 06:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:27 BJ

MARTEL NO. 78006 34 CLIENT SAMPLE IDENTIFICATION PBES-34-FC Sample Date/Time 11/07/2024 06:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:29 BJ

MARTEL NO. 78006 35 CLIENT SAMPLE IDENTIFICATION PBES-35-DB Sample Date/Time 11/07/2024 06:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:32 BJ

MARTEL NO. 78006 36 CLIENT SAMPLE IDENTIFICATION PBES-36-FC Sample Date/Time 11/07/2024 06:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:35 BJ

MARTEL NO. 78006 37 CLIENT SAMPLE IDENTIFICATION PBES-37-DB Sample Date/Time 11/07/2024 06:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:43 BJ

MARTEL NO. 78006 38 CLIENT SAMPLE IDENTIFICATION PBES-38-FC Sample Date/Time 11/07/2024 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:46 BJ



MARTEL NO. 78006 39 CLIENT SAMPLE IDENTIFICATION PBES-39-DB Sample Date/Time 11/07/2024 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:37 BJ

MARTEL NO. 78006 40 CLIENT SAMPLE IDENTIFICATION PBES-40-FC Sample Date/Time 11/07/2024 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:40 BJ

MARTEL NO. 78006 41 CLIENT SAMPLE IDENTIFICATION PBES-41-FC Sample Date/Time 11/07/2024 06:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:48 BJ

MARTEL NO. 78006 42 CLIENT SAMPLE IDENTIFICATION PBES-42-DB Sample Date/Time 11/07/2024 06:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:51 BJ

MARTEL NO. 78006 43 CLIENT SAMPLE IDENTIFICATION PBES-43-FC Sample Date/Time 11/07/2024 06:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 18:53 BJ

MARTEL NO. 78006 44 CLIENT SAMPLE IDENTIFICATION PBES-44-DC Sample Date/Time 11/07/2024 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:03 BJ

MARTEL NO. 78006 45 CLIENT SAMPLE IDENTIFICATION PBES-45-DC Sample Date/Time 11/07/2024 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:08 BJ

MARTEL NO. 78006 46 CLIENT SAMPLE IDENTIFICATION PBES-46-FC Sample Date/Time 11/07/2024 06:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/08/2025 13:18 EK



Certificate of Analysis

MARTEL NO. 78006 47 CLIENT SAMPLE IDENTIFICATION PBES-47-DB Sample Date/Time 11/07/2024 06:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:13 BJ

MARTEL NO. 78006 48 CLIENT SAMPLE IDENTIFICATION PBES-48-FC Sample Date/Time 11/07/2024 06:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:16 BJ

MARTEL NO. 78006 49 CLIENT SAMPLE IDENTIFICATION PBES-49-FC Sample Date/Time 11/07/2024 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:18 BJ

MARTEL NO. 78006 50 CLIENT SAMPLE IDENTIFICATION PBES-50-DB Sample Date/Time 11/07/2024 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:21 BJ

MARTEL NO. 78006 51 CLIENT SAMPLE IDENTIFICATION PBES-51-FC Sample Date/Time 11/07/2024 20:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:23 BJ

MARTEL NO. 78006 52 CLIENT SAMPLE IDENTIFICATION PBES-52-DC Sample Date/Time 11/07/2024 21:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:26 BJ

MARTEL NO. 78006 53 CLIENT SAMPLE IDENTIFICATION PBES-53-FC Sample Date/Time 11/07/2024 24:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:28 BJ

MARTEL NO. 78006 56 CLIENT SAMPLE IDENTIFICATION PBES-56-DC Sample Date/Time 11/07/2024 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:36 BJ



Certificate of Analysis

MARTEL NO. 78006 57 CLIENT SAMPLE IDENTIFICATION PBES-57-DC Sample Date/Time 11/07/2024 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:43 BJ

MARTEL NO. 78006 62 CLIENT SAMPLE IDENTIFICATION PBES-62-FC Sample Date/Time 11/07/2024 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:46 BJ

MARTEL NO. 78006 63 CLIENT SAMPLE IDENTIFICATION PBES-63-DB Sample Date/Time 11/07/2024 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:48 BJ

MARTEL NO. 78006 80 CLIENT SAMPLE IDENTIFICATION PBES-80-DC Sample Date/Time 11/07/2024 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:51 BJ

MARTEL NO. 78006 81 CLIENT SAMPLE IDENTIFICATION PBES-81-DC Sample Date/Time 11/07/2024 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:53 BJ

MARTEL NO. 78006 90 CLIENT SAMPLE IDENTIFICATION PBES-90-FC Sample Date/Time 11/07/2024 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 19:55 BJ

MARTEL NO. 78006 91 CLIENT SAMPLE IDENTIFICATION PBES-91-DB Sample Date/Time 11/07/2024 06:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.87	ug/l*	EPA .200.8	2	01/07/2025 19:58 BJ

MARTEL NO. 78006 95 CLIENT SAMPLE IDENTIFICATION PBES-95-FC Sample Date/Time 11/07/2024 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.68	ug/l	EPA .200.8	2	01/07/2025 20:00 BJ



MARTEL NO. 78006 96 CLIENT SAMPLE IDENTIFICATION PBES-96-BU Sample Date/Time 11/07/2024 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 20:03 BJ

MARTEL NO. 78006 97 CLIENT SAMPLE IDENTIFICATION PBES-97-BU Sample Date/Time 11/07/2024 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/07/2025 20:12 BJ

MARTEL NO. 78006 1F CLIENT SAMPLE IDENTIFICATION PBES-1F-FC FLUSH Sample Date/Time 11/07/2024 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:42 BJ

MARTEL NO. 78006 2F CLIENT SAMPLE IDENTIFICATION PBES-2F-FC FLUSH Sample Date/Time 11/07/2024 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:45 BJ

MARTEL NO. 78006 3F CLIENT SAMPLE IDENTIFICATION PBES-3F-FC FLUSH Sample Date/Time 11/07/2024 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 19:56 BJ

MARTEL NO. 78006 4F CLIENT SAMPLE IDENTIFICATION PBES-4F-DC FLUSH Sample Date/Time 11/07/2024 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 20:01 BJ

MARTEL NO. 78006 6F CLIENT SAMPLE IDENTIFICATION PBES-6F-FC FLUSH Sample Date/Time 11/07/2024 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 20:03 BJ

MARTEL NO. 78006 7F CLIENT SAMPLE IDENTIFICATION PBES-7F-FC FLUSH Sample Date/Time 11/07/2024 06:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	12/16/2024 20:06 BJ



Certificate of Analysis

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78006	53	PBES-53F-F FLUSH				11/07/2024 06:47	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	12/16/2024 20:09 BJ	

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/6/24 5:49am End Date/Time: 11/6/24 6:49am
 Sampler/Relinquished By: NEVERSON Received at Martel by: Simms-Clark Date/Time: 11/6/24
11/7/24

21 C. Paul Barnhart Elementary School
First Draw

4800 Lancaster Circle Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78006

Martel #	Sample #	Location ID #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb.)</small>	Outlet Key Codes	Room/Location	Consumption <small>C or NC?</small>	Flush	Sample Time
							Flush Date	
1	1	PBES-1-FC	sink 2 compartment	FC	kitchen 2 comp sink	C	11/6	5:49
2	2	PBES-2-FC	island sink next to 2 comp sink	FC	kitchen sink	C	11/6	5:49
3	3	PBES-3-FC	island sink	FC	kitchen sink	C	11/6	5:49
4	4	PBES-4-DC	water fountain	DC	kitchen	C	11/6	5:49
5	5	PBES-5-IM	Ice Machine	IM	kitchen	C	11/6	5:49
6	6	PBES-6-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	11/6	5:49
7	7	PBES-7-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	11/6	5:49
8	8	PBES-8-FC	sink	FC	music room	C	11/6	5:51
9	9	PBES-9-DB	bubbler	DB	music room	C	11/6	5:51
10	10	PBES-10-DC	water fountain	DC	corridor	C	11/6	5:54
11	11	PBES-11-DC	water fountain	DC	corridor	C	11/6	5:54
12	12	PBES-12-FC	sink	FC	teacher lounge	C	11/6	5:57
13	13	PBES-13-DB	bubbler	DB	teacher lounge	C	11/6	5:57
14	28	PBES-28-FC	sink on right	FC	Classroom - K	C	11/6	6:00
15	29	PBES-29-FC	sink on left	FC	Classroom - K	C	11/6	6:00
16	30	PBES-30-FC	sink	FC	Classroom 114 - K	C	11/6	6:02
17	31	PBES-31-DB	bubbler	DB	Classroom 114 - K	C	11/6	6:02
18	32	PBES-32-FC	sink	FC	Classroom 113 - K	C	11/6	6:04
19	33	PBES-33-DB	bubbler	DB	Classroom 113 - K	C	11/6	6:04
20	34	PBES-34-FC	sink	FC	Classroom 105 - K	C	11/6	6:06
21	35	PBES-35-DB	bubbler	DB	Classroom 105 - K	C	11/6	6:06
22	36	PBES-36-FC	sink	FC	Classroom 109 - K	C	11/6	6:06
23	37	PBES-37-DB	bubbler	DB	Classroom 109 - K	C	11/6	6:06
24	38	PBES-38-FC	sink - Right	FC	Classroom 3 - Pre-K	C	11/6	6:11

21 C. Paul Barnhart Elementary School

First Draw

4800 Lancaster Circle Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78006

							Flush	
25	39	PBES-39-DB	bubbler	DB	Classroom 3 - Pre-K	C	11/6	6:11
26	40	PBES-40-FC	sink - Left	FC	Classroom 3 - Pre-K	C	11/6	6:11
27	41	PBES-41-FC	sink - Right	FC	Classroom 2 - Pre-K	C	11/6	6:13
28	42	PBES-42-DB	bubbler	DB	Classroom 2 - Pre-K	C	11/6	6:13
29	43	PBES-43-FC	sink - Left	FC	Classroom 2 - Pre-K	C	11/6	6:13
30	44	PBES-44-DC	water fountain	DC	corridor	C	11/6	6:15
31	45	PBES-45-DC	water fountain	DC	corridor	C	11/6	6:15
32	46	PBES-46-FC	sink - Left	FC	CR 1 - Pre-K	C	11/6	6:17
33	47	PBES-47-DB	bubbler	DB	CR 1 - Pre-K	C	11/6	6:17
34	48	PBES-48-FC	sink - Right	FC	CR 1 - Pre-K	C	11/6	6:17
35	49	PBES-49-FC	sink - Left	FC	Pre-K	C	11/6	6:19
36	50	PBES-50-DB	bubbler	DB	Pre-K	C	11/6	6:19
37	51	PBES-51-FC	sink - Right	FC	Pre-K	C	11/6	6:19
38	52	PBES-52-DC	water fountain	DC	corridor	C	11/6	6:20
39	53	PBES-53-FC	sink	FC	nurse office	C	11/6	6:21
40	56	PBES-56-DC	water fountain	DC	corridor (2nd Floor)	C	11/6	6:24
41	57	PBES-57-DC	water fountain	DC	corridor (2nd Floor)	C	11/6	6:24
42	62	PBES-62-FC	sink	FC	CR 23 (Sp-Ed) Pull Out (2nd Floor)	C	11/6	6:26
43	63	PBES-63-DB	bubbler	DB	CR 23 (Sp-Ed) Pull Out (2nd Floor)	C	11/6	6:26
44	80	PBES-80-DC	water fountain	DC	corridor (2nd Floor)	C	11/6	6:29
45	81	PBES-81-DC	water fountain	DC	corridor (2nd Floor)	C	11/6	6:29
46	90	PBES-90-FC	sink	FC	CR 10 (Sp-Ed) Pull Out (2nd Floor)	C	11/6	6:31
47	91	PBES-91-DB	bubbler	DB	CR 10 (Sp-Ed) Pull Out (2nd Floor)	C	11/6	6:31
48	95	PBES-95-FC	sink	FC	(Sp-Ed) Pull Out (2nd Floor)	C	11/6	6:32
49	96	PBES-96-BU	Bottler Filler	BU	Corridor	C	11/6	5:54
50	97	PBES-97-BU	Bottler Filler	BU	Corridor	C	11/6	6:29
51	1F	PBES-1F-FC	sink 2 compartment	FC	kitchen 2 comp sink	C		FLUSH 6:41
52	2F	PBES-2F-FC	island sink next to 2 comp sink	FC	kitchen sink	C		FLUSH 6:41
53	3F	PBES-3F-FC	island sink	FC	kitchen sink	C		FLUSH 6:41
54	4F	PBES-4F-DC	water fountain	DC	kitchen	C		FLUSH 6:41
55	6F	PBES-6F-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C		FLUSH 6:41
56	7F	PBES-7F-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C		FLUSH 6:41

21 C. Paul Barnhart Elementary School

First Draw

4800 Lancaster Circle Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

							Flush	78006
57	53F	PBES-53F-FC	sink	FC	nurse office	C		FLUSH 6:47