



District Name: Nixa Public Schools				Project Number: B5237030				State Action Level: 5 ppb			Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet		
Campus Name: Century Elementary				Water Source: Municipal, Rural, Well				Municipal			Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR				Faucet Testing									
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
Century Elementary	Teacher's Work Room 107	DF	sink with fountain	N	CES-107-DF-01	D	7:58AM	12/28/2023	Mandy Carlson	<1.00		NA	
	112	DF	sink with fountain	N	CES-112-DF-02	D	8:05AM	12/28/2023	Mandy Carlson	<1.00	calcium build-up	NA	
	113	DF	sink with fountain	N	CES-113-DF-03	D	8:08AM	12/28/2023	Mandy Carlson	<1.00		NA	
	100 Hallway	HF	shorter fountain on right	N	CES-100H-RHF-04	D	8:11AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	taller fountain on left	N	CES-100H-LHF-05	D	8:11AM	12/28/2023	Mandy Carlson	<1.00		NA	
	114	DF	sink with fountain	N	CES-114-DF-06	D	8:14AM	12/28/2023	Mandy Carlson	<1.00		NA	
	116	DF	sink with fountain	N	CES-116-DF-07	D	8:17AM	12/28/2023	Mandy Carlson	<1.00		NA	
	117	DF	sink with fountain	N	CES-117-DF-08	D	8:20AM	12/28/2023	Mandy Carlson	<1.00		NA	
	115	DF	sink with fountain	N	CES-115-DF-09	D	8:21AM	12/28/2023	Mandy Carlson	<1.00		NA	
	218	DF	sink with fountain	N	CES-218-DF-10	D	8:25AM	12/28/2023	Mandy Carlson	2.3		NA	
	219	DF	sink with fountain	N	CES-219-DF-11	D	8:37AM	12/28/2023	Mandy Carlson	<1.00		NA	
	220	DF	sink with fountain	N	CES-220-DF-12	D	8:31AM	12/28/2023	Mandy Carlson	1.2		NA	
	221	DF	sink with fountain	N	CES-221-DF-13	D	8:33AM	12/28/2023	Mandy Carlson	2.2		NA	
	222	DF	sink with fountain	N	CES-222-DF-14	D	8:35AM	12/28/2023	Mandy Carlson	<1.00		NA	
	223	DF	sink with fountain	N	CES-223-DF-15	D	8:37AM	12/28/2023	Mandy Carlson	<1.00		NA	
	224	DF	sink with fountain	N	CES-224-DF-16	D	8:37AM	12/28/2023	Mandy Carlson	<1.00		NA	
	Hallway near 222	HF	taller fountain on left	N	CES-H-LHF-17	D	8:43AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	shorter fountain on right	N	CES-H-RHF-18	D	8:43AM	12/28/2023	Mandy Carlson	<1.00		NA	
	402	DF	sink with fountain	N	CES-402-DF-19	D	8:47AM	12/28/2023	Mandy Carlson	<1.00		NA	
	403	DF	sink with fountain	N	CES-403-DF-20	D	8:49AM	12/28/2023	Mandy Carlson	<1.00		NA	
	404	DF	sink with fountain	N	CES-404-DF-21	D	8:52AM	12/28/2023	Mandy Carlson	<1.00		NA	
	406	DF	sink with fountain	N	CES-406-DF-22	D	8:53AM	12/28/2023	Mandy Carlson	<1.00		NA	
	405	DF	sink with fountain	N	CES-405-DF-23	D	8:57AM	12/28/2023	Mandy Carlson	<1.00		NA	
	407	DF	sink with fountain	N	CES-407-DF-24	D	8:58AM	12/28/2023	Mandy Carlson	<1.00		NA	
	408	DF	sink with fountain	N	CES-408-DF-25	D	9:02AM	12/28/2023	Mandy Carlson	1	low water pressure	NA	
	410	DF	sink with fountain	N	CES-410-DF-26	D	9:09AM	12/28/2023	Mandy Carlson	<1.00	low water pressure	NA	
	409	DF	sink with fountain	N	CES-409-DF-27	D	9:11AM	12/28/2023	Mandy Carlson	<1.00		NA	
	411	DF	sink with fountain	N	CES-411-DF-28	D	9:13AM	12/28/2023	Mandy Carlson	1.5	low water pressure	NA	
	500 Hallway near 501	HF	taller fountain on left	N	CES-500H-LHF-29	D	9:16AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	shorter fountain on right	N	CES-500H-RHF-30	D	9:16AM	12/28/2023	Mandy Carlson	<1.00		NA	
	501	DF	sink with fountain	N	CES-501-DF-31	D	9:19AM	12/28/2023	Mandy Carlson	<1.00		NA	
	502	DF	sink with fountain	N	CES-502-DF-32	D	9:20AM	12/28/2023	Mandy Carlson	1.1		NA	
	503	DF	sink with fountain	N	CES-503-DF-33	D	9:22AM	12/28/2023	Mandy Carlson	<1.00		NA	
	504	DF	sink with fountain	N	CES-504-DF-34	D	9:24AM	12/28/2023	Mandy Carlson	<1.00		NA	
	505	DF	sink with fountain	N	CES-505-DF-35	D	9:26AM	12/28/2023	Mandy Carlson	<1.00		NA	
	507	DF	sink with fountain	N	CES-507-DF-36	D	9:28AM	12/28/2023	Mandy Carlson	<1.00		NA	
	500 Hallway next to Gym 509	BR	bottle filler	Y	CES-GH-BR-37	D	9:33AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on right	N	CES-GH-RHF-38	D	9:33AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on left	N	CES-GH-LHF-39	D	9:33AM	12/28/2023	Mandy Carlson	<1.00		NA	
	311	DF	sink with fountain	N	CES-311-DF-40	D	9:35AM	12/28/2023	Mandy Carlson	<1.00		NA	
	309	DF	sink with fountain	N	CES-309-DF-41	D	9:37AM	12/28/2023	Mandy Carlson	<1.00		NA	
	310	DF	sink with fountain	N	CES-310-DF-42	D	9:39AM	12/28/2023	Mandy Carlson	<1.00		NA	
	308	DF	sink with fountain	N	CES-308-DF-43	D	9:41AM	12/28/2023	Mandy Carlson	<1.00		NA	
	300 Hallway next to 309	HF	shorter fountain on right	N	CES-300H-RHF-44	D	9:44AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	taller fountain on left	N	CES-300H-LHF-45	D	9:44AM	12/28/2023	Mandy Carlson	<1.00		NA	
	306	DF	sink with fountain	N	CES-306-DF-46	D	9:47AM	12/28/2023	Mandy Carlson	<1.00		NA	
	304	DF	sink with fountain	N	CES-304-DF-47	D	9:48AM	12/28/2023	Mandy Carlson	<1.00		NA	
	307	DF	sink with fountain	N	CES-307-DF-48	D	9:51AM	12/28/2023	Mandy Carlson	<1.00		NA	
	305	DF	sink with fountain	N	CES-305-DF-49	D	9:51AM	12/28/2023	Mandy Carlson	<1.00		NA	
	302	DF	sink with fountain	N	CES-302-DF-50	D	9:53AM	12/28/2023	Mandy Carlson	<1.00		NA	
303	DF	sink with fountain	N	CES-303-DF-51	D	9:58AM	12/28/2023	Mandy Carlson	<1.00		NA		
300 Hallway near 209 Gym	HF	shorter fountain on right	N	CES-300H-RHF-52	D	10:01AM	12/28/2023	Mandy Carlson	<1.00		NA		
	HF	taller fountain on left	N	CES-300H-LHF-53	D	10:01AM	12/28/2023	Mandy Carlson	<1.00		NA		
	BR	bottle filler	Y	CES-300H-BR-54	D	10:01AM	12/28/2023	Mandy Carlson	<1.00		NA		
Kitchen	KF	double sink faucet	Y	CES-K-KF-55	D	10:06AM	12/28/2023	Mandy Carlson	1.3		NA		
	KF	handwashing sink near serving area	Y	CES-K-HKF-56	D	10:08AM	12/28/2023	Mandy Carlson	2.7		NA		
	KF	handwashing sink near dish room	N	CES-K-HKF-57	D	10:09AM	12/28/2023	Mandy Carlson	8.6		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.		
	KF	sprayer	N	CES-K-SKF-58	D	10:10AM	12/28/2023	Mandy Carlson	1.9		NA		
	KF	triple sink right faucet	Y	CES-K-RKF-59	D	10:12AM	12/28/2023	Mandy Carlson	5.7		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.		



Century Elementary	Kitchen	KF	triple sink left faucet	Y	CES-K-LKF-60	D	10:12AM	12/28/2023	Mandy Carlson	6.1		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
	209 Gym	WF	shorter fountain on right	N	CES-G-WF-61	D	10:22AM	12/28/2023	Mandy Carlson	<1.00			NA
		WF	taller fountain on left	N	CES-G-WF-62	D	10:22AM	12/28/2023	Mandy Carlson	<1.00			NA

Red Bold = at or above state action level
ppb = parts per billion
< = below laboratory reporting limit



District Name: Nixa Public Schools				Project Number: B5237030				State Action Level: 5 ppb			Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet		
Campus Name: ESPY Elementary				Water Source: Municipal, Rural, Well				Municipal			Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR				Faucet Testing									
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
ESPY Elementary	Workroom	TF	sink faucet	Y	ESPY-WR-TF-01	D	11:41AM	12/27/2023	Mandy Carlson	3.4		NA	
	103	CF	classroom faucet	Y	ESPY-103-CF-02	D	11:45AM	12/27/2023	Mandy Carlson	20.9		Take out of service and replace or add filter, perform flush (2nd draw) sampling	
	101	CF	classroom faucet	N	ESPY-101-CF-03	D	11:46AM	12/27/2023	Mandy Carlson	3.9		NA	
	200 Hallway across from room 200	HF	fountain on right	N	ESPY-200H-RHF-04	D	11:50AM	12/27/2023	Mandy Carlson	NA	lid opened during transit, and volume was lost	Resample	
		HF	fountain on left	N	ESPY-200H-LHF-05	D	11:50AM	12/27/2023	Mandy Carlson	<1.00		NA	
	200	CF	classroom faucet	N	ESPY-200-CF-06	D	11:51AM	12/27/2023	Mandy Carlson	1.6		NA	
	201	CF	classroom faucet	N	ESPY-201-CF-07	D	11:58AM	12/27/2023	Mandy Carlson	2.5		NA	
	202	CF	classroom faucet	N	ESPY-202-CF-08	D	12:01PM	12/27/2023	Mandy Carlson	2.4		NA	
	204	CF	classroom faucet	N	ESPY-204-CF-09	D	12:02PM	12/27/2023	Mandy Carlson	1.7		NA	
	203	CF	classroom faucet	N	ESPY-203-CF-10	D	12:05PM	12/27/2023	Mandy Carlson	2		NA	
	205	CF	classroom faucet	N	ESPY-205-CF-11	D	12:07PM	12/27/2023	Mandy Carlson	2.3		NA	
	206	CF	classroom faucet	Y	ESPY-206-CF-12	D	12:09PM	12/27/2023	Mandy Carlson	2.2		NA	
	207	CF	classroom faucet	N	ESPY-207-CF-13	D	12:10PM	12/27/2023	Mandy Carlson	8.5		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
	208	CF	classroom faucet	Y	ESPY-208-CF-14	D	12:12PM	12/27/2023	Mandy Carlson	7.2		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
	102	CF	classroom faucet	Y	ESPY-102-CF-15	D	12:15PM	12/27/2023	Mandy Carlson	4		NA	
		DF	drinking fountain	N	ESPY-102-DF-16	D	12:15PM	12/27/2023	Mandy Carlson	3.3		NA	
		KF	double sink, faucet on right	Y	ESPY-K-RKF-17	D	12:19PM	12/27/2023	Mandy Carlson	3.3		NA	
	Kitchen	KF	double sink, faucet on left	Y	ESPY-K-LKF-18	D	12:19PM	12/27/2023	Mandy Carlson	5.3		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
		KF	sprayer	N	ESPY-K-SKF-19	D	12:21PM	12/27/2023	Mandy Carlson	6.4		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
		KF	triple sink, faucet on right	Y	ESPY-K-RKF-20	D	12:26PM	12/27/2023	Mandy Carlson	23.2		Take out of service and replace or add filter, perform flush (2nd draw) sampling	
		KF	triple sink, faucet on left	N	ESPY-K-LKF-21	D	12:26PM	12/27/2023	Mandy Carlson	16.3		Take out of service and replace or add filter, perform flush (2nd draw) sampling	
		KF	handwashing sink	Y	ESPY-K-HKF-22	D	12:28PM	12/27/2023	Mandy Carlson	2.2		NA	
	113	CF	classroom faucet	N	ESPY-113-CF-23	D	12:30PM	12/27/2023	Mandy Carlson	9.8		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
	Main Hallway outside of Multi-Purpose Room	BR	bottle filler	Y	ESPY-MH-BR-24	D	12:33PM	12/27/2023	Mandy Carlson	<1.00		NA	
		HF	taller fountain on left	N	ESPY-MH-LHF-25	D	12:35PM	12/27/2023	Mandy Carlson	<1.00		NA	
		HF	shorter fountain on right	N	ESPY-MH-RHF-26	D	12:35PM	12/27/2023	Mandy Carlson	<1.00		NA	
	115	CF	classroom faucet	N	ESPY-115-CF-27	D	12:36PM	12/27/2023	Mandy Carlson	1.3	laboratory mislabeled as ESPY-HS-CF-27	NA	
	117	CF	classroom faucet	N	ESPY-117-CF-28	D	12:37PM	12/27/2023	Mandy Carlson	9.2		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
	Secondary Lab	CF	classroom faucet	Y	ESPY-SL-CF-29	D	12:40PM	12/27/2023	Mandy Carlson	2.5		NA	
		DF	drinking fountain	N	ESPY-SL-DF-30	D	12:40PM	12/27/2023	Mandy Carlson	1		NA	
	Main Hallway across from Secondary Lab	BR	bottle filler	Y	ESPY-MH-BR-31	D	12:45PM	12/27/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on left	N	ESPY-MH-LHF-32	D	12:46PM	12/27/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on right	N	ESPY-MH-RHF-33	D	12:46PM	12/27/2023	Mandy Carlson	<1.00		NA	
		CF	classroom faucet	Y	ESPY-121-CF-34	D	12:50PM	12/27/2023	Mandy Carlson	4		NA	
		DF	drinking fountain	N	ESPY-121-DF-35	D	12:50PM	12/27/2023	Mandy Carlson	1.7		NA	
	121	CF	classroom faucet	Y	ESPY-123-CF-36	D	12:55PM	12/27/2023	Mandy Carlson	1.5		NA	
	123	DF	drinking fountain	N	ESPY-123-DF-37	D	12:55PM	12/27/2023	Mandy Carlson	<1.00		NA	
		CF	classroom faucet	N	ESPY-124-CF-38	D	12:57PM	12/27/2023	Mandy Carlson	<1.00		NA	
	FEMA GYM	BR	bottle filler	Y	ESPY-FEMA-BR-39	D	1:00PM	12/27/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on the right	N	ESPY-FEMA-RWF-40	D	1:00PM	12/27/2023	Mandy Carlson	<1.00		NA	
WF		fountain on the left	N	ESPY-FEMA-LWF-41	D	1:00PM	12/27/2023	Mandy Carlson	<1.00		NA		
300 Hallway next boy's restroom	BR	bottle filler	Y	ESPY-300H-BR-42	D	1:05PM	12/27/2023	Mandy Carlson	<1.00		NA		
	HF	fountain	N	ESPY-300H-HF-43	D	1:05PM	12/27/2023	Mandy Carlson	<1.00		NA		



ESPY Elementary	300 Hallway next girl's restroom	HF	single fountain	N	ESPY-300H-HF-44	D	1:13PM	12/27/2023	Mandy Carlson	<1.00	NA
	301	CF	classroom faucet	N	ESPY-301-CF-45	D	1:16PM	12/27/2023	Mandy Carlson	1.2	NA
	302	CF	classroom faucet	N	ESPY-302-CF-46	D	1:17PM	12/27/2023	Mandy Carlson	2.9	NA
	304	CF	classroom faucet	N	ESPY-304-CF-47	D	1:18PM	12/27/2023	Mandy Carlson	2.2	NA
	303	CF	classroom faucet	Y	ESPY-303-CF-48	D	1:20PM	12/27/2023	Mandy Carlson	1.2	NA
	305	CF	classroom faucet	Y	ESPY-305-CF-49	D	1:21PM	12/27/2023	Mandy Carlson	2.1	NA
	306	CF	classroom faucet	N	ESPY-306-CF-50	D	1:23PM	12/27/2023	Mandy Carlson	1.8	NA
	308	CF	classroom faucet	N	ESPY-308-CF-51	D	1:24PM	12/27/2023	Mandy Carlson	1.5	NA
	307	CF	classroom faucet	N	ESPY-307-CF-52	D	1:26PM	12/27/2023	Mandy Carlson	1.1	NA
	309	CF	classroom faucet	Y	ESPY-309-CF-53	D	1:27PM	12/27/2023	Mandy Carlson	2.1	NA
	310	CF	classroom faucet	N	ESPY-310-CF-54	D	1:30PM	12/27/2023	Mandy Carlson	2.4	NA
	311	CF	classroom faucet	Y	ESPY-311-CF-55	D	1:31PM	12/27/2023	Mandy Carlson	4	NA
	312	CF	classroom faucet	N	ESPY-312-CF-56	D	1:32PM	12/27/2023	Mandy Carlson	4.9	NA
	<p>Red Bold = at or above state action level ppb = parts per billion < = below laboratory reporting limit</p>										



District Name: Nixa Public Schools				Project Number: B5237030				State Action Level: 5 ppb		Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet			
Campus Name: High Pointe Elementary				Water Source: Municipal, Rural, Well				Municipal		Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.			
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR				Faucet Testing									
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
High Pointe Elementary	Library	DF	office sink with fountain	N	HPE-L-DF-01	D	12:45PM	12/28/2023	Mandy Carlson	3.3		NA	
	204	DF	sink with fountain	N	HPE-204-DF-02	D	12:49PM	12/28/2023	Mandy Carlson	<1.00	high water pressure	NA	
	206	DF	sink with fountain	N	HPE-206-DF-03	D	12:52PM	12/28/2023	Mandy Carlson	<1.00		NA	
	208	DF	sink with fountain	N	HPE-208-DF-04	D	12:54PM	12/28/2023	Mandy Carlson	<1.00		NA	
	210	DF	sink with fountain	N	HPE-210-DF-05	D	12:55PM	12/28/2023	Mandy Carlson	<1.00		NA	
	200 Hallway near 210	BR		bottle filler	Y	HPE-200H-BR-06	D	1:03PM	12/28/2023	Mandy Carlson	<1.00		NA
		HF		fountain on left	N	HPE-200H-LHF-07	D	1:03PM	12/28/2023	Mandy Carlson	<1.00		NA
		HF		fountain on right	N	HPE-200H-RHF-08	D	1:03PM	12/28/2023	Mandy Carlson	<1.00		NA
		212	DF	sink with fountain	N	HPE-212-DF-09	D	1:05PM	12/28/2023	Mandy Carlson	<1.00		NA
		214	DF	sink with fountain	N	HPE-214-DF-10	D	1:06PM	12/28/2023	Mandy Carlson	<1.00		NA
		216	DF	sink with fountain	N	HPE-216-DF-11	D	1:08PM	12/28/2023	Mandy Carlson	<1.00		NA
		221	DF	sink with fountain	N	HPE-221-DF-12	D	1:10PM	12/28/2023	Mandy Carlson	<1.00		NA
		219	DF	sink with fountain	N	HPE-219-DF-13	D	1:12PM	12/28/2023	Mandy Carlson	<1.00		NA
		217	DF	sink with fountain	N	HPE-217-DF-14	D	1:13PM	12/28/2023	Mandy Carlson	<1.00		NA
		215	DF	sink with fountain	N	HPE-215-DF-15	D	1:15PM	12/28/2023	Mandy Carlson	<1.00		NA
	Office	DF	sink with fountain	N	HPE-O-DF-16	D	1:18PM	12/28/2023	Mandy Carlson	<1.00		NA	
	Nurse Office	DF	sink with fountain	N	HPE-NO-DF-17	D	1:19PM	12/28/2023	Mandy Carlson	<1.00		NA	
	301	DF	sink with fountain	N	HPE-301-DF-18	D	1:25PM	12/28/2023	Mandy Carlson	<1.00		NA	
	303	DF	sink with fountain	N	HPE-303-DF-19	D	1:26PM	12/28/2023	Mandy Carlson	3.6		NA	
	305	DF	sink with fountain	N	HPE-305-DF-20	D	1:27PM	12/28/2023	Mandy Carlson	1.3		NA	
	307	DF	sink with fountain	N	HPE-307-DF-21	D	1:28PM	12/28/2023	Mandy Carlson	1.6		NA	
	309	DF	sink with fountain	N	HPE-309-DF-22	D	1:30PM	12/28/2023	Mandy Carlson	3.8		NA	
	Hallway to Gym	BR		bottle filler	Y	HPE-GH-BR-23	D	1:34PM	12/28/2023	Mandy Carlson	<1.00		NA
		HF		fountain on right	N	HPE-GH-HF-24	D	1:34PM	12/28/2023	Mandy Carlson	<1.00		NA
		HF		fountain on left	N	HPE-GH-HF-25	D	1:34PM	12/28/2023	Mandy Carlson	<1.00		NA
	310	DF	sink with fountain	N	HPE-310-DF-26	D	1:36PM	12/28/2023	Mandy Carlson	1.2		NA	
	312	DF	sink with fountain	N	HPE-312-DF-27	D	1:38PM	12/28/2023	Mandy Carlson	1.2	high water pressure	NA	
	316	DF	sink with fountain	N	HPE-316-DF-28	D	1:40PM	12/28/2023	Mandy Carlson	8.5		Take out of service, and replace or add filter, perform flush (2nd draw) sampling.	
	318	DF	sink with fountain	N	HPE-318-DF-29	D	1:52PM	12/28/2023	Mandy Carlson	1.3		NA	
	320	DF	sink with fountain	N	HPE-320-DF-30	D	1:53PM	12/28/2023	Mandy Carlson	<1.00		NA	
	326	DF	sink with fountain	N	HPE-326-DF-31	D	1:56PM	12/28/2023	Mandy Carlson	<1.00		NA	
	323	DF	sink with fountain	N	HPE-323-DF-32	D	1:57PM	12/28/2023	Mandy Carlson	3.7		NA	
	321	DF	sink with fountain	N	HPE-321-DF-33	D	1:59PM	12/28/2023	Mandy Carlson	<1.00		NA	
	319	DF	sink with fountain	N	HPE-319-DF-34	D	2:01PM	12/28/2023	Mandy Carlson	<1.00		NA	
	400 Hallway	HF		shorter fountain on right	N	HPE-400H-HF-35	D	2:04PM	12/28/2023	Mandy Carlson	<1.00		NA
		HF		taller fountain on left	N	HPE-400H-HF-36	D	2:04PM	12/28/2023	Mandy Carlson	<1.00		NA
	406	DF	sink with fountain	N	HPE-406-DF-37	D	2:06PM	12/28/2023	Mandy Carlson	<1.00		NA	
	408	DF	sink with fountain	N	HPE-408-DF-38	D	2:08PM	12/28/2023	Mandy Carlson	<1.00		NA	
	410	DF	sink with fountain	N	HPE-410-DF-39	D	2:09PM	12/28/2023	Mandy Carlson	<1.00		NA	
	412	DF	sink with fountain	N	HPE-412-DF-40	D	2:11PM	12/28/2023	Mandy Carlson	<1.00		NA	
	414	DF	sink with fountain	N	HPE-414-DF-41	D	2:12PM	12/28/2023	Mandy Carlson	<1.00		NA	
	411	DF	sink with fountain	N	HPE-411-DF-42	D	2:13PM	12/28/2023	Mandy Carlson	<1.00		NA	
	409	DF	sink with fountain	N	HPE-409-DF-43	D	2:14PM	12/28/2023	Mandy Carlson	<1.00		NA	
	407	DF	sink with fountain	N	HPE-407-DF-44	D	2:19PM	12/28/2023	Mandy Carlson	<1.00		NA	
	405	DF	sink with fountain	N	HPE-405-DF-45	D	2:20PM	12/28/2023	Mandy Carlson	<1.00		NA	
	403	DF	sink with fountain	N	HPE-403-DF-46	D	2:22PM	12/28/2023	Mandy Carlson	<1.00		NA	
	Kitchen	KF		handwashing sink near restroom	Y	HPE-K-HKF-47	D	2:26PM	12/28/2023	Mandy Carlson	<1.00		NA
		KF		double sink faucet	N	HPE-K-KF-48	D	2:29PM	12/28/2023	Mandy Carlson	3.7		NA
		KF		triple sink, left faucet	N	HPE-K-LKF-49	D	2:31PM	12/28/2023	Mandy Carlson	2.8		NA
		KF		triple sink, right faucet	Y	HPE-K-RKF-50	D	2:31PM	12/28/2023	Mandy Carlson	3.3		NA
KF			handwashing sink near dish room	Y	HPE-K-HKF-51	D	2:34PM	12/28/2023	Mandy Carlson	1		NA	
	KF		sprayer	N	HPE-K-SKF-52	D	2:34PM	12/28/2023	Mandy Carlson	1.4		NA	

Red Bold = at or above state action level
 ppb = parts per billion
 < = below laboratory reporting limit



District Name: Nixa Public Schools					Project Number: B5237030				State Action Level: 5 ppb		Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet		
Campus Name: Mathews Elementary					Water Source: Municipal, Rural, Well				Municipal		Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR					Faucet Testing								
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
Mathews Elementary	Nurse Office	DF	sink with fountain	N	ME-NO-DF-01	D	12:47PM	12/29/2023	Mandy Carlson	<1.00		NA	
	215	DF	sink with fountain	N	ME-215-DF-02	D	12:49PM	12/29/2023	Mandy Carlson	<1.00		NA	
	210	DF	sink with fountain	N	ME-210-DF-03	D	12:51PM	12/29/2023	Mandy Carlson	<1.00		NA	
	200 Hallway across from 208	HF	shorter fountain on right	N	ME-200H-RHF-04	D	12:54PM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	taller fountain on left	N	ME-200H-LHF-05	D	12:54PM	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	ME-200H-BR-06	D	12:54PM	12/29/2023	Mandy Carlson	<1.00		NA	
	207	DF	sink with fountain	N	ME-207-DF-07	D	12:57PM	12/29/2023	Mandy Carlson	<1.00		NA	
	205	DF	sink with fountain	N	ME-205-DF-08	D	1:00PM	12/29/2023	Mandy Carlson	<1.00		NA	
	206	DF	sink with fountain	N	ME-206-DF-09	D	1:02PM	12/29/2023	Mandy Carlson	<1.00		NA	
	204	DF	sink with fountain	N	ME-204-DF-10	D	1:03PM	12/29/2023	Mandy Carlson	2.9		NA	
	203	DF	sink with fountain	N	ME-203-DF-11	D	1:04PM	12/29/2023	Mandy Carlson	<1.00		NA	
	201	DF	sink with fountain	N	ME-201-DF-12	D	1:05PM	12/29/2023	Mandy Carlson	1.4		NA	
	202	DF	sink with fountain	N	ME-202-DF-13	D	1:07PM	12/29/2023	Mandy Carlson	<1.00		NA	
	200	DF	sink with fountain	N	ME-200-DF-14	D	1:08PM	12/29/2023	Mandy Carlson	<1.00		NA	
	199	DF	sink with fountain	N	ME-199-DF-15	D	1:11PM	12/29/2023	Mandy Carlson	<1.00		NA	
	197	DF	sink with fountain	N	ME-197-DF-16	D	1:12PM	12/29/2023	Mandy Carlson	<1.00		NA	
	198	DF	sink with fountain	N	ME-198-DF-17	D	1:21PM	12/29/2023	Mandy Carlson	<1.00		NA	
	196	DF	sink with fountain	N	ME-196-DF-18	D	1:13PM	12/29/2023	Mandy Carlson	<1.00		NA	
	316	DF	sink with fountain	Y	ME-316-DF-19	D	1:25PM	12/29/2023	Mandy Carlson	1.3		NA	
	314	DF	sink with fountain	N	ME-314-DF-20	D	1:27PM	12/29/2023	Mandy Carlson	3.8		NA	
	300 Hallway near 312	HF	taller fountain on left	N	ME-300H-LHF-21	D	1:35PM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	shorter fountain on right	N	ME-300H-RHF-22	D	1:35PM	12/29/2023	Mandy Carlson	<1.00		NA	
		DF	sink with fountain	N	ME-310-DF-23	D	1:37PM	12/29/2023	Mandy Carlson	<1.00		NA	
	308	DF	sink with fountain	N	ME-308-DF-24	D	1:39PM	12/29/2023	Mandy Carlson	<1.00		NA	
	309	DF	sink with fountain	N	ME-309-DF-25	D	1:43PM	12/29/2023	Mandy Carlson	<1.00		NA	
	306	DF	sink with fountain	N	ME-306-DF-26	D	1:47PM	12/29/2023	Mandy Carlson	<1.00		NA	
	304	DF	sink with fountain	N	ME-304-DF-27	D	1:47PM	12/29/2023	Mandy Carlson	<1.00		NA	
	307	DF	sink with fountain	N	ME-307-DF-28	D	1:49PM	12/29/2023	Mandy Carlson	<1.00		NA	
	305	DF	sink with fountain	N	ME-305-DF-29	D	1:51PM	12/29/2023	Mandy Carlson	<1.00		NA	
	300 Hallway near 302	HF	shorter fountain on right	N	ME-300H-HF-30	D	2:00PM	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	ME-300H-BR-31	D	2:00PM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	taller fountain on left	N	ME-300H-LHF-32	D	2:00PM	12/29/2023	Mandy Carlson	<1.00		NA	
	302	DF	sink with fountain	N	ME-302-DF-33	D	2:03PM	12/29/2023	Mandy Carlson	<1.00		NA	
	300	DF	sink with fountain	N	ME-300-DF-34	D	2:04PM	12/29/2023	Mandy Carlson	1.8		NA	
	303	DF	sink with fountain	N	ME-303-DF-35	D	2:06PM	12/29/2023	Mandy Carlson	<1.00		NA	
	301	DF	sink with fountain	N	ME-301-DF-36	D	2:09PM	12/29/2023	Mandy Carlson	<1.00		NA	
	313	DF	sink with fountain	N	ME-313-DF-37	D	2:13PM	12/29/2023	Mandy Carlson	<1.00		NA	
	315	DF	sink with fountain	N	ME-315-DF-38	D	2:14PM	12/29/2023	Mandy Carlson	<1.00		NA	
	317	DF	sink with fountain	N	ME-317-DF-39	D	2:15PM	12/29/2023	Mandy Carlson	<1.00		NA	
	Gym	WF	shorter fountain on right	N	ME-G-WF-40	D	2:20PM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	taller fountain on left	N	ME-G-WF-41	D	2:20PM	12/29/2023	Mandy Carlson	<1.00		NA	
	Kitchen	KF	triple sink, right faucet	Y	ME-K-KF-42	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	triple sink, left faucet	Y	ME-K-KF-43	D	-	12/29/2023	Mandy Carlson	1.7		NA	
		KF	handwashing sink next to triple sink	Y	ME-K-KF-44	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	handwashing sink near ice machine	N	ME-K-KF-45	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	Cafeteria	KF	double sink faucet	Y	ME-K-KF-46	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	shorter fountain on right	N	ME-C-WF-47	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	taller fountain on left	N	ME-C-WF-48	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	331	DF	sink with fountain	D	ME-331-DF-49	D	-	12/29/2023	Mandy Carlson	<1.00		NA	

Red Bold = at or above state action level
 ppb = parts per billion
 <= below laboratory reporting limit



District Name: Nixa Public Schools					Project Number: B5237030				State Action Level: 5 ppb		Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet		
Campus Name: JTSD					Water Source: Municipal, Rural, Well				Municipal		Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR					Faucet Testing								
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
JTSD	124 Nurse Office	NF	sink faucet	N	JTSD-NO-NF-01	D	9:23AM	12/27/2023	Mandy Carlson	2.9		NA	
	109	CF	classroom faucet	N	JTSD-109-CF-02	D	9:25AM	12/27/2023	Mandy Carlson	<1.00		NA	
		DF	drinking fountain	N	JTSD-109-DF-03	D	9:25AM	12/27/2023	Mandy Carlson	2.4		NA	
	108	CF	classroom faucet	N	JTSD-108-CF-04	D	9:29AM	12/27/2023	Mandy Carlson	<1.00		NA	
		DF	drinking fountain	N	JTSD-108-DF-05	D	9:29AM	12/27/2023	Mandy Carlson	<1.00		NA	
	107	CF	classroom faucet	Y	JTSD-107-CF-06	D	9:33AM	12/27/2023	Mandy Carlson	1.1		NA	
		DF	drinking fountain	N	JTSD-107-DF-07	D	9:33AM	12/27/2023	Mandy Carlson	3.7		NA	
	106 - Teacher Workroom	TF	sink faucet	Y	JTSD-106-TF-08	D	9:34AM	12/27/2023	Mandy Carlson	2.1		NA	
	Hallway near 123 Multipurpose Room	BR	bottle filler	Y	JTSD-H-BR-09	D	9:39AM	12/27/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on left side	N	JTSD-H-LHF-10	D	9:39AM	12/27/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on right side	N	JTSD-H-RHF-11	D	9:39AM	12/27/2023	Mandy Carlson	<1.00		NA	
	Kitchen	KF	double sink, single faucet	Y	JTSD-K-KF-12	D	9:42AM	12/27/2023	Mandy Carlson	<1.00		NA	
		KF	handwashing sink in dish room	Y	JTSD-K-HKF-13	D	9:44AM	12/27/2023	Mandy Carlson	6.5		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
		KF	sprayer	N	JTSD-K-SKF-14	D	9:45AM	12/27/2023	Mandy Carlson	5.8		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
		KF	triple sink faucet on right	N	JTSD-K-RKF-15	D	9:49AM	12/27/2023	Mandy Carlson	2.7		NA	
	300	KF	triple sink faucet on left	Y	JTSD-K-LKF-16	D	9:49AM	12/27/2023	Mandy Carlson	2.1		NA	
		CF	classroom faucet	Y	JTSD-300-CF-17	D	9:52AM	12/27/2023	Mandy Carlson	8.8		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
	314	DF	drinking fountain	N	JTSD-300-DF-18	D	9:52AM	12/27/2023	Mandy Carlson	12.2		Take out of service and replace or add filter, perform flush (2nd draw) sampling	
		CF	classroom faucet	Y	JTSD-314-CF-19	D	9:56AM	12/27/2023	Mandy Carlson	8.6		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
	Hallway next to room 301	DF	drinking fountain	N	JTSD-314-DF-20	D	9:56AM	12/27/2023	Mandy Carlson	16.9		Take out of service and replace or add filter, perform flush (2nd draw) sampling	
		HF	hallway fountain	N	JTSD-300H-HF-21	D	9:59AM	12/27/2023	Mandy Carlson	4.6		NA	
	301	CF	classroom faucet	Y	JTSD-301-CF-22	D	10:01AM	12/27/2023	Mandy Carlson	9.2	calcium build-up around aerator	Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
		DF	drinking fountain	N	JTSD-301-DF-23	D	10:01AM	12/27/2023	Mandy Carlson	18		Take out of service and replace or add filter, perform flush (2nd draw) sampling	
	302	CF	classroom faucet	Y	JTSD-302-CF-24	D	10:03AM	12/27/2023	Mandy Carlson	4.7		NA	
	Hallway near 307	BR	bottle filler	Y	JTSD-300H-BR-25	D	10:06AM	12/27/2023	Mandy Carlson	3.1	calcium build-up around aerator	NA	
		HF	water fountain	N	JTSD-300H-HF-26	D	10:06AM	12/27/2023	Mandy Carlson	3.1		NA	
	307	CF	classroom faucet	N	JTSD-307-CF-27	D	10:10AM	12/27/2023	Mandy Carlson	3.1		NA	
	310	CF	classroom faucet	Y	JTSD-310-CF-28	D	10:16AM	12/27/2023	Mandy Carlson	5.2	broken aerator	Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
	308	CF	classroom faucet	Y	JTSD-308-CF-29	D	10:17AM	12/27/2023	Mandy Carlson	3.1		NA	
	309	CF	classroom faucet	Y	JTSD-309-CF-30	D	10:19AM	12/27/2023	Mandy Carlson	2.7		NA	
	311	CF	classroom faucet	Y	JTSD-311-CF-31	D	10:21AM	12/27/2023	Mandy Carlson	3.8	broken aerator	NA	
	312	CF	classroom faucet	Y	JTSD-312-CF-32	D	10:22AM	12/27/2023	Mandy Carlson	4.5		NA	
	FEMA Gym	WF	fountain on right side	N	JTSD-FEMA-RWF-33	D	-	12/27/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on left side	N	JTSD-FEMA-LWF-34	D	-	12/27/2023	Mandy Carlson	<1.00		NA	
	200	CF	classroom faucet	Y	JTSD-200-CF-35	D	10:30AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up and visible mold around aerator	NA	
	212	DF	drinking fountain	N	JTSD-212-DF-36	D	10:35AM	12/27/2023	Mandy Carlson	<1.00		NA	
		CF	classroom faucet	Y	JTSD-212-CF-37	D	10:35AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up around aerator	NA	
	201	CF	classroom faucet	Y	JTSD-201-CF-38	D	10:38AM	12/27/2023	Mandy Carlson	1.2	calcium build-up and visible mold around aerator	NA	
		DF	drinking fountain	N	JTSD-201-DF-39	D	10:38AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up around bubbler	NA	



JTSO	211	CF	classroom faucet	Y	JTSD-211-CF-40	D	10:40AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up and visible mold around aerator	NA	
		DF	drinking fountain	N	JTSD-211-DF-41	D	10:40AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up around bubbler	NA	
	202	CF	classroom faucet	Y	JTSD-202-CF-42	D	10:44AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up and visible mold around aerator	NA	
		DF	drinking fountain	N	JTSD-202-DF-43	D	10:44AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up around aerator	NA	
	210	CF	classroom faucet	Y	JTSD-210-CF-44	D	10:48AM	12/27/2023	Mandy Carlson	1.5	calcium build-up around aerator	NA	
		DF	drinking fountain	N	JTSD-210-DF-45	D	10:48AM	12/27/2023	Mandy Carlson	1	calcium build-up around bubbler	NA	
	203	CF	classroom faucet	Y	JTSD-203-CF-46	D	10:52AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up and visible mold around aerator	NA	
		DF	drinking fountain	N	JTSD-203-DF-47	D	10:52AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up around bubbler	NA	
	209	CF	classroom faucet	Y	JTSD-209-CF-48	D	10:55AM	12/27/2023	Mandy Carlson	<1.00	calcium build-up and visible mold around aerator	NA	
		DF	drinking fountain	N	JTSD-209-DF-49	D	10:55AM	12/27/2023	Mandy Carlson	4.5		NA	
	204	CF	classroom faucet	Y	JTSD-204-CF-50	D	11:00AM	12/27/2023	Mandy Carlson	2.8	calcium build-up and visible mold around aerator	NA	
		DF	drinking fountain	N	JTSD-204-DF-51	D	11:00AM	12/27/2023	Mandy Carlson	1.1	calcium build-up around bubbler	NA	
	208	CF	classroom faucet	Y	JTSD-208-CF-52	D	11:03AM	12/27/2023	Mandy Carlson	1.7	calcium build-up around aerator	NA	
	205	CF	classroom faucet	Y	JTSD-205-CF-53	D	11:05AM	12/27/2023	Mandy Carlson	1.3	calcium build-up around aerator	NA	
	206	CF	classroom faucet	Y	JTSD-206-CF-54	D	-	12/27/2023	Mandy Carlson	3.3	broken aerator	NA	
	207	CF	faucet on left	Y	JTSD-207-LCF-55	D	11:11AM	12/27/2023	Mandy Carlson	3.6	calcium build-up around aerator	NA	
		CF	faucet on right	Y	JTSD-207-RCF-56	D	11:11AM	12/27/2023	Mandy Carlson	2.4	calcium build-up around aerator	NA	
	JTSO	Outside (North) Modular	CF	classroom faucet	Y	JTSD-OM-CF-57	D	11:20AM	12/27/2023	Mandy Carlson	<1.00		NA
			WF	water fountain	N	JTSD-OM-WF-58	D	11:20AM	12/27/2023	Mandy Carlson	<1.00		NA

Red Bold = at or above state action level

ppb = parts per billion

< = below laboratory reporting limit



District Name: Nixa Public Schools				Project Number: B5237030				State Action Level: 5 ppb			Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet		
Campus Name: Inman Intermediate				Water Source: Municipal, Rural, Well				Municipal			Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR				Faucet Testing									
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
Inman Intermediate	200 Hallway near 205	HF	single fountain	N	IIS-200H-HF-01	D	10:23AM	12/29/2023	Mandy Carlson	<1.00		NA	
	205	DF	sink with fountain	N	IIS-205-DF-02	D	10:26AM	12/29/2023	Mandy Carlson	<1.00		NA	
	206	DF	sink with fountain	N	IIS-206-DF-03	D	10:28AM	12/29/2023	Mandy Carlson	<1.00		NA	
	204	DF	sink with fountain	N	IIS-204-DF-04	D	10:29AM	12/29/2023	Mandy Carlson	<1.00		NA	
	203	DF	sink with fountain	N	IIS-203-DF-05	D	10:30AM	12/29/2023	Mandy Carlson	<1.00		NA	
	202	DF	sink with fountain	N	IIS-202-DF-06	D	10:32AM	12/29/2023	Mandy Carlson	<1.00		NA	
	201	DF	sink with fountain	N	IIS-201-DF-07	D	10:33AM	12/29/2023	Mandy Carlson	<1.00		NA	
	200	DF	sink with fountain	N	IIS-200-DF-08	D	10:34AM	12/29/2023	Mandy Carlson	1.3		NA	
	Gym Area	WF	fountain on left	N	IIS-G-WF-09	D	10:39AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on right	N	IIS-G-WF-10	D	10:39AM	12/29/2023	Mandy Carlson	<1.00		NA	
	100	DF	sink with fountain	N	IIS-100-DF-11	D	10:46AM	12/29/2023	Mandy Carlson	<1.00		NA	
	Main Hall across from 100	HF	shorter fountain on left	N	IIS-MH-LHF-12	D	10:50AM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	taller fountain on right	N	IIS-MH-RHF-13	D	10:50AM	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	IIS-MH-BR-14	D	10:50AM	12/29/2023	Mandy Carlson	<1.00		NA	
	101	DF	sink with fountain	N	IIS-101-DF-15	D	10:52AM	12/29/2023	Mandy Carlson	<1.00		NA	
	102	DF	sink with fountain	N	IIS-102-DF-16	D	10:53AM	12/29/2023	Mandy Carlson	<1.00	visible mold around bubbler	NA	
	103	DF	sink with fountain	N	IIS-103-DF-17	D	10:55AM	12/29/2023	Mandy Carlson	<1.00		NA	
	104	DF	sink with fountain	N	IIS-104-DF-18	D	10:55AM	12/29/2023	Mandy Carlson	<1.00		NA	
	105	DF	sink with fountain	N	IIS-105-DF-19	D	10:57AM	12/29/2023	Mandy Carlson	1.6		NA	
	Cafeteria Hallway	WF	fountain near office	N	IIS-H-WF-20	D	11:00AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain near kitchen	N	IIS-H-WF-21	D	11:00AM	12/29/2023	Mandy Carlson	<1.00		NA	
	Kitchen	KF	double sink faucet	Y	IIS-K-KF-22	D	11:03AM	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	handwashing sink near dish room	Y	IIS-K-HKF-23	D	11:04AM	12/29/2023	Mandy Carlson	<1.00	laboratory mislabeled as IIS-K-KRF-23	NA	
		KF	sprayer	N	IIS-K-KF-24	D	11:05AM	12/29/2023	Mandy Carlson	3.1		NA	
		KF	triple sink, right faucet	Y	IIS-K-RKF-25	D	11:07AM	12/29/2023	Mandy Carlson	1.5		NA	
		KF	triple sink, left faucet	Y	IIS-K-LKF-26	D	11:07AM	12/29/2023	Mandy Carlson	<1.00		NA	
	115	DF	sink with fountain	N	IIS-115-DF-27	D	11:11AM	12/29/2023	Mandy Carlson	<1.00	visible mold around bubbler	NA	
	116	DF	sink with fountain	N	IIS-116-DF-28	D	11:13AM	12/29/2023	Mandy Carlson	<1.00		NA	
	117	DF	sink with fountain	N	IIS-117-DF-29	D	11:14AM	12/29/2023	Mandy Carlson	<1.00		NA	
	118	DF	sink with fountain	N	IIS-118-DF-30	D	11:15AM	12/29/2023	Mandy Carlson	<1.00		NA	
	119	DF	sink with fountain	N	IIS-119-DF-31	D	11:23AM	12/29/2023	Mandy Carlson	<1.00	visible mold around bubbler	NA	
	120	DF	sink with fountain	N	IIS-120-DF-32	D	11:24AM	12/29/2023	Mandy Carlson	<1.00	visible mold around bubbler	NA	
	121	DF	sink with fountain	N	IIS-121-DF-33	D	11:25AM	12/29/2023	Mandy Carlson	<1.00		NA	
	100 Hallway across from 122	HF	fountain on left	N	IIS-100H-LHF-34	D	11:30AM	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	IIS-100H-BR-35	D	11:30AM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on right	N	IIS-100H-RHF-36	D	11:30AM	12/29/2023	Mandy Carlson	<1.00		NA	
	400	DF	sink with fountain	N	IIS-400-DF-37	D	11:35AM	12/29/2023	Mandy Carlson	<1.00		NA	
	401	DF	sink with fountain	N	IIS-401-DF-38	D	11:36AM	12/29/2023	Mandy Carlson	<1.00		NA	
	402	DF	sink with fountain	N	IIS-402-DF-39	D	11:38AM	12/29/2023	Mandy Carlson	<1.00		NA	
	403	DF	sink with fountain	N	IIS-403-DF-40	D	11:39AM	12/29/2023	Mandy Carlson	<1.00		NA	
	404	DF	sink with fountain	N	IIS-404-DF-41	D	11:41AM	12/29/2023	Mandy Carlson	<1.00		NA	
	400 Hallway	WF	water fountain	N	IIS-400H-WF-42	D	11:42AM	12/29/2023	Mandy Carlson	<1.00		NA	
	405	DF	sink with fountain	Y	IIS-405-DF-43	D	11:43AM	12/29/2023	Mandy Carlson	<1.00		NA	
	406	DF	sink with fountain	Y	IIS-406-DF-44	D	11:45AM	12/29/2023	Mandy Carlson	<1.00		NA	
	407	DF	sink with fountain	Y	IIS-407-DF-45	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	408	DF	sink with fountain	Y	IIS-408-DF-46	D	-	12/29/2023	Mandy Carlson	<1.00		NA	

Red Bold = at or above state action level
 ppb = parts per billion
 < = below laboratory reporting limit



District Name: Nixa Public Schools				Project Number: B5237030				State Action Level: 5 ppb			Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Campus Name: Summit Intermediate				Water Source: Municipal, Rural, Well				Municipal					
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR				Faucet Testing									
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
Summit Intermediate	300 Hallway near 303	BR	bottle filler	Y	SI-300H-BR-01	D	10:51AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on left	N	SI-300H-LHF-02	D	10:51AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on right	N	SI-300H-RHF-03	D	10:51AM	12/28/2023	Mandy Carlson	<1.00		NA	
	303	DF	sink with fountain	N	SI-303-DF-04	D	10:55AM	12/28/2023	Mandy Carlson	7.4	low water pressure	Take out of service, and replace or add filter, perform flush (2nd draw) sampling.	
	304	DF	sink with fountain	N	SI-304-DF-05	D	10:56AM	12/28/2023	Mandy Carlson	3.8		NA	
	305	DF	sink with fountain	N	SI-305-DF-06	D	10:57AM	12/28/2023	Mandy Carlson	<1.00		NA	
	306	DF	sink with fountain	N	SI-306-DF-07	D	10:59AM	12/28/2023	Mandy Carlson	5.5		Take out of service, and replace or add filter, perform flush (2nd draw) sampling.	
	308	DF	sink with fountain	N	SI-308-DF-08	D	11:01AM	12/28/2023	Mandy Carlson	6.7	low water pressure	Take out of service, and replace or add filter, perform flush (2nd draw) sampling.	
	309	DF	sink with fountain	N	SI-309-DF-09	D	11:05AM	12/28/2023	Mandy Carlson	2.8		NA	
	310	DF	sink with fountain	N	SI-310-DF-10	D	12:26PM	12/28/2023	Mandy Carlson	1.1		NA	
	311	DF	sink with fountain	N	SI-311-DF-11	D	11:06AM	12/28/2023	Mandy Carlson	<1.00		NA	
	312	DF	sink with fountain	N	SI-312-DF-12	D	11:09AM	12/28/2023	Mandy Carlson	<1.00		NA	
	313	DF	sink with fountain	N	SI-313-DF-13	D	11:10AM	12/28/2023	Mandy Carlson	1.8		NA	
	314	DF	sink with fountain	N	SI-314-DF-14	D	11:12AM	12/28/2023	Mandy Carlson	<1.00		NA	
	315	DF	sink with fountain	N	SI-315-DF-15	D	11:13AM	12/28/2023	Mandy Carlson	2.9	low water pressure	NA	
	316	DF	sink with fountain	N	SI-316-DF-16	D	11:15AM	12/28/2023	Mandy Carlson	3.8		NA	
	317	DF	sink with fountain	N	SI-317-DF-17	D	11:17AM	12/28/2023	Mandy Carlson	5.9		Take out of service, and replace or add filter, perform flush (2nd draw) sampling.	
	201	DF	sink with fountain	N	SI-201-DF-18	D	11:20AM	12/28/2023	Mandy Carlson	4.8		NA	
	202	DF	sink with fountain	N	SI-202-DF-19	D	11:23AM	12/28/2023	Mandy Carlson	2.8		NA	
	203	DF	sink with fountain	N	SI-203-DF-20	D	11:25AM	12/28/2023	Mandy Carlson	1.2		NA	
	200 Hallway near 204	HF	taller fountain on left side	N	SI-200H-LHF-21	D	11:28AM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	shorter fountain on right side	N	SI-200H-RHF-22	D	11:28AM	12/28/2023	Mandy Carlson	<1.00		NA	
		205	DF	sink with fountain	N	SI-205-DF-23	D	11:30AM	12/28/2023	Mandy Carlson	<1.00		NA
		206	DF	sink with fountain	N	SI-206-DF-24	D	11:31AM	12/28/2023	Mandy Carlson	<1.00		NA
		207	DF	sink with fountain	N	SI-207-DF-25	D	11:32AM	12/28/2023	Mandy Carlson	1.2		NA
		208	DF	sink with fountain	N	SI-208-DF-26	D	11:42AM	12/28/2023	Mandy Carlson	<1.00		NA
		209	DF	sink with fountain	N	SI-209-DF-27	D	11:45AM	12/28/2023	Mandy Carlson	<1.00		NA
		210	DF	sink with fountain	N	SI-210-DF-28	D	11:47AM	12/28/2023	Mandy Carlson	<1.00		NA
		211	DF	sink with fountain	N	SI-211-DF-29	D	11:48AM	12/28/2023	Mandy Carlson	1.2		NA
		212	DF	sink with fountain	N	SI-212-DF-30	D	11:50AM	12/28/2023	Mandy Carlson	<1.00		NA
		215	DF	sink with fountain	N	SI-215-DF-31	D	11:52AM	12/28/2023	Mandy Carlson	4.6	low water pressure	NA
		216	DF	sink with fountain	N	SI-216-DF-32	D	11:53AM	12/28/2023	Mandy Carlson	<1.00		NA
		217	DF	sink with fountain	N	SI-217-DF-33	D	11:55AM	12/28/2023	Mandy Carlson	4.3	low water pressure	NA
		134 -Band Room	DF	sink with fountain	N	SI-134-DF-34	D	11:58AM	12/28/2023	Mandy Carlson	5.9	low water pressure	Take out of service, and replace or add filter, perform flush (2nd draw) sampling.
		133	DF	sink with fountain	N	SI-133-DF-35	D	12:00PM	12/28/2023	Mandy Carlson	2.7		NA
	131	DF	sink with fountain	N	SI-131-DF-36	D	12:02PM	12/28/2023	Mandy Carlson	4.4		NA	
	130	DF	sink with fountain	N	SI-130-DF-37	D	12:05PM	12/28/2023	Mandy Carlson	4.4		NA	
	129	DF	sink with fountain	N	SI-129-DF-38	D	12:07PM	12/28/2023	Mandy Carlson	4		NA	
	100 Hallway across from 134	HF	shorter fountain on right side	N	SI-100H-RHF-39	D	12:12PM	12/28/2023	Mandy Carlson	<1.00		NA	
		HF	taller fountain on left side	N	SI-100H-LHF-40	D	12:12PM	12/28/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	SI-100H-BR-41	D	12:12PM	12/28/2023	Mandy Carlson	<1.00		NA	
	Kitchen	KF	handwashing sink near restroom	Y	SI-K-HKF-42	D	12:16PM	12/28/2023	Mandy Carlson	14.8		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace or add filter as soon as possible. Perform flush (2nd draw) sampling.	
KF		double sink near stove	Y	SI-K-KF-43	D	12:17PM	12/28/2023	Mandy Carlson	<1.00		NA		
KF		handwashing sink in dish room	Y	SI-K-HKF-44	D	12:19PM	12/28/2023	Mandy Carlson	16.5		Take out of service, and replace or add filter, perform flush (2nd draw) sampling.		
KF		sprayer	N	SI-K-SKF-45	D	12:21PM	12/28/2023	Mandy Carlson	1.7		NA		
KF		triple sink, left faucet	Y	SI-K-LKF-46	D	12:21PM	12/28/2023	Mandy Carlson	1.8		NA		
KF	triple sink, right faucet	Y	SI-K-RKF-47	D	12:21PM	12/28/2023	Mandy Carlson	1.6		NA			

Red Bold = at or above state action level
 ppb = parts per billion
 <= below laboratory reporting limit



District Name: Nixa Public Schools				Project Number: B5237030				State Action Level: 5 ppb			Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet		
Campus Name: Junior High School				Water Source: Municipal, Rural, Well				Municipal			Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR				Faucet Testing									
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
Junior High	Commons	BR	bottle filler	Y	NJH-C-BR-01	D	8:13AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on right	N	NJH-C-RWF-02	D	8:13AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on left	N	NJH-C-LWF-03	D	8:13AM	12/29/2023	Mandy Carlson	<1.00	visible mold on bubbler	NA	
	Kitchen	KF	sink in serving area	Y	NJH-K-KF-04	D	8:17AM	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	double sink, near ovens	Y	NJH-K-KF-05	D	9:19AM	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	single sink outside of dish room	Y	NJH-K-KF-06	D	8:21AM	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	triple sink, left faucet	Y	NJH-K-LKF-07	D	8:23AM	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	triple sink, right faucet	Y	NJH-K-RKF-08	D	8:23AM	12/29/2023	Mandy Carlson	<1.00		NA	
	Auditorium Lobby	KF	sprayer	N	NJH-K-KF-09	D	8:23AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on left	N	NJH-AL-WF-10	D	8:33AM	12/29/2023	Mandy Carlson	1.7		NA	
	Aux. Gym outside Girl's Restroom	WF	shorter fountain on right	N	NJH-AG-RWF-11	D	8:37AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	taller fountain on left	N	NJH-AG-LWF-12	D	8:37AM	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NJH-AG-BR-13	D	8:37AM	12/29/2023	Mandy Carlson	<1.00		NA	
	Hall between Aux. Gym Boy's and Girl's Restrooms	WF	shorter fountain on right	N	NJH-AG-WF-14	D	8:43AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	taller fountain on left	N	NJH-AG-WF-15	D	8:43AM	12/29/2023	Mandy Carlson	<1.00		NA	
	Aux. Gym outside Boy's Restroom	WF	shorter fountain on right	N	NJH-AG-WF-16	D	8:48AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	taller fountain on left	N	NJH-AG-WF-17	D	8:48AM	12/29/2023	Mandy Carlson	<1.00		NA	
	Girl's Lower Locker room L2	BR	bottle filler	Y	NJH-AG-BR-18	D	8:48AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain	N	NJH-L2-WF-19	D	-	12/29/2023	Mandy Carlson	<1.00	visible mold around bubbler	NA	
	Girl's Upper Locker room L1	WF	fountain	N	NJH-L1-WF-20	D	-	12/29/2023	Mandy Carlson	1.4		NA	
	East Hallway outside main gym next to E3	HF	fountain on left	N	NJH-EH-LHF-21	D	9:06AM	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	not operational, not sampled	Y	-	D	-	12/29/2023	Mandy Carlson	-		Sample after repair	
	East Hallway near E18	HF	fountain on right	N	NJH-EH-RHF-22	D	9:06AM	12/29/2023	Mandy Carlson	1.1		NA	
		HF	fountain on right	N	NJH-EH-RHF-23	D	9:15AM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on left	N	NJH-EH-LHF-24	D	9:15AM	12/29/2023	Mandy Carlson	<1.00		NA	
	North Hallway next to N15 Library	BR	bottle filler	Y	NJH-EH-BR-25	D	9:15AM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on right	N	NJH-NH-RHF-26	D	9:17AM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on left	N	NJH-NH-LHF-27	D	9:18AM	12/29/2023	Mandy Carlson	<1.00		NA	
	C23 - FACS	KF	right side, right sink	Y	NJH-C23-KF-28	D	9:28AM	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	back wall, right sink	Y	NJH-C23-KF-29	D	9:28AM	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	back wall, left sink	Y	NJH-C23-KF-30	D	9:28AM	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	left wall, left sink	Y	NJH-C23-KF-31	D	9:28AM	12/29/2023	Mandy Carlson	<1.00		NA	
	North Hallway near N7	KF	left side, front sink	Y	NJH-C23-KF-32	D	9:28AM	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on right	N	NJH-NH-HF-33	D	9:30AM	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NJH-NH-BR-34	D	9:30AM	12/29/2023	Mandy Carlson	<1.00		NA	
	West Hallway near W7 between restrooms	WF	fountain on left	N	NJH-WH-LWF-35	D	9:33AM	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on right	N	NJH-WH-RWF-36	D	9:35AM	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NJH-WH-BR-37	D	9:35AM	12/29/2023	Mandy Carlson	<1.00		NA	
	Counselor's Office	WF	water fountain	N	NJH-CO-WF-38	D	9:38AM	12/29/2023	Mandy Carlson	<1.00		NA	
	Central Hallway near Commons	HF	fountain on left	N	NJH-CH-LHF-39	D	9:52AM	12/29/2023	Mandy Carlson	<1.00		NA	
HF		fountain on right	N	NJH-CH-HF-40	D	9:52AM	12/29/2023	Mandy Carlson	<1.00		NA		
BR		bottle filler	Y	NJH-CH-HF-41	D	9:52AM	12/29/2023	Mandy Carlson	<1.00		NA		

Red Bold = at or above state action level
 ppb = parts per billion
 < = below laboratory reporting limit



District Name: Nixa Public Schools				Project Number: B5237030				State Action Level: 5 ppb			Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet		
Campus Name: High School				Water Source: Municipal, Rural, Well				Municipal			Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Faucet Inventory (outlet types): Classroom Faucet-CF, Hall Fountain-HF, Drinking Fountain-DF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Fountain/Faucet-OF (describe), Bottle Refill Faucet-BR				Faucet Testing									
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations	
High School	3rd Floor Hallway between restrooms near elevator	HF	shorter fountain on right	N	NHS-3F-WF-01	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	taller fountain on left	N	NHS-3F-WF-02	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NHS-3F-BR-03	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	2nd Floor - 2001 wrestling room	WF	fountain on left side	N	NHS-2001-WF-04	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on right side	N	NHS-2001-WF-05	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NHS-2001-BR-06	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	2nd Floor Hallway near 281	HF	fountain on right side	N	NHS-H-WF-07	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	fountain on left side	N	NHS-H-WF-08	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NHS-H-BR-09	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	2nd Floor Hallway near 228	HF	fountain	N	NHS-H-WF-10	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NHS-H-BR-11	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	2nd Floor - 218 FACS	KF	closest to the door on right wall	Y	NHS-218-KF-12	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		KF		Y	NHS-218-KF-13	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		KF		Y	NHS-218-KF-14	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		KF		Y	NHS-218-KF-15	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		KF		Y	NHS-218-KF-16	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		KF		Y	NHS-218-KF-17	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		KF	wall straight from door	Y	NHS-218-KF-18	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	2nd Floor Hallway near 208	HF	taller fountain on left	N	NHS-2H-HF-20	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	shorter fountain on right	N	NHS-2H-HF-21	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	shorter fountain on right	N	NHS-2H-HF-22	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	2nd Floor Hallway near elevator	HF	taller fountain on left	N	NHS-2H-HF-23	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NHS-2H-BR-24	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		HF	shorter fountain on right	N	NHS-1H-HF-25	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	1st Floor Hallway near 191	HF	taller fountain on left	N	NHS-1H-HF-26	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NHS-1H-BR-27	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on left side	N	NHS-1001-WF-28	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	1st Floor - 1001 Weight Room	BR	bottle filler	Y	NHS-1001-BR-29	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on right side	N	NHS-1001-WF-30	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
	1st Floor - Commons	WF	fountain on right side	N	NHS-C-WF-31	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		WF	fountain on left side	N	NHS-C-WF-32	D	-	12/29/2023	Mandy Carlson	<1.00		NA	
		BR	bottle filler	Y	NHS-C-BR-33	D	-	12/29/2023	Mandy Carlson	<1.00		NA	

Red Bold = at or above state action level
 ppb = parts per billion
 < = below laboratory reporting limit



District Name: Nixa Public Schools					Project Number: B52370303				State Action Level: 5 ppb		Notes - *Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.	
Campus Name: SCORE					Water Source: Municipal, Rural, Well				Municipal			
Faucet Inventory (outlet types): Classroom Faucet- CF , Hall Fountain- HF , Drinking Fountain- DF , Kitchen Faucet- KF , Bath Faucet- BF , Ice Maker- IM , Locker Room Faucet- LF , Water Fountain Chilled- WF , Nurse Room Faucet- NF , Teacher Room Faucet- TF , Shop Faucet- SF , Coffee Maker (Java)- JF , Other Fountain/Faucet- OF (describe) , Bottle Refill Faucet- BR					Faucet Testing							
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Time	Date	Sampler Name	Results ppb	Notes	Recommendations
SCORE	Cafeteria	WF	fountain on right	N	SCORE-C-WF-01	D	12:15PM	12/29/2023	Mandy Carlson	<1.00		NA
		WF	fountain on left	N	SCORE-C-WF-02	D	12:15PM	12/29/2023	Mandy Carlson	<1.00		NA
		BR	bottle filler	Y	SCORE-C-BR-03	D	12:15PM	12/29/2023	Mandy Carlson	<1.00		NA
	Kitchen	KF	triple sink faucet	N	SCORE-K-KF-04	D	12:20PM	12/29/2023	Mandy Carlson	<1.00		NA
		KF	single sink faucet	Y	SCORE-K-KF-05	D	12:20PM	12/29/2023	Mandy Carlson	1.2		NA

Red Bold = at or above state action level
 ppb = parts per billion
 < = below laboratory reporting limit