

ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John
St. John Environmental Consulting
5515 Grace Ave.
Saint Louis, Missouri 63116

Generated 7/1/2024 8:15:02 AM

JOB DESCRIPTION

St Joseph School District - 1000 S 9th

JOB NUMBER

810-109533-1

Eurofins Eaton Analytical South Bend

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
7/1/2024 8:15:02 AM

Authorized for release by
Pamela Brown, Project Manager
Pamela.Brown@et.eurofinsus.com
(574)233-4777

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
QC Sample Results	9
QC Association Summary	11
Lab Chronicle	12
Certification Summary	14
Method Summary	15
Sample Summary	16
Chain of Custody	17
Receipt Checklists	18



Definitions/Glossary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: St. John Environmental Consulting
Project: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Job ID: 810-109533-1

Eurofins Eaton Analytical South Bend

Job Narrative 810-109533-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 6/26/2024 9:45 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Client Sample ID: SJ 1000-1 ICE

Lab Sample ID: 810-109533-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.92		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJ 1000-2 WF

Lab Sample ID: 810-109533-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJ 1000-4 Sink

Lab Sample ID: 810-109533-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJ 1000-5 WF

Lab Sample ID: 810-109533-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJ 1000-6 WF

Lab Sample ID: 810-109533-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	90		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJ 1000-7 WF

Lab Sample ID: 810-109533-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJ 1000-8 Sink

Lab Sample ID: 810-109533-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJ 1000-9 WF

Lab Sample ID: 810-109533-8

No Detections.

Client Sample ID: SJ 1000-10 WF

Lab Sample ID: 810-109533-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.0		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Client Sample ID: SJ 1000-1 ICE

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-1

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.92		0.50		ug/L			06/29/24 12:45	1

Client Sample ID: SJ 1000-2 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-2

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6		0.50		ug/L			06/29/24 12:54	1

Client Sample ID: SJ 1000-4 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-3

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0		0.50		ug/L			06/29/24 12:55	1

Client Sample ID: SJ 1000-5 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-4

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L			06/29/24 12:57	1

Client Sample ID: SJ 1000-6 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-5

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	90		0.50		ug/L		06/27/24 13:10	06/28/24 13:18	1

Client Sample ID: SJ 1000-7 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-6

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		0.50		ug/L			06/29/24 13:02	1

Client Sample ID: SJ 1000-8 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-7

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.4		0.50		ug/L			06/29/24 13:03	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Client Sample ID: SJ 1000-9 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-8

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			06/29/24 13:05	1

Client Sample ID: SJ 1000-10 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-9

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		0.50		ug/L			06/29/24 13:07	1

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-104371/103

Matrix: Drinking Water

Analysis Batch: 104371

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			06/29/24 12:50	1

Lab Sample ID: MB 810-104371/12

Matrix: Drinking Water

Analysis Batch: 104371

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			06/29/24 10:21	1

Lab Sample ID: MB 810-104371/73

Matrix: Drinking Water

Analysis Batch: 104371

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			06/29/24 12:01	1

Lab Sample ID: LCS 810-104371/104

Matrix: Drinking Water

Analysis Batch: 104371

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	46.2		ug/L		92	85 - 115

Lab Sample ID: LCS 810-104371/74

Matrix: Drinking Water

Analysis Batch: 104371

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	47.7		ug/L		95	85 - 115

Lab Sample ID: LLCS 810-104371/11

Matrix: Drinking Water

Analysis Batch: 104371

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.309	J	ug/L		103	50 - 150

Lab Sample ID: 810-109533-4 MS

Matrix: Drinking Water

Analysis Batch: 104371

Client Sample ID: SJ 1000-5 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	1.2		50.0	46.7		ug/L		91	70 - 130

Lab Sample ID: 810-109533-4 MSD

Matrix: Drinking Water

Analysis Batch: 104371

Client Sample ID: SJ 1000-5 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	1.2		50.0	44.7		ug/L		87	70 - 130	5	20

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-104188/1-A
Matrix: Drinking Water
Analysis Batch: 104341

Client Sample ID: Method Blank
Prep Type: Total Recoverable
Prep Batch: 104188

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L		06/27/24 13:10	06/28/24 12:55	1

Lab Sample ID: LCS 810-104188/3-A
Matrix: Drinking Water
Analysis Batch: 104341

Client Sample ID: Lab Control Sample
Prep Type: Total Recoverable
Prep Batch: 104188

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.0		ug/L		102	85 - 115

Lab Sample ID: LLCS 810-104188/2-A
Matrix: Drinking Water
Analysis Batch: 104341

Client Sample ID: Lab Control Sample
Prep Type: Total Recoverable
Prep Batch: 104188

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.298	J	ug/L		99	50 - 150

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Metals

Prep Batch: 104188

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109533-5	SJ 1000-6 WF	Total Recoverable	Drinking Water	200.8	
MB 810-104188/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	
LCS 810-104188/3-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	
LLCS 810-104188/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	

Analysis Batch: 104341

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109533-5	SJ 1000-6 WF	Total Recoverable	Drinking Water	200.8	104188
MB 810-104188/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	104188
LCS 810-104188/3-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	104188
LLCS 810-104188/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	104188

Analysis Batch: 104371

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109533-1	SJ 1000-1 ICE	Total/NA	Drinking Water	200.8	
810-109533-2	SJ 1000-2 WF	Total/NA	Drinking Water	200.8	
810-109533-3	SJ 1000-4 Sink	Total/NA	Drinking Water	200.8	
810-109533-4	SJ 1000-5 WF	Total/NA	Drinking Water	200.8	
810-109533-6	SJ 1000-7 WF	Total/NA	Drinking Water	200.8	
810-109533-7	SJ 1000-8 Sink	Total/NA	Drinking Water	200.8	
810-109533-8	SJ 1000-9 WF	Total/NA	Drinking Water	200.8	
810-109533-9	SJ 1000-10 WF	Total/NA	Drinking Water	200.8	
MB 810-104371/103	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104371/12	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104371/73	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-104371/104	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-104371/74	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-104371/11	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-109533-4 MS	SJ 1000-5 WF	Total/NA	Drinking Water	200.8	
810-109533-4 MSD	SJ 1000-5 WF	Total/NA	Drinking Water	200.8	

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Client Sample ID: SJ 1000-1 ICE

Lab Sample ID: 810-109533-1

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104371	CA	EA SB	06/29/24 12:45

Client Sample ID: SJ 1000-2 WF

Lab Sample ID: 810-109533-2

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104371	CA	EA SB	06/29/24 12:54

Client Sample ID: SJ 1000-4 Sink

Lab Sample ID: 810-109533-3

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104371	CA	EA SB	06/29/24 12:55

Client Sample ID: SJ 1000-5 WF

Lab Sample ID: 810-109533-4

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104371	CA	EA SB	06/29/24 12:57

Client Sample ID: SJ 1000-6 WF

Lab Sample ID: 810-109533-5

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104188	NB	EA SB	06/27/24 13:10
Total Recoverable	Analysis	200.8		1	104341	NB	EA SB	06/28/24 13:18

Client Sample ID: SJ 1000-7 WF

Lab Sample ID: 810-109533-6

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104371	CA	EA SB	06/29/24 13:02

Client Sample ID: SJ 1000-8 Sink

Lab Sample ID: 810-109533-7

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104371	CA	EA SB	06/29/24 13:03

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Client Sample ID: SJ 1000-9 WF
Date Collected: 06/25/24 08:00
Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-8
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104371	CA	EA SB	06/29/24 13:05

Client Sample ID: SJ 1000-10 WF
Date Collected: 06/25/24 08:00
Date Received: 06/26/24 09:45

Lab Sample ID: 810-109533-9
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104371	CA	EA SB	06/29/24 13:07

Laboratory References:
EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Accreditation/Certification Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24

1
2
3
4
5
6
7
8
9
10
11
12
13
14

Method Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB
200.8	Preparation, Total Recoverable Metals	EPA	EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Sample Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - 1000 S 9th

Job ID: 810-109533-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-109533-1	SJ 1000-1 ICE	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109533-2	SJ 1000-2 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109533-3	SJ 1000-4 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109533-4	SJ 1000-5 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109533-5	SJ 1000-6 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109533-6	SJ 1000-7 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109533-7	SJ 1000-8 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109533-8	SJ 1000-9 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109533-9	SJ 1000-10 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45

Euromins Eaton Analytical: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

154
Dean



Environment Testing
America

1071

Client Information		Sampler: Ian St. John		Lab P/N:		Carrier Tracking No.:		COC No.:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page: Page 1 of 1	
Company: St. Joseph School District		Due Date Requested:		PWSID:		Analysis Requested		Job #:	
Address: 1415 North 26th Street		TAT Requested (days):		Standard		Preservation Codes:		M - Hexane N - None O - AsBio2 ---PWS	
City: St. Joseph		Compliance Project: ☐ Yes ☐ No		PO #:		810-109533 Chain of Custody		ecalydrate	
State, Zip: Missouri 64506		Project Name: St. Joseph School District		Project #:		Field Filtered Sample (Yes or No)		Total Number of containers	
Phone: 816-671-4000		Site: 1000 S. 9th		SSOW#:		PO in Drinking Water		Other:	
Email: CaseyHousman@stjohnenv.com		Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=Grab) (BT=Butter, AW=Air)	
		ST 1000-1 ICE		6/25/24 0800		5		W	
		ST 1000-2 W/F							
		ST 1000-3 Sink							
		ST 1000-4 Sink							
		ST 1000-5 W/F							
		ST 1000-6 W/F							
		ST 1000-7 W/F							
		ST 1000-8 Sink							
		ST 1000-9 W/F							
		ST 1000-10 W/F							
		ST 1000-11							
		ST 1000-12							
		ST 1000-13							
		ST 1000-14							
		ST 1000-15							
		ST 1000-16							
		ST 1000-17							
		ST 1000-18							
		ST 1000-19							
		ST 1000-20							
		ST 1000-21							
		ST 1000-22							
		ST 1000-23							
		ST 1000-24							
		ST 1000-25							
		ST 1000-26							
		ST 1000-27							
		ST 1000-28							
		ST 1000-29							
		ST 1000-30							
		ST 1000-31							
		ST 1000-32							
		ST 1000-33							
		ST 1000-34							
		ST 1000-35							
		ST 1000-36							
		ST 1000-37							
		ST 1000-38							
		ST 1000-39							
		ST 1000-40							
		ST 1000-41							
		ST 1000-42							
		ST 1000-43							
		ST 1000-44							
		ST 1000-45							
		ST 1000-46							
		ST 1000-47							
		ST 1000-48							
		ST 1000-49							
		ST 1000-50							
		ST 1000-51							
		ST 1000-52							
		ST 1000-53							
		ST 1000-54							
		ST 1000-55							
		ST 1000-56							
		ST 1000-57							
		ST 1000-58							
		ST 1000-59							
		ST 1000-60							
		ST 1000-61							
		ST 1000-62							
		ST 1000-63							
		ST 1000-64							
		ST 1000-65							
		ST 1000-66							
		ST 1000-67							
		ST 1000-68							
		ST 1000-69							
		ST 1000-70							
		ST 1000-71							
		ST 1000-72							
		ST 1000-73							
		ST 1000-74							
		ST 1000-75							
		ST 1000-76							
		ST 1000-77							
		ST 1000-78							
		ST 1000-79							
		ST 1000-80							
		ST 1000-81							
		ST 1000-82							
		ST 1000-83							
		ST 1000-84							
		ST 1000-85							
		ST 1000-86							
		ST 1000-87							
		ST 1000-88							
		ST 1000-89							
		ST 1000-90							
		ST 1000-91							
		ST 1000-92							
		ST 1000-93							
		ST 1000-94							
		ST 1000-95							
		ST 1000-96							
		ST 1000-97							
		ST 1000-98							
		ST 1000-99							
		ST 1000-100							
		ST 1000-101							
		ST 1000-102							
		ST 1000-103							
		ST 1000-104							
		ST 1000-105							
		ST 1000-106							
		ST 1000-107							
		ST 1000-108							
		ST 1000-109							
		ST 1000-110							
		ST 1000-111							
		ST 1000-112							
		ST 1000-113							
		ST 1000-114							
		ST 1000-115							
		ST 1000-116							
		ST 1000-117							
		ST 1000-118							
		ST 1000-119							
		ST 1000-120							
		ST 1000-121							
		ST 1000-122							
		ST 1000-123							
		ST 1000-124							
		ST 1000-125							
		ST 1000-126							
		ST 1000-127							
		ST 1000-128							
		ST 1000-129							
		ST 1000-130							
		ST 1000-131							
		ST 1000-132							
		ST 1000-133							
		ST 1000-134							
		ST 1000-135							
		ST 1000-136							
		ST 1000-137							
		ST 1000-138							
		ST 1000-139							
		ST 1000-140							
		ST 1000-141							
		ST 1000-142							
		ST 1000-143							
		ST 1000-144							
		ST 1000-145							
		ST 1000-146							
		ST 1000-147							
		ST 1000-148							
		ST 1000-149							
		ST 1000-150							
		ST 1000-151							
		ST 1000-152							
		ST 1000-153							
		ST 1000-154							
		ST 1000-155							
		ST 1000-156							
		ST 1000-157							
		ST 1000-158							
		ST 1000-159							
		ST 1000-160							
		ST 1000-161							
		ST 1000-162							
		ST 1000-163							
		ST 1000-164							
		ST 1000-165							
		ST 1000-166							
		ST 1000-167							
		ST 1000-168							
		ST 1000-169							
		ST 1000-170							
		ST 1000-171							
		ST 1000-172							
		ST 1000-173							
		ST 1000-174							
		ST 1000-175							
		ST 1000-176							
		ST 1000-177							
		ST 1000-178							
		ST 1000-179							
		ST 1000-180							
		ST 1000-181							
		ST 1000-182							
		ST 1000-183							
		ST 1000-184							
		ST 1000-185							
		ST 1000-186							
		ST 1000-187							
		ST 1000-188							
		ST 1000-189							
		ST 1000-190							
		ST 1000-191							
		ST 1000-192							
		ST 1000-193							
		ST 1000-194							
		ST 1000-195							
		ST 1000-196							
		ST 1000-197							
		ST 1000-198							
		ST 1000-199							
		ST 1000-200							
		ST 1000-201							
		ST 1000-202							
		ST 1000-203							
		ST 1000-204							
		ST 1000-205							
		ST 1000-206							
		ST 1000-207							
		ST 1000-208							
		ST 1000-209							
		ST 1000-210							
		ST 1000-211							
		ST 1000-212							
		ST 1000-213							
		ST 1000-214							
		ST 1000-215							
		ST 1000-216							
		ST 1000-217							
		ST 1000-218							
		ST 1000-219							
		ST 1000-220							
		ST 1000-221							
		ST 1000-222							
		ST 1000-223							
		ST 1000-224							
		ST 1000-225							
		ST 1000-226							
		ST 1000-227							
		ST 1000-228							
		ST 1000-229							
		ST 1000-230							
		ST 1000-231							

Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-109533-1

Login Number: 109533

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Moffitt, Tisha

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	False	Thermal preservation not required.
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	