

ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John
St. John Environmental Consulting
5515 Grace Ave.
Saint Louis, Missouri 63116

Generated 7/4/2024 2:59:12 AM

JOB DESCRIPTION

St. Joseph School District - Carden Park

JOB NUMBER

810-109597-1

Eurofins Eaton Analytical South Bend

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
7/4/2024 2:59:12 AM

Authorized for release by
Pamela Brown, Project Manager
Pamela.Brown@et.eurofinsus.com
(574)233-4777

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	9
QC Sample Results	15
QC Association Summary	18
Lab Chronicle	20
Certification Summary	26
Method Summary	27
Sample Summary	28
Chain of Custody	29
Receipt Checklists	34



Definitions/Glossary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: St. John Environmental Consulting
Project: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Job ID: 810-109597-1

Eurofins Eaton Analytical South Bend

Job Narrative 810-109597-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 6/26/2024 9:45 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Receipt Exceptions

One or more containers for the following sample(s) was received empty:

SJCP - 1 WF
SJCP - 6 WF
SJCP - 13 WF
SJCP - 17 SINK
SJCP - 21 SINK
SJCP - 22 SINK
SJCP - 29 SINK
SJCP - 34 SINK
SJCP - 35 SINK
SJCP - 37 WF
SJCP - 47 SINK

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 2 WF

Lab Sample ID: 810-109597-1

No Detections.

Client Sample ID: SJCP - 3 Sink

Lab Sample ID: 810-109597-2

No Detections.

Client Sample ID: SJCP - 4 Sink

Lab Sample ID: 810-109597-3

No Detections.

Client Sample ID: SJCP - 5 WF

Lab Sample ID: 810-109597-4

No Detections.

Client Sample ID: SJCP - 7 Sink

Lab Sample ID: 810-109597-5

No Detections.

Client Sample ID: SJCP - 8 Sink

Lab Sample ID: 810-109597-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.59		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCP - 9 Bubbler

Lab Sample ID: 810-109597-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCP - 10 Sink

Lab Sample ID: 810-109597-8

No Detections.

Client Sample ID: SJCP - 11 Bubbler

Lab Sample ID: 810-109597-9

No Detections.

Client Sample ID: SJCP - 12 WF

Lab Sample ID: 810-109597-10

No Detections.

Client Sample ID: SJCP - 14 Sink

Lab Sample ID: 810-109597-11

No Detections.

Client Sample ID: SJCP - 15 Bubbler

Lab Sample ID: 810-109597-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.57		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCP - 16 Sink

Lab Sample ID: 810-109597-13

No Detections.

Client Sample ID: SJCP - 18 Sink

Lab Sample ID: 810-109597-14

No Detections.

Client Sample ID: SJCP - 19 Sink

Lab Sample ID: 810-109597-15

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 20 Sink

Lab Sample ID: 810-109597-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCP - 23 Sink

Lab Sample ID: 810-109597-17

No Detections.

Client Sample ID: SJCP - 24 Sink

Lab Sample ID: 810-109597-18

No Detections.

Client Sample ID: SJCP - 25 WF

Lab Sample ID: 810-109597-19

No Detections.

Client Sample ID: SJCP - 26 WF

Lab Sample ID: 810-109597-20

No Detections.

Client Sample ID: SJCP - 27 WF

Lab Sample ID: 810-109597-21

No Detections.

Client Sample ID: SJCP - 28 WF

Lab Sample ID: 810-109597-22

No Detections.

Client Sample ID: SJCP - 30 Sink

Lab Sample ID: 810-109597-23

No Detections.

Client Sample ID: SJCP - 31 WF

Lab Sample ID: 810-109597-24

No Detections.

Client Sample ID: SJCP - 32 WF

Lab Sample ID: 810-109597-25

No Detections.

Client Sample ID: SJCP - 33 Sink

Lab Sample ID: 810-109597-26

No Detections.

Client Sample ID: SJCP - 36 Sink

Lab Sample ID: 810-109597-27

No Detections.

Client Sample ID: SJCP - 38 WF

Lab Sample ID: 810-109597-28

No Detections.

Client Sample ID: SJCP - 39 Sink

Lab Sample ID: 810-109597-29

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCP - 40 Sink

Lab Sample ID: 810-109597-30

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 41 Sink

Lab Sample ID: 810-109597-31

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.55		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCP - 42 Sink

Lab Sample ID: 810-109597-32

No Detections.

Client Sample ID: SJCP - 43 WF

Lab Sample ID: 810-109597-33

No Detections.

Client Sample ID: SJCP - 44 WF

Lab Sample ID: 810-109597-34

No Detections.

Client Sample ID: SJCP - 45 Sink

Lab Sample ID: 810-109597-35

No Detections.

Client Sample ID: SJCP - 46 Sink

Lab Sample ID: 810-109597-36

No Detections.

Client Sample ID: SJCP - 48 WF

Lab Sample ID: 810-109597-37

No Detections.

Client Sample ID: SJCP - 49 WF

Lab Sample ID: 810-109597-38

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 2 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-1

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 15:48	1

Client Sample ID: SJCP - 3 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-2

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 15:51	1

Client Sample ID: SJCP - 4 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-3

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 15:54	1

Client Sample ID: SJCP - 5 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-4

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 15:56	1

Client Sample ID: SJCP - 7 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-5

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 16:05	1

Client Sample ID: SJCP - 8 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-6

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.59		0.50		ug/L			07/02/24 16:08	1

Client Sample ID: SJCP - 9 Bubbler

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-7

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L		07/02/24 12:38	07/03/24 13:39	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 10 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-8

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 16:11	1

Client Sample ID: SJCP - 11 Bubbler

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-9

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 16:14	1

Client Sample ID: SJCP - 12 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-10

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 16:16	1

Client Sample ID: SJCP - 14 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-11

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 16:19	1

Client Sample ID: SJCP - 15 Bubbler

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-12

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.57		0.50		ug/L			07/02/24 13:44	1

Client Sample ID: SJCP - 16 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-13

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 13:46	1

Client Sample ID: SJCP - 18 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-14

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 13:51	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 19 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-15

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 13:52	1

Client Sample ID: SJCP - 20 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-16

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.4		0.50		ug/L			07/02/24 13:54	1

Client Sample ID: SJCP - 23 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-17

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 13:56	1

Client Sample ID: SJCP - 24 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-18

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 13:57	1

Client Sample ID: SJCP - 25 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-19

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 13:59	1

Client Sample ID: SJCP - 26 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-20

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:01	1

Client Sample ID: SJCP - 27 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-21

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:02	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 28 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-22

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:07	1

Client Sample ID: SJCP - 30 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-23

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:09	1

Client Sample ID: SJCP - 31 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-24

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:10	1

Client Sample ID: SJCP - 32 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-25

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:15	1

Client Sample ID: SJCP - 33 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-26

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:17	1

Client Sample ID: SJCP - 36 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-27

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:19	1

Client Sample ID: SJCP - 38 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-28

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:20	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 39 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-29

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4		0.50		ug/L			07/02/24 14:22	1

Client Sample ID: SJCP - 40 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-30

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:24	1

Client Sample ID: SJCP - 41 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-31

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.55		0.50		ug/L			07/02/24 14:25	1

Client Sample ID: SJCP - 42 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-32

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:33	1

Client Sample ID: SJCP - 43 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-33

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:35	1

Client Sample ID: SJCP - 44 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-34

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:37	1

Client Sample ID: SJCP - 45 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-35

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:38	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 46 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-36

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:43	1

Client Sample ID: SJCP - 48 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-37

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:45	1

Client Sample ID: SJCP - 49 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-38

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:46	1

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-104689/101
Matrix: Drinking Water
Analysis Batch: 104689

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 14:30	1

Lab Sample ID: MB 810-104689/11
Matrix: Drinking Water
Analysis Batch: 104689

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 12:03	1

Lab Sample ID: MB 810-104689/71
Matrix: Drinking Water
Analysis Batch: 104689

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 13:41	1

Lab Sample ID: LCS 810-104689/102
Matrix: Drinking Water
Analysis Batch: 104689

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.3		ug/L		103	85 - 115

Lab Sample ID: LCS 810-104689/72
Matrix: Drinking Water
Analysis Batch: 104689

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	53.4		ug/L		107	85 - 115

Lab Sample ID: LLCS 810-104689/10
Matrix: Drinking Water
Analysis Batch: 104689

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.275	J	ug/L		92	50 - 150

Lab Sample ID: 810-109597-13 MS
Matrix: Drinking Water
Analysis Batch: 104689

Client Sample ID: SJCP - 16 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	48.1		ug/L		95	70 - 130

Lab Sample ID: 810-109597-13 MSD
Matrix: Drinking Water
Analysis Batch: 104689

Client Sample ID: SJCP - 16 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	49.0		ug/L		97	70 - 130	2	20

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-109597-24 MS

Matrix: Drinking Water

Analysis Batch: 104689

Client Sample ID: SJCP - 31 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	53.3		ug/L		107	70 - 130

Lab Sample ID: 810-109597-24 MSD

Matrix: Drinking Water

Analysis Batch: 104689

Client Sample ID: SJCP - 31 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	52.1		ug/L		104	70 - 130	2	20

Lab Sample ID: 810-109597-35 MS

Matrix: Drinking Water

Analysis Batch: 104689

Client Sample ID: SJCP - 45 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	53.7		ug/L		107	70 - 130

Lab Sample ID: 810-109597-35 MSD

Matrix: Drinking Water

Analysis Batch: 104689

Client Sample ID: SJCP - 45 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	54.1		ug/L		107	70 - 130	1	20

Lab Sample ID: MB 810-104696/11

Matrix: Drinking Water

Analysis Batch: 104696

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 13:29	1

Lab Sample ID: MB 810-104696/45

Matrix: Drinking Water

Analysis Batch: 104696

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 15:03	1

Lab Sample ID: LCS 810-104696/46

Matrix: Drinking Water

Analysis Batch: 104696

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	49.0		ug/L		98	85 - 115

Lab Sample ID: LLCS 810-104696/12

Matrix: Drinking Water

Analysis Batch: 104696

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.281	J	ug/L		94	50 - 150

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-109597-4 MS

Matrix: Drinking Water

Analysis Batch: 104696

Client Sample ID: SJCP - 5 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	47.8		ug/L		96	70 - 130

Lab Sample ID: 810-109597-4 MSD

Matrix: Drinking Water

Analysis Batch: 104696

Client Sample ID: SJCP - 5 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	49.0		ug/L		98	70 - 130	2	20

Lab Sample ID: MB 810-104650/1-A

Matrix: Drinking Water

Analysis Batch: 104792

Client Sample ID: Method Blank

Prep Type: Total Recoverable

Prep Batch: 104650

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L		07/02/24 12:38	07/03/24 13:10	1

Lab Sample ID: LCS 810-104650/3-A

Matrix: Drinking Water

Analysis Batch: 104792

Client Sample ID: Lab Control Sample

Prep Type: Total Recoverable

Prep Batch: 104650

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	53.2		ug/L		106	85 - 115

Lab Sample ID: LLCS 810-104650/2-A

Matrix: Drinking Water

Analysis Batch: 104792

Client Sample ID: Lab Control Sample

Prep Type: Total Recoverable

Prep Batch: 104650

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.275	J	ug/L		92	50 - 150

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Metals

Prep Batch: 104650

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109597-7	SJCP - 9 Bubbler	Total Recoverable	Drinking Water	200.8	
MB 810-104650/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	
LCS 810-104650/3-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	
LLCS 810-104650/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	

Analysis Batch: 104689

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109597-12	SJCP - 15 Bubbler	Total/NA	Drinking Water	200.8	
810-109597-13	SJCP - 16 Sink	Total/NA	Drinking Water	200.8	
810-109597-14	SJCP - 18 Sink	Total/NA	Drinking Water	200.8	
810-109597-15	SJCP - 19 Sink	Total/NA	Drinking Water	200.8	
810-109597-16	SJCP - 20 Sink	Total/NA	Drinking Water	200.8	
810-109597-17	SJCP - 23 Sink	Total/NA	Drinking Water	200.8	
810-109597-18	SJCP - 24 Sink	Total/NA	Drinking Water	200.8	
810-109597-19	SJCP - 25 WF	Total/NA	Drinking Water	200.8	
810-109597-20	SJCP - 26 WF	Total/NA	Drinking Water	200.8	
810-109597-21	SJCP - 27 WF	Total/NA	Drinking Water	200.8	
810-109597-22	SJCP - 28 WF	Total/NA	Drinking Water	200.8	
810-109597-23	SJCP - 30 Sink	Total/NA	Drinking Water	200.8	
810-109597-24	SJCP - 31 WF	Total/NA	Drinking Water	200.8	
810-109597-25	SJCP - 32 WF	Total/NA	Drinking Water	200.8	
810-109597-26	SJCP - 33 Sink	Total/NA	Drinking Water	200.8	
810-109597-27	SJCP - 36 Sink	Total/NA	Drinking Water	200.8	
810-109597-28	SJCP - 38 WF	Total/NA	Drinking Water	200.8	
810-109597-29	SJCP - 39 Sink	Total/NA	Drinking Water	200.8	
810-109597-30	SJCP - 40 Sink	Total/NA	Drinking Water	200.8	
810-109597-31	SJCP - 41 Sink	Total/NA	Drinking Water	200.8	
810-109597-32	SJCP - 42 Sink	Total/NA	Drinking Water	200.8	
810-109597-33	SJCP - 43 WF	Total/NA	Drinking Water	200.8	
810-109597-34	SJCP - 44 WF	Total/NA	Drinking Water	200.8	
810-109597-35	SJCP - 45 Sink	Total/NA	Drinking Water	200.8	
810-109597-36	SJCP - 46 Sink	Total/NA	Drinking Water	200.8	
810-109597-37	SJCP - 48 WF	Total/NA	Drinking Water	200.8	
810-109597-38	SJCP - 49 WF	Total/NA	Drinking Water	200.8	
MB 810-104689/101	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104689/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104689/71	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-104689/102	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-104689/72	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-104689/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-109597-13 MS	SJCP - 16 Sink	Total/NA	Drinking Water	200.8	
810-109597-13 MSD	SJCP - 16 Sink	Total/NA	Drinking Water	200.8	
810-109597-24 MS	SJCP - 31 WF	Total/NA	Drinking Water	200.8	
810-109597-24 MSD	SJCP - 31 WF	Total/NA	Drinking Water	200.8	
810-109597-35 MS	SJCP - 45 Sink	Total/NA	Drinking Water	200.8	
810-109597-35 MSD	SJCP - 45 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 104696

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109597-1	SJCP - 2 WF	Total/NA	Drinking Water	200.8	
810-109597-2	SJCP - 3 Sink	Total/NA	Drinking Water	200.8	

Eurofins Eaton Analytical South Bend

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Metals (Continued)

Analysis Batch: 104696 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109597-3	SJCP - 4 Sink	Total/NA	Drinking Water	200.8	
810-109597-4	SJCP - 5 WF	Total/NA	Drinking Water	200.8	
810-109597-5	SJCP - 7 Sink	Total/NA	Drinking Water	200.8	
810-109597-6	SJCP - 8 Sink	Total/NA	Drinking Water	200.8	
810-109597-8	SJCP - 10 Sink	Total/NA	Drinking Water	200.8	
810-109597-9	SJCP - 11 Bubbler	Total/NA	Drinking Water	200.8	
810-109597-10	SJCP - 12 WF	Total/NA	Drinking Water	200.8	
810-109597-11	SJCP - 14 Sink	Total/NA	Drinking Water	200.8	
MB 810-104696/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104696/45	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-104696/46	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-104696/12	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-109597-4 MS	SJCP - 5 WF	Total/NA	Drinking Water	200.8	
810-109597-4 MSD	SJCP - 5 WF	Total/NA	Drinking Water	200.8	

Analysis Batch: 104792

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109597-7	SJCP - 9 Bubbler	Total Recoverable	Drinking Water	200.8	104650
MB 810-104650/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	104650
LCS 810-104650/3-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	104650
LLCS 810-104650/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	104650

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 2 WF

Lab Sample ID: 810-109597-1

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 15:48

Client Sample ID: SJCP - 3 Sink

Lab Sample ID: 810-109597-2

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 15:51

Client Sample ID: SJCP - 4 Sink

Lab Sample ID: 810-109597-3

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 15:54

Client Sample ID: SJCP - 5 WF

Lab Sample ID: 810-109597-4

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 15:56

Client Sample ID: SJCP - 7 Sink

Lab Sample ID: 810-109597-5

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 16:05

Client Sample ID: SJCP - 8 Sink

Lab Sample ID: 810-109597-6

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 16:08

Client Sample ID: SJCP - 9 Bubbler

Lab Sample ID: 810-109597-7

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 13:39

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 10 Sink

Lab Sample ID: 810-109597-8

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 16:11

Client Sample ID: SJCP - 11 Bubbler

Lab Sample ID: 810-109597-9

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 16:14

Client Sample ID: SJCP - 12 WF

Lab Sample ID: 810-109597-10

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 16:16

Client Sample ID: SJCP - 14 Sink

Lab Sample ID: 810-109597-11

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104696	NB	EA SB	07/02/24 16:19

Client Sample ID: SJCP - 15 Bubbler

Lab Sample ID: 810-109597-12

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 13:44

Client Sample ID: SJCP - 16 Sink

Lab Sample ID: 810-109597-13

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 13:46

Client Sample ID: SJCP - 18 Sink

Lab Sample ID: 810-109597-14

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 13:51

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 19 Sink

Lab Sample ID: 810-109597-15

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 13:52

Client Sample ID: SJCP - 20 Sink

Lab Sample ID: 810-109597-16

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 13:54

Client Sample ID: SJCP - 23 Sink

Lab Sample ID: 810-109597-17

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 13:56

Client Sample ID: SJCP - 24 Sink

Lab Sample ID: 810-109597-18

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 13:57

Client Sample ID: SJCP - 25 WF

Lab Sample ID: 810-109597-19

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 13:59

Client Sample ID: SJCP - 26 WF

Lab Sample ID: 810-109597-20

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:01

Client Sample ID: SJCP - 27 WF

Lab Sample ID: 810-109597-21

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:02

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 28 WF

Lab Sample ID: 810-109597-22

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:07

Client Sample ID: SJCP - 30 Sink

Lab Sample ID: 810-109597-23

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:09

Client Sample ID: SJCP - 31 WF

Lab Sample ID: 810-109597-24

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:10

Client Sample ID: SJCP - 32 WF

Lab Sample ID: 810-109597-25

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:15

Client Sample ID: SJCP - 33 Sink

Lab Sample ID: 810-109597-26

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:17

Client Sample ID: SJCP - 36 Sink

Lab Sample ID: 810-109597-27

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:19

Client Sample ID: SJCP - 38 WF

Lab Sample ID: 810-109597-28

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:20

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 39 Sink

Lab Sample ID: 810-109597-29

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:22

Client Sample ID: SJCP - 40 Sink

Lab Sample ID: 810-109597-30

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:24

Client Sample ID: SJCP - 41 Sink

Lab Sample ID: 810-109597-31

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:25

Client Sample ID: SJCP - 42 Sink

Lab Sample ID: 810-109597-32

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:33

Client Sample ID: SJCP - 43 WF

Lab Sample ID: 810-109597-33

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:35

Client Sample ID: SJCP - 44 WF

Lab Sample ID: 810-109597-34

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:37

Client Sample ID: SJCP - 45 Sink

Lab Sample ID: 810-109597-35

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:38

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Client Sample ID: SJCP - 46 Sink
Date Collected: 06/25/24 08:00
Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-36
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:43

Client Sample ID: SJCP - 48 WF
Date Collected: 06/25/24 08:00
Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-37
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:45

Client Sample ID: SJCP - 49 WF
Date Collected: 06/25/24 08:00
Date Received: 06/26/24 09:45

Lab Sample ID: 810-109597-38
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104689	CA	EA SB	07/02/24 14:46

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Accreditation/Certification Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24

1
2
3
4
5
6
7
8
9
10
11
12
13
14

Method Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB
200.8	Preparation, Total Recoverable Metals	EPA	EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777


Sample Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Carden Park

Job ID: 810-109597-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-109597-1	SJCP - 2 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-2	SJCP - 3 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-3	SJCP - 4 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-4	SJCP - 5 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-5	SJCP - 7 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-6	SJCP - 8 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-7	SJCP - 9 Bubbler	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-8	SJCP - 10 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-9	SJCP - 11 Bubbler	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-10	SJCP - 12 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-11	SJCP - 14 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-12	SJCP - 15 Bubbler	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-13	SJCP - 16 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-14	SJCP - 18 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-15	SJCP - 19 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-16	SJCP - 20 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-17	SJCP - 23 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-18	SJCP - 24 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-19	SJCP - 25 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-20	SJCP - 26 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-21	SJCP - 27 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-22	SJCP - 28 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-23	SJCP - 30 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-24	SJCP - 31 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-25	SJCP - 32 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-26	SJCP - 33 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-27	SJCP - 36 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-28	SJCP - 38 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-29	SJCP - 39 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-30	SJCP - 40 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-31	SJCP - 41 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-32	SJCP - 42 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-33	SJCP - 43 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-34	SJCP - 44 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-35	SJCP - 45 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-36	SJCP - 46 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-37	SJCP - 48 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109597-38	SJCP - 49 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45

Chain of Custody Record



Environment Testing
America

1007

1st
DRAW

Client Information		Sampler: Ian St. John		Lab PM:		Carrier Tracking No(s):		COC No:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page: Page 1 of 6	
Company: St. Joseph School District		PWSID:		Analysis Requested		Job #:			
Address: 1415 North 26th Street		Due Date Requested:		Perform MS/MSD (Yes or No)		Total Number of Containers		Preservation Codes:	
City: St. Joseph		TAT Requested (days): Standard		Field Filtered Sample (Yes or No)				A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:	
State, Zip: Missouri 64506		Compliance Project: Δ Yes Δ No						M - Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2SO4 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Trizma Z - other (specify)	
Phone: 816-671-4000		PO #:							
Email: CaseyHousman@sjsd.k12.mo.us		WO #:							
Project Name: St. Joseph School District		Project #:							
Site: CARDEN PARK		SSOW#:							
Sample Identification		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=wastewater, AT=tissue, AA=air)	Special Instructions/Note:			
ST CP-1 WF	6/25/24 0800	G	W			Empty			
ST CP-2 WF						* Preserved upon receipt * kw blase			
ST CP-3 Sink						EMPTY			
ST CP-4 Sink									
ST CP-5 WF									
ST CP-6 WF									
ST CP-7 Sink									
ST CP-8 Sink									
ST CP-9 Bubblers									
ST CP-10 Sink									
ST CP-11 Bubblers									
Possible Hazard Identification ☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) ☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months			
Deliverable Requested: I, II, III, IV, Other (specify)						Special Instructions/QC Requirements:			
Empty Kit Relinquished by:						Method of Shipment:			
Relinquished by: [Signature]						Received by: Kamreen Williams 6/26/24 0945			
Relinquished by:						Received by:			
Relinquished by:						Received by:			
Custody Seals Intact: Δ Yes Δ No						Cooler Temperature(s) °C and Other Remarks: Ambient			

Chain of Custody Record



Environment Testing
America

697

Client Information		Sampler: Ian St. John		Lab PM:		Carrier Tracking No(s):		COC No:	
Client Contact:		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page: 3 of 5	
Company: Casey Housman		PWSID:		Due Date Requested:		Analysis Requested		Job #:	
Address: St. Joseph School District		TAT Requested (days): Standard		Compliance Project: ☐ Yes ☒ No		Field Filtered Sample (Yes or No)		Preservation Codes:	
City: St. Joseph		PO #:		WO #:		Project #:		A - HCL	
State, Zip: Missouri 64506		SSOW#:		Sample Date		Sample Time		B - NaOH	
Phone: 816-671-4000		Sample Type (C=Comp, G=grab)		Matrix (W=Water, S=Solid, O=Other)		Preservation Code: (ST=Tissue, A=Air)		C - Zn Acetate	
Email: CaseyHousman@sjsd.k12.mo.us		Sample Date		Sample Time		Preservation Code: (ST=Tissue, A=Air)		D - Nitric Acid	
Project Name: St. Joseph School District		Sample Date		Sample Time		Preservation Code: (ST=Tissue, A=Air)		E - NaHSO4	
Site: CARDEN PARK		Sample Date		Sample Time		Preservation Code: (ST=Tissue, A=Air)		F - MeOH	
Sample Identification		Sample Date		Sample Time		Preservation Code: (ST=Tissue, A=Air)		G - Amchlor	
STCP-12 WF		0800		G		W		H - Ascorbic Acid	
STCP-13 WF								I - Ice	
STCP-14 Sink								J - DI Water	
STCP-15 Bubble								K - EDTA	
STCP-16 Sink								L - EDA	
STCP-17 Sink								Other:	
STCP-18 "								M - Hexane	
STCP-19 "								N - None	
STCP-20 "								O - AsNaO2	
STCP-21 "								P - Na2O4S	
STCP-22 "								Q - Na2SO3	
								R - Na2SO4	
								S - H2SO4	
								T - TSP Dodecahydrate	
								U - Acetone	
								V - MCAA	
								W - pH 4-5	
								Y - Trizma	
								Z - other (specify)	
Possible Hazard Identification		☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological		Date:		Time:		Special Instructions/Note:	
Deliverable Requested: I, II, III, IV, Other (specify)		☐ Return To Client ☒ Disposal By Lab ☐ Archive For		Months		Special Instructions/QC Requirements:		Total Number of containers	
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:		Special Instructions/Note:	
Relinquished by: [Signature]		Date: APRIL 14, 2024		Time:		Company: [Signature]		Special Instructions/Note:	
Relinquished by:		Date:		Time:		Company:		Special Instructions/Note:	
Relinquished by:		Date:		Time:		Company:		Special Instructions/Note:	
Custody Seals Intact: ☐ Yes ☒ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks:		Company:		Special Instructions/Note:	

Chain of Custody Record



Environment Testing
America

2067

Client Information		Sampler: Ian St. John		Lab PM:		Carrier Tracking No(s):		COC No:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page: 3 of 5	
Company: St. Joseph School District		PWSID:		Due Date Requested:		Analysis Requested		Job #:	
Address: 1415 North 26th Street		TAT Requested (days): Standard		Compliance Project: ☐ Yes ☒ No		Perform MS/MSD (Yes or No)		Preservation Codes:	
City: St. Joseph		PO #:		WO #:		Field Filtered Sample (Yes or No)		A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:	
Phone: 816-671-4000		Project #:		SSOW#:		Total Number of Containers		M - Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2SO4 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Trizma Z - other (specify)	
Email: CaseyHousman@sjsd.k12.mo.us		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=soil, T=tissue, A=air)	
Project Name: St. Joseph School District		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Preservation Code:	
Site: CARDEN PARK		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Special Instructions/Note:	
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Special Instructions/Note:	
ST CP-23 Spk		0800		G		W		Special Instructions/Note:	
ST CP-24 Spk								Special Instructions/Note:	
ST CP-25 WF								Special Instructions/Note:	
ST CP-26 WF								Special Instructions/Note:	
ST CP-27 WF								Special Instructions/Note:	
ST CP-28 WF								Special Instructions/Note:	
ST CP-29 Spk								Special Instructions/Note:	
ST CP-30 Spk								Special Instructions/Note:	
ST CP-31 WF								Special Instructions/Note:	
ST CP-32 WF								Special Instructions/Note:	
ST CP-33 Spk								Special Instructions/Note:	
Possible Hazard Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Special Instructions/Note:	
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Special Instructions/Note:	
Deliverable Requested: I, II, III, IV, Other (specify)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Special Instructions/Note:	
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:		Special Instructions/Note:	
Relinquished by: [Signature]		Date/Time: APRIL 14, 2024		Company: [Signature]		Date/Time: [Signature]		Company: [Signature]	
Relinquished by:		Date/Time:		Company:		Date/Time:		Company:	
Relinquished by:		Date/Time:		Company:		Date/Time:		Company:	
Custody Seals Intact: ☐ Yes ☒ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks:		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		Special Instructions/Note:	
						☐ Return To Client ☒ Disposal By Lab ☐ Archive For		Months	

Chain of Custody Record



Environment Testing
America

Client Information		Sampler: Ian St. John		Lab PM:		Carrier Tracking No(s):		COC No:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page: 4 of 5	
Company: St. Joseph School District		PWSID:		Analysis Requested		Job #:			
Address: 1415 North 26th Street		Due Date Requested:		Perform MS/MSD (Yes or No)		Total Number of containers		Preservation Codes:	
City: St. Joseph		TAT Requested (days): Standard		Field Filtered Sample (Yes or No)				A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDTA M - Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Trizma Z - other (specify)	
State, Zip: Missouri 64506		Compliance Project: ☐ Yes ☒ No							
Phone: 816-671-4000		PO #:							
Email: CaseyHousman@sjsd.k12.mo.us		WO #:							
Project Name: St. Joseph School District		Project #:							
Site: Carden Park		SSOW#:							
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=soil, ST=tissue, A=air)	
SJ CP-34 Sink		0800		G		W			
SJ CP-35 " "									
SJ CP-36 " "									
SJ CP-37 WF									
SJ CP-38 WF									
SJ CP-39 Sink									
SJ CP-40 " "									
SJ CP-41 " "									
SJ CP-42 " "									
SJ CP-43 WF WF									
SJ CP-44 WF WF									
Possible Hazard Identification		☒ Non-Hazard		☐ Flammable		☐ Skin Irritant		☐ Poison B	
Deliverable Requested: I, II, III, IV, Other (specify)		☐ Unknown		☐ Radiological					
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:		Special Instructions/QC Requirements:	
Relinquished by: [Signature]		Date/Time: April 14, 2024				Received by: [Signature]		Date/Time: 6/26/24	
Relinquished by:		Date/Time:				Received by:		Date/Time:	
Relinquished by:		Date/Time:				Received by:		Date/Time:	
Custody Seals Intact: ☐ Yes ☐ No		Custody Seal No.:				Cooler Temperature(s) °C and Other Remarks:			

[illegible]

Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-109597-1

Login Number: 109597

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Williams, Kameron

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	False	Thermal preservation not required.
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	False	Refer to Job Narrative for details.
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	