

ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John
St. John Environmental Consulting
5515 Grace Ave.
Saint Louis, Missouri 63116

Generated 7/8/2024 6:24:00 PM

JOB DESCRIPTION

St. Joseph School District - Central High School

JOB NUMBER

810-109581-1

Eurofins Eaton Analytical South Bend

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
7/8/2024 6:24:00 PM

Authorized for release by
Pamela Brown, Project Manager
Pamela.Brown@et.eurofinsus.com
(574)233-4777

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	13
QC Sample Results	24
QC Association Summary	29
Lab Chronicle	32
Certification Summary	43
Method Summary	44
Sample Summary	45
Chain of Custody	47
Receipt Checklists	56



Definitions/Glossary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Qualifiers

Metals

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: St. John Environmental Consulting
Project: St. Joseph School District - Central High School

Job ID: 810-109581-1

Job ID: 810-109581-1

Eurofins Eaton Analytical South Bend

Job Narrative 810-109581-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 6/26/2024 9:45 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Receipt Exceptions

One or more containers for the following samples were received empty: SJCH-1 Sink (810-109581-1), SJCH-2 WF (810-109581-2), SJCH-3 WF (810-109581-3), SJCH-4 Sink (810-109581-4), SJCH-5 Snk (810-109581-5), SJCH-6 WF (810-109581-6), SJCH-7 WF (810-109581-7), SJCH-8 Sink (810-109581-8), SJCH-9 Sink (810-109581-9), SJCH-10 Sink (810-109581-10), SJCH-11 WF (810-109581-11), SJCH-12 Sink (810-109581-12), SJCH-13 Sink (810-109581-13), SJCH-14 Sink (810-109581-14), SJCH-15 Sink (810-109581-15), SJCH-16 Sink (810-109581-16), SJCH-17 Sink (810-109581-17), SJCH-18 Sink (810-109581-18), SJCH-19 WF (810-109581-19), SJCH-20 WF (810-109581-20), SJCH-21 Sink (810-109581-21), SJCH-22 Sink (810-109581-22), SJCH-23 Sink (810-109581-23), SJCH-24 Sink (810-109581-24), SJCH-25 WF (810-109581-25), SJCH-26 WF (810-109581-26), SJCH-27 WF (810-109581-27), SJCH-28 WF (810-109581-28), SJCH-29 WF (810-109581-29), SJCH-30 WF (810-109581-30), SJCH-31 Sink (810-109581-31), SJCH-32 Sink (810-109581-32), SJCH-33 Sink (810-109581-33), SJCH-34 Sink (810-109581-34), SJCH-35 WF (810-109581-35), SJCH-36 ICE (810-109581-36), SJCH-37 Sink (810-109581-37), SJCH-38 WF (810-109581-38), SJCH-39 WF (810-109581-39), SJCH-40 WF (810-109581-40), SJCH-41 WF (810-109581-41), SJCH-42 WF (810-109581-42), SJCH-43 WF (810-109581-43), SJCH-45 WF (810-109581-44), SJCH-47 Sink (810-109581-45), SJCH-48 Sink (810-109581-46), SJCH-49 Sink (810-109581-47), SJCH-50 Sink (810-109581-48), SJCH-51 Sink (810-109581-49), SJCH-52 Sink (810-109581-50), SJCH-53 WF (810-109581-51), SJCH-54 Sink (810-109581-52), SJCH-55 Sink (810-109581-53), SJCH-56 Sink (810-109581-54), SJCH-57 Sink (810-109581-55), SJCH-60 Sink (810-109581-56), SJCH-61 WF (810-109581-57), SJCH-62 WF (810-109581-58), SJCH-63 WF (810-109581-59), SJCH-64 WF (810-109581-60), SJCH-65 Sink (810-109581-61), SJCH-66 Sink (810-109581-62), SJCH-68 Sink (810-109581-63), SJCH-69 Sink (810-109581-64), SJCH-70 Sink (810-109581-65), SJCH-71 Sink (810-109581-66), SJCH-72 Sink (810-109581-67), SJCH-73 Sink (810-109581-68), SJCH-74 Sink (810-109581-69), SJCH-75 Sink (810-109581-70), SJCH-76 Sink (810-109581-71), SJCH-77 WF (810-109581-72), SJCH-78 Sink (810-109581-73), SJCH-79 Sink (810-109581-74), SJCH-80 Sink (810-109581-75) and SJCH-81 Sink (FH Kitchen) (810-109581-76).
Bottles SJ CH- 44 WF, SJ CH-46 Sink, SJ CH-58 Sink, SJ CH-59 Sink, SJ CH-67 Sink

Metals

Method 200.8_SDWA: The continuing calibration verification (CCV) analyzed in 810-104716 was outside the method criteria of + 10 % but within + 15% for Lead. As indicated in the reference method, this continuing calibration verification (CCV) will be used as the closing CCV and previous samples will not be reanalyzed.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-1 Sink

Lab Sample ID: 810-109581-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.0		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCH-2 WF

Lab Sample ID: 810-109581-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-3 WF

Lab Sample ID: 810-109581-3

No Detections.									
----------------	--	--	--	--	--	--	--	--	--

Client Sample ID: SJCH-4 Sink

Lab Sample ID: 810-109581-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-5 Snk

Lab Sample ID: 810-109581-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-6 WF

Lab Sample ID: 810-109581-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-7 WF

Lab Sample ID: 810-109581-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.68		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-8 Sink

Lab Sample ID: 810-109581-8

No Detections.									
----------------	--	--	--	--	--	--	--	--	--

Client Sample ID: SJCH-9 Sink

Lab Sample ID: 810-109581-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-10 Sink

Lab Sample ID: 810-109581-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCH-11 WF

Lab Sample ID: 810-109581-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-12 Sink

Lab Sample ID: 810-109581-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	15		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-13 Sink

Lab Sample ID: 810-109581-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.3		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCH-14 Sink

Lab Sample ID: 810-109581-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-15 Sink

Lab Sample ID: 810-109581-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-16 Sink

Lab Sample ID: 810-109581-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-17 Sink

Lab Sample ID: 810-109581-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-18 Sink

Lab Sample ID: 810-109581-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.96		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-19 WF

Lab Sample ID: 810-109581-19

No Detections.

Client Sample ID: SJCH-20 WF

Lab Sample ID: 810-109581-20

No Detections.

Client Sample ID: SJCH-21 Sink

Lab Sample ID: 810-109581-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.9		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCH-22 Sink

Lab Sample ID: 810-109581-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.2		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCH-23 Sink

Lab Sample ID: 810-109581-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	100		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-24 Sink

Lab Sample ID: 810-109581-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-25 WF

Lab Sample ID: 810-109581-25

No Detections.

Client Sample ID: SJCH-26 WF

Lab Sample ID: 810-109581-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-27 WF

Lab Sample ID: 810-109581-27

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-28 WF

Lab Sample ID: 810-109581-28

No Detections.

Client Sample ID: SJCH-29 WF

Lab Sample ID: 810-109581-29

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.92		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-30 WF

Lab Sample ID: 810-109581-30

No Detections.

Client Sample ID: SJCH-31 Sink

Lab Sample ID: 810-109581-31

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	29		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-32 Sink

Lab Sample ID: 810-109581-32

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.60		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-33 Sink

Lab Sample ID: 810-109581-33

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	14		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCH-34 Sink

Lab Sample ID: 810-109581-34

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	8.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-35 WF

Lab Sample ID: 810-109581-35

No Detections.

Client Sample ID: SJCH-36 ICE

Lab Sample ID: 810-109581-36

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-37 Sink

Lab Sample ID: 810-109581-37

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.6	F1	0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-38 WF

Lab Sample ID: 810-109581-38

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.92		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-39 WF

Lab Sample ID: 810-109581-39

No Detections.

Client Sample ID: SJCH-40 WF

Lab Sample ID: 810-109581-40

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-41 WF

Lab Sample ID: 810-109581-41

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-42 WF

Lab Sample ID: 810-109581-42

No Detections.

Client Sample ID: SJCH-43 WF

Lab Sample ID: 810-109581-43

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.77		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-45 WF

Lab Sample ID: 810-109581-44

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-47 Sink

Lab Sample ID: 810-109581-45

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	16		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-48 Sink

Lab Sample ID: 810-109581-46

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	14		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-49 Sink

Lab Sample ID: 810-109581-47

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-50 Sink

Lab Sample ID: 810-109581-48

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	32		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCH-51 Sink

Lab Sample ID: 810-109581-49

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	15		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-52 Sink

Lab Sample ID: 810-109581-50

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	17		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-53 WF

Lab Sample ID: 810-109581-51

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-54 Sink

Lab Sample ID: 810-109581-52

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	66		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-55 Sink

Lab Sample ID: 810-109581-53

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	45		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-56 Sink

Lab Sample ID: 810-109581-54

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	21		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-57 Sink

Lab Sample ID: 810-109581-55

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	20		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-60 Sink

Lab Sample ID: 810-109581-56

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	98		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: SJCH-61 WF

Lab Sample ID: 810-109581-57

No Detections.

Client Sample ID: SJCH-62 WF

Lab Sample ID: 810-109581-58

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	64		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-63 WF

Lab Sample ID: 810-109581-59

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-64 WF

Lab Sample ID: 810-109581-60

No Detections.

Client Sample ID: SJCH-65 Sink

Lab Sample ID: 810-109581-61

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	85		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-66 Sink

Lab Sample ID: 810-109581-62

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-68 Sink

Lab Sample ID: 810-109581-63

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-69 Sink

Lab Sample ID: 810-109581-64

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-70 Sink

Lab Sample ID: 810-109581-65

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-71 Sink

Lab Sample ID: 810-109581-66

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	62		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-72 Sink

Lab Sample ID: 810-109581-67

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	19		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-73 Sink

Lab Sample ID: 810-109581-68

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-74 Sink

Lab Sample ID: 810-109581-69

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-75 Sink

Lab Sample ID: 810-109581-70

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	8.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-76 Sink

Lab Sample ID: 810-109581-71

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-77 WF

Lab Sample ID: 810-109581-72

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-78 Sink

Lab Sample ID: 810-109581-73

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-79 Sink

Lab Sample ID: 810-109581-74

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-80 Sink

Lab Sample ID: 810-109581-75

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	16		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: SJCH-81 Sink (FH Kitchen)

Lab Sample ID: 810-109581-76

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.75		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-1 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-1

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.0		0.50		ug/L		07/02/24 12:38	07/03/24 13:54	1

Client Sample ID: SJCH-2 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-2

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ug/L			07/02/24 23:13	1

Client Sample ID: SJCH-3 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-3

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 23:15	1

Client Sample ID: SJCH-4 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-4

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.5		0.50		ug/L			07/02/24 23:16	1

Client Sample ID: SJCH-5 Snk

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-5

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.4		0.50		ug/L			07/02/24 23:21	1

Client Sample ID: SJCH-6 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-6

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ug/L			07/02/24 23:23	1

Client Sample ID: SJCH-7 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-7

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.68		0.50		ug/L			07/02/24 23:25	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-8 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-8

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 23:26	1

Client Sample ID: SJCH-9 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-9

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		0.50		ug/L			07/02/24 23:28	1

Client Sample ID: SJCH-10 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-10

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L		07/02/24 12:38	07/03/24 13:56	1

Client Sample ID: SJCH-11 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-11

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L			07/02/24 23:33	1

Client Sample ID: SJCH-12 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-12

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15		0.50		ug/L			07/02/24 23:35	1

Client Sample ID: SJCH-13 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-13

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.3		0.50		ug/L		07/02/24 12:38	07/03/24 13:58	1

Client Sample ID: SJCH-14 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-14

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.8		0.50		ug/L			07/02/24 23:36	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-15 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-15

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		0.50		ug/L			07/02/24 23:38	1

Client Sample ID: SJCH-16 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-16

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9		0.50		ug/L			07/02/24 23:39	1

Client Sample ID: SJCH-17 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-17

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.0		0.50		ug/L			07/02/24 23:55	1

Client Sample ID: SJCH-18 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-18

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.96		0.50		ug/L			07/02/24 23:58	1

Client Sample ID: SJCH-19 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-19

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 00:01	1

Client Sample ID: SJCH-20 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-20

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 00:03	1

Client Sample ID: SJCH-21 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-21

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.9		0.50		ug/L		07/02/24 12:38	07/03/24 14:00	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-22 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-22

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.2		0.50		ug/L		07/02/24 12:38	07/03/24 14:02	1

Client Sample ID: SJCH-23 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-23

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	100		0.50		ug/L			07/03/24 00:06	1

Client Sample ID: SJCH-24 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-24

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50		ug/L			07/03/24 00:09	1

Client Sample ID: SJCH-25 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-25

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 00:12	1

Client Sample ID: SJCH-26 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-26

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3		0.50		ug/L			07/03/24 00:20	1

Client Sample ID: SJCH-27 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-27

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L			07/03/24 00:23	1

Client Sample ID: SJCH-28 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-28

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 00:27	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-29 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-29

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.92		0.50		ug/L			07/03/24 00:37	1

Client Sample ID: SJCH-30 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-30

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 00:40	1

Client Sample ID: SJCH-31 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-31

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	29		0.50		ug/L			07/08/24 13:44	1

Client Sample ID: SJCH-32 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-32

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.60		0.50		ug/L			07/03/24 00:46	1

Client Sample ID: SJCH-33 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-33

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	14		0.50		ug/L		07/02/24 12:38	07/03/24 14:04	1

Client Sample ID: SJCH-34 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-34

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.5		0.50		ug/L			07/03/24 00:49	1

Client Sample ID: SJCH-35 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-35

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 00:52	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-36 ICE

Lab Sample ID: 810-109581-36

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6		0.50		ug/L			07/03/24 00:54	1

Client Sample ID: SJCH-37 Sink

Lab Sample ID: 810-109581-37

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.6	F1	0.50		ug/L			07/03/24 00:57	1

Client Sample ID: SJCH-38 WF

Lab Sample ID: 810-109581-38

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.92		0.50		ug/L			07/03/24 01:06	1

Client Sample ID: SJCH-39 WF

Lab Sample ID: 810-109581-39

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 01:09	1

Client Sample ID: SJCH-40 WF

Lab Sample ID: 810-109581-40

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ug/L			07/03/24 11:14	1

Client Sample ID: SJCH-41 WF

Lab Sample ID: 810-109581-41

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4		0.50		ug/L			07/03/24 11:16	1

Client Sample ID: SJCH-42 WF

Lab Sample ID: 810-109581-42

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 11:17	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-43 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-43

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.77		0.50		ug/L			07/03/24 11:19	1

Client Sample ID: SJCH-45 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-44

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4		0.50		ug/L			07/03/24 11:20	1

Client Sample ID: SJCH-47 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-45

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16		0.50		ug/L			07/03/24 11:22	1

Client Sample ID: SJCH-48 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-46

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	14		0.50		ug/L			07/03/24 11:24	1

Client Sample ID: SJCH-49 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-47

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.4		0.50		ug/L			07/03/24 11:25	1

Client Sample ID: SJCH-50 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-48

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	32		0.50		ug/L		07/02/24 12:38	07/03/24 14:06	1

Client Sample ID: SJCH-51 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-49

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15		0.50		ug/L			07/03/24 11:27	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-52 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-50

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	17		0.50		ug/L			07/03/24 11:32	1

Client Sample ID: SJCH-53 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-51

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6		0.50		ug/L			07/03/24 15:55	1

Client Sample ID: SJCH-54 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-52

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	66		0.50		ug/L			07/03/24 15:57	1

Client Sample ID: SJCH-55 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-53

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	45		0.50		ug/L			07/03/24 16:00	1

Client Sample ID: SJCH-56 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-54

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	21		0.50		ug/L			07/03/24 16:03	1

Client Sample ID: SJCH-57 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-55

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	20		0.50		ug/L			07/03/24 16:06	1

Client Sample ID: SJCH-60 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-56

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	98		0.50		ug/L		07/02/24 12:38	07/03/24 14:08	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-61 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-57

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 16:09	1

Client Sample ID: SJCH-62 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-58

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	64		0.50		ug/L			07/03/24 16:12	1

Client Sample ID: SJCH-63 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-59

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9		0.50		ug/L			07/03/24 16:15	1

Client Sample ID: SJCH-64 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-60

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 16:18	1

Client Sample ID: SJCH-65 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-61

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	85		0.50		ug/L			07/03/24 16:20	1

Client Sample ID: SJCH-66 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-62

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.2		0.50		ug/L			07/03/24 09:57	1

Client Sample ID: SJCH-68 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-63

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.2		0.50		ug/L			07/03/24 09:59	1

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-69 Sink

Lab Sample ID: 810-109581-64

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			07/03/24 10:02	1

Client Sample ID: SJCH-70 Sink

Lab Sample ID: 810-109581-65

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.5		0.50		ug/L			07/03/24 10:05	1

Client Sample ID: SJCH-71 Sink

Lab Sample ID: 810-109581-66

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	62		0.50		ug/L			07/03/24 10:07	1

Client Sample ID: SJCH-72 Sink

Lab Sample ID: 810-109581-67

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	19		0.50		ug/L			07/03/24 10:10	1

Client Sample ID: SJCH-73 Sink

Lab Sample ID: 810-109581-68

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.2		0.50		ug/L			07/03/24 10:18	1

Client Sample ID: SJCH-74 Sink

Lab Sample ID: 810-109581-69

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50		ug/L			07/03/24 10:21	1

Client Sample ID: SJCH-75 Sink

Lab Sample ID: 810-109581-70

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.2		0.50		ug/L			07/03/24 10:24	1

Eurofins Eaton Analytical South Bend

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-76 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-71

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.9		0.50		ug/L			07/03/24 10:27	1

Client Sample ID: SJCH-77 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-72

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ug/L			07/03/24 10:35	1

Client Sample ID: SJCH-78 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-73

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ug/L			07/03/24 10:38	1

Client Sample ID: SJCH-79 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-74

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.8		0.50		ug/L			07/03/24 10:41	1

Client Sample ID: SJCH-80 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-75

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16		0.50		ug/L			07/03/24 10:44	1

Client Sample ID: SJCH-81 Sink (FH Kitchen)

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-76

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.75		0.50		ug/L			07/03/24 10:47	1

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-104700/101
Matrix: Drinking Water
Analysis Batch: 104700

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 22:55	1

Lab Sample ID: MB 810-104700/11
Matrix: Drinking Water
Analysis Batch: 104700

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 20:28	1

Lab Sample ID: LCS 810-104700/102
Matrix: Drinking Water
Analysis Batch: 104700

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	49.6		ug/L		99	85 - 115

Lab Sample ID: LLCS 810-104700/10
Matrix: Drinking Water
Analysis Batch: 104700

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.291	J	ug/L		97	50 - 150

Lab Sample ID: 810-109581-9 MS
Matrix: Drinking Water
Analysis Batch: 104700

Client Sample ID: SJCH-9 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	2.2		50.0	51.4		ug/L		98	70 - 130

Lab Sample ID: 810-109581-9 MSD
Matrix: Drinking Water
Analysis Batch: 104700

Client Sample ID: SJCH-9 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	2.2		50.0	52.9		ug/L		101	70 - 130	3	20

Lab Sample ID: MB 810-104716/11
Matrix: Drinking Water
Analysis Batch: 104716

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/02/24 23:47	1

Lab Sample ID: MB 810-104716/73
Matrix: Drinking Water
Analysis Batch: 104716

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 02:42	1

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: LCS 810-104716/13

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	47.8		ug/L		96	85 - 115

Lab Sample ID: LCS 810-104716/74

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	56.2		ug/L		112	85 - 115

Lab Sample ID: LLCS 810-104716/12

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.243	J	ug/L		81	50 - 150

Lab Sample ID: 810-109581-25 MS

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: SJCH-25 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	48.4		ug/L		96	70 - 130

Lab Sample ID: 810-109581-25 MSD

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: SJCH-25 WF

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	48.8		ug/L		97	70 - 130	1	20

Lab Sample ID: 810-109581-37 MS

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: SJCH-37 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	4.6	F1	50.0	68.0		ug/L		127	70 - 130

Lab Sample ID: 810-109581-37 MSD

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: SJCH-37 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	4.6	F1	50.0	59.6		ug/L		110	70 - 130	13	20

Lab Sample ID: 810-109581-67 MS

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: SJCH-72 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	12	*+ F1	50.0	75.6		ug/L		126	70 - 130

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-109581-67 MSD

Matrix: Drinking Water

Analysis Batch: 104716

Client Sample ID: SJCH-72 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	12	*+ F1	50.0	75.2		ug/L		125	70 - 130	1	20

Lab Sample ID: MB 810-104764/11

Matrix: Drinking Water

Analysis Batch: 104764

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 09:32	1

Lab Sample ID: MB 810-104764/71

Matrix: Drinking Water

Analysis Batch: 104764

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 11:11	1

Lab Sample ID: LCS 810-104764/72

Matrix: Drinking Water

Analysis Batch: 104764

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	50.3		ug/L		101	85 - 115

Lab Sample ID: LLCS 810-104764/10

Matrix: Drinking Water

Analysis Batch: 104764

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.298	J	ug/L		99	50 - 150

Lab Sample ID: 810-109581-49 MS

Matrix: Drinking Water

Analysis Batch: 104764

Client Sample ID: SJCH-51 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	15		50.0	71.3		ug/L		113	70 - 130

Lab Sample ID: 810-109581-49 MSD

Matrix: Drinking Water

Analysis Batch: 104764

Client Sample ID: SJCH-51 Sink

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	15		50.0	72.9		ug/L		116	70 - 130	2	20

Lab Sample ID: MB 810-104829/11

Matrix: Drinking Water

Analysis Batch: 104829

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 09:51	1

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-104829/138
Matrix: Drinking Water
Analysis Batch: 104829

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/03/24 15:49	1

Lab Sample ID: LCS 810-104829/12
Matrix: Drinking Water
Analysis Batch: 104829

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	48.1		ug/L		96	85 - 115

Lab Sample ID: LCS 810-104829/139
Matrix: Drinking Water
Analysis Batch: 104829

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	47.1		ug/L		94	85 - 115

Lab Sample ID: LLCS 810-104829/10
Matrix: Drinking Water
Analysis Batch: 104829

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.306	J	ug/L		102	50 - 150

Lab Sample ID: 810-109581-61 MS
Matrix: Drinking Water
Analysis Batch: 104829

Client Sample ID: SJCH-65 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	85		50.0	130		ug/L		90	70 - 130

Lab Sample ID: 810-109581-61 MSD
Matrix: Drinking Water
Analysis Batch: 104829

Client Sample ID: SJCH-65 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	85		50.0	129		ug/L		88	70 - 130	1	20

Lab Sample ID: 810-109581-67 MS
Matrix: Drinking Water
Analysis Batch: 104829

Client Sample ID: SJCH-72 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	19		50.0	66.2		ug/L		94	70 - 130

Lab Sample ID: 810-109581-67 MSD
Matrix: Drinking Water
Analysis Batch: 104829

Client Sample ID: SJCH-72 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	19		50.0	65.7		ug/L		93	70 - 130	1	20

Eurofins Eaton Analytical South Bend

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-104986/12

Matrix: Drinking Water

Analysis Batch: 104986

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			07/08/24 13:38	1

Lab Sample ID: LCS 810-104986/13

Matrix: Drinking Water

Analysis Batch: 104986

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	48.8		ug/L		98	85 - 115

Lab Sample ID: LLCS 810-104986/11

Matrix: Drinking Water

Analysis Batch: 104986

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.296	J	ug/L		99	50 - 150

Lab Sample ID: MB 810-104650/1-A

Matrix: Drinking Water

Analysis Batch: 104792

Client Sample ID: Method Blank

Prep Type: Total Recoverable

Prep Batch: 104650

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L		07/02/24 12:38	07/03/24 13:10	1

Lab Sample ID: LCS 810-104650/3-A

Matrix: Drinking Water

Analysis Batch: 104792

Client Sample ID: Lab Control Sample

Prep Type: Total Recoverable

Prep Batch: 104650

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	53.2		ug/L		106	85 - 115

Lab Sample ID: LLCS 810-104650/2-A

Matrix: Drinking Water

Analysis Batch: 104792

Client Sample ID: Lab Control Sample

Prep Type: Total Recoverable

Prep Batch: 104650

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.275	J	ug/L		92	50 - 150

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Metals

Prep Batch: 104650

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109581-1	SJCH-1 Sink	Total Recoverable	Drinking Water	200.8	
810-109581-10	SJCH-10 Sink	Total Recoverable	Drinking Water	200.8	
810-109581-13	SJCH-13 Sink	Total Recoverable	Drinking Water	200.8	
810-109581-21	SJCH-21 Sink	Total Recoverable	Drinking Water	200.8	
810-109581-22	SJCH-22 Sink	Total Recoverable	Drinking Water	200.8	
810-109581-33	SJCH-33 Sink	Total Recoverable	Drinking Water	200.8	
810-109581-48	SJCH-50 Sink	Total Recoverable	Drinking Water	200.8	
810-109581-56	SJCH-60 Sink	Total Recoverable	Drinking Water	200.8	
MB 810-104650/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	
LCS 810-104650/3-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	
LLCS 810-104650/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	

Analysis Batch: 104700

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109581-2	SJCH-2 WF	Total/NA	Drinking Water	200.8	
810-109581-3	SJCH-3 WF	Total/NA	Drinking Water	200.8	
810-109581-4	SJCH-4 Sink	Total/NA	Drinking Water	200.8	
810-109581-5	SJCH-5 Snk	Total/NA	Drinking Water	200.8	
810-109581-6	SJCH-6 WF	Total/NA	Drinking Water	200.8	
810-109581-7	SJCH-7 WF	Total/NA	Drinking Water	200.8	
810-109581-8	SJCH-8 Sink	Total/NA	Drinking Water	200.8	
810-109581-9	SJCH-9 Sink	Total/NA	Drinking Water	200.8	
810-109581-11	SJCH-11 WF	Total/NA	Drinking Water	200.8	
810-109581-12	SJCH-12 Sink	Total/NA	Drinking Water	200.8	
810-109581-14	SJCH-14 Sink	Total/NA	Drinking Water	200.8	
810-109581-15	SJCH-15 Sink	Total/NA	Drinking Water	200.8	
810-109581-16	SJCH-16 Sink	Total/NA	Drinking Water	200.8	
MB 810-104700/101	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104700/11	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-104700/102	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-104700/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-109581-9 MS	SJCH-9 Sink	Total/NA	Drinking Water	200.8	
810-109581-9 MSD	SJCH-9 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 104716

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109581-17	SJCH-17 Sink	Total/NA	Drinking Water	200.8	
810-109581-18	SJCH-18 Sink	Total/NA	Drinking Water	200.8	
810-109581-19	SJCH-19 WF	Total/NA	Drinking Water	200.8	
810-109581-20	SJCH-20 WF	Total/NA	Drinking Water	200.8	
810-109581-23	SJCH-23 Sink	Total/NA	Drinking Water	200.8	
810-109581-24	SJCH-24 Sink	Total/NA	Drinking Water	200.8	
810-109581-25	SJCH-25 WF	Total/NA	Drinking Water	200.8	
810-109581-26	SJCH-26 WF	Total/NA	Drinking Water	200.8	
810-109581-27	SJCH-27 WF	Total/NA	Drinking Water	200.8	
810-109581-28	SJCH-28 WF	Total/NA	Drinking Water	200.8	
810-109581-29	SJCH-29 WF	Total/NA	Drinking Water	200.8	
810-109581-30	SJCH-30 WF	Total/NA	Drinking Water	200.8	
810-109581-32	SJCH-32 Sink	Total/NA	Drinking Water	200.8	
810-109581-34	SJCH-34 Sink	Total/NA	Drinking Water	200.8	
810-109581-35	SJCH-35 WF	Total/NA	Drinking Water	200.8	

Eurofins Eaton Analytical South Bend

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Metals (Continued)

Analysis Batch: 104716 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109581-36	SJCH-36 ICE	Total/NA	Drinking Water	200.8	
810-109581-37	SJCH-37 Sink	Total/NA	Drinking Water	200.8	
810-109581-38	SJCH-38 WF	Total/NA	Drinking Water	200.8	
810-109581-39	SJCH-39 WF	Total/NA	Drinking Water	200.8	
MB 810-104716/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104716/73	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-104716/13	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-104716/74	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-104716/12	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-109581-25 MS	SJCH-25 WF	Total/NA	Drinking Water	200.8	
810-109581-25 MSD	SJCH-25 WF	Total/NA	Drinking Water	200.8	
810-109581-37 MS	SJCH-37 Sink	Total/NA	Drinking Water	200.8	
810-109581-37 MSD	SJCH-37 Sink	Total/NA	Drinking Water	200.8	
810-109581-67 MS	SJCH-72 Sink	Total/NA	Drinking Water	200.8	
810-109581-67 MSD	SJCH-72 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 104764

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109581-40	SJCH-40 WF	Total/NA	Drinking Water	200.8	
810-109581-41	SJCH-41 WF	Total/NA	Drinking Water	200.8	
810-109581-42	SJCH-42 WF	Total/NA	Drinking Water	200.8	
810-109581-43	SJCH-43 WF	Total/NA	Drinking Water	200.8	
810-109581-44	SJCH-45 WF	Total/NA	Drinking Water	200.8	
810-109581-45	SJCH-47 Sink	Total/NA	Drinking Water	200.8	
810-109581-46	SJCH-48 Sink	Total/NA	Drinking Water	200.8	
810-109581-47	SJCH-49 Sink	Total/NA	Drinking Water	200.8	
810-109581-49	SJCH-51 Sink	Total/NA	Drinking Water	200.8	
810-109581-50	SJCH-52 Sink	Total/NA	Drinking Water	200.8	
MB 810-104764/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104764/71	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-104764/72	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-104764/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-109581-49 MS	SJCH-51 Sink	Total/NA	Drinking Water	200.8	
810-109581-49 MSD	SJCH-51 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 104792

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109581-1	SJCH-1 Sink	Total Recoverable	Drinking Water	200.8	104650
810-109581-10	SJCH-10 Sink	Total Recoverable	Drinking Water	200.8	104650
810-109581-13	SJCH-13 Sink	Total Recoverable	Drinking Water	200.8	104650
810-109581-21	SJCH-21 Sink	Total Recoverable	Drinking Water	200.8	104650
810-109581-22	SJCH-22 Sink	Total Recoverable	Drinking Water	200.8	104650
810-109581-33	SJCH-33 Sink	Total Recoverable	Drinking Water	200.8	104650
810-109581-48	SJCH-50 Sink	Total Recoverable	Drinking Water	200.8	104650
810-109581-56	SJCH-60 Sink	Total Recoverable	Drinking Water	200.8	104650
MB 810-104650/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	104650
LCS 810-104650/3-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	104650
LLCS 810-104650/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	104650

Eurofins Eaton Analytical South Bend

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Metals

Analysis Batch: 104829

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109581-51	SJCH-53 WF	Total/NA	Drinking Water	200.8	
810-109581-52	SJCH-54 Sink	Total/NA	Drinking Water	200.8	
810-109581-53	SJCH-55 Sink	Total/NA	Drinking Water	200.8	
810-109581-54	SJCH-56 Sink	Total/NA	Drinking Water	200.8	
810-109581-55	SJCH-57 Sink	Total/NA	Drinking Water	200.8	
810-109581-57	SJCH-61 WF	Total/NA	Drinking Water	200.8	
810-109581-58	SJCH-62 WF	Total/NA	Drinking Water	200.8	
810-109581-59	SJCH-63 WF	Total/NA	Drinking Water	200.8	
810-109581-60	SJCH-64 WF	Total/NA	Drinking Water	200.8	
810-109581-61	SJCH-65 Sink	Total/NA	Drinking Water	200.8	
810-109581-62	SJCH-66 Sink	Total/NA	Drinking Water	200.8	
810-109581-63	SJCH-68 Sink	Total/NA	Drinking Water	200.8	
810-109581-64	SJCH-69 Sink	Total/NA	Drinking Water	200.8	
810-109581-65	SJCH-70 Sink	Total/NA	Drinking Water	200.8	
810-109581-66	SJCH-71 Sink	Total/NA	Drinking Water	200.8	
810-109581-67	SJCH-72 Sink	Total/NA	Drinking Water	200.8	
810-109581-68	SJCH-73 Sink	Total/NA	Drinking Water	200.8	
810-109581-69	SJCH-74 Sink	Total/NA	Drinking Water	200.8	
810-109581-70	SJCH-75 Sink	Total/NA	Drinking Water	200.8	
810-109581-71	SJCH-76 Sink	Total/NA	Drinking Water	200.8	
810-109581-72	SJCH-77 WF	Total/NA	Drinking Water	200.8	
810-109581-73	SJCH-78 Sink	Total/NA	Drinking Water	200.8	
810-109581-74	SJCH-79 Sink	Total/NA	Drinking Water	200.8	
810-109581-75	SJCH-80 Sink	Total/NA	Drinking Water	200.8	
810-109581-76	SJCH-81 Sink (FH Kitchen)	Total/NA	Drinking Water	200.8	
MB 810-104829/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-104829/138	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-104829/12	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-104829/139	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-104829/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-109581-61 MS	SJCH-65 Sink	Total/NA	Drinking Water	200.8	
810-109581-61 MSD	SJCH-65 Sink	Total/NA	Drinking Water	200.8	
810-109581-67 MS	SJCH-72 Sink	Total/NA	Drinking Water	200.8	
810-109581-67 MSD	SJCH-72 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 104986

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-109581-31	SJCH-31 Sink	Total/NA	Drinking Water	200.8	
MB 810-104986/12	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-104986/13	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-104986/11	Lab Control Sample	Total/NA	Drinking Water	200.8	

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-1 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-1

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 13:54

Client Sample ID: SJCH-2 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-2

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:13

Client Sample ID: SJCH-3 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-3

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:15

Client Sample ID: SJCH-4 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-4

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:16

Client Sample ID: SJCH-5 Snk

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-5

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:21

Client Sample ID: SJCH-6 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-6

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:23

Client Sample ID: SJCH-7 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-7

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:25

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-8 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-8

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:26

Client Sample ID: SJCH-9 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-9

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:28

Client Sample ID: SJCH-10 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-10

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 13:56

Client Sample ID: SJCH-11 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-11

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:33

Client Sample ID: SJCH-12 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-12

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:35

Client Sample ID: SJCH-13 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-13

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 13:58

Client Sample ID: SJCH-14 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-14

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:36

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-15 Sink

Lab Sample ID: 810-109581-15

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:38

Client Sample ID: SJCH-16 Sink

Lab Sample ID: 810-109581-16

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104700	NB	EA SB	07/02/24 23:39

Client Sample ID: SJCH-17 Sink

Lab Sample ID: 810-109581-17

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/02/24 23:55

Client Sample ID: SJCH-18 Sink

Lab Sample ID: 810-109581-18

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/02/24 23:58

Client Sample ID: SJCH-19 WF

Lab Sample ID: 810-109581-19

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:01

Client Sample ID: SJCH-20 WF

Lab Sample ID: 810-109581-20

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:03

Client Sample ID: SJCH-21 Sink

Lab Sample ID: 810-109581-21

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 14:00

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-22 Sink

Lab Sample ID: 810-109581-22

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 14:02

Client Sample ID: SJCH-23 Sink

Lab Sample ID: 810-109581-23

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:06

Client Sample ID: SJCH-24 Sink

Lab Sample ID: 810-109581-24

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:09

Client Sample ID: SJCH-25 WF

Lab Sample ID: 810-109581-25

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:12

Client Sample ID: SJCH-26 WF

Lab Sample ID: 810-109581-26

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:20

Client Sample ID: SJCH-27 WF

Lab Sample ID: 810-109581-27

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:23

Client Sample ID: SJCH-28 WF

Lab Sample ID: 810-109581-28

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:27

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-29 WF

Lab Sample ID: 810-109581-29

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:37

Client Sample ID: SJCH-30 WF

Lab Sample ID: 810-109581-30

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:40

Client Sample ID: SJCH-31 Sink

Lab Sample ID: 810-109581-31

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104986	CA	EA SB	07/08/24 13:44

Client Sample ID: SJCH-32 Sink

Lab Sample ID: 810-109581-32

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:46

Client Sample ID: SJCH-33 Sink

Lab Sample ID: 810-109581-33

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 14:04

Client Sample ID: SJCH-34 Sink

Lab Sample ID: 810-109581-34

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:49

Client Sample ID: SJCH-35 WF

Lab Sample ID: 810-109581-35

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:52

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-36 ICE

Lab Sample ID: 810-109581-36

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:54

Client Sample ID: SJCH-37 Sink

Lab Sample ID: 810-109581-37

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 00:57

Client Sample ID: SJCH-38 WF

Lab Sample ID: 810-109581-38

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 01:06

Client Sample ID: SJCH-39 WF

Lab Sample ID: 810-109581-39

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104716	CA	EA SB	07/03/24 01:09

Client Sample ID: SJCH-40 WF

Lab Sample ID: 810-109581-40

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:14

Client Sample ID: SJCH-41 WF

Lab Sample ID: 810-109581-41

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:16

Client Sample ID: SJCH-42 WF

Lab Sample ID: 810-109581-42

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:17

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-43 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-43

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:19

Client Sample ID: SJCH-45 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-44

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:20

Client Sample ID: SJCH-47 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-45

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:22

Client Sample ID: SJCH-48 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-46

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:24

Client Sample ID: SJCH-49 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-47

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:25

Client Sample ID: SJCH-50 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-48

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 14:06

Client Sample ID: SJCH-51 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-49

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:27

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-52 Sink

Lab Sample ID: 810-109581-50

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104764	CA	EA SB	07/03/24 11:32

Client Sample ID: SJCH-53 WF

Lab Sample ID: 810-109581-51

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 15:55

Client Sample ID: SJCH-54 Sink

Lab Sample ID: 810-109581-52

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 15:57

Client Sample ID: SJCH-55 Sink

Lab Sample ID: 810-109581-53

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 16:00

Client Sample ID: SJCH-56 Sink

Lab Sample ID: 810-109581-54

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 16:03

Client Sample ID: SJCH-57 Sink

Lab Sample ID: 810-109581-55

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 16:06

Client Sample ID: SJCH-60 Sink

Lab Sample ID: 810-109581-56

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			104650	NB	EA SB	07/02/24 12:38
Total Recoverable	Analysis	200.8		1	104792	NB	EA SB	07/03/24 14:08

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-61 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-57

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 16:09

Client Sample ID: SJCH-62 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-58

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 16:12

Client Sample ID: SJCH-63 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-59

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 16:15

Client Sample ID: SJCH-64 WF

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-60

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 16:18

Client Sample ID: SJCH-65 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-61

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 16:20

Client Sample ID: SJCH-66 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-62

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 09:57

Client Sample ID: SJCH-68 Sink

Date Collected: 06/25/24 08:00

Date Received: 06/26/24 09:45

Lab Sample ID: 810-109581-63

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 09:59

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-69 Sink

Lab Sample ID: 810-109581-64

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:02

Client Sample ID: SJCH-70 Sink

Lab Sample ID: 810-109581-65

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:05

Client Sample ID: SJCH-71 Sink

Lab Sample ID: 810-109581-66

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:07

Client Sample ID: SJCH-72 Sink

Lab Sample ID: 810-109581-67

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:10

Client Sample ID: SJCH-73 Sink

Lab Sample ID: 810-109581-68

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:18

Client Sample ID: SJCH-74 Sink

Lab Sample ID: 810-109581-69

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:21

Client Sample ID: SJCH-75 Sink

Lab Sample ID: 810-109581-70

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:24

Eurofins Eaton Analytical South Bend

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Client Sample ID: SJCH-76 Sink

Lab Sample ID: 810-109581-71

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:27

Client Sample ID: SJCH-77 WF

Lab Sample ID: 810-109581-72

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:35

Client Sample ID: SJCH-78 Sink

Lab Sample ID: 810-109581-73

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:38

Client Sample ID: SJCH-79 Sink

Lab Sample ID: 810-109581-74

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:41

Client Sample ID: SJCH-80 Sink

Lab Sample ID: 810-109581-75

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:44

Client Sample ID: SJCH-81 Sink (FH Kitchen)

Lab Sample ID: 810-109581-76

Date Collected: 06/25/24 08:00

Matrix: Drinking Water

Date Received: 06/26/24 09:45

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	104829	NB	EA SB	07/03/24 10:47

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Accreditation/Certification Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24

1
2
3
4
5
6
7
8
9
10
11
12
13
14

Method Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB
200.8	Preparation, Total Recoverable Metals	EPA	EA SB

Protocol References:
EPA = US Environmental Protection Agency

Laboratory References:
EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Sample Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-109581-1	SJCH-1 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-2	SJCH-2 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-3	SJCH-3 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-4	SJCH-4 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-5	SJCH-5 Snk	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-6	SJCH-6 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-7	SJCH-7 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-8	SJCH-8 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-9	SJCH-9 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-10	SJCH-10 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-11	SJCH-11 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-12	SJCH-12 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-13	SJCH-13 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-14	SJCH-14 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-15	SJCH-15 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-16	SJCH-16 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-17	SJCH-17 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-18	SJCH-18 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-19	SJCH-19 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-20	SJCH-20 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-21	SJCH-21 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-22	SJCH-22 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-23	SJCH-23 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-24	SJCH-24 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-25	SJCH-25 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-26	SJCH-26 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-27	SJCH-27 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-28	SJCH-28 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-29	SJCH-29 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-30	SJCH-30 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-31	SJCH-31 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-32	SJCH-32 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-33	SJCH-33 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-34	SJCH-34 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-35	SJCH-35 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-36	SJCH-36 ICE	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-37	SJCH-37 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-38	SJCH-38 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-39	SJCH-39 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-40	SJCH-40 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-41	SJCH-41 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-42	SJCH-42 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-43	SJCH-43 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-44	SJCH-45 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-45	SJCH-47 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-46	SJCH-48 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-47	SJCH-49 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-48	SJCH-50 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-49	SJCH-51 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-50	SJCH-52 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-51	SJCH-53 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-52	SJCH-54 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-53	SJCH-55 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-54	SJCH-56 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45

Sample Summary

Client: St. John Environmental Consulting
Project/Site: St. Joseph School District - Central High School

Job ID: 810-109581-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-109581-55	SJCH-57 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-56	SJCH-60 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-57	SJCH-61 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-58	SJCH-62 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-59	SJCH-63 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-60	SJCH-64 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-61	SJCH-65 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-62	SJCH-66 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-63	SJCH-68 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-64	SJCH-69 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-65	SJCH-70 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-66	SJCH-71 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-67	SJCH-72 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-68	SJCH-73 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-69	SJCH-74 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-70	SJCH-75 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-71	SJCH-76 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-72	SJCH-77 WF	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-73	SJCH-78 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-74	SJCH-79 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-75	SJCH-80 Sink	Drinking Water	06/25/24 08:00	06/26/24 09:45
810-109581-76	SJCH-81 Sink (FH Kitchen)	Drinking Water	06/25/24 08:00	06/26/24 09:45

Chain of Custody Record

1st Draw

Client Information		Sampler: Ian St. John		Lab PM:		Carrier Tracking No(s):		COC No:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page 1 of 8	
Company: St. Joseph School District		PMSID:		Analysis Requested		Job #:		168	
Address: 1415 North 26th Street		Due Date Requested:		TAT Requested (days): Standard		Preservation Codes:		A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - H2SO4 G - TSP Dodecahydrate H - Acetone I - MCAA J - pH 4-5 K - Trizma L - other (specify)	
City: St. Joseph		Compliance Project: ☐ Yes ☐ No		PO #:		Barcode: 810-109581 Chain of Custody			
State, Zip: Missouri 64506		WO #:		Project #:		Field Filtered Sample (Yes or No)			
Phone: 816-671-4000		SSOW#:		Sample Date		Sample Type (C=Comp, G=Grab)		Matrix (W=Water, S=sediment, O=Overstool, BR=Blank, A=Air)	
Email: CaseyHousman@sjisd.k12.mo.us		Project #:		Sample Time		Field Filtered Sample (Yes or No)		Total Number	
Project Name: St. Joseph School District		Project #:		Preservation Code:		Field Filtered Sample (Yes or No)		Special Instructions/Note:	
Site: Central High School		Project #:		Preservation Code:		Field Filtered Sample (Yes or No)		(* Are samples that were rec'd empty * Kuo 6/30/24	
Sample Identification		Sample Date		Sample Type (C=Comp, G=Grab)		Matrix (W=Water, S=sediment, O=Overstool, BR=Blank, A=Air)		Total Number	
STCH-1 Sink		6/25/24 0830		G		W		1	
STCH-2 W/F									
STCH-3 W/F									
STCH-4 Sink									
STCH-5 Sink									
STCH-6 W/F									
STCH-7 W/F									
STCH-8 Sink									
STCH-9 Sink									
STCH-10 Sink									
STCH-11 W/F									
Possible Hazard Identification		Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological ☐		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		Return To Client ☐ Disposal By Lab ☒ Archive For ☐ Months			
Deliverable Requested: I, II, III, IV, Other (specify)		Special Instructions/QC Requirements:		Method of Shipment:					
Empty Kit Relinquished by:		Date:		Time:		Received by:		Date/Time:	
Relinquished by: [Signature]		April 14, 2024				[Signature]		6/26/24 9:54 AM	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: ☐ Yes ☐ No		Custody Seal No.:		Colder Temperature(s) °C and Other Remarks: Ambient					

Eurofins Eaton Analytical: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Client Information		Sampler: Ian St. John		Lab PM:		Carrier Tracking No(s):		COC No:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page: 2 of 8	
Company: St. Joseph School District		Due Date Requested:		Analysis Requested					
Address: 1415 North 26th Street		TAT Requested (days): Standard							
City: St. Joseph		Compliance Project: Δ Yes Δ No							
State, Zip: Missouri 64506		PO #:							
Phone: 816-671-4000		WO #:							
Email: CaseyHousman@sjisd.k12.mo.us		Project #:							
Project Name: St. Joseph School District		SSOW#:							
Site: Central High School		Sample Date		Sample Time		Sample Type (C=Comp, G=Grab)		Matrix (W=Water, S=Soil, O=Overstool, SR=Trims, AW=)	
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=Grab)		Matrix (W=Water, S=Soil, O=Overstool, SR=Trims, AW=)	
STCH-12 Sink		6/25/24		0800		G		W	
STCH-13 Sink									
STCH-14 Sink									
STCH-15 Sink									
STCH-16 Sink									
STCH-17 Sink									
STCH-18 Sink									
STCH-19 WF									
STCH-20 WF									
STCH-21 Sink									
STCH-22 Sink									
Possible Hazard Identification									
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological									
Deliverable Requested: I, II, III, IV, Other (Specify)									
Empty Kit Relinquished by:		Date:		Time:					
Relinquished by: [Signature]		Date/Time: 6/25/24		Company:					
Relinquished by:		Date/Time:		Company:					
Relinquished by:		Date/Time:		Company:					
Custody Seals Intact: Δ Yes Δ No		Custody Seal No.:							
Custody Seals Intact: Δ Yes Δ No		Custody Seal No.:							
Special Instructions/Note: Pb in Drinking Water									
Total Number of containers									
Preservation Codes:									
A - HCL									
B - NaOH									
C - Zn Acetate									
D - Nitric Acid									
E - HNO3									
F - MeOH									
G - Acetone									
H - Ascorbic Acid									
I - DI Water									
J - EDTA									
K - EDTA									
L - EDTA									
M - Hexane									
N - None									
O - AsH2O2									
P - Na2OAS									
Q - Na2SO3									
R - Na2SO3									
S - H2SO4									
T - TSP Dodecylhydrate									
U - Acetone									
V - MeOH									
W - PH 4-5									
Y - Trims									
Z - other (specify)									
Other:									
Special Instructions/Note:									
Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)									
☐ Return To Client ☒ Disposal By Lab ☐ Archive For Months									
Special Instructions/QC Requirements:									
Method of Shipment:									
Received by:		Date/Time: 6/25/24		Company: EEA					
Received by:		Date/Time:		Company:					
Received by:		Date/Time:		Company:					
Cooler Temperature(s) °C and Other Remarks: Ambient									

Chain of Custody Record

Client Information		Sampler: Ian St. John		Lab PM:		Carrier Tracking No(s):		COC No:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page: 3 of 8	
Company: St. Joseph School District		PWSID:		Analysis Requested		Job #:			
Address: 1415 North 26th Street		Due Date Requested:							
City: St. Joseph		TAT Requested (days): Standard							
State, ZIP: Missouri 64506		Compliance Project: ☐ Yes ☒ No							
Phone: 816-674-4000		WO #:							
Email: CaseyHousman@sjisd.k12.mo.us		Project #:							
Project Name: St. Joseph School District		SSOM#:							
Site: Central High									
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=Grab)		Matrix (Mercuric, Sealed, Overhead, BT=Therm, A=Air)	
STCH-23 Sink		6/25/24		0850		G		W	
STCH-24 Sink									
STCH-25 WF									
STCH-26 WF									
STCH-27 WF									
STCH-28 WF									
STCH-29 WF									
STCH-30 WF									
STCH-31 Sink									
STCH-32 Sink									
STCH-33 Sink									
Possible Hazard Identification		☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological							
Deliverable Requested: I, II, III, IV, Other (specify)									
Empty Kit Relinquished by:		Date:		Time:					
Relinquished by: <i>[Signature]</i>		Date/Time: April 14, 2024		Company:		Received by: <i>[Signature]</i>		Date/Time: 4/26/24 0455am	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: ☒ Yes ☐ No		Custody Seal No.:				Cooler Temperature(s) °C and Other Remarks: Ambient		Company:	

- Preservation Codes:
- A - HCL
 - B - NaOH
 - C - Zn Acetate
 - D - Nitric Acid
 - E - Nitric Acid
 - F - MeOH
 - G - Ammonia
 - H - Ascorbic Acid
 - I - Ice
 - J - DI Water
 - K - EDTA
 - L - EDA
 - M - Hexane
 - N - None
 - O - AsHClO2
 - P - Na2OAS
 - R - Na2S2O3
 - S - H2SO4
 - T - TSP Dodecylhydrate
 - U - Acetone
 - V - MCAA
 - W - pH 4-5
 - X - Trizma
 - Z - other (specify)

Special Instructions/Note:

PO in Drinking Water

Eurofins Eaton Analytical: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Client Information		Sampler: Ian St. John		Lab P.M.		Carrier Tracking No(s):		COC No:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenv.com		State of Origin: MO		Page: 4 of 8	
Company: St. Joseph School District		Due Date Requested:		Analysis Requested		Job #:			
Address: 1415 North 26th Street		TAT Requested (days): Standard							
City: St. Joseph		Compliance Project: ☐ Yes ☒ No							
State, Zip: Missouri 64506		PO #:							
Phone: 816-671-4000		WO #:							
Email: CaseyHousman@sjsd.k12.mo.us		Project #:							
Project Name: St. Joseph School District		SSOW#:							
Site: Central High									
Sample Identification		Sample Date		Sample Type (C=comp, G=grab)		Matrix (M=metal, S=solid, L=liquid, A=air)		Field Filtered Sample (Yes or No)	
ST CH-34 Sink		6/15/24 0800		G		W		Perform MS/MSD (Yes or No)	
ST CH-35 WFE								PB in Drinking Water	
ST CH-36 Ice									
ST CH-37 Sink									
ST CH-38 WFE									
ST CH-39 WFE									
ST CH-40 WFE									
ST CH-41 WFE									
ST CH-42 WFE									
ST CH-43 WFE									
ST CH-44 WFE									
Possible Hazard Identification									
☐ Non-hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological									
Deliverable Requested: I, II, III, IV, Other (specify)									
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:			
Relinquished by: [Signature]		Date/Time: 6/14/2024							
Relinquished by: [Signature]		Date/Time:							
Relinquished by:		Date/Time:							
Custody Seals Intact: ☒ Yes ☐ No		Custody Seal No.:							
Cooler Temperature(s) °C and Other Remarks: Ambient									
Special Instructions/Note:									
Total Number of containers									
Preservation Codes:									
A - HCl									
B - NaOH									
C - Zn Acetate									
D - Nitric Acid									
E - NaHSO4									
F - NaOH									
G - Ammonia									
H - Ascorbic Acid									
I - Isc									
J - DI Water									
K - EDTA									
L - EDA									
M - Hexane									
N - None									
O - AsH2O2									
P - Na2OAS									
Q - Na2SO3									
R - Na2CO3									
S - H2SO4									
T - TSP Dodecahydrate									
U - Acetone									
V - MCA									
W - pH 4-5									
Y - Tizma									
Z - other (specify)									
Other:									

110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Client Information		Sampler: Ian St. John		Lab P.M.		Carrier Tracking No(s):		COCC No:	
Client Contact: Casey Housman		Phone: 314-853-4668		E-Mail: ian@stjohnenvy.com		State of Origin: MO		Page: 6 of 8	
Company: St. Joseph School District		PMSID:		Analysis Requested		Total Number of containers		Special Instructions/Note:	
Address: 1415 North 26th Street		Due Date Requested:		Filtered Sample (Yes or No)		MS/MSD (Yes or No)		Preservation Codes:	
City: St. Joseph		TAT Requested (days): Standard						A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - HNO3 F - MeOH G - Anhydrous H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDTA M - Hexane N - None O - Ascorbic P - Na2OAS Q - Na2S2O3 R - Na2S2O5 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - PH 4-5 Y - Trizma Z - other (specify)	
State, Zip: Missouri 64506		PO #:							
Email: 816-671-4000		WO #:							
Project Name: CaseyHousman@sjisd.k12.mo.us		Project #:							
Site: Central High		SSOW#:							
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=Water, S=solid, O=Other)	
ST CH-56 Sink		6/25/24		0800		G		W	
ST CH-57 Sink									
ST CH-58 Sink									
ST CH-59 Sink									
ST CH-60 Sink									
ST CH-61 W/F									
ST CH-62 W/F									
ST CH-63 W/F									
ST CH-64 W/F									
ST CH-65 Sink									
ST CH-66 Sink									
Possible Hazard Identification									
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological									
Deliverable Requested: I, II, III, IV, Other (specify)									
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment:			
Relinquished by: <i>[Signature]</i>		Date/Time: June 14, 2024		Company: Casey Housman		Received by: <i>[Signature]</i>		Date/Time: 6/26/24	
Relinquished by: <i>[Signature]</i>		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: ☒ Yes ☐ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: Δ White					

Eurofins Eaton Analytical: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Client Information		Sampler: Ian St. John		Lab Pk: _____		Carrier Tracking No(s): _____		COC No: _____			
Client Contact: Casey Housman		Phone: 314-853-4668		Email: ian@stjohnenv.com		State of Origin: MO		Page: 7 of 8			
Company: St. Joseph School District		Due Date Requested: _____		PWSID: _____		Analysis Requested		Job #:			
Address: 1415 North 26th Street		TAT Requested (days): Standard		Compliance Project: ☐ Yes ☐ No		Field Filtered Sample (Yes or No)		Preservation Codes:			
City: St. Joseph		BO #: _____		WO #: _____		Project #:		A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - HNO3 G - Amelcor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other: _____			
State, Zip: Missouri 64506		Project Name: CaseyHousman@sjsd.k12.mo.us		SSOW #: _____		Sample Identification		M - Hexane N - None O - Asht02 P - Na2O4S Q - Na2SO3 R - Na2SO3 S - H2SO4 T - TSP Dodecahydrate U - Asstone V - MCAA W - pH 4-5 Y - Triene Z - other (specify)			
Phone: 616-671-4000		Site: CENTRAL High		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (Water, Sealed, Overstated, Br-Tissue, AWA)	
Email: CaseyHousman@sjsd.k12.mo.us		Project #:		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (Water, Sealed, Overstated, Br-Tissue, AWA)	
Project Name: St. Joseph School District		SSOW #:		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (Water, Sealed, Overstated, Br-Tissue, AWA)	
Site: CENTRAL High		SSOW #:		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (Water, Sealed, Overstated, Br-Tissue, AWA)	
Sample Identification		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (Water, Sealed, Overstated, Br-Tissue, AWA)		Field Filtered Sample (Yes or No)	
STCH-67 Sink		0800		5		12		Pol in Drinking Water		Total Number of containers	
STCH-68 Sink										Special Instructions/Note:	
STCH-69 Sink											
STCH-70 Sink											
STCH-71 Sink											
STCH-72 Sink											
STCH-73 Sink											
STCH-74 Sink											
STCH-75 Sink											
STCH-76 Sink											
STCH-77 Wf											
Possible Hazard Identification		Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological ☐		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		Return To Client ☐ Disposal By Lab ☒ Archive For _____ Months		Special Instructions/OC Requirements:		Method of Shipment:	
Deliverable Requested: I, II, III, IV, Other (specify)		Empty Kit Relinquished by: _____		Date: _____		Time: _____		Received by: _____		Date/Time: _____	
Relinquished by: _____		Date/Time: _____		Company: _____		Received by: _____		Date/Time: _____		Company: _____	
Relinquished by: _____		Date/Time: _____		Company: _____		Received by: _____		Date/Time: _____		Company: _____	
Relinquished by: _____		Date/Time: _____		Company: _____		Received by: _____		Date/Time: _____		Company: _____	
Custody Seals Intact: ☒ Yes ☐ No		Custody Seal No.: _____		Cooler Temperature(s) °C and Other Remarks: Ambient							

110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record



Environment Testing
America

Client Information		Sampler:	Ian St. John		Lab PM:			Carrier Tracking No(s):			COC No:		
Client Contact:		Phone:	314-853-4668		E-Mail:	ian@stjohnenv.com		State of Origin:	MO		Page 8 of 8		
Company:		St. Joseph School District		PMSID:			Analysis Requested						
Address:		1415 North 26th Street		Due Date Requested:									
City:		St. Joseph		TAT Requested (days):	Standard								
State, Zip:		Missouri 64506		Compliance Project:	Δ Yes Δ No								
Phone:		816-671-4000		PO #:									
Email:		CaseyHousman@sisd.k12.mo.us		WO #:									
Project Name:		St. Joseph School District		Project #:									
Site:		Central High		SSOWM:									
Sample Identification		Sample Date	Sample Time	Sample Type (C=Comp, G=Grab)	Matrix (Weigher, Smelter, Comminution, BFT/Trans. A=44)	Total Number of Containers		Special Instructions/Note:		Preservation Codes:			
ST-78 Snak		4/23/24	0800	G	W	No		PB in Drinking Water		A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Acetic Acid H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA M - Hexane N - None O - AsH2O2 P - Na2OAS Q - Na2SO3 R - Na2S2O4 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Triene Z - other (specify)			
ST-79 Snak													
ST-80 Snak													
ST-81 Snak (EX Kitchens)													
ST-82													
ST-83													
ST-84													
ST-85													
ST-86													
ST-87													
ST-88													
ST-89													
ST-90													
ST-91													
ST-92													
ST-93													
ST-94													
ST-95													
ST-96													
ST-97													
ST-98													
ST-99													
ST-100													
ST-101													
ST-102													
ST-103													
ST-104													
ST-105													
ST-106													
ST-107													
ST-108													
ST-109													
ST-110													
ST-111													
ST-112													
ST-113													
ST-114													
ST-115													
ST-116													
ST-117													
ST-118													
ST-119													
ST-120													
ST-121													
ST-122													
ST-123													
ST-124													
ST-125													
ST-126													
ST-127													
ST-128													
ST-129													
ST-130													
ST-131													
ST-132													
ST-133													
ST-134													
ST-135													
ST-136													
ST-137													
ST-138													
ST-139													
ST-140													
ST-141													
ST-142													
ST-143													
ST-144													
ST-145													
ST-146													
ST-147													
ST-148													
ST-149													
ST-150													
ST-151													
ST-152													
ST-153													
ST-154													
ST-155													
ST-156													
ST-157													
ST-158													
ST-159													
ST-160													
ST-161													
ST-162													
ST-163													
ST-164													
ST-165													
ST-166													
ST-167													
ST-168													
ST-169													
ST-170													
ST-171													
ST-172													
ST-173													
ST-174													
ST-175													
ST-176													
ST-177													
ST-178													
ST-179													
ST-180													
ST-181													
ST-182													
ST-183													
ST-184													
ST-185													
ST-186													
ST-187													
ST-188													
ST-189													
ST-190													
ST-191													
ST-192													
ST-193													
ST-194													
ST-195													
ST-196													
ST-197													
ST-198													
ST-199													
ST-200													
ST-201													
ST-202													
ST-203													
ST-204													
ST-205													
ST-206													
ST-207													
ST-208													
ST-209													
ST-210													
ST-211													
ST-212													
ST-213													
ST-214													
ST-215													
ST-216													
ST-217													
ST-218													
ST-219													
ST-220													
ST-221													
ST-222													
ST-223													
ST-224													
ST-225													
ST-226													
ST-227													
ST-228													
ST-229													
ST-230													
ST-231													
ST-232													
ST-233													
ST-234													
ST-235													
ST-236													
ST-237													
ST-238													
ST-239													
ST-240													
ST-241													
ST-242													
ST-243													
ST-244													
ST-245													
ST-246													
ST-247													
ST-248													
ST-249													
ST-250													
ST-251													
ST-252													
ST-253													
ST-254													
ST-255													
ST-256													
ST-257													
ST-258													
ST-259													
ST-260													
ST-261													
ST-262													
ST-263													
ST-264													
ST-265													
ST-266													
ST-267													
ST-268													
ST-269													
ST-270													
ST-271													
ST-272													
ST-273													
ST-274													
ST-275													
ST-276													
ST-277													
ST-278													
ST-279													
ST-280													
ST-281													
ST-282													
ST-283													
ST-284													

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-109581-1

Login Number: 109581

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Moffitt, Tisha

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	False	Thermal preservation not required.
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	