



ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John
St. John Environmental Consulting
5515 Grace Ave.
Saint Louis, Missouri 63116

Generated 8/12/2024 11:56:02 PM

JOB DESCRIPTION

St Joseph School District - Lindbergh Elem

JOB NUMBER

810-114276-1

Eurofins Eaton Analytical South Bend

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
8/12/2024 11:56:02 PM

Authorized for release by
Pamela Brown, Project Manager
Pamela.Brown@et.eurofinsus.com
(574)233-4777

Table of Contents

Cover Page 1

Table of Contents 3

Definitions/Glossary 4

Case Narrative 5

Detection Summary 6

Client Sample Results 7

QC Sample Results 8

QC Association Summary 9

Lab Chronicle 10

Certification Summary 11

Method Summary 12

Sample Summary 13

Chain of Custody 14

Receipt Checklists 16



Definitions/Glossary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: St. John Environmental Consulting
Project: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Job ID: 810-114276-1

Eurofins Eaton Analytical South Bend

Job Narrative 810-114276-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The sample was received on 8/5/2024 9:15 AM. Unless otherwise noted below, the sample arrived in good condition, and, where required, properly preserved and on ice.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Client Sample ID: SJLE-23 Sink

Lab Sample ID: 810-114276-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	33		0.50		ug/L	1		200.8	Total/NA

Client Sample Results

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Client Sample ID: SJLE-23 Sink

Date Collected: 08/01/24 08:00

Date Received: 08/05/24 09:15

Lab Sample ID: 810-114276-1

Matrix: Drinking Water

Method: EPA 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	33		0.50		ug/L			08/12/24 13:45	1

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

QC Sample Results

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-109645/11
Matrix: Drinking Water
Analysis Batch: 109645

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			08/12/24 12:39	1

Lab Sample ID: MB 810-109645/41
Matrix: Drinking Water
Analysis Batch: 109645

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			08/12/24 13:30	1

Lab Sample ID: LCS 810-109645/42
Matrix: Drinking Water
Analysis Batch: 109645

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	50.4		ug/L		101	85 - 115

Lab Sample ID: LLCS 810-109645/10
Matrix: Drinking Water
Analysis Batch: 109645

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.321	J	ug/L		107	50 - 150

QC Association Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Metals

Analysis Batch: 109645

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-114276-1	SJLE-23 Sink	Total/NA	Drinking Water	200.8	
MB 810-109645/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-109645/41	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-109645/42	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-109645/10	Lab Control Sample	Total/NA	Drinking Water	200.8	

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Client Sample ID: SJLE-23 Sink

Date Collected: 08/01/24 08:00

Date Received: 08/05/24 09:15

Lab Sample ID: 810-114276-1

Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	109645	NB	EA SB	08/12/24 13:45

Laboratory References:
EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Accreditation/Certification Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24

1
2
3
4
5
6
7
8
9
10
11
12
13
14

Method Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Sample Summary

Client: St. John Environmental Consulting
Project/Site: St Joseph School District - Lindbergh Elem

Job ID: 810-114276-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-114276-1	SJLE-23 Sink	Drinking Water	08/01/24 08:00	08/05/24 09:15

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

7/25

[illegible]

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14

Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-114276-1

Login Number: 114276

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Alfred, Robbin

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	False	Thermal preservation not required.
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	