ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John St. John Environmental Consulting 5515 Grace Ave. Saint Louis, Missouri 63116

Generated 12/23/2024 8:27:11 AM

JOB DESCRIPTION

St. Joseph School District - Keatley Center

JOB NUMBER

810-132151-1

Eurofins Eaton Analytical South Bend 110 S Hill Street South Bend IN 46617



Eurofins Eaton Analytical South Bend

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization

Generated 12/23/2024 8:27:11 AM

Authorized for release by Pamela Brown, Project Manager Pamela.Brown@et.eurofinsus.com (574)233-4777

13

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
QC Sample Results	8
QC Association Summary	9
Lab Chronicle	10
Certification Summary	11
Method Summary	12
Sample Summary	13
Chain of Custody	14
Receipt Chacklists	16

10

12

Definitions/Glossary

Client: St. John Environmental Consulting

Project/Site: St. Joseph School District - Keatley Center

Job ID: 810-132151-1

Qualifiers

M	eta	Is

Qualifier Qualifier Description

J Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Appreviation	These commonly used appreviations may or may not be present in this report.
\	Listed under the "D" column to designate that the result is reported on a dry weight basis

Listed under the "D" column to designate that the result is reported on a dry weight basis

%R Percent Recovery
CFL Contains Free Liquid
CFU Colony Forming Unit
CNF Contains No Free Liquid

DER Duplicate Error Ratio (normalized absolute difference)

Dil Fac Dilution Factor

DL Detection Limit (DoD/DOE)

DL, RA, RE, IN Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample

DLC Decision Level Concentration (Radiochemistry)

EDL Estimated Detection Limit (Dioxin)

LOD Limit of Detection (DoD/DOE)

LOQ Limit of Quantitation (DoD/DOE)

MCL EPA recommended "Maximum Contaminant Level"

MDA Minimum Detectable Activity (Radiochemistry)

MDC Minimum Detectable Concentration (Radiochemistry)

MDL Method Detection Limit
ML Minimum Level (Dioxin)
MPN Most Probable Number
MQL Method Quantitation Limit

NC Not Calculated

ND Not Detected at the reporting limit (or MDL or EDL if shown)

NEG Negative / Absent
POS Positive / Present

PQL Practical Quantitation Limit

PRES Presumptive
QC Quality Control

RER Relative Error Ratio (Radiochemistry)

RL Reporting Limit or Requested Limit (Radiochemistry)

RPD Relative Percent Difference, a measure of the relative difference between two points

TEF Toxicity Equivalent Factor (Dioxin)
TEQ Toxicity Equivalent Quotient (Dioxin)

TNTC Too Numerous To Count

Eurofins Eaton Analytical South Bend

Case Narrative

Client: St. John Environmental Consulting

Project: St. Joseph School District - Keatley Center

Eurofins Eaton Analytical South Bend Job ID: 810-132151-1

> Job Narrative 810-132151-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 12/18/2024 10:00 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Job ID: 810-132151-1

Detection Summary

Client: St. John Environmental Consulting

Project/Site: St. Joseph School District - Keatley Center

Job ID: 810-132151-1

Lab Sam	ple I	D: 81	0-132	151-1
---------	-------	-------	-------	-------

Analyte	Result Qualifier	RL	MDL Unit	Dil Fac D	Method	Prep Type
Lead	210	0.50	ug/L	1	200.8	Total/NA

Client Sample ID: SJKC-2 Sink Lab Sample ID: 810-132151-2

Analyte	Result Qualifier	RL	MDL Unit	Dil Fac D	Method	Prep Type
Lead	9.1	0.50	ug/L	1	200.8	Total/NA

- 5

_

5

6

8

40

11

13

Client Sample Results

Client: St. John Environmental Consulting

Client Sample ID: SJKC-1 Sink

Project/Site: St. Joseph School District - Keatley Center

Lab Sample ID: 810-132151-1

Matrix: Drinking Water

Date Collected: 12/13/24 08:00 Date Received: 12/18/24 10:00

Job ID: 810-132151-1

Method: EPA 200.8 - Metals (ICP/MS)

Analyte Result Qualifier RLMDL Unit D Prepared Dil Fac Analyzed Lead 0.50 12/19/24 22:32 210 ug/L

Client Sample ID: SJKC-2 Sink Lab Sample ID: 810-132151-2

Date Collected: 12/13/24 08:00 **Matrix: Drinking Water**

Date Received: 12/18/24 10:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte Result Qualifier RL **MDL** Unit D **Prepared** Analyzed Dil Fac

Lead 0.50 ug/L 12/19/24 22:34 9.1

Job ID: 810-132151-1

Client: St. John Environmental Consulting

Project/Site: St. Joseph School District - Keatley Center

Prep Type: Total/NA

Prep Type: Total/NA

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MBL 810-127415/12 Client Sample ID: Method Blank Prep Type: Total/NA

Matrix: Drinking Water

Analysis Batch: 127415

MBL MBL Analyzed Result Qualifier RL **MDL** Unit Dil Fac Analyte D Prepared 0.50 12/19/24 15:36 Lead < 0.12 ug/L

Lab Sample ID: MBL 810-127415/132 Client Sample ID: Method Blank **Matrix: Drinking Water Prep Type: Total/NA**

Analysis Batch: 127415

MBL MBL **MDL** Unit Result Qualifier RL D Prepared Analyzed Dil Fac Analyte 0.50 12/19/24 21:04 Lead < 0.12 ug/L

Lab Sample ID: MBL 810-127415/162 Client Sample ID: Method Blank **Prep Type: Total/NA**

Matrix: Drinking Water Analysis Batch: 127415

MBL MBL Result Qualifier RL Analyte MDL Unit Prepared Analyzed Dil Fac Lead <0.12 0.50 12/19/24 22:26 ug/L

Lab Sample ID: LCS 810-127415/133 **Client Sample ID: Lab Control Sample Prep Type: Total/NA Matrix: Drinking Water**

Analysis Batch: 127415

Spike LCS LCS %Rec Analyte Added Result Qualifier Unit %Rec Limits 49.9 Lead 50.0 ug/L 100 85 - 115

Lab Sample ID: LCS 810-127415/163 **Client Sample ID: Lab Control Sample**

Matrix: Drinking Water Analysis Batch: 127415

LCS LCS Spike %Rec Analyte Added Limits Result Qualifier Unit %Rec Lead 50.0 51.5 103 85 - 115 ug/L

Lab Sample ID: LLCS 810-127415/11 **Client Sample ID: Lab Control Sample**

Matrix: Drinking Water Analysis Batch: 127415

Spike LLCS LLCS %Rec Added Result Qualifier Limits Analyte Unit D %Rec 0.300 0.307 J Lead ug/L 102 50 - 150

QC Association Summary

Client: St. John Environmental Consulting

Project/Site: St. Joseph School District - Keatley Center

Metals

Analysis Batch: 127415

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-132151-1	SJKC-1 Sink	Total/NA	Drinking Water	200.8	
810-132151-2	SJKC-2 Sink	Total/NA	Drinking Water	200.8	
MBL 810-127415/12	Method Blank	Total/NA	Drinking Water	200.8	
MBL 810-127415/132	Method Blank	Total/NA	Drinking Water	200.8	
MBL 810-127415/162	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-127415/133	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-127415/163	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-127415/11	Lab Control Sample	Total/NA	Drinking Water	200.8	

Job ID: 810-132151-1

3

4

5

9

10

12

13

Lab Chronicle

Client: St. John Environmental Consulting

Project/Site: St. Joseph School District - Keatley Center

Client Sample ID: SJKC-1 Sink

Lab Sample ID: 810-132151-1

Date Collected: 12/13/24 08:00 Matrix: Drinking Water
Date Received: 12/18/24 10:00

Prep TypeTypeMethodRunFactorNumberAnalystLabor AnalyzedTotal/NAAnalysis200.81127415CAEA SB12/19/24 22:32

Client Sample ID: SJKC-2 Sink Lab Sample ID: 810-132151-2

Date Collected: 12/13/24 08:00 Matrix: Drinking Water

Date Received: 12/18/24 10:00

Batch Batch Dilution **Batch** Prepared **Prep Type** Type Method Run Factor **Number Analyst** Lab or Analyzed Total/NA Analysis 200.8 127415 CA EA SB 12/19/24 22:34

Laboratory References:

EASB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Job ID: 810-132151-1

3

4

7

9

11

13

Accreditation/Certification Summary

Client: St. John Environmental Consulting

Project/Site: St. Joseph School District - Keatley Center

Job ID: 810-132151-1

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-27

Method Summary

Client: St. John Environmental Consulting

Project/Site: St. Joseph School District - Keatley Center

 Method
 Method Description
 Protocol
 Laboratory

 200.8
 Metals (ICP/MS)
 EPA
 EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EASB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Job ID: 810-132151-1

2

4

5

8

46

11

Sample Summary

Client: St. John Environmental Consulting Project/Site: St. Joseph School District - Keatley Center

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-132151-1	SJKC-1 Sink	Drinking Water	12/13/24 08:00	12/18/24 10:00
810-132151-2	SJKC-2 Sink	Drinking Water	12/13/24 08:00	12/18/24 10:00

Job ID: 810-132151-1

EUROTINS Eaton Analyitcal: South Bend



Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-132151-1

Login Number: 132151 List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Williams, Kameron

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	False	Thermal preservation not required.
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

3

Λ

5

7

10

12

13