



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

December 29, 2020

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX: (541) 830-6375

RE: Table Rock Central

Order No.: 20120799

Dear John Harding:

Neilson Research Corporation received 25 sample(s) on 12/15/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 20120799
Date: 12/29/2020


CLIENT: Eagle Point School District #9

Project: Table Rock Central

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-01 Client Sample ID: C-22-S
 Collection Date: 12/15/2020 4:53:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-22-S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.81		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-02 Client Sample ID: C-22-F
 Collection Date: 12/15/2020 4:53:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-22-F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.760		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-03 Client Sample ID: C-23-S
 Collection Date: 12/15/2020 4:56:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-23-S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.51		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-04 Client Sample ID: C-23-F
 Collection Date: 12/15/2020 4:56:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-23-F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.489		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-05 Client Sample ID: C-23-WB
 Collection Date: 12/15/2020 4:58:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-23-WB


Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.367		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-06 Client Sample ID: C-23-DF-1
 Collection Date: 12/15/2020 4:58:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-23-DF-1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.297		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-07 Client Sample ID: C-23-DF-2
 Collection Date: 12/15/2020 4:59:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-23-DF-2

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.288		0.103	µg/L	1	12/18/2020	15.0	A

Lab ID: 20120799-08 Client Sample ID: C-BBR-1
 Collection Date: 12/15/2020 5:03:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-BBR-1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.22		0.103	µg/L	1	12/18/2020	15.0	A

Lab ID: 20120799-09 Client Sample ID: C-BBR-2
 Collection Date: 12/15/2020 5:04:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-BBR-2

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.77		0.103	µg/L	1	12/18/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-10 Client Sample ID: C-BBR-3
 Collection Date: 12/15/2020 5:04:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-BBR-3

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.58		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-11 Client Sample ID: C-BBR-4
 Collection Date: 12/15/2020 5:06:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-BBR-4

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.14		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-12 Client Sample ID: C-GRR-1
 Collection Date: 12/15/2020 5:08:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-GRR-1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	5.44		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-13 Client Sample ID: C-GRR-2
 Collection Date: 12/15/2020 5:09:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-GRR-2

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.15		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-14 Client Sample ID: C-GRR-3
 Collection Date: 12/15/2020 5:11:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-GRR-3

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	7.04		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-15 Client Sample ID: C-GRR-4
 Collection Date: 12/15/2020 5:12:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-GRR-4

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	7.71		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-16 Client Sample ID: C-25-S
 Collection Date: 12/15/2020 5:15:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-25-S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.19		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-17 Client Sample ID: C-25-F
 Collection Date: 12/15/2020 5:16:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-25-F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.928		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-18 Client Sample ID: C-26-8
 Collection Date: 12/15/2020 5:18:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-26-8

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	5.10		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-19 Client Sample ID: C-26-F
 Collection Date: 12/15/2020 5:19:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-26-F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.614		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-20 Client Sample ID: C-27-S
 Collection Date: 12/15/2020 5:20:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-27-S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.54		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-21 Client Sample ID: C-27-F
 Collection Date: 12/15/2020 5:20:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-27-F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.388		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-22 Client Sample ID: C-28-S
 Collection Date: 12/15/2020 5:21:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-28-S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.18		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-23 Client Sample ID: C-28-F
 Collection Date: 12/15/2020 5:22:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: C-28-F


Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.414		0.103	µg/L	1	12/18/2020	15.0	A	

Lab ID: 20120799-24 Client Sample ID: RR-1
 Collection Date: 12/15/2020 5:25:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: RR-1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.60		0.103	µg/L	1	12/18/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120799
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120799
Received Date: 12/15/2020 1:10:00 PM
Reported Date: 12/29/2020 1:58:49 PM

Sample Information:

Lab ID: 20120799-25 Client Sample ID: RR-2
 Collection Date: 12/15/2020 5:26:00 AM Collected By: Dale Newton
 Matrix: Drinking Water Sample Location: RR-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.63		0.103	µg/L	1	12/18/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120799
 29-Dec-20

Client: Eagle Point School District #9
Project: Table Rock Central

TestCode: LEAD_DW

Sample ID: MB-10123	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: PBW	Batch ID: 10123	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259046						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10123	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: LCSW	Batch ID: 10123	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259047						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.8 0.104 100 0 99.8 85 115

Sample ID: 20120794-47AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: BatchQC	Batch ID: 10123	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259049						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual


Lead 132 0.104 100 35.1 97.3 70 130

Sample ID: 20120794-47AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: BatchQC	Batch ID: 10123	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259050						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 133 0.104 100 35.1 97.9 70 130 132 0.431 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120799
 29-Dec-20

Client: Eagle Point School District #9
Project: Table Rock Central

TestCode: LEAD_DW

Sample ID: MB-10124	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: PBW	Batch ID: 10124	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259260						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10124	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: LCSW	Batch ID: 10124	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259261						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.104 100 0 101 85 115

Sample ID: 20120799-04AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: C-23-F	Batch ID: 10124	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259263						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.1 0.104 100 0.489 98.6 70 130

Sample ID: 20120799-04AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: C-23-F	Batch ID: 10124	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259264						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 98.8 0.104 100 0.489 98.3 70 130 99.1 0.234 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120799
 29-Dec-20

Client: Eagle Point School District #9
Project: Table Rock Central

TestCode: LEAD_DW

Sample ID: MB-10127	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: PBW	Batch ID: 10127	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259288						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10127	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: LCSW	Batch ID: 10127	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259289						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 98.3 0.104 100 0 98.3 85 115

Sample ID: 20120801-01AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: BatchQC	Batch ID: 10127	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259293						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 98.7 0.104 100 1.81 96.8 70 130

Sample ID: 20120801-01AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/17/2020	RunNo: 17871						
Client ID: BatchQC	Batch ID: 10127	TestNo: E200.8	E200.8	Analysis Date: 12/18/2020	SeqNo: 259294						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.4 0.104 100 1.81 97.5 70 130 98.7 0.695 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original

Sample Log-In Check List

Client Name: **EAGLEPTSCHOOL**

Work Order Number: **20120799**

RcptNo: **1**

Logged by:	Naomi Orr	12/15/2020 1:10:00 PM	
Completed By:	Krizzle Calip	12/16/2020 8:22:09 AM	
Reviewed By:	Naomi Orr	12/29/2020 1:54:17 PM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
- Custody seals intact on shipping container/cooler? Yes No Not Present
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No HNO3 pH<2
No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:
The sample submitted contained visible sediments (fraction 03 and 16).

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 2 of 93
error no
12-15-2020

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point Sch Dist 9</u>	Project Name: <u>Table Rock Central</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>203 N. Platt</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point OR, 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>HardingJ@eaglept.k12.or.us</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: <u>830-6376</u> Fax:			<input type="checkbox"/> Other _____
Collected By (Print): <u>Dale Newton</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>Dale Newton</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	Remarks/Field Data	NRC Sample # (Lab Use Only)
<u>C-BAR-4 85223</u>			<u>12-15</u>	<u>5:06 A</u>	<u>1</u>	<u>X</u>		<u>11</u>
<u>C-GRA-1 85349</u>			<u>12-15</u>	<u>5:08 A</u>	<u>1</u>	<u>X</u>		<u>12</u>
<u>C-GRA-2 85221</u>			<u>12-15</u>	<u>5:09 A</u>	<u>1</u>	<u>X</u>		<u>13</u>
<u>C-GRA-3 85227</u>			<u>12-15</u>	<u>5:11 A</u>	<u>1</u>	<u>X</u>		<u>14</u>
<u>C-GRA-4 85350</u>			<u>12-15</u>	<u>5:12 A</u>	<u>1</u>	<u>X</u>		<u>15</u>
<u>C-25-S 85310</u>			<u>12-15</u>	<u>5:15 A</u>	<u>1</u>	<u>X</u>		<u>16</u>
<u>C-25-F 85293</u>			<u>12-15</u>	<u>5:16 A</u>	<u>1</u>	<u>X</u>		<u>17</u>
<u>C-26-8 85329</u>			<u>12-15</u>	<u>5:18</u>	<u>1</u>	<u>X</u>		<u>18</u>
<u>C-26 F 85298</u>			<u>12-15</u>	<u>5:19 A</u>	<u>1</u>	<u>X</u>		<u>19</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>Dale Newton</u>		<u>Dale Newton</u>	<u>12-15</u>	<u>12:10</u>
Received By: <u>John Harding</u>		<u>John Harding</u>	<u>12/15</u>	<u>12:10</u>
Relinquished By: <u>John Harding</u>		<u>John Harding</u>	<u>12:15</u>	<u>1:10</u>
Received By:				
Relinquished By:				
Received By Laboratory: <u>Amber</u>		<u>Noomi Orr</u>	<u>12-15-2020</u>	<u>13:10</u>

Section G Lab Use Only

Temp: <u>amb</u>
4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received: <u>84</u>
pH Checked: <u>N/A</u>
COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>N/A</u>
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via UPS FedEX Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

