

NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

6/21/2016

Ken Gruenwald
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: Eagle Point-Lead Testing

Order No.: 1606566

Dear Ken Gruenwald:

Neilson Research Corporation received 20 sample(s) on 6/14/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Eagle Point School District #9

Date: 21-Jun-16

Project: Eagle Point-Lead Testing

CASE NARRATIVE

Lab Order: 1606566

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-01A**

Collection Date: **6/10/2016 7:00:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: Hillside Elementary 204

Collectors Name: Ken Gruenwald

Sample Location: DF Outside B Wing

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.19		0.00103	mg/L	1.3 AL	6/16/2016	OML
Lead	EPA 200.8	A	0.000131		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-02A**

Collection Date: **6/10/2016 7:00:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: Hillside Elementary 205

Collectors Name: Ken Gruenwald

Sample Location: DF C Wing Room 5

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.640		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.000375		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-03A**

Collection Date: **6/10/2016 7:20:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: Eagle Rock Elem 206

Collectors Name: Ken Gruenwald

Sample Location: Drinking Fountain Cafeteria

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.471		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00225		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-04A**

Collection Date: **6/10/2016 7:20:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Client Sample ID: Eagle Rock Elem 207

Collectors Name: Ken Gruenwald

Sample Location: DF C Classroom 10

Source:

Eagle Point-Lead Testing

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.424		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.000912		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-05A**

Collection Date: **6/13/2016 6:00:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: Little Butte Gym 107

Collectors Name: Ken Gruenwald

Sample Location: Gym

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0696		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00900		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-06A**

Collection Date: **6/13/2016 6:30:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: High School Shop 110

Collectors Name: Ken Gruenwald

Sample Location: Shop

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	0.405		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.000512		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-07A**

Collection Date: **6/12/2016 6:25:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: EPHS Eagle Center 109

Collectors Name: Ken Gruenwald

Sample Location: Eagle Center

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.279		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00139		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-08A**

Collection Date: **6/13/2016 6:15:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Client Sample ID: EPHS New Gym 108

Collectors Name: Ken Gruenwald

Sample Location: Gym

Source:

Eagle Point-Lead Testing

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.546		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.000399		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524

Lab Order: **1606566**
NRC Sample ID: **1606566-09A**
Collection Date: **6/10/2016 7:45:00 AM**
Received Date: **6/14/2016 11:00:00 AM**
Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: EPHS Softball Field 106
Collectors Name: Ken Gruenwald
Sample Location: Softball Field
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.174		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00691		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-10A**

Collection Date: **6/10/2016 7:20:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: EPHS FB Stadium 104

Collectors Name: Ken Gruenwald

Sample Location: RR Sink

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.227		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00480		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524

Lab Order: **1606566**
NRC Sample ID: **1606566-11A**
Collection Date: **6/10/2016 7:35:00 AM**
Received Date: **6/14/2016 11:00:00 AM**
Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: EPHS Baseball Stadium 105
Collectors Name: Ken Gruenwald
Sample Location: Baseball Stadium
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0295		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00188		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524

Lab Order: **1606566**
NRC Sample ID: **1606566-12A**
Collection Date: **6/10/2016 7:00:00 AM**
Received Date: **6/14/2016 11:00:00 AM**
Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: Old JR High 102
Collectors Name: Ken Gruenwald
Sample Location: CLCL RR
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.125		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00320		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-13A**

Collection Date: **6/10/2016 7:00:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: Old JR High 101

Collectors Name: Ken Gruenwald

Sample Location: Gym Sink

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.183		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00108		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524

Lab Order: **1606566**
NRC Sample ID: **1606566-14A**
Collection Date: **6/14/2016 6:20:00 AM**
Received Date: **6/14/2016 11:00:00 AM**
Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: EP Middle School 111
Collectors Name: Ken Gruenwald
Sample Location: Café Drinking Fountain
Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.304		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00137		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-15A**

Collection Date: **6/14/2016 6:30:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: EP Middle School 112

Collectors Name: Ken Gruenwald

Sample Location: Commons Drinking Fountain

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.364		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00182		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-16A**

Collection Date: **6/10/2016 6:45:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Client Sample ID: EPMS Maint Shop 202

Collectors Name: Ken Gruenwald

Sample Location: Kitchen Sink

Source:

Eagle Point-Lead Testing

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0593		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00415		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-17A**

Collection Date: **6/10/2016 7:30:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Client Sample ID: Transportation Dept 201

Collectors Name: Ken Gruenwald

Sample Location: Kitchen Sink

Source:

Eagle Point-Lead Testing

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	0.0300		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.000868		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-18A**

Collection Date: **6/10/2016 7:10:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Client Sample ID: District Office 203

Collectors Name: Ken Gruenwald

Sample Location: Kitchen Sink

Source:

Eagle Point-Lead Testing

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.344		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.00238		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-19A**

Collection Date: **6/10/2016 7:10:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Eagle Point-Lead Testing

Client Sample ID: URCEO 103

Collectors Name: Ken Gruenwald

Sample Location:

Source:

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.198		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.000396		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1606566**

NRC Sample ID: **1606566-20A**

Collection Date: **6/10/2016 7:35:00 AM**

Received Date: **6/14/2016 11:00:00 AM**

Reported Date: **6/21/2016 8:33:51 AM**

Sample Information:

Client Sample ID: AAP 208

Collectors Name: Ken Gruenwald

Sample Location: Drinking Fountain

Source:

Eagle Point-Lead Testing

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.641		0.000515	mg/L	1.3 AL	6/15/2016	OML
Lead	EPA 200.8	A	0.000557		0.000103	mg/L	0.020 AL	6/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

CLIENT: Eagle Point School District #9
Work Order: 1606566
Project: Eagle Point-Lead Testing

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID MB-35464	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 6/15/2016	RunNo: 87873						
Client ID: ZZZZZ	Batch ID: 35464	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 6/15/2016	SeqNo: 1311562						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	ND	0.000515
Lead	ND	0.000103

Sample ID LCS-35464	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 6/15/2016	RunNo: 87873						
Client ID: ZZZZZ	Batch ID: 35464	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 6/15/2016	SeqNo: 1311563						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.09187	0.000520	0.1	0	91.9	85	115
Lead	0.09411	0.000104	0.1	0	94.1	85	115

Sample ID 1606566-20AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 6/15/2016	RunNo: 87873						
Client ID: AAP 208	Batch ID: 35464	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 6/15/2016	SeqNo: 1311564						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.7366	0.000520	0.1	0.641	95.7	70	130
Lead	0.09556	0.000104	0.1	0.0005568	95.0	70	130

Sample ID 1606566-20AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 6/15/2016	RunNo: 87873						
Client ID: AAP 208	Batch ID: 35464	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 6/15/2016	SeqNo: 1311565						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.7418	0.000520	0.1	0.641	101	70	130	0.7366	0.703	20
Lead	0.09565	0.000104	0.1	0.0005568	95.1	70	130	0.09556	0.0979	20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory
 243 South Gampe Street • Mcelford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information Company: JCSD 9 Address: PO Box 548 Email: gtruenwaldk@eaglepnt.k12.or.us Phone: 541 830-6377 Fax: Collected By (Print): Ken Greenwald Collected By (Sign): <i>Ken Greenwald</i> Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Fax Report <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Section B Required Project Information Project Name: Hillside Elementary Project Number: Report To: Copy To: P.O. #
Section C Invoice Information Attention: Company Name: Address: P.O. #	Section D Rqst Status (Subject to Scheduling) <input checked="" type="checkbox"/> Standard 10-14 Days <input type="checkbox"/> 5 Business Days (50% surcharge) <input type="checkbox"/> 3 Business Days (75% surcharge) <input type="checkbox"/> 24 - 48 hours (100% surcharge) Other _____ Authorized <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers				Analysis Requested												
					1	2	3	4	1	2	3	4									
204		DW	6/11/16	7AM																	
DF outside Bays																					
205		DW	6/10/16	7AM																	
DF C wings																					
Room 5																					

Section F Relinquish/Receive Relinquished By: <i>Ken Greenwald</i> Sign Received By: Relinquished By: Received By: Relinquished By: Received By Laboratory: <i>Crystal Lewis</i>	Section G Lab Use Only Temp: <i>Ambient</i> 4°C +/- 2°C: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Received on Ice: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Number of Bottles Received: <i>2</i> pH Checked: COC Seals Intact: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Field Blank Included: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Received Via <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand
---	--

Payment <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # _____	Received Via <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand
---	--



Environmental Testing Laboratory
 243 South Grape Street • Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information

Company: JCSD 9
 Address: PO Box 548
 Email: gruenwaldk@eaglepnt.k12.or.us
 Phone: 541 830-0377 Fax:
 Collected By (Print): Kend Greenwald
 Collected By (Sign): [Signature]
 Email Report Yes No
 Fax Report Yes No

Section B Required Project Information

Project Name: Early Risk Element
 Project Number:
 Report To:
 Copy To:
 P.O. #

Section C Invoice Information

Attention:
 Company Name:
 Address:
 P.O. #

Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other:
 Authorized Yes No

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
206		BUS	6/10/16	7:20 AM			1000566	03
DE CATERINA								
207		BUS	6/10/16	7:20 AM			10018	04
DE C								
Classroom 10								


*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive

Relinquished By:	Sign	Date	Time
<u>[Signature]</u>	<u>[Signature]</u>	6/14/16	11 AM
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	<u>[Signature]</u>	Crystal Lewis	10/14/16

Section G Lab Use Only

Temp: Ambient
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 2
 pH Checked:
 COC Seals Intact: Yes No
 Field Blank Included: Yes No
 Received Via: UPS FedEx Other Hand
 Payment: Invoice Cash VISA M/C Check # Amount



Environmental Testing Laboratory
 243 South Grape Street • Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
 Required Client Information

Company: JICSD 9
 Address: PO Box 548
 Email: pguenwaldk@caglepnt.k12.or.us
 Phone: 541 830-6377 Fax:
 Collected By (Print): Ken Guenwaldk
 Collected By (Sign): *Ken Guenwaldk*
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
 Required Project Information

Project Name: District Office
 Project Number:
 Report To:
 Copy To:
 P.O. #

Section C
 Invoice Information

Attention:
 Company Name:
 Address:
 P.O. #

Section D
 Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E
 Sample Information

Sample ID	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested
203		DW	6/14/16	10:00 AM		
<i>Fitland</i>						
<i>Smith</i>						
<i>Ken</i>						

Section F
 Relinquish/Receive

Relinquished By: *Ken Guenwaldk* Sign
 Received By:
 Relinquished By:
 Received By:
 Relinquished By:
 Received By:
 Relinquished By:
 Received By: Laboratory *Crystal Lewis*

Section G
 Lab Use Only

Temp: Ambient
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received:
 pH Checked:
 COC Seals Intact: Yes No N/A
 Field Blank Included: Yes No
 Received Via: UPS FedEX Other Hand
 Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

