



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

3/10/2017

Ken Gruenwald
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: Lead Study-Eagle Point High School

Order No.: 1702882

Dear Ken Gruenwald:

Neilson Research Corporation received 66 sample(s) on 2/28/2017 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Ronald W. Canady
Project Manager

245 S Grape St • Medford, OR 97501 • (541) 770-5678
400 SE G St, Suite B • Grants Pass, OR 97526 • (541) 479-4053

www.nrclabs.com

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Eagle Point School District #9
Project: Lead Study-Eagle Point High School
Lab Order: 1702882

Date: 10-Mar-17

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548
Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:02 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-01

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27708
Source: City Water
Sample Location: E-1

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0111		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-02

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27741
Source: City Water
Sample Location: E-2

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0122		0.0001	mg/L	1	3/8/2017	A

Lab ID: 1702882-03

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27589
Source: City Water
Sample Location: E-3

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00599		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-04

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27591
Source: City Water
Sample Location: E-4

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00932		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-05

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27588
Source: City Water
Sample Location: E-5

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0457	CF*	0.0001	mg/L	1	3/8/2017	A

Qualifiers:

- | | |
|--|---|
| <ul style="list-style-type: none"> * Value exceeds Maximum Contaminant Level E Value above quantitation range J Analyte detected below quantitation limits S Spike Recovery outside accepted recovery limits | <ul style="list-style-type: none"> B Analyte detected in the associated Method Blank H Holding times for preparation or analysis exceeded ND Not Detected at the Minimum Reporting Limit |
|--|---|

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:02 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-06

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27740

Source: City Water

Sample Location: E-6

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00232		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-07

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27738

Source: City Water

Sample Location: E-7

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00197		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-08

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27745

Source: City Water

Sample Location: E-8

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00308		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-09

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27594

Source: City Water

Sample Location: E-9

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00569		0.0001	mg/L	1	3/8/2017	A

Lab ID: 1702882-10

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27586

Source: City Water

Sample Location: E-10

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00185		0.000103	mg/L	1	3/7/2017	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 1702882

Received Date: 2/28/2017 8:44:00 AM

Reported Date: 3/10/2017 2:07:02 PM

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-11

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27585

Source: City Water

Sample Location: E-11

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.0166	CF	0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-12

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27584

Source: City Water

Sample Location: E-12

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.0229	CF*	0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-13

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27746

Source: City Water

Sample Location: E-13

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00226		0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-14

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27583

Source: City Water

Sample Location: E-14

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.0218	CF*	0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-15

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27743

Source: City Water

Sample Location: E-15

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00288		0.000103	mg/L	1	3/7/2017	A	

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:02 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-16

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27737

Source: City Water

Sample Location: E-16

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00157		0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-17

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27735

Source: City Water

Sample Location: E-17

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00194		0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-18

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27605

Source: City Water

Sample Location: E-18

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00750		0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-19

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27742

Source: City Water

Sample Location: E-19

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00145		0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-20

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27747

Source: City Water

Sample Location: E-20

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00125		0.000103	mg/L	1	3/7/2017	A	

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 1702882

Received Date: 2/28/2017 8:44:00 AM

Reported Date: 3/10/2017 2:07:02 PM

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-21

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #19240

Source: City Water

Sample Location: E-21

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00503		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-22

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #19319

Source: City Water

Sample Location: E-22

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00144		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-23

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #19232

Source: City Water

Sample Location: E-23

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0256	CF*	0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-24

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27717

Source: City Water

Sample Location: E-24

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0161	CF	0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-25

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27712

Source: City Water

Sample Location: E-25

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0233	CF*	0.000103	mg/L	1	3/7/2017	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548
Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**
Reported Date: **3/10/2017 2:07:02 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-26

Collection Date: 2/24/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27724
Source: City Water
Sample Location: F-1

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0160	CF	0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-27

Collection Date: 2/24/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27734
Source: City Water
Sample Location: F-2

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0139		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-28

Collection Date: 2/24/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27733
Source: City Water
Sample Location: F-3

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0127		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-29

Collection Date: 2/24/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27725
Source: City Water
Sample Location: F-4

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.200	CF*	0.0002	mg/L	2	3/9/2017	A

Lab ID: 1702882-30

Collection Date: 2/24/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27727
Source: City Water
Sample Location: F-5

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0321	CF*	0.000103	mg/L	1	3/7/2017	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 1702882

Received Date: 2/28/2017 8:44:00 AM

Reported Date: 3/10/2017 2:07:02 PM

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-31

Collection Date: 2/24/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27721

Source: City Water

Sample Location: F-6

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	1.01	CF*	0.001	mg/L	10	3/9/2017	A	

Lab ID: 1702882-32

Collection Date: 2/24/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27723

Source: City Water

Sample Location: F-7

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00107		0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-33

Collection Date: 2/24/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27728

Source: City Water

Sample Location: F-8

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00221		0.000103	mg/L	1	3/7/2017	A	

Lab ID: 1702882-34

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27729

Source: City Water

Sample Location: G-1

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.137	CF*	0.0001	mg/L	1	3/8/2017	A	

Lab ID: 1702882-35

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27600

Source: City Water

Sample Location: G-4

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00949		0.000103	mg/L	1	3/7/2017	A	

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548
Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:02 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-36

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27718
Source: City Water
Sample Location: G-5

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0106		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-37

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27711
Source: City Water
Sample Location: G-6

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0641	CF*	0.0001	mg/L	1	3/8/2017	A

Lab ID: 1702882-38

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27603
Source: City Water
Sample Location: G-7

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00112		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-39

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27531
Source: City Water
Sample Location: G-8

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0118		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-40

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27530
Source: City Water
Sample Location: G-9

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0193	CF	0.000103	mg/L	1	3/7/2017	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:02 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-41

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27546

Source: City Water

Sample Location: G-10

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00443		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-42

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27533

Source: City Water

Sample Location: G-11

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0202	CF*	0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-43

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27529

Source: City Water

Sample Location: G-12

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.000959		0.000103	mg/L	1	3/7/2017	A

Lab ID: 1702882-44

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27540

Source: City Water

Sample Location: G-13

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00128		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-45

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27598

Source: City Water

Sample Location: G-14

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00757		0.000103	mg/L	1	3/8/2017	A

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:03 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-46

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27602

Source: City Water

Sample Location: G-15

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0130		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-47

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27593

Source: City Water

Sample Location: G-16

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.000872		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-48

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27709

Source: City Water

Sample Location: G-17

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0142		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-49

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27720

Source: City Water

Sample Location: G-18

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0139		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-50

Collection Date: 2/23/2017 7:00:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27726

Source: City Water

Sample Location: G-19

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00423		0.000103	mg/L	1	3/8/2017	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548
Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:03 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-51

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27714
Source: City Water
Sample Location: G-20

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00423		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-52

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27715
Source: City Water
Sample Location: G-21

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00566		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-53

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27732
Source: City Water
Sample Location: G-22

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00634		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-54

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27748
Source: City Water
Sample Location: H-1

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00995		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-55

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27597
Source: City Water
Sample Location: H-3

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0216	CF*	0.000103	mg/L	1	3/8/2017	A

Qualifiers:

- | | |
|--|---|
| <ul style="list-style-type: none"> * Value exceeds Maximum Contaminant Level E Value above quantitation range J Analyte detected below quantitation limits S Spike Recovery outside accepted recovery limits | <ul style="list-style-type: none"> B Analyte detected in the associated Method Blank H Holding times for preparation or analysis exceeded ND Not Detected at the Minimum Reporting Limit |
|--|---|

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548
Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:03 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-56

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27592
Source: City Water
Sample Location: H-4

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00662		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-57

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27730
Source: City Water
Sample Location: H-5

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00774		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-58

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27604
Source: City Water
Sample Location: H-6

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00831		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-59

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27606
Source: City Water
Sample Location: H-7

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00742		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-60

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27596
Source: City Water
Sample Location: H-8

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0287	CF*	0.000103	mg/L	1	3/8/2017	A

Qualifiers:

- | | |
|--|---|
| <ul style="list-style-type: none"> * Value exceeds Maximum Contaminant Level E Value above quantitation range J Analyte detected below quantitation limits S Spike Recovery outside accepted recovery limits | <ul style="list-style-type: none"> B Analyte detected in the associated Method Blank H Holding times for preparation or analysis exceeded ND Not Detected at the Minimum Reporting Limit |
|--|---|

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548
Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:03 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-61

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27736
Source: City Water
Sample Location: H-9

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0207	CF*	0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-62

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27707
Source: City Water
Sample Location: H-10

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0143		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-63

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27587
Source: City Water
Sample Location: H-11

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.00711		0.000103	mg/L	1	3/8/2017	A

Lab ID: 1702882-64

Collection Date: 2/23/2017 7:00:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27744
Source: City Water
Sample Location: H-12

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0102		0.0001	mg/L	1	3/8/2017	A

Lab ID: 1702882-65

Collection Date: 2/28/2017 7:30:00 AM
Matrix: DRINKING WATER

Client Sample ID: Bottle #27560
Source: City Water
Sample Location: I-1

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Lead	0.0100		0.0001	mg/L	1	3/8/2017	A

Qualifiers:

- | | |
|--|---|
| <ul style="list-style-type: none"> * Value exceeds Maximum Contaminant Level E Value above quantitation range J Analyte detected below quantitation limits S Spike Recovery outside accepted recovery limits | <ul style="list-style-type: none"> B Analyte detected in the associated Method Blank H Holding times for preparation or analysis exceeded ND Not Detected at the Minimum Reporting Limit |
|--|---|

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: **1702882**

Received Date: **2/28/2017 8:44:00 AM**

Reported Date: **3/10/2017 2:07:03 PM**

Sample Information: Lead Study-Eagle Point High School

Lab ID: 1702882-66

Collection Date: 2/28/2017 7:30:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27562

Source: City Water

Sample Location: I-2

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Lead	0.000725		0.0001	mg/L	1	3/8/2017	A

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation
DATA FLAGS

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
MI	Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
Q	Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
T	Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100
Revision 3
Effective Date: 6/3/16

CLIENT: Eagle Point School District #9
Work Order: 1702882
Project: Lead Study-Eagle Point High School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID MB-37745	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93563						
Client ID: ZZZZZ	Batch ID: 37745	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/7/2017	SeqNo: 1418509						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-37746	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93563						
Client ID: ZZZZZ	Batch ID: 37746	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/7/2017	SeqNo: 1418537						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-37747	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93589						
Client ID: ZZZZZ	Batch ID: 37747	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/8/2017	SeqNo: 1418895						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-37748	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93589						
Client ID: ZZZZZ	Batch ID: 37748	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/8/2017	SeqNo: 1418923						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID LCS-37745	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93563						
Client ID: ZZZZZ	Batch ID: 37745	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/7/2017	SeqNo: 1418510						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1068 0.000104 0.1 0.00001854 107 85 115

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Eagle Point School District #9
Work Order: 1702882
Project: Lead Study-Eagle Point High School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	LCS-37746	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	3/3/2017	RunNo:	93563					
Client ID:	ZZZZZ	Batch ID:	37746	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	3/7/2017	SeqNo:	1418538					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.1080		0.000104		0.1		0.00002678		108	85	115				
------	--	--------	--	----------	--	-----	--	------------	--	-----	----	-----	--	--	--	--

Sample ID	LCS-37747	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	3/3/2017	RunNo:	93589					
Client ID:	ZZZZZ	Batch ID:	37747	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	3/8/2017	SeqNo:	1418896					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.1026		0.000104		0.1		0.0000103		103	85	115				
------	--	--------	--	----------	--	-----	--	-----------	--	-----	----	-----	--	--	--	--

Sample ID	LCS-37748	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	3/3/2017	RunNo:	93589					
Client ID:	ZZZZZ	Batch ID:	37748	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	3/8/2017	SeqNo:	1418924					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.1032		0.000100		0.1		0.000011		103	85	115				
------	--	--------	--	----------	--	-----	--	----------	--	-----	----	-----	--	--	--	--

Sample ID	1702882-19AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	3/3/2017	RunNo:	93563					
Client ID:	Bottle #27742	Batch ID:	37745	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	3/7/2017	SeqNo:	1418533					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.1082		0.000104		0.1		0.001445		107	70	130				
------	--	--------	--	----------	--	-----	--	----------	--	-----	----	-----	--	--	--	--

Sample ID	1702882-43AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	3/3/2017	RunNo:	93563					
Client ID:	Bottle #27529	Batch ID:	37746	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	3/7/2017	SeqNo:	1418561					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.1077		0.000104		0.1		0.0009589		107	70	130				
------	--	--------	--	----------	--	-----	--	-----------	--	-----	----	-----	--	--	--	--

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Eagle Point School District #9
Work Order: 1702882
Project: Lead Study-Eagle Point High School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	1702882-63AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93589					
Client ID:	Bottle #27587	Batch ID: 37747	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/8/2017	SeqNo: 1418919					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1104	0.000104	0.1	0.007109	103	70	130				
------	--------	----------	-----	----------	-----	----	-----	--	--	--	--

Sample ID	1702882-66AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93589					
Client ID:	Bottle #27562	Batch ID: 37748	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/8/2017	SeqNo: 1418944					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1035	0.000100	0.1	0.000725	103	70	130				
------	--------	----------	-----	----------	-----	----	-----	--	--	--	--

Sample ID	1702882-19AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93563					
Client ID:	Bottle #27742	Batch ID: 37745	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/7/2017	SeqNo: 1418534					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1085	0.000104	0.1	0.001445	107	70	130	0.1082	0.298	20	
------	--------	----------	-----	----------	-----	----	-----	--------	-------	----	--

Sample ID	1702882-43AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93563					
Client ID:	Bottle #27529	Batch ID: 37746	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/7/2017	SeqNo: 1418562					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1070	0.000104	0.1	0.0009589	106	70	130	0.1077	0.588	20	
------	--------	----------	-----	-----------	-----	----	-----	--------	-------	----	--

Sample ID	1702882-63AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 3/3/2017	RunNo: 93589					
Client ID:	Bottle #27587	Batch ID: 37747	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 3/8/2017	SeqNo: 1418920					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1108	0.000104	0.1	0.007109	104	70	130	0.1104	0.408	20	
------	--------	----------	-----	----------	-----	----	-----	--------	-------	----	--

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Eagle Point School District #9
Work Order: 1702882
Project: Lead Study-Eagle Point High School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	1702882-66AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	3/3/2017	RunNo:	93589											
Client ID:	Bottle #27562	Batch ID:	37748	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	3/8/2017	SeqNo:	1418945											
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC		LowLimit		HighLimit		RPD Ref Val		%RPD		RPDLimit		Qual
Lead		0.1046		0.000100		0.1		0.000725		104		70		130		0.1035		1.03		20		

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory
 245 South Grape Street + Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
 Required Client Information

Company: JCSD 9
 Address: PO Box 548
 Email: aruennwaldk@eaglepnt.k12.or.us
 Phone: 541 830-6377 Fax:
 Collected By (Print): Steve Lambert
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
 Required Project Information

Project Name: Eagle Point High
 Project Number:
 Report To:
 Copy To:

Section C
 Invoice Information

Attention:
 Company Name:
 Address:
 P.O. #

Section D
 Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other:
 Authorized Yes No

Section E
 Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
E1		DW	2/27/08	11:20am	DB		1702882	01
E2		DW	2/27/08					02
E3		DW	2/27/08					03
E4		DW	2/27/08					04
E5		DW	2/27/08					05
E6		DW	2/27/08					06
E7		DW	2/27/08					07
E8		DW	2/27/08					08
E9		DW	2/27/08					09
E10		DW	2/27/08					10

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Storage C - Oil WP - Wipe OT - Other

Section F
 Refinquinsh/Receive

Received By: *Steve Lambert* Sign
 Date: 2/28/08 Time: 8:30P

Received By: *Steve Lambert* Print
 Date: 2/28/08 Time: 8:30P

Received By: *Denise Ford*
 Date: 2/28/08 Time: 8:44A

Received By Laboratory: *University of Oregon*

Section G
 Lab Use Only

Temp: *AMB*
 4°C +/- 2°C: Yes No
 Received or Iss: Yes No
 Number of Bottles Received: *25*
 pH Checked: *NA*
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Payment: Invoice Cash Received Via UPS FedEx Other Hand
 VISA, M/C Check # Amount



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company:	JOSD 2	Project Name:	Eagle Point High	Attention:		<input checked="" type="checkbox"/> Standard 10-14 Days	
Address:	PO Box 548	Project Number:		Company Name:		<input type="checkbox"/> 5 Business Days (50% surcharge)	
Email:	gruenwaldk@eaglept.k12.or.us	Report To:		Address:		<input type="checkbox"/> 3 Business Days (75% surcharge)	
Phone:	541 830-6377 Fax:	Copy To:		P.O. #		<input type="checkbox"/> 24 - 48 hours (100% surcharge)	
Collected By (Print):	Steve Lambert					Other:	
Collected By (Sign):						Authorized	Yes <input type="checkbox"/> No <input type="checkbox"/>
Email Report	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
Fax Report	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						

Section E Sample Information		Date		Time		No. of Containers		Analysis Requested		NRC Workorder #	NRC Sample #
Sample ID	Comp/Grab	Matrix*	Collected	Collected						(Lab Use Only)	(Lab Use Only)
E11		DW	2/29/17	2PM	2					1702882	11
E12		DW									12
E13		DW									13
E14		DW									14
E15		DW									15
E16		DW									16
E17		DW									17
E18		DW									18
E19		DW									19
E20		DW									20

Section F Relinquish/Receive		Section G Lab Use Only	
Relinquished By:	Steve Lambert	Temp:	4°C +/- 2°C: Yes <input type="checkbox"/> No <input type="checkbox"/>
Received By:	Steve Lambert	Received on Ice:	Yes <input type="checkbox"/> No <input type="checkbox"/>
Relinquished By:		Number of Bottles Received:	
Received By:		pH Checked:	
Relinquished By:		COC Seals Intact:	Yes <input type="checkbox"/> No <input type="checkbox"/> NA
Received By Laboratory:	Denise Neal	Field Blank Included:	Yes <input type="checkbox"/> No <input type="checkbox"/>

Payment:	Invoice	Cash	VISA, M/C	Check #	Amount:
Received Via:	UPS	FedEX	Other	Hand	



Environmental Testing Laboratory
 245 South Grape Street + Medford, OR 97501
 (541) 770-5678 fax (541) 770-2961

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Chain of Custody Record

Section A
 Required Client Information

Company: JCSD 9
 Address: PO Box 548
 Email: stuanwaldk@eaglepnt.k12.or.us
 Phone: 541 830-6377 Fax:
 Collected By (Print): Steve Lambert
 Collected By (Sign):
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
 Required Project Information

Project Name: Eagle Point High
 Project Number:
 Report To:
 Copy To:
 P.O. #

Section C
 Invoice Information

Attention:
 Company Name:
 Address:
 P.O. #

Section D
 Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other:
 Authorized Yes No

Section E
 Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Use Only)	NRC Sample # (Lab Use Only)
E21		DW	2/28/17	7 AM	20		1708882	21
E22		DW						22
E23		DW						23
E24		DW						24
E25		DW						25
		DW						
		DW						
		DW						
		DW						

Section F
 Relinquish/Receive

Relinquished By: *Steve Lambert* Sign: *Steve Lambert* Print: *Steve Lambert* Date: *2/28/17* Time: *8:44*
 Received By:
 Relinquished By:
 Received By:
 Relinquished By:
 Received By:
 Relinquished By: *Steve Lambert* Sign: *Steve Lambert* Print: *Steve Lambert* Date: *2/28/17* Time: *8:44*

Section G
 Lab Use Only

Temp: _____
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Boilies Received:
 pH Checked:
 COC Seal Intact: Yes No NA
 Field Blank Included: Yes No

Payment: Invoice Cash VISA, M/C
 Received Via: UPS FedEx Other Hand
 Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: JCSD 9
 Address: PO Box 549
 Email: rruenwaldk@eaglept.k12.or.us
 Phone: 541 830-6377 Fax:
 Collected By (Print): Steve Lambert
 Collected By (Sign):
 Email Report Yes No Mail Report: Yes No
 Fax Report Yes No

Section B
Required Project Information

Project Name: Eagle Point High
 Project Number:
 Report To:
 Copy To:
 P.O. #

Section C
Invoice Information

Attention:
 Company Name:
 Address:
 P.O. #

Section D

Rush Status (Subject to Scheduling):
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other:
 Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # <small>(Lab Use Only)</small>	NRC Sample # <small>(Lab Use Only)</small>
G11	#	275.33	DW	4/23/17	7 AM		1702888	48
G12		275.29	DW					48
G13		275.40	DW					49
G14		275.98	DW					49
G15		276.08	DW					49
G16		275.93	DW					49
G17		277.09	DW					48
G18		277.20	DW					49
G19		277.26	DW					50
G20		277.14	DW					50

Section F
Relinquish/Receive

Relinquished By: *Steve Lambert* Sign: *Steve Lambert* Print: *Steve Lambert* Date: *4/27/17* Time: *2:44*
 Received By: *Janice Neal* Sign: *Janice Neal* Print: *Janice Neal* Date: *2/28/18* Time: *8:44*

Section G
Lab Use Only

Temp: _____
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: _____
 pH Checked: _____
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No
 Payment: Cash Invoice VISA, M/C UPS FedEX Other Hand
 Check # _____ Amount: _____



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ___ of ___

Section A

Required Client Information

Company: JCSD 9
 Address: PO Box 548
 Email: gruenwaldk@esglepnt.k12.or.us
 Phone: 541 830-8377 Fax:
 Collected By (Print): Steve Lambert
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
Required Project Information

Project Name: Eagle Point High
 Project Number:
 Report To:
 Coop To:
 Collected By (Print): Steve Lambert

Section C
Invoice Information

Attention:
 Company Name:
 Address:
 P.O. #

Section D
Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other
 Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested
G21 # 27715	DW	DW	2/28/17	7:44	pb	
G22 27732	DW	DW				
		DW				
		DW				
		DW				
		DW				
		DW				
		DW				
		DW				
		DW				
		DW				

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Solid/Slud SL - Sludge O - Oil WPF - Wipe OI - Other

Section G
Lab Use Only

Temp: _____
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: _____
 PH Checked: _____
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Payment: Invoice Cash VISA/MC Check # _____
 Received Via: UPS FedEx Other Hand
 Amount: _____

Section F
Relinquish/Receive

Relinquished By: *Steve Lambert* Sign: *[Signature]* Print: *Steve Lambert* Date: *2/28/17* Time: *8:44*
 Received By: _____
 Relinquished By: _____
 Received By: _____
 Relinquished By: _____
 Received By: _____



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ___ of ___

Section A Required Client Information

Company: JCSD 9
 Address: PO Box 548
 Email: ETUENWALDK@EAGLEPNT.K12.OR.US
 Phone: 541 850-6377 Fax:
 Collector By (Print): Steve Lambert
 Collected By (Sign):
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B Required Project Information

Project Name: Eagle Point High
 Project Number:
 Report To:
 Copy To:
 Attention:
 Company Name:
 Address:
 P.O. #

Section C Invoice Information

Analysis Requested
 Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other:
 Authorized: Yes No

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # <small>(Lab Use Only)</small>	NRC Sample # <small>(Lab Use Only)</small>
H 1		DW	4/23/17	7 PM	20		1702888	58
H 2		DW						58
H 3		DW						57
H 4		DW						57
H 5		DW						57
H 6		DW						57
H 7		DW						57
H 8		DW						57
H 9		DW						57
H 10		DW						57

Section F
 Relinquish/Receive
 Relinquished By: *[Signature]* Sign
 Received By: *[Signature]* Sign
 Relinquished By:
 Received By:
 Relinquished By:
 Received By Laboratory: *[Signature]*

Section G
 Lab Use Only
 Terr: *AMB*
 4°C +/- 2°C: Yes No
 Received on ice: Yes No
 Number of Bottles Received: *11*
 pH Checked: *NA*
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Received Via: Invoice Cash VISA M/C Check # _____
 Amount: _____
 Received Via: UPS FedEx Other Hand
 Payment: Invoice Cash VISA M/C Check # _____
 Amount: _____

