



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

January 09, 2021

John Harding  
Eagle Point School District #9  
PO Box 548  
Eagle Point, OR 97524  
TEL: (541) 830-1240  
FAX (541) 830-6375

RE: Eagle Rock Elementary

Order No.: 20121199

Dear John Harding:

Neilson Research Corporation received 75 sample(s) on 12/22/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Senior Project Manager  
245 S Grape St  
Medford, OR 97501



Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Case Narrative

WO#: 20121199  
Date: 1/9/2021

---

**CLIENT:** Eagle Point School District #9

**Project:** Eagle Rock Elementary

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-01      Client Sample ID: ER1  
 Collection Date: 12/22/2020 6:45:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.35		0.103	µg/L	1	12/29/2020	15.0	A

**Lab ID:** 20121199-02      Client Sample ID: ER2  
 Collection Date: 12/22/2020 6:47:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER2

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.17		0.103	µg/L	1	12/29/2020	15.0	A


**Lab ID:** 20121199-03      Client Sample ID: ER3  
 Collection Date: 12/22/2020 6:47:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER3

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.00		0.103	µg/L	1	12/29/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-04      Client Sample ID: ER4  
 Collection Date: 12/22/2020 6:50:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER4

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.08		0.103	µg/L	1	12/29/2020	15.0	A	

**Lab ID:** 20121199-05      Client Sample ID: ER5  
 Collection Date: 12/22/2020 6:50:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER5

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.74		0.103	µg/L	1	12/29/2020	15.0	A	

**Lab ID:** 20121199-06      Client Sample ID: ER6  
 Collection Date: 12/22/2020 6:52:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER6

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.15		0.103	µg/L	1	12/29/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-07      Client Sample ID: ER7  
 Collection Date: 12/22/2020 6:52:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER7

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.84		0.103	µg/L	1	12/29/2020	15.0	A	

**Lab ID:** 20121199-08      Client Sample ID: ER8  
 Collection Date: 12/22/2020 6:52:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER8

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.81		0.103	µg/L	1	12/29/2020	15.0	A	

**Lab ID:** 20121199-09      Client Sample ID: ER9  
 Collection Date: 12/22/2020 6:54:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER9

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	8.07		0.103	µg/L	1	12/29/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-10      Client Sample ID: ER10  
 Collection Date: 12/22/2020 6:54:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER10

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.77		0.103	µg/L	1	12/29/2020	15.0	A

**Lab ID:** 20121199-11      Client Sample ID: ER11  
 Collection Date: 12/22/2020 6:56:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER11

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.60		0.103	µg/L	1	12/29/2020	15.0	A


**Lab ID:** 20121199-12      Client Sample ID: ER12  
 Collection Date: 12/22/2020 6:56:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER12

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.72		0.100	µg/L	1	12/29/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-13      Client Sample ID: ER13  
 Collection Date: 12/22/2020 6:56:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER13

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.50		0.103	µg/L	1	12/29/2020	15.0	A

**Lab ID:** 20121199-14      Client Sample ID: ER14  
 Collection Date: 12/22/2020 7:02:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER14

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.16		0.103	µg/L	1	12/29/2020	15.0	A

**Lab ID:** 20121199-15      Client Sample ID: ER15  
 Collection Date: 12/22/2020 7:02:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER15

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.52		0.103	µg/L	1	12/29/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-16      Client Sample ID: ER16  
 Collection Date: 12/22/2020 7:02:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER16

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.31		0.103	µg/L	1	12/29/2020	15.0	A

**Lab ID:** 20121199-17      Client Sample ID: ER17  
 Collection Date: 12/22/2020 7:50:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER17

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.14		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-18      Client Sample ID: ER18  
 Collection Date: 12/22/2020 7:50:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER18

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.919		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-19      Client Sample ID: ER19  
 Collection Date: 12/22/2020 7:55:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER19

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.676		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-20      Client Sample ID: ER20  
 Collection Date: 12/22/2020 7:55:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER20

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.13		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-21      Client Sample ID: ER21  
 Collection Date: 12/22/2020 7:57:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER21

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.86		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-22      Client Sample ID: ER22  
 Collection Date: 12/22/2020 7:57:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER22

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.60		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-23      Client Sample ID: ER23  
 Collection Date: 12/22/2020 7:59:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER23

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.980		0.103	µg/L	1	12/30/2020	15.0	A


**Lab ID:** 20121199-24      Client Sample ID: ER24  
 Collection Date: 12/22/2020 7:59:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER24

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.896		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-25      Client Sample ID: ER25  
 Collection Date: 12/22/2020 8:00:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER25

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.38		0.103	µg/L	1	12/30/2020	15.0	A	

**Lab ID:** 20121199-26      Client Sample ID: ER26  
 Collection Date: 12/22/2020 8:00:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER26

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.994		0.103	µg/L	1	12/30/2020	15.0	A	

**Lab ID:** 20121199-27      Client Sample ID: ER27  
 Collection Date: 12/22/2020 8:15:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER27

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.04		0.103	µg/L	1	12/30/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-28      Client Sample ID: ER28  
 Collection Date: 12/22/2020 8:15:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER28

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.05		0.103	µg/L	1	12/30/2020	15.0	A	

**Lab ID:** 20121199-29      Client Sample ID: ER29  
 Collection Date: 12/22/2020 8:15:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER29

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.697		0.103	µg/L	1	12/30/2020	15.0	A	


**Lab ID:** 20121199-30      Client Sample ID: ER30  
 Collection Date: 12/22/2020 8:20:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER30

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.564		0.103	µg/L	1	12/30/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-31      Client Sample ID: ER31  
 Collection Date: 12/22/2020 8:20:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER31

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.794		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-32      Client Sample ID: ER32  
 Collection Date: 12/22/2020 8:20:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER32

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.743		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-33      Client Sample ID: ER33  
 Collection Date: 12/22/2020 8:30:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER33

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.17		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-34      Client Sample ID: ER34  
 Collection Date: 12/22/2020 8:30:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER34

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.27		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-35      Client Sample ID: ER35  
 Collection Date: 12/22/2020 8:32:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER35

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.860		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-36      Client Sample ID: ER36  
 Collection Date: 12/22/2020 8:32:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER36

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.08		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-37      Client Sample ID: ER37  
 Collection Date: 12/22/2020 8:35:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER37

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.05		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-38      Client Sample ID: ER38  
 Collection Date: 12/22/2020 8:35:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER38

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.36		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-39      Client Sample ID: ER39  
 Collection Date: 12/22/2020 8:37:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER39

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.00		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-40      Client Sample ID: ER40  
 Collection Date: 12/22/2020 8:37:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER40

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.36		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-41      Client Sample ID: ER41  
 Collection Date: 12/22/2020 9:15:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER41

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.06		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-42      Client Sample ID: ER42  
 Collection Date: 12/22/2020 9:15:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER42

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.01		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-43      Client Sample ID: ER43  
 Collection Date: 12/22/2020 9:17:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER43

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.356		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-44      Client Sample ID: ER44  
 Collection Date: 12/22/2020 9:17:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER44

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.594		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-45      Client Sample ID: ER45  
 Collection Date: 12/22/2020 9:19:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER45

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.307		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-46      Client Sample ID: ER46  
 Collection Date: 12/22/2020 9:19:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER46

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.268		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-47      Client Sample ID: ER47  
 Collection Date: 12/22/2020 9:21:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER47

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.66		0.103	µg/L	1	12/30/2020	15.0	A


**Lab ID:** 20121199-48      Client Sample ID: ER48  
 Collection Date: 12/22/2020 9:21:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER48

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.651		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-49      Client Sample ID: ER49  
 Collection Date: 12/22/2020 9:30:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER49

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.311		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-50      Client Sample ID: ER50  
 Collection Date: 12/22/2020 9:30:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER50

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.324		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-51      Client Sample ID: ER51  
 Collection Date: 12/22/2020 9:32:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER51

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.249		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-52      Client Sample ID: ER52  
 Collection Date: 12/22/2020 9:32:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER52

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.333		0.103	µg/L	1	12/30/2020	15.0	A	

**Lab ID:** 20121199-53      Client Sample ID: ER53  
 Collection Date: 12/22/2020 9:33:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER53

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.332		0.103	µg/L	1	12/30/2020	15.0	A	

**Lab ID:** 20121199-54      Client Sample ID: ER54  
 Collection Date: 12/22/2020 9:34:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER54

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.209		0.103	µg/L	1	12/30/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-55      Client Sample ID: ER55  
 Collection Date: 12/22/2020 9:35:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER55

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.391		0.103	µg/L	1	12/30/2020	15.0	A

**Lab ID:** 20121199-56      Client Sample ID: ER56  
 Collection Date: 12/22/2020 9:40:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER56

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.479		0.103	µg/L	1	12/30/2020	15.0	A


**Lab ID:** 20121199-57      Client Sample ID: ER57  
 Collection Date: 12/22/2020 9:40:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER57

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.424		0.103	µg/L	1	12/30/2020	15.0	A

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-58      Client Sample ID: ER58  
 Collection Date: 12/22/2020 9:45:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER58

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.73		0.103	µg/L	1	12/30/2020	15.0	A	

**Lab ID:** 20121199-59      Client Sample ID: ER59  
 Collection Date: 12/22/2020 9:50:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER59

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.38		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-60      Client Sample ID: ER60  
 Collection Date: 12/22/2020 9:50:00 AM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER60

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	4.58		0.103	µg/L	1	12/31/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-61      Client Sample ID: ER61  
 Collection Date: 12/21/2020 12:30:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER61

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.58		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-62      Client Sample ID: ER62  
 Collection Date: 12/21/2020 12:30:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER62

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.613		0.103	µg/L	1	12/31/2020	15.0	A	


**Lab ID:** 20121199-63      Client Sample ID: ER63  
 Collection Date: 12/21/2020 12:45:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER63

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	14.2		0.103	µg/L	1	12/31/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-64      Client Sample ID: ER64  
 Collection Date: 12/21/2020 12:45:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER64

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.61		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-65      Client Sample ID: ER65  
 Collection Date: 12/21/2020 12:50:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER65

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.52		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-66      Client Sample ID: ER66  
 Collection Date: 12/21/2020 12:55:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER66

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	5.86		0.103	µg/L	1	12/31/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-67      Client Sample ID: ER67  
 Collection Date: 12/21/2020 1:00:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER67

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.61		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-68      Client Sample ID: ER68  
 Collection Date: 12/21/2020 1:10:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER68

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	9.18		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-69      Client Sample ID: ER69  
 Collection Date: 12/21/2020 1:15:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER69

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.831		0.103	µg/L	1	12/31/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-70      Client Sample ID: ER70  
 Collection Date: 12/21/2020 1:15:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER70

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.01		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-71      Client Sample ID: ER71  
 Collection Date: 12/21/2020 1:15:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER71

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	47.0	*	0.100	µg/L	1	12/29/2020	15.0	A	

**Lab ID:** 20121199-72      Client Sample ID: ER72  
 Collection Date: 12/21/2020 1:15:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER72

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	6.33		0.103	µg/L	1	12/31/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20121199  
 Date Reported: 1/9/2021

Eagle Point School District #9  
 PO Box 548  
 Eagle Point, OR 97524

**Lab Order:** 20121199  
**Received Date:** 12/22/2020 11:42:00 AM  
**Reported Date:** 1/9/2021 10:46:46 AM

Sample Information:

**Lab ID:** 20121199-73      Client Sample ID: ER73  
 Collection Date: 12/21/2020 1:15:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER73

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	5.23		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-74      Client Sample ID: ER74  
 Collection Date: 12/21/2020 1:15:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER74

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	10.9		0.103	µg/L	1	12/31/2020	15.0	A	

**Lab ID:** 20121199-75      Client Sample ID: ER75  
 Collection Date: 12/21/2020 1:45:00 PM      Collected By: Fred Estabrook  
 Matrix: Drinking Water      Sample Location: ER75

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	34.2	*	0.100	µg/L	1	12/29/2020	15.0	A	

<b>QUALIFIERS</b>	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 20121199  
 09-Jan-21

**Client:** Eagle Point School District #9  
**Project:** Eagle Rock Elementary

**TestCode:** LEAD\_DW

Sample ID: <b>MB-10264</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/29/2020</b>	RunNo: <b>18105</b>						
Client ID: <b>PBW</b>	Batch ID: <b>10264</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/29/2020</b>	SeqNo: <b>263570</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.100									

Sample ID: <b>LCS-10264</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/29/2020</b>	RunNo: <b>18105</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>10264</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/29/2020</b>	SeqNo: <b>263571</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	99.4	0.100	100	0	99.4	85	115				

Sample ID: <b>20121199-75AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/29/2020</b>	RunNo: <b>18105</b>						
Client ID: <b>ER75</b>	Batch ID: <b>10264</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/29/2020</b>	SeqNo: <b>263581</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	131	0.100	100	34.2	97.1	70	130				

Sample ID: <b>20121199-75AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/29/2020</b>	RunNo: <b>18105</b>						
Client ID: <b>ER75</b>	Batch ID: <b>10264</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/29/2020</b>	SeqNo: <b>263582</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	130	0.100	100	34.2	96.1	70	130	131	0.796	20	

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- PL Permit Limit
- CI Sample container temperature is out of limit as specified at testcode
- MI Recovery outside control limits due to Matrix Interference
- RL Reporting Detection Limit
- E Value above quantitation range
- ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 20121199  
 09-Jan-21

**Client:** Eagle Point School District #9  
**Project:** Eagle Rock Elementary

**TestCode:** LEAD\_DW

Sample ID: <b>MB-10249</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>PBW</b>	Batch ID: <b>10249</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/29/2020</b>	SeqNo: <b>263624</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.103			

Sample ID: <b>LCS-10249</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>LCSW</b>	Batch ID: <b>10249</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/29/2020</b>	SeqNo: <b>263625</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	102	0.104	100	0	102 85 115

Sample ID: <b>20121199-18AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>ER18</b>	Batch ID: <b>10249</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263646</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	97.3	0.104	100	0.919	96.4 70 130

Sample ID: <b>20121199-18AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>ER18</b>	Batch ID: <b>10249</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263647</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	99.7	0.104	100	0.919	98.8 70 130 97.3 2.50 20

**Qualifiers:** \* Value exceeds Maximum Contaminant Level. CI Sample container temperature is out of limit as specified at testcode E Value above quantitation range  
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit  
 PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 20121199  
 09-Jan-21

**Client:** Eagle Point School District #9

**Project:** Eagle Rock Elementary

**TestCode:** LEAD\_DW

Sample ID: <b>MB-10250</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>PBW</b>	Batch ID: <b>10250</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263650</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.103									
------	----	-------	--	--	--	--	--	--	--	--	--

Sample ID: <b>LCS-10250</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>LCSW</b>	Batch ID: <b>10250</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263651</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	102	0.104	100	0	102	85	115				
------	-----	-------	-----	---	-----	----	-----	--	--	--	--

Sample ID: <b>20121199-38AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>ER38</b>	Batch ID: <b>10250</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263674</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	103	0.104	100	1.36	102	70	130				
------	-----	-------	-----	------	-----	----	-----	--	--	--	--

Sample ID: <b>20121199-38AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>ER38</b>	Batch ID: <b>10250</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263675</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	102	0.104	100	1.36	100	70	130	103	1.22	20	
------	-----	-------	-----	------	-----	----	-----	-----	------	----	--

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level.
- H Holding times for preparation or analysis exceeded
- PL Permit Limit
- CI Sample container temperature is out of limit as specified at testcode
- MI Recovery outside control limits due to Matrix Interference
- RL Reporting Detection Limit
- E Value above quantitation range
- ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 20121199  
 09-Jan-21

**Client:** Eagle Point School District #9  
**Project:** Eagle Rock Elementary

**TestCode:** LEAD\_DW

Sample ID: <b>MB-10251</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>PBW</b>	Batch ID: <b>10251</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263678</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.103			

Sample ID: <b>LCS-10251</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>LCSW</b>	Batch ID: <b>10251</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263679</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	103	0.104	100	0	103 85 115

Sample ID: <b>20121199-58AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>ER58</b>	Batch ID: <b>10251</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263702</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	103	0.104	100	1.73	102 70 130

Sample ID: <b>20121199-58AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/28/2020</b>	RunNo: <b>18105</b>
Client ID: <b>ER58</b>	Batch ID: <b>10251</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/30/2020</b>	SeqNo: <b>263703</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	102	0.104	100	1.73	100 70 130 103 1.48 20

**Qualifiers:** \* Value exceeds Maximum Contaminant Level. CI Sample container temperature is out of limit as specified at testcode E Value above quantitation range  
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit  
 PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 20121199  
 09-Jan-21

**Client:** Eagle Point School District #9  
**Project:** Eagle Rock Elementary

**TestCode:** LEAD\_DW

Sample ID: <b>MB-10261</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/29/2020</b>	RunNo: <b>18165</b>
Client ID: <b>PBW</b>	Batch ID: <b>10261</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/31/2020</b>	SeqNo: <b>264664</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.103			

Sample ID: <b>LCS-10261</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/29/2020</b>	RunNo: <b>18165</b>
Client ID: <b>LCSW</b>	Batch ID: <b>10261</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/31/2020</b>	SeqNo: <b>264665</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	95.5	0.104	100	0	95.5 85 115

Sample ID: <b>20121203-03AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/29/2020</b>	RunNo: <b>18165</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>10261</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/31/2020</b>	SeqNo: <b>264688</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	93.8	0.104	100	0	93.8 70 130

Sample ID: <b>20121203-03AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/29/2020</b>	RunNo: <b>18165</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>10261</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/31/2020</b>	SeqNo: <b>264689</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	94.8	0.104	100	0	94.8 70 130 93.8 1.02 20

**Qualifiers:** \* Value exceeds Maximum Contaminant Level. CI Sample container temperature is out of limit as specified at testcode E Value above quantitation range  
 H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit  
 PL Permit Limit RL Reporting Detection Limit

Original

# Sample Log-In Check List

Client Name: **EAGLEPTSCHOOL** Work Order Number: **20121199** RcptNo: **1**

Logged by:	<b>Sarah Spence</b>	<b>12/22/2020 11:42:00 AM</b>	<i>Sarah Spence</i>
Completed By:	<b>Katherine Crooks</b>	<b>12/23/2020 12:48:19 PM</b>	<i>Katherine Crooks</i>
Reviewed By:	<b>Naomi Orr</b>	<b>1/8/2021 12:05:03 PM</b>	<i>Naomi Orr</i>

**Chain of Custody**

1. Is Chain of Custody complete? Yes  No  Not Present   
 2. How was the sample delivered? Client

**Log In**

3. Coolers are present? Yes  No  NA   
 4. Shipping container/cooler in good condition? Yes  No   
 Custody seals intact on shipping container/cooler? Yes  No  Not Present   
 No. Seal Date: Signed By:  
 5. Was an attempt made to cool the samples? Yes  No  NA   
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes  No  NA   
 7. Sample(s) in proper container(s)? Yes  No   
 8. Sufficient sample volume for indicated test(s)? Yes  No   
 9. Are samples (except VOA and ONG) properly preserved? Yes  No   
 10. Was preservative added to bottles? Yes  No  NA   
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes  No  HNO<sub>3</sub>, pH<2  
 No VOA Vials   
 12. Were any sample containers received broken? Yes  No   
 13. Does paperwork match bottle labels? Yes  No   
 (Note discrepancies on chain of custody)  
 14. Are matrices correctly identified on Chain of Custody? Yes  No   
 15. Is it clear what analyses were requested? Yes  No   
 16. Were all holding times able to be met? Yes  No   
 (If no, notify customer for authorization.)

**Special Handling (if applicable)**

17. Was client notified of all discrepancies with this order? Yes  No  NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:  
The sample submitted contained visible sediments (samples 08, 10, 11, 12, 40)

**Cooler Information**

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b> Required Client Information	<b>Section B</b> Required Project Information	<b>Section C</b> Invoice Information	<b>Section D</b> Rush Status (Subject to Scheduling)
Company: <u>EAGLE POINT SD#9</u>	Project Name: <u>Eagle Rock Elem</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>203 N. PLATT</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>EAGLE POINT, OR 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>hardingj@eaglepointk12.or.us</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: <u>541-473-5710</u> Fax:			<input type="checkbox"/> Other _____
Collected By (Print): <u>FRED ESTABROOK</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No		
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					No. of Containers	Analysis Requested										NRC Workorder # <u>20221199</u> (Lab Use Only)	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks/Field Data	NRC Sample # (Lab Use Only)										
ER1			12/22	6:45	✓												
ER2				6:47	✓												
ER3				6:47	✓												
ER4				6:50	✓												
ER5				6:50	✓												
ER6				6:52	✓												
ER7				6:52	✓												
ER8				6:52	✓												
ER9				6:54	✓												
ER10				6:54	✓												

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>FRED ESTABROOK</u>		12/22	8:17
Received By: <u>[Signature]</u>		<u>John Harding</u>		12/22	8:17
Relinquished By: <u>[Signature]</u>		<u>FRED ESTABROOK</u>		<del>12/22</del>	<del>8:17</del>
Received By:					
Relinquished By: <u>[Signature]</u>		<u>John Harding</u>		12/22/2020	1142
Received By Laboratory: <u>[Signature]</u>		<u>JMS</u>		12/22/2020	1142

Section G Lab Use Only	
Temp: <u>Amb</u>	
4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Number of Bottles Received: <u>75</u>	
pH Checked: <u>N/A</u>	
COC Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Received Via  UPS  FedEx  Other  Hand

Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_



Environmental Testing Laboratory  
245 South Grape Street \* Medford, OR 97501  
(541) 770-5678 Fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b> Required Client Information		<b>Section B</b> Required Project Information		<b>Section C</b> Invoice Information		<b>Section D</b> Rush Status (Subject to Scheduling)	
Company: <u>Eagle Point SD#9</u>		Project Name: <u>Eagle Rock Clarity</u>		Attention:		<input checked="" type="checkbox"/> Standard 10-14 Days	
Address: <u>203 N. Platt</u>		Project Number:		Company Name:		<input type="checkbox"/> 5 Business Days (50% surcharge)	
<u>Eagle Point, OR 97524</u>		Report To:		Address:		<input type="checkbox"/> 3 Business Days (75% surcharge)	
Email: <u>HARDINGJ@eaglepoint.kiz.or.us</u>		Copy To:		P.O. #		<input type="checkbox"/> 24 - 48 hours (100% surcharge)	
Phone: <u>(541) 993-7710</u> Fax:						<input type="checkbox"/> Other _____	
Collected By (Print): <u>FRED ESTARCOOK</u>						Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Collected By (Sign): <u>[Signature]</u>							
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No					
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No							

Section E Sample Information					No. of Containers	Analysis Requested						NRC Workorder # (Lab Use Only) <u>20121199</u>	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Lead							Remarks/Field Data
FR11			12/21	6:56	✓								11
FR12				6:56	✓								12
ER13				6:56	✓								13
FR14				7:02	✓								14
ER15				7:02	✓								15
ER16				7:02	✓								16
ER17				7:50	✓								17
ER18				7:50	✓								18
ER19				7:55	✓								19
ER20				7:55	✓								20

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>		<u>FRED ESTARCOOK</u>	<u>12/22</u>	<u>8:17</u>
Received By:	<u>[Signature]</u>		<u>John Harding</u>	<u>12/22</u>	<u>8:17</u>
Relinquished By:	<u>[Signature]</u>		<u>FRED ESTARCOOK</u>		
Received By:					
Relinquished By:	<u>[Signature]</u>		<u>John Harding</u>	<u>12/22/2020</u>	<u>1142</u>
Received By Laboratory:	<u>[Signature]</u>		<u>JNSPERCE</u>	<u>12/22/2020</u>	<u>1142</u>

<b>Section G</b> Lab Use Only	
Temp:	<u>Am V</u>
4°C +/- 2°C:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received:	<u>75</u>
pH Checked:	<u>N/A</u>
COC Seals Intact:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Field Blank Included:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via  UPS  FedEx  Other  Hand

Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_



# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b> Required Client Information	<b>Section B</b> Required Project Information	<b>Section C</b> Invoice Information	<b>Section D</b> Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>Edge Rock Clean</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>203 N. Platt</u> <u>Eagle Point, OR 97524</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
Email: <u>HARDING J@eaglepnt.k12.or.us</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Phone: <u>541-973-7710</u> Fax:	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Collected By (Print): <u>FRED ESTABROOK</u>			<input type="checkbox"/> Other _____
Collected By (Sign): <u>[Signature]</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					No. of Containers	Analysis Requested										NRC Workorder # <u>20121199</u> (Lab Use Only)			
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks/Field Data	NRC Sample # (Lab Use Only)												
ER31			<u>12/22</u>	<u>8:20</u>	Lead												<u>31</u>	<u>30</u>	
ER32				<u>8:20</u>														<u>32</u>	<u>31</u>
ER33				<u>8:30</u>														<u>33</u>	<u>32</u>
ER34				<u>8:30</u>														<u>34</u>	<u>33</u>
ER35				<u>8:32</u>														<u>35</u>	<u>34</u>
ER36				<u>8:32</u>														<u>36</u>	<u>35</u>
ER37				<u>8:35</u>														<u>37</u>	<u>36</u>
ER38				<u>8:35</u>														<u>38</u>	<u>37</u>
ER39				<u>8:37</u>														<u>39</u>	<u>38</u>
ER40				<u>8:37</u>														<u>40</u>	<u>39</u>

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>		<u>FRED ESTABROOK</u>	<u>12/22</u>	<u>8:17</u>
Received By:	<u>[Signature]</u>		<u>John Harding</u>	<u>12/22</u>	<u>8:17</u>
Relinquished By:					
Received By:					
Relinquished By:	<u>[Signature]</u>		<u>John Harding</u>	<u>12/22/2012</u>	<u>1142</u>
Received By Laboratory:	<u>[Signature]</u>		<u>JMS</u>	<u>12/22/2012</u>	<u>1142</u>

Section G Lab Use Only	
Temp:	<u>AM10</u>
4°C +/- 2°C:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received:	<u>75</u>
pH Checked:	<u>N/A</u>
COC Seals Intact:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Field Blank Included:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via  UPS  FedEx  Other  Hand

Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>EAGLE POINT SD #9</u>	Project Name: <u>Eagle Rock Elem</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days <input type="checkbox"/> 5 Business Days (50% surcharge) <input type="checkbox"/> 3 Business Days (75% surcharge) <input type="checkbox"/> 24 - 48 hours (100% surcharge) <input type="checkbox"/> Other _____
Address: <u>203 N. PLATT</u>	Project Number:	Company Name:	
<u>EAGLE POINT, OR 97524</u>	Report To:	Address:	
Email: <u>HARDINGJ@eaglepoint.k12.or.us</u>	Copy To:	P.O. #	
Phone: <u>541-978-7710</u> Fax:			
Collected By (Print): <u>FRED ESTABROOK</u>			
Collected By (Sign): <u>[Signature]</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

### Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
ER 41			12/22	9:15	✓		30121199	41
ER 42				9:15	✓			42
ER 43				9:17	✓			43
ER 44				9:17	✓			44
ER 45				9:19	✓			45
ER 46				9:19	✓			46
ER 47				9:21	✓			47
ER 48				9:21	✓			48
ER 49				9:30	✓			49
ER 50				9:30	✓			50

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

*Handwritten notes: "lead" in the No. of Containers column; "Error on 12/22/20" and "41-49" in the NRC Sample # column.*

### Section F Relinquish/Receive

Relinquished/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>FRED ESTABROOK</u>	<u>FRED ESTABROOK</u>	<u>12/22</u>	<u>9:17</u>
Received By: <u>[Signature]</u>	<u>John Harding</u>	<u>John Harding</u>	<u>12/22</u>	<u>9:17</u>
Relinquished By: <u>[Signature]</u>	<u>John Harding</u>	<u>John Harding</u>	<u>12/22/2020</u>	<u>1142</u>
Received By Laboratory: <u>JNS</u>	<u>JNS</u>	<u>JNS</u>	<u>12/22/2020</u>	<u>1142</u>

### Section G Lab Use Only

Temp: amb

4°C +/- 2°C:  Yes  No

Received on Ice:  Yes  No

Number of Bottles Received: 75

pH Checked: N/A

COC Seals Intact:  Yes  No  NA

Field Blank Included:  Yes  No

Received Via  UPS  FedEx  Other  Hand

Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

**Section A**

**Required Client Information**

Company: EAGLE POINT SD #9  
 Address: 203 N. Platt  
EAGLE POINT, OR 97524  
 Email: HARDINGJ@EAGLEPNT.K12.OR.US  
 Phone: 541-973-7710 Fax: \_\_\_\_\_  
 Collected By (Print): FRED ESTABROOK  
 Collected By (Sign): [Signature]  
 Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

**Section B**

**Required Project Information**

Project Name: Eagle Rock Claim  
 Project Number: \_\_\_\_\_  
 Report To: \_\_\_\_\_  
 Copy To: \_\_\_\_\_

**Section C**

**Invoice Information**

Attention: \_\_\_\_\_  
 Company Name: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 P.O. # \_\_\_\_\_

**Section D**

**Rush Status (Subject to Scheduling)**

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

**Section E**

**Sample Information**

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)		Remarks/Field Data	NRC Sample # (Lab Use Only)
ER51			12/22	9:32	1													51	50
ER52				9:32	1													52	51
ER53				9:33	1													53	52
ER54				9:34	1													54	53
ER55				9:35	1													55	54
ER56				9:40	1													56	55
ER57				9:40	1													57	56
ER58				9:45	1													58	57
ER59				9:50	1													59	58
ER60				9:50	1													60	59

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F**

**Relinquish/Receive**

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>FRED ESTABROOK</u>	<u>12/22</u>	<u>8:17</u>
Received By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/22</u>	<u>8:17</u>
Relinquished By: _____	_____	_____	_____	_____
Received By: _____	_____	_____	_____	_____
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/22/2020</u>	<u>1142</u>
Received By Laboratory: <u>[Signature]</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>12/22/2020</u>	<u>1142</u>

**Section G**

**Lab Use Only**

Temp: Amb  
 4°C +/- 2°C:  Yes  No  
 Received on Ice:  Yes  No  
 Number of Bottles Received: 75  
 pH Checked: N/A  
 COC Seals Intact:  Yes  No  NA  
 Field Blank Included:  Yes  No

Received Via  UPS  FedEx  Other  Hand

Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_



Environmental Testing Laboratory  
245 South Grape Street \* Medford, OR 97501  
(541) 770-5678 fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b> Required Client Information	<b>Section B</b> Required Project Information	<b>Section C</b> Invoice Information	<b>Section D</b> Rush Status (Subject to Scheduling)
Company: <u>EAGLE POINT SD 109</u>	Project Name: <u>Eagle Rock Elem</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>203 N. PLATT</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>EAGLE POINT, OR 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>HARDINGJO@eaglepnt.k12.or.us</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: <u>541-973-7710</u> Fax:			<input type="checkbox"/> Other _____
Collected By (Print): <u>FRED ESTABROOK</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

**Section E**  
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder #: (Lab Use Only) <u>2012/199</u>	NRC Sample # (Lab Use Only)
ER 61			<u>12/22</u>	<u>12:30</u>	<u>1</u>												<u>61</u>
ER 62				<u>12:30</u>	<u>1</u>												<u>62</u>
ER 63				<u>12:45</u>	<u>1</u>												<u>63</u>
ER 64				<u>12:45</u>	<u>1</u>												<u>64</u>
ER 65				<u>12:50</u>	<u>1</u>												<u>65</u>
ER 66				<u>12:55</u>	<u>1</u>												<u>66</u>
ER 67				<u>1:00</u>	<u>1</u>												<u>67</u>
ER 68				<u>1:10</u>	<u>1</u>												<u>68</u>
ER 69				<u>1:15</u>	<u>1</u>												<u>69</u>
ER 70				<u>1:15</u>	<u>1</u>												<u>70</u>

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F**

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>FRED ESTABROOK</u>	<u>12/22</u>	<u>8:17</u>
Received By: <u>[Signature]</u>		<u>John Harding</u>	<u>12/22</u>	<u>8:17</u>
Relinquished By:				
Received By:				
Relinquished By: <u>[Signature]</u>		<u>John Harding</u>	<u>12/22/2012</u>	<u>1142</u>
Received By Laboratory: <u>[Signature]</u>		<u>JNS</u>	<u>12/22/2012</u>	<u>1142</u>

**Section G**  
Lab Use Only

Temp: <u>Amb</u>
4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received: <u>75</u>
pH Checked: <u>N/A</u>
COC Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via  UPS  FedEx  Other  Hand

Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>EAGLE POINT SD#9</u>	Project Name: <u>Eagle Rock Elem</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days <input type="checkbox"/> 5 Business Days (50% surcharge) <input type="checkbox"/> 3 Business Days (75% surcharge) <input type="checkbox"/> 24 - 48 hours (100% surcharge) <input type="checkbox"/> Other _____
Address: <u>203 N. PLATT</u>	Project Number:	Company Name:	
<u>EAGLE POINT, OR 97524</u>	Report To:	Address:	
Email: <u>HARDINGJO@EAGLEPNT.K12.OR.US</u>	Copy To:	P.O. #	
Phone: <u>541-913-7710</u> Fax:			
Collected By (Print): <u>FRED ESTABROOK</u>			
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No		
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

**Section E  
Sample Information**

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
ER 71			12/22	1:15	✓		20121199	71	70
ER 72				1:15	✓			72	71
ER 73				1:15	✓			73	72
ER 74				1:15	✓			74	73
ER 75				1:45	✓			75	74

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F  
Relinquish/Receive**

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>FRED ESTABROOK</u>	12/22	8:17
Received By: <u>[Signature]</u>		<u>John Harding</u>	12/22	8:17
Relinquished By:				
Received By:				
Relinquished By: <u>[Signature]</u>		<u>John Harding</u>	12/22/2020	1142
Received By Laboratory: <u>[Signature]</u>		<u>S.N. SPENCE</u>	12/22/2020	1142

**Section G  
Lab Use Only**

Temp: <u>Amb</u>
4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received: <u>11475</u>
pH Checked: <u>N/A</u>
COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via  UPS  FedEx  Other  Hand

Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

- B Analyte detected in the associated method blank.
- BA BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- D1 The diesel elution pattern for the sample is not typical.
- D2 The sample appears to be a heavier hydrocarbon range than diesel.
- D3 The sample appears to be a lighter hydrocarbon range than diesel.
- D4 Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
- D5 Detected hydrocarbons in the diesel range appear to be weathered diesel.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- G1 The gasoline elution pattern for the sample is not typical.
- G2 The sample appears to be a heavier hydrocarbon range than gasoline.
- G3 The sample appears to be a lighter hydrocarbon range than gasoline.
- G4 Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT  At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- NLR No Legionella Recovered.
- PLR Presence of Legionella Recovered.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 Duplicate analysis failed due to result being at or near the method reporting limit.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- # Value exceeds regulatory level for TCLP contaminant.
- X1 The motor oil elution pattern for the sample is not typical.
- X2 The sample appears to be a heavier hydrocarbon range than motor oil.
- X3 The sample appears to be a lighter hydrocarbon range than motor oil.
- \* Value exceeds Maximum Contaminant Level or is outside the acceptable range.