



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

December 29, 2020

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX: (541) 830-6375

RE: Hillside Elementary

Order No.: 20120819

Dear John Harding:

Neilson Research Corporation received 89 sample(s) on 12/15/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Original



**NEILSON
RESEARCH
CORPORATION**

*Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com*

Case Narrative

WO#: 20120819
Date: 12/29/2020


CLIENT: Eagle Point School District #9

Project: Hillside Elementary

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-01 Client Sample ID: A-Rm #2 Sink
 Collection Date: 12/15/2020 5:54:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #2 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.386		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-02 Client Sample ID: A-Rm #2 Fountain
 Collection Date: 12/15/2020 5:54:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #2 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.461		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-03 Client Sample ID: A-Rm #4 Sink
 Collection Date: 12/15/2020 5:57:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #4 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.654		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-04 Client Sample ID: A-Rm #4 Fountain
 Collection Date: 12/15/2020 5:57:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #4 Fountain

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.723		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-05 Client Sample ID: A-Rm #6 Sink
 Collection Date: 12/15/2020 5:59:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #6 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.454		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-06 Client Sample ID: A-Rm #6 Fountain
 Collection Date: 12/15/2020 5:59:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #6 Fountain

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.411		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-07 Client Sample ID: A-Girls RR Sink #1
 Collection Date: 12/15/2020 5:42:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Girls RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.523		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-08 Client Sample ID: A-Girls RR Sink #2
 Collection Date: 12/15/2020 5:40:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Girls RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.37		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-09 Client Sample ID: A-Boys RR Sink #1
 Collection Date: 12/15/2020 5:36:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Boys RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.282		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-10 Client Sample ID: A-Boys RR Sink #2
 Collection Date: 12/15/2020 5:35:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Boys RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.23		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-11 Client Sample ID: A-Rm #1 Sink
 Collection Date: 12/15/2020 5:53:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #1 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.72		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-12 Client Sample ID: A-Rm #1 Fountain
 Collection Date: 12/15/2020 5:52:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #1 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.754		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-13 Client Sample ID: A-Rm #3 Sink
 Collection Date: 12/15/2020 5:49:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #3 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.49		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-14 Client Sample ID: A-Rm #3 Fountain
 Collection Date: 12/15/2020 5:50:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #3 Fountain

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	25.3	*	0.100	µg/L	1	12/20/2020	15.0	A	

Lab ID: 20120819-15 Client Sample ID: A-Rm #5 Sink
 Collection Date: 12/15/2020 5:47:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #5 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.375		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-16 Client Sample ID: A-Rm #5 Fountain
 Collection Date: 12/15/2020 5:45:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: A-Rm #5 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.340		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-17 Client Sample ID: B-Rm #2 Sink
 Collection Date: 12/15/2020 4:57:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #2 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.368		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-18 Client Sample ID: B-Rm #2 Fountain
 Collection Date: 12/15/2020 4:59:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #2 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.438		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-19 Client Sample ID: B-Rm #4 Sink
 Collection Date: 12/15/2020 4:54:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #4 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.593		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-20 Client Sample ID: B-Rm #4 Fountain
 Collection Date: 12/15/2020 4:53:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #4 Fountain

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.774		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-21 Client Sample ID: B-Rm #6 Sink
 Collection Date: 12/15/2020 4:51:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #6 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.417		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-22 Client Sample ID: B-Rm #6 Fountain
 Collection Date: 12/15/2020 4:50:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #6 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.270		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-23 Client Sample ID: B-Girls RR Sink #1
 Collection Date: 12/15/2020 5:25:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Girls RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.97		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-24 Client Sample ID: B-Girls RR Sink #2
 Collection Date: 12/15/2020 5:23:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Girls RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.419		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-25 Client Sample ID: B-Boys RR Sink #1
 Collection Date: 12/15/2020 5:19:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Boys RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	1.02		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-26 Client Sample ID: B-Boys RR Sink #2
 Collection Date: 12/15/2020 5:13:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Boys RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.581		0.103	µg/L	1	12/19/2020	15.0	A	


Lab ID: 20120819-27 Client Sample ID: B-Rm #1 Sink
 Collection Date: 12/15/2020 5:12:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #1 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.435		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-28 Client Sample ID: B-Rm #1 Fountain
 Collection Date: 12/15/2020 5:16:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #1 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.521		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-29 Client Sample ID: B-Rm #3 Sink
 Collection Date: 12/15/2020 5:10:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #3 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.410		0.103	µg/L	1	12/19/2020	15.0	A


Lab ID: 20120819-30 Client Sample ID: B-Rm #3 Fountain
 Collection Date: 12/15/2020 5:13:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #3 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.451		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-31 Client Sample ID: B-Rm #5 Sink
 Collection Date: 12/15/2020 5:05:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #5 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.338		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-32 Client Sample ID: B-Rm #5 Fountain
 Collection Date: 12/15/2020 5:03:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: B-Rm #5 Fountain

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.466		0.103	µg/L	1	12/19/2020	15.0	A	


Lab ID: 20120819-33 Client Sample ID: C-Rm #2 Sink
 Collection Date: 12/15/2020 6:12:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #2 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.896		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-34 Client Sample ID: C-Rm #2 Fountain
 Collection Date: 12/15/2020 6:10:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #2 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.686		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-35 Client Sample ID: C-Rm #4 Sink
 Collection Date: 12/15/2020 6:14:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #4 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.354		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-36 Client Sample ID: C-Rm #4 Fountain
 Collection Date: 12/15/2020 6:15:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #4 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.414		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-37 Client Sample ID: C-Rm #6 Sink
 Collection Date: 12/15/2020 6:20:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #6 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.515		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-38 Client Sample ID: C-Rm #6 Fountain
 Collection Date: 12/15/2020 6:17:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #6 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.468		0.103	µg/L	1	12/19/2020	15.0	A


Lab ID: 20120819-39 Client Sample ID: C-Girls RR Sink #1
 Collection Date: 12/15/2020 6:04:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Girls RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.857		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-40 Client Sample ID: C-Girls RR Sink #2
 Collection Date: 12/15/2020 6:00:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Girls RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.85		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-41 Client Sample ID: C-Boys RR Sink #1
 Collection Date: 12/15/2020 6:16:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Boys RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.87		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-42 Client Sample ID: C-Boys RR Sink #2
 Collection Date: 12/15/2020 6:15:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Boys RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.321		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-43 Client Sample ID: C-Rm #1 Sink
 Collection Date: 12/15/2020 6:00:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #1 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.772		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-44 Client Sample ID: C-Rm #1 Fountain
 Collection Date: 12/15/2020 6:07:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #1 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.426		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-45 Client Sample ID: C-Rm #3 Sink
 Collection Date: 12/15/2020 6:05:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #3 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.24		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-46 Client Sample ID: C-Rm #3 Fountain
 Collection Date: 12/15/2020 6:02:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #3 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.562		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-47 Client Sample ID: C-Rm #5 Sink
 Collection Date: 12/15/2020 6:15:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #5 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.339		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-48 Client Sample ID: C-Rm #5 Fountain
 Collection Date: 12/15/2020 6:15:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: C-Rm #5 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.439		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-49 Client Sample ID: D-Boys RR Sink #1
 Collection Date: 12/15/2020 7:00:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Boys RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.263		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-50 Client Sample ID: D-Boys RR Sink #2
 Collection Date: 12/15/2020 7:00:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Boys RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.517		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-51 Client Sample ID: D-Girls RR Sink #1
 Collection Date: 12/15/2020 6:50:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Girls RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.07		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-52 Client Sample ID: D-Girls RR Sink #2
 Collection Date: 12/15/2020 7:00:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Girls RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.83		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-53 Client Sample ID: D-Shower Rm Sink
 Collection Date: 12/15/2020 6:50:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Shower Rm Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.597		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-54 Client Sample ID: D-Shower
 Collection Date: 12/15/2020 6:45:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Shower

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	36.8	*	0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-55 Client Sample ID: D-Rm #2 Sink
 Collection Date: 12/15/2020 6:42:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #2 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.410		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-56 Client Sample ID: D-Rm #2 Fountain
 Collection Date: 12/15/2020 6:45:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #2 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.754		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-57 Client Sample ID: D-Rm #4 Sink
 Collection Date: 12/15/2020 6:40:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #4 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.591		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-58 Client Sample ID: D-Rm #4 Fountain
 Collection Date: 12/15/2020 6:40:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #4 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.842		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-59 Client Sample ID: D-Rm #6 Sink
 Collection Date: 12/15/2020 6:37:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #6 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.243		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-60 Client Sample ID: D-Rm #6 Fountain
 Collection Date: 12/15/2020 6:37:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #6 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.478		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-61 Client Sample ID: D-Rm #1 Sink
 Collection Date: 12/15/2020 6:35:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #1 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.661		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-62 Client Sample ID: D-Rm #1 Fountain
 Collection Date: 12/15/2020 6:35:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #1 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.445		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-63 Client Sample ID: D-Rm #3 Sink
 Collection Date: 12/15/2020 6:30:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #3 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.11		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-64 Client Sample ID: D-Rm #3 Fountain
 Collection Date: 12/15/2020 6:30:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #3 Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.34		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-65 Client Sample ID: D-Rm #5 Sink
 Collection Date: 12/15/2020 6:30:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #5 Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.379		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-66 Client Sample ID: D-Rm #5 Fountains
 Collection Date: 12/15/2020 6:30:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: D-Rm #5 Fountains

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.472		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-67 Client Sample ID: Courtyard Fountain #1
 Collection Date: 12/15/2020 4:43:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Courtyard Fountain #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.676		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-68 Client Sample ID: Gym Boys RR Sink #1
 Collection Date: 12/15/2020 4:31:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Gym Boys RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.736		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-69 Client Sample ID: Gym Boys RR Sink #2
 Collection Date: 12/15/2020 4:23:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Gym Boys RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.74		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-70 Client Sample ID: Gym Girls RR Sink #1
 Collection Date: 12/15/2020 4:35:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Gym Girls RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.378		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-71 Client Sample ID: Gym Girls RR Sink #2
 Collection Date: 12/15/2020 4:40:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Gym Girls RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.509		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-72 Client Sample ID: Kitchen Sink #1
 Collection Date: 12/15/2020 4:21:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Kitchen Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.500		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-73 Client Sample ID: Kitchen Handwash #2
 Collection Date: 12/15/2020 4:17:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Kitchen Handwash #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.700		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-74 Client Sample ID: Eye Wash KEW Station #3
 Collection Date: 12/15/2020 4:12:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Eye Wash KEW Station #3

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.78		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-75 Client Sample ID: Kitchen Sink #4
 Collection Date: 12/15/2020 4:15:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Kitchen Sink #4

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.31		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-76 Client Sample ID: Kitchen Sink #5
 Collection Date: 12/15/2020 4:19:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Kitchen Sink #5

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.554		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-77 Client Sample ID: Kitchen HW #6 (Hand Wash)
 Collection Date: 12/15/2020 4:20:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Kitchen HW #6 (Hand Wash)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.528		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-78 Client Sample ID: Kitchen Sink #7
 Collection Date: 12/15/2020 4:20:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Kitchen Sink #7

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.247		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-79 Client Sample ID: Gym Fountain #1
 Collection Date: 12/15/2020 4:26:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Gym Fountain #1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.729		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-80 Client Sample ID: Gym Fountain #2
 Collection Date: 12/15/2020 4:38:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Gym Fountain #2

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.653		0.103	µg/L	1	12/19/2020	15.0	A	

Lab ID: 20120819-81 Client Sample ID: Hallway Fountain #1
 Collection Date: 12/15/2020 4:36:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Hallway Fountain #1

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.722		0.103	µg/L	1	12/19/2020	15.0	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-82 Client Sample ID: Hallway Fountain #2
 Collection Date: 12/15/2020 4:23:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Hallway Fountain #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.904		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-83 Client Sample ID: Hallway Fountain #3
 Collection Date: 12/15/2020 4:24:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Hallway Fountain #3

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.158		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-84 Client Sample ID: Staff RR Sink #2
 Collection Date: 12/15/2020 4:28:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Staff RR Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.428		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point , OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-85 Client Sample ID: Staff RR Sink #3
 Collection Date: 12/15/2020 4:30:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Staff RR Sink #3

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.629		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-86 Client Sample ID: Health Room Sink #1
 Collection Date: 12/15/2020 4:02:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Health Room Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.607		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-87 Client Sample ID: Health Room Sink #2
 Collection Date: 12/15/2020 4:07:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Health Room Sink #2

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.285		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20120819
 Date Reported: 12/29/2020

Eagle Point School District #9
 PO Box 548
 Eagle Point, OR 97524

Lab Order: 20120819
Received Date: 12/15/2020 12:48:00 PM
Reported Date: 12/29/2020 5:00:00 PM

Sample Information:

Lab ID: 20120819-88 Client Sample ID: Staff Room Sink #1 (Office)
 Collection Date: 12/15/2020 4:05:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Staff Room Sink #1 (Office)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.467		0.103	µg/L	1	12/19/2020	15.0	A

Lab ID: 20120819-89 Client Sample ID: Staff RR Sink #1
 Collection Date: 12/15/2020 4:00:00 AM Collected By: Kevin Watson
 Matrix: Drinking Water Sample Location: Staff RR Sink #1

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.18		0.103	µg/L	1	12/19/2020	15.0	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120819
 29-Dec-20

Client: Eagle Point School District #9
Project: Hillside Elementary

TestCode: LEAD_DW

Sample ID: MB-10151	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: PBW	Batch ID: 10151	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259465						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10151	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: LCSW	Batch ID: 10151	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259466						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 100 0.104 100 0 100 85 115

Sample ID: 20120817-01AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: BatchQC	Batch ID: 10151	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259468						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 98.8 0.104 100 2.01 96.8 70 130

Sample ID: 20120817-01AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: BatchQC	Batch ID: 10151	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259469						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 94.8 0.104 100 2.01 92.8 70 130 98.8 4.11 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120819
 29-Dec-20

Client: Eagle Point School District #9
Project: Hillside Elementary

TestCode: LEAD_DW

Sample ID: MB-10153	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: PBW	Batch ID: 10153	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259493						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10153	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: LCSW	Batch ID: 10153	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259494						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.7 0.104 100 0 99.7 85 115

Sample ID: 20120819-12AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: A-Rm #1 Fountain	Batch ID: 10153	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259496						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 97.6 0.104 100 0.754 96.8 70 130


Sample ID: 20120819-12AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: A-Rm #1 Fountain	Batch ID: 10153	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259497						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 98.2 0.104 100 0.754 97.5 70 130 97.6 0.686 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120819
 29-Dec-20

Client: Eagle Point School District #9
Project: Hillside Elementary

TestCode: LEAD_DW

Sample ID: MB-10156	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: PBW	Batch ID: 10156	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259521						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10156	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: LCSW	Batch ID: 10156	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259522						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 109 0.104 100 0 109 85 115

Sample ID: 20120819-33AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: C-Rm #2 Sink	Batch ID: 10156	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259524						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 106 0.104 100 0.896 106 70 130

Sample ID: 20120819-33AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: C-Rm #2 Sink	Batch ID: 10156	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259525						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 101 0.104 100 0.896 99.7 70 130 106 5.64 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120819
 29-Dec-20

Client: Eagle Point School District #9
Project: Hillside Elementary

TestCode: LEAD_DW

Sample ID: MB-10157	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: PBW	Batch ID: 10157	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259549						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10157	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: LCSW	Batch ID: 10157	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259550						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 99.5 0.104 100 0 99.5 85 115

Sample ID: 20120819-53AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: D-Shower Rm Sink	Batch ID: 10157	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259552						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 98.4 0.104 100 0.597 97.8 70 130

Sample ID: 20120819-53AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17890						
Client ID: D-Shower Rm Sink	Batch ID: 10157	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259553						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 97.5 0.104 100 0.597 96.9 70 130 98.4 0.947 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120819
 29-Dec-20

Client: Eagle Point School District #9
Project: Hillside Elementary

TestCode: LEAD_DW

Sample ID: MB-10158	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: PBW	Batch ID: 10158	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259816						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.103

Sample ID: LCS-10158	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: LCSW	Batch ID: 10158	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259817						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 94.2 0.104 100 0 94.2 85 115

Sample ID: 20120819-73AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: Kitchen Handwash #	Batch ID: 10158	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259819						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 96.1 0.104 100 0.700 95.4 70 130

Sample ID: 20120819-73AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: Kitchen Handwash #	Batch ID: 10158	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259820						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 98.9 0.104 100 0.700 98.2 70 130 96.1 2.89 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20120819
 29-Dec-20

Client: Eagle Point School District #9
Project: Hillside Elementary

TestCode: LEAD_DW

Sample ID: MB-10142	SampType: MBLK	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: PBW	Batch ID: 10142	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259877						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.100

Sample ID: LCS-10142	SampType: LCS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: LCSW	Batch ID: 10142	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259878						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 198 0.100 200 0 99.0 85 115

Sample ID: 20120794-03AMS	SampType: MS	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: BatchQC	Batch ID: 10142	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259880						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 254 0.100 200 68.2 92.7 70 130 E

Sample ID: 20120794-03AMSD	SampType: MSD	TestCode: LEAD_DW	Units: µg/L	Prep Date: 12/18/2020	RunNo: 17903						
Client ID: BatchQC	Batch ID: 10142	TestNo: E200.8	E200.8	Analysis Date: 12/19/2020	SeqNo: 259881						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 261 0.100 200 68.2 96.6 70 130 254 3.02 20 E

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Sample Log-In Check List

Client Name: **EAGLEPTSCHOOL**

Work Order Number: **20120819**

RcptNo: **1**

Logged by:	Tamra Schmedemann	12/15/2020 12:48:00 PM	<i>Tamra Schmedemann</i>
Completed By:	Krizzle Calip	12/16/2020 8:28:51 AM	<i>Krizzle Calip</i>
Reviewed By:	Naomi Orr	12/29/2020 4:44:33 PM	<i>Naomi Orr</i>

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
- Custody seals intact on shipping container/cooler? Yes No Not Present
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No HNO3 pH<2
No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

The sample submitted contained visible sediments (fraction 08, 14, 23, 26, 40, 41, 51, 52, 54, 67, 69, 74, 84, 85, and 87).

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>HILLSIDE Elementary</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>185 EAST MAIN ST.</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point OR. 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>HARDING J @ Eagle Pnt. K12. OR.US</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: _____ Fax: _____			<input type="checkbox"/> Other _____
Collected By (Print): <u>KEVIN WATSON</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks/Field Data	NRC Sample # (Lab Use Only)										
<u>A-RM # 2 SINK</u>			<u>12/15</u>	<u>5:54 AM</u>	<u>✓</u>												
<u>A-RM # 2 Fountain</u>			<u>12/15</u>	<u>5:54 AM</u>	<u>✓</u>												
<u>A-RM # 4 SINK</u>			<u>12/15</u>	<u>5:57 AM</u>	<u>✓</u>												
<u>A-RM # 4 Fountain</u>			<u>12/15</u>	<u>5:57 AM</u>	<u>✓</u>												
<u>A-RM # 6 SINK</u>			<u>12/15</u>	<u>5:59 AM</u>	<u>✓</u>												
<u>A-RM # 6 fountain</u>			<u>12/15</u>	<u>5:59 AM</u>	<u>✓</u>												

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Section G Lab Use Only	
Relinquished By: <u>[Signature]</u>	Received By: <u>[Signature]</u>	Temp: <u>9</u>	4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Relinquished By: <u>[Signature]</u>	Received By: <u>[Signature]</u>	Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Number of Bottles Received: <u>6</u>
Relinquished By: _____	Received By: _____	pH Checked: <u>NA</u>	COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No NA
Relinquished By: _____	Received By: _____	Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Received Via <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand
Relinquished By: <u>Tamara Schmederer</u>	Received By: <u>Tamara Schmederer</u>	Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # _____ Amount _____	

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>HILLSIDE Elementary</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>185 EAST MAIN ST. Eagle Point OR. 97524</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
Email: <u>HARDING J @ Eagle Pt. K12. OR.US</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Phone: _____ Fax: _____	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Collected By (Print): <u>Kevin Watson</u>			<input type="checkbox"/> Other _____
Collected By (Sign): <u>Kevin Watson</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					No. of Containers	Analysis Requested							NRC Workorder # (Lab Use Only)		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks/Field Data	NRC Sample # (Lab Use Only)								
<u>A-GIRLS RR SINK #1</u>			<u>12/15</u>	<u>5:42 AM</u>	<u>Lead</u>									<u>20120819</u>	<u>07</u>
<u>A-GIRLS RR SINK #2</u>			<u>12/15</u>	<u>5:40 AM</u>	<u>Lead</u>										<u>08</u>
<u>A-BOYS RR SINK #1</u>			<u>12/15</u>	<u>5:36 AM</u>	<u>Lead</u>										<u>09</u>
<u>A-BOYS RR SINK #2</u>			<u>12/15</u>	<u>5:35 AM</u>	<u>Lead</u>										<u>10</u>
<u>A-RM #1 SINK</u>			<u>12/15</u>	<u>5:53 AM</u>	<u>Lead</u>										<u>11</u>
<u>A-RM #1 Fountain</u>			<u>12/15</u>	<u>5:52 AM</u>	<u>Lead</u>										<u>12</u>
<u>A-RM #3 SINK</u>			<u>12/15</u>	<u>5:49 AM</u>	<u>Lead</u>										<u>13</u>
<u>A-RM #3 Fountain</u>			<u>12/15</u>	<u>5:50 AM</u>	<u>Lead</u>										<u>14</u>
<u>A-RM #5 SINK</u>			<u>12/15</u>	<u>5:47 AM</u>	<u>Lead</u>										<u>15</u>
<u>A-RM #5 Fountain</u>			<u>12/15</u>	<u>5:45 AM</u>	<u>Lead</u>										<u>16</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>Kevin Watson</u>		<u>Kevin Watson</u>	<u>12-15</u>	<u>11:00 AM</u>
Received By: <u>John Harding</u>		<u>John Harding</u>	<u>12/15</u>	<u>11:00</u>
Relinquished By: <u>John Harding</u>		<u>John Harding</u>	<u>12:15</u>	<u>12:48</u>
Received By:				
Relinquished By:				
Received By: <u>Tom Schmader</u>		<u>Tom Schmader</u>	<u>12:15</u>	<u>12:48</u>

Section G Lab Use Only	
Temp:	<u>0C/51</u>
4°C +/- 2°C:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received:	<u>10</u>
pH Checked:	<u>NA</u>
COC Seals Intact:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Field Blank Included:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received Via	<input type="checkbox"/> UPS <input type="checkbox"/> FedEX <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand
Payment:	<input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>HILLSIDE Elementary</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>185 EAST MAIN ST. Eagle Point Ore. 97524</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
Email: <u>HARDING J @ Eagle Pt. OR. gov</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Phone: _____ Fax: _____	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Collected By (Print): <u>KEVIN WATSON</u>			<input type="checkbox"/> Other _____
Collected By (Sign): <u>[Signature]</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					No. of Containers	Analysis Requested										NRC Workorder # <u>20120819</u> (Lab Use Only)	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks/Field Data	NRC Sample # (Lab Use Only)										
B-Rm # 2 Sink			12/15	4:57 AM	✓		17										
B-Rm # 2 Fountain			12/15	4:59 AM	✓		18										
B-Rm # 4 Sink			12/15	4:54 AM	✓		19										
B-Rm # 4 Fountain			12/15	7:53 AM	✓		20										
B-Rm # 6 Sink			12/15	4:57 AM	✓		21										
B-Rm # 6 Fountain			12/15	4:50 AM	✓		22										

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>	<u>KEVIN WATSON</u>		12/15	11:00 AM
Received By:	<u>[Signature]</u>	<u>John Harding</u>		12/15	11:00
Relinquished By:	<u>[Signature]</u>	<u>John Harding</u>		12/15	12:48
Received By:					
Relinquished By:	<u>[Signature]</u>	<u>Tamara Schmeider</u>		12:15	12:48
Received By Laboratory:					

Section G Lab Use Only	
Temp:	<u>40/60</u>
4°C +/- 2°C:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received:	<u>6</u>
pH Checked:	<u>NA</u>
COC Seals Intact:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No NA
Field Blank Included:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via UPS FedEX Other Hand
 Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Eagle Point SD #9
 Address: 185 EAST MAIN ST.
Eagle Point OR. 97524
 Email: HARDING J @ Eagle Pt. K12. OR.US
 Phone: _____ Fax: _____
 Collected By (Print): Kevin Watson
 Collected By (Sign): [Signature]
 Email Report Yes ___ No Mail Report ___ Yes ___ No
 Fax Report ___ Yes ___ No

Section B

Required Project Information

Project Name: HILLSIDE Elementary
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: _____
 Company Name: _____
 Address: _____
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

Standard 10-14 Days
 ___ 5 Business Days (50% surcharge)
 ___ 3 Business Days (75% surcharge)
 ___ 24 - 48 hours (100% surcharge)
 ___ Other _____
 Authorized ___ Yes ___ No

Section E

Sample Information

Blue Wrmg

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
B-GIRLS RR SINK #1			12/15	5:25 AM	✓		20120819		23
B-GIRLS RR SINK #2			12/15	5:23 AM	✓			24	
B-Boys RR SINK #1			12/15	5:19 AM	✓			25	
B-Boys RR SINK #2			12/15	5:13 AM	✓			26	
B-Rm #1 SINK			12/15	5:19 AM	✓			27	
B-Rm #1 Fountain			12/15	5:16 AM	✓			28	
B-Rm #3 SINK			12/15	5:10 AM	✓			29	
B-Rm #3 Fountain			12/15	5:13 AM	✓			30	
B-Rm #5 SINK			12/15	5:05 AM	✓			31	
B-Rm #5 Fountain			12/15	5:03 AM	✓			32	

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
<u>[Signature]</u>	<u>[Signature]</u>	<u>Kevin Watson</u>	<u>12/15</u>	<u>11:00 AM</u>
<u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>11:00</u>
<u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>	<u>12:48</u>
Relinquished By:				
Received By Laboratory:	<u>[Signature]</u>	<u>Tamara Schmedeman</u>	<u>12/15</u>	<u>12:48</u>

Section G

Lab Use Only

Temp: am b.
 4°C +/- 2°C: ___ Yes ___ No
 Received on Ice: ___ Yes ___ No
 Number of Bottles Received: 10
 pH Checked: n/a
 COC Seals Intact: ___ Yes ___ No ___ NA
 Field Blank Included: ___ Yes ___ No

Received Via ___ UPS ___ FedEX ___ Other ___ Hand

Payment: Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>HILLSIDE Elementary</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>185 EAST MAIN ST. Eagle Point OR. 97524</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
Email: <u>HARDING J @ Eagle Pnt. K12. OR.US</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Phone: _____ Fax: _____	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Collected By (Print): <u>Kevin Watson</u>			<input type="checkbox"/> Other _____
Collected By (Sign): <u>Kevin Watson</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>20120819</u>			
<u>(ORANGE WING)</u>					No. of Containers <u>Lead</u>											Remarks/Field Data		NRC Sample # (Lab Use Only)
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected														
<u>C-Rm # 2 Sink</u>			<u>12-15</u>	<u>6:12 AM</u>													<u>33</u>	
<u>C-Rm # 2 Fountain</u>			<u>12-15</u>	<u>6:10 AM</u>													<u>34</u>	
<u>C-Rm # 4 Sink</u>			<u>12-15</u>	<u>6:14 AM</u>													<u>35</u>	
<u>C-Rm # 4 Fountain</u>			<u>12-15</u>	<u>6:15 AM</u>													<u>36</u>	
<u>C-Rm # 6 Sink</u>			<u>12-15</u>	<u>6:20 AM</u>													<u>37</u>	
<u>C-Rm # 6 Fountain</u>			<u>12-15</u>	<u>6:17 AM</u>												<u>38</u>		

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Sign		Print		Date		Time	
Relinquished By:	<u>Kevin Watson</u>	Received By:	<u>John Harding</u>			<u>12-15</u>	<u>11:00 AM</u>		
Relinquished By:	<u>John Harding</u>	Received By:	<u>John Harding</u>			<u>12-15</u>	<u>12:50</u>		
Relinquished By:		Received By:					<u>2:50</u>		
Relinquished By:		Received By:							
Received By Laboratory:	<u>Tamara Schmiedl</u>	Received By Laboratory:	<u>Tamara Schmiedl</u>			<u>12-15</u>	<u>12:48</u>		

Section G Lab Use Only	
Temp:	<u>AMB</u>
4°C +/- 2°C:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received:	<u>6</u>
pH Checked:	<u>NA</u>
COC Seals Intact:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Field Blank Included:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received Via	<input type="checkbox"/> UPS <input type="checkbox"/> FedEX <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand
Payment:	<input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # _____ Amount _____



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Eagle Point SD #9</u>		Project Name: <u>Hillside Elementary</u>		Attention:		<input checked="" type="checkbox"/> Standard 10-14 Days	
Address: <u>185 East Main St.</u>		Project Number:		Company Name:		<input type="checkbox"/> 5 Business Days (50% surcharge)	
<u>Eagle Point OR. 97524</u>		Report To:		Address:		<input type="checkbox"/> 3 Business Days (75% surcharge)	
Email: <u>Harding J @ Eagle Pnt. K12. OR. US</u>		Copy To:		P.O. #		<input type="checkbox"/> 24 - 48 hours (100% surcharge)	
Phone: _____ Fax: _____						<input type="checkbox"/> Other _____	
Collected By (Print): <u>Kevin Watson</u>						Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	
Collected By (Sign): <u>[Signature]</u>							
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No					
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No							

Section E Sample Information					No. of Containers	Analysis Requested						NRC Workorder # <u>2012089</u> (Lab Use Only)			
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected								Remarks/Field Data	NRC Sample # (Lab Use Only)		
<u>C-Girls RR Sink #1</u>			<u>12-15</u>	<u>6:04 AM</u>	<u>Lead</u>										<u>39</u>
<u>C-Girls RR Sink #2</u>			<u>12-15</u>	<u>6:00 AM</u>	<u>Lead</u>										<u>40</u>
<u>C-Boys RR Sink #1</u>			<u>12-15</u>	<u>6:16 AM</u>	<u>Lead</u>										<u>41</u>
<u>C-Boys RR Sink #2</u>			<u>12-15</u>	<u>6:15 AM</u>	<u>Lead</u>										<u>42</u>
<u>C-Rm #1 Sink</u>			<u>12-15</u>	<u>6:00 AM</u>	<u>Lead</u>										<u>43</u>
<u>C-Rm #1 Fountain</u>			<u>12-15</u>	<u>6:07 AM</u>	<u>Lead</u>										<u>44</u>
<u>C-Rm #3 Sink</u>			<u>12-15</u>	<u>6:05 AM</u>	<u>Lead</u>										<u>45</u>
<u>C-Rm #3 Fountain</u>			<u>12-15</u>	<u>6:02 AM</u>	<u>Lead</u>										<u>46</u>
<u>C-Rm #5 Sink</u>			<u>12-15</u>	<u>6:15 AM</u>	<u>Lead</u>										<u>47</u>
<u>C-Rm #5 Fountain</u>			<u>12-15</u>	<u>6:15 AM</u>	<u>Lead</u>										<u>48</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F		Section G	
Relinquish/Receive	Sign	Print	Date
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>Kevin Watson</u>	<u>12-15</u>
Received By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Harding</u>	<u>12/15</u>
Received By:			
Relinquished By:			
Received By Laboratory: <u>[Signature]</u>	<u>[Signature]</u>	<u>Tamra Schmalen</u>	<u>12/15</u>

Section G Lab Use Only	
Temp: <u>61.6</u>	
4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Number of Bottles Received: <u>10</u>	
pH Checked: <u>NA</u>	
COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Eagle Point SD #9
 Address: 185 EAST MAIN ST.
Eagle Point OR. 97524
 Email: HARDING J @ EAGLE PNT. OR. US
 Phone: _____ Fax: _____
 Collected By (Print): KEVIN WATSON
 Collected By (Sign): [Signature]
 Email Report Yes ___ No Mail Report ___ Yes ___ No
 Fax Report ___ Yes ___ No

Section B

Required Project Information

Project Name: HILLSIDE Elementary
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: _____
 Company Name: _____
 Address: _____
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

Standard 10-14 Days
 ___ 5 Business Days (50% surcharge)
 ___ 3 Business Days (75% surcharge)
 ___ 24 - 48 hours (100% surcharge)
 ___ Other _____
 Authorized ___ Yes ___ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested														
D-Boys RR sink #1			12/15	7:00 AM	1	Lead														
D-Boys RR sink #2			12/15	7:00 AM	1	Lead														
D-Girls RR sink #1			12/15	6:50 AM	1	Lead														
D-Girls RR sink #2			12/15	7:00 AM	1	Lead														
D-Shower RM sink			12/15	6:50 AM	1	Lead														
D-Shower			12/15	6:45 AM	1	Lead														
D-Rm #2 sink			12/15	6:42 AM	1	Lead														
D-Rm #2 fountain			12/15	6:45 AM	1	Lead														
D-Rm #4 sink			12/15	6:40 AM	1	Lead														
D-Rm #4 fountain			12/15	6:40 AM	1	Lead														

NRC Workorder #

(Lab Use Only)	<u>20120819</u>
Remarks/Field Data	NRC Sample # (Lab Use Only)
	<u>49</u>
	<u>50</u>
	<u>51</u>
	<u>52</u>
	<u>53</u>
	<u>54</u>
	<u>55</u>
	<u>56</u>
	<u>57</u>
	<u>58</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>KEVIN WATSON</u>	<u>12-15</u>	<u>11:00 AM</u>
Received By: <u>[Signature]</u>		<u>John Harding</u>	<u>12/15</u>	<u>11:00</u>
Relinquished By: <u>[Signature]</u>		<u>John Harding</u>	<u>12/15</u>	<u>12:48</u>
Received By: _____				
Relinquished By: _____				
Received By: Laboratory <u>[Signature]</u>		<u>Tamra Schueler</u>	<u>12/15</u>	<u>12:48</u>

Section G

Lab Use Only

Temp: amb.
 4°C +/- 2°C: ___ Yes ___ No
 Received on Ice: ___ Yes ___ No
 Number of Bottles Received: 10
 pH Checked: N/A
 COC Seals Intact: ___ Yes ___ No ___ NA
 Field Blank Included: ___ Yes ___ No
 Received Via ___ UPS ___ FedEx ___ Other ___ Hand
 Payment: Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount: _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>HILLSIDE Elementary</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>185 EAST MAIN ST.</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point ore. 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>HARDING J @ EAGLE PNT. K12. OR.US</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: _____ Fax: _____			<input type="checkbox"/> Other _____
Collected By (Print): <u>Kevin Watson</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>Kevin Watson</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information		Analysis Requested										NRC Workorder # (Lab Use Only)		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers								Remarks/Field Data	NRC Sample # (Lab Use Only)
D-Rm #6 SINK			12/15	6:37 AM	✓	Lead								59
D-Rm #6 Fountain			12/15	6:37 AM	✓									60
D-Rm #1 SINK			12/15	6:35 AM	✓									61
D-Rm #1 Fountain			12/15	6:35 AM	✓									62
D-Rm #3 SINK			12/15	6:30 AM	✓									63
D-Rm #3 Fountain			12/15	6:30 AM	✓									64
D-Rm #5 SINK			12/15	6:30 AM	✓									65
D-Rm #5 Fountains			12/15	6:30 AM	✓									66

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive		Print		Date	Time
Relinquished By: <u>Kevin Watson</u>	Signature: <u>Kevin Watson</u>			12-15	11:00 AM
Received By: <u>John Harding</u>	Signature: <u>John Harding</u>			12/15	11:00
Relinquished By: <u>John Harding</u>	Signature: <u>John Harding</u>			12/15	12:50
Received By: _____	Signature: _____				48
Relinquished By: _____	Signature: _____				
Received By Laboratory: <u>Jane Schmolten</u>	Signature: <u>Jane Schmolten</u>			12/15	12:48

Section G Lab Use Only	
Temp: <u>6m6</u>	
4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Number of Bottles Received: <u>8</u>	
pH Checked: <u>N/A</u>	
COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No NA	
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>Hillside Elementary</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>185 East Main St.</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point OR 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>Harding J @ Eagle Pnt. K12. OR. US</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: _____ Fax: _____			<input type="checkbox"/> Other _____
Collected By (Print): <u>Kevin Watson</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>Kevin Watson</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>20120819</u>		
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers												
<u>COURTYARD Fountain #1</u>			<u>12/15</u>	<u>4:43 AM</u>	<u>Lead</u>	<input checked="" type="checkbox"/>											
<u>Gym Boys RR Sink #1</u>			<u>12/15</u>	<u>4:31 AM</u>	<u>Lead</u>	<input checked="" type="checkbox"/>											
<u>Gym Boys RR Sink #2</u>			<u>12/15</u>	<u>4:33 AM</u>	<u>Lead</u>	<input checked="" type="checkbox"/>											
<u>Gym Girls RR Sink #1</u>			<u>12/15</u>	<u>4:35 AM</u>	<u>Lead</u>	<input checked="" type="checkbox"/>											
<u>Gym Girls RR Sink #2</u>			<u>12/15</u>	<u>4:40 AM</u>	<u>Lead</u>	<input checked="" type="checkbox"/>											

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F		Section G	
Relinquish/Receive	Sign	Print	Lab Use Only
			Temp:
Relinquished By: <u>Kevin Watson</u>	<u>Kevin Watson</u>	<u>Kevin Watson</u>	<u>12/15</u>
Received By: <u>John Harding</u>	<u>John Harding</u>	<u>John Harding</u>	<u>11:00 AM</u>
Relinquished By: <u>John Harding</u>	<u>John Harding</u>	<u>John Harding</u>	<u>12/15</u>
Received By:			<u>12:48</u>
Relinquished By:			
Received By Laboratory: <u>Tanna Schmedeman</u>	<u>Tanna Schmedeman</u>	<u>Tanna Schmedeman</u>	<u>12/15</u>
			<u>12:48</u>

Temp: AMT

4°C +/- 2°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: 5

pH Checked: NA

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>HILLSIDE Elementary</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>185 EAST MAIN ST.</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point ORC 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>HARDING J @ Eagle Pnt. K12. OR.US</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: _____ Fax: _____			<input type="checkbox"/> Other _____
Collected By (Print): <u>Kevin Watson</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No		
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					No. of Containers	Analysis Requested										NRC Workorder # <u>20120819</u> (Lab Use Only)	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks/Field Data	NRC Sample # (Lab Use Only)										
Kitchen Sink #1			12/15	4:21 AM	✓		72										
Kitchen HANDWASH #2			12/15	4:17 AM	✓		73										
EYE WASH K.E.W STATION #3			12/15	4:12 AM	✓		74										
Kitchen Sink #4			12/15	4:15 AM	✓		75										
Kitchen Sink #5			12/15	4:19 AM	✓		76										
Kitchen HW #6 (Handwash)			12/15	4:20 AM	✓		77										
Kitchen Sink #7			12/15	4:20 AM	✓		78										
Gym Fountain #1			12/15	4:26 AM	✓		79										
Gym Fountain #2			12/15	4:38 AM	✓		80										

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F		Section G	
Relinquish/Receive	Sign	Print	Lab Use Only
		Date	Time
Relinquished By: <u>[Signature]</u>	<u>Kevin Watson</u>	12/15	11:00 AM
Received By: <u>[Signature]</u>	<u>John Harding</u>	12/15	11:00 AM
Relinquished By: <u>[Signature]</u>	<u>John Harding</u>	12/15	12:48
Received By:			
Relinquished By:			
Received By Laboratory: <u>[Signature]</u>	<u>[Signature]</u>	12/15	12:48

Temp: [Signature]

4°C +/- 2°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: 9

pH Checked: N/A

COC Seals Intact: Yes No N/A

Field Blank Included: Yes No

Received Via UPS FedEX Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>HILLSIDE Elementary</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>185 EAST MAIN ST.</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point OR. 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>HARDING J @ EAGLE PNT. K12. OR.US</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: _____ Fax: _____			<input type="checkbox"/> Other _____
Collected By (Print): <u>KEVIN WATSON</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>Kevin Watson</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information					No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only) <u>20120819</u>	
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected		Remarks/Field Data	NRC Sample # (Lab Use Only)										
<u>HALWAY Fountain #1</u>			<u>12/15</u>	<u>4:36 AM</u>	<u>✓</u>		<u>81</u>										
<u>HALWAY Fountain #2</u>			<u>12/15</u>	<u>4:23 AM</u>	<u>✓</u>		<u>82</u>										
<u>HALWAY Fountain #3</u>			<u>12/15</u>	<u>4:24 AM</u>	<u>✓</u>		<u>83</u>										
<u>STAFF RR SINK #2</u>			<u>12/15</u>	<u>4:28</u>	<u>✓</u>		<u>84</u>										
<u>STAFF RR SINK #3</u>			<u>12/15</u>	<u>4:30 AM</u>	<u>✓</u>		<u>85</u>										
<u>HEALTH ROOM SINK #1</u>			<u>12/15</u>	<u>4:02 AM</u>	<u>✓</u>		<u>86</u>										
<u>HEALTH ROOM SINK #2</u>			<u>12/15</u>	<u>4:07 AM</u>	<u>✓</u>		<u>87</u>										
<u>STAFF ROOM SINK #1 (office)</u>			<u>12/15</u>	<u>4:05 AM</u>	<u>✓</u>		<u>88</u>										
<u>STAFF RR SINK #1</u>			<u>12/15</u>	<u>4:00 AM</u>	<u>✓</u>		<u>89</u>										

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F	Sign	Print	Date	Time
Relinquished By:	<u>Kevin Watson</u>	<u>KEVIN WATSON</u>	<u>12/15</u>	<u>11:00 AM</u>
Received By:	<u>John Harding</u>	<u>John Harding</u>	<u>12/15</u>	<u>11:00 AM</u>
Relinquished By:	<u>John Harding</u>	<u>John Harding</u>	<u>12/15</u>	<u>12:48</u>
Received By:				
Relinquished By:				
Received By Laboratory:				

Section G Lab Use Only
Temp: <u>5.1 C</u>
4°C +/- 2°C: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Number of Bottles Received: <u>9</u>
pH Checked: <u>N/A</u>
COC Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>NA</u>
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via UPS FedEx Other Hand

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

- B Analyte detected in the associated method blank.
- BA BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- D1 The diesel elution pattern for the sample is not typical.
- D2 The sample appears to be a heavier hydrocarbon range than diesel.
- D3 The sample appears to be a lighter hydrocarbon range than diesel.
- D4 Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
- D5 Detected hydrocarbons in the diesel range appear to be weathered diesel.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- G1 The gasoline elution pattern for the sample is not typical.
- G2 The sample appears to be a heavier hydrocarbon range than gasoline.
- G3 The sample appears to be a lighter hydrocarbon range than gasoline.
- G4 Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- NLR No Legionella Recovered.
- PLR Presence of Legionella Recovered.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 Duplicate analysis failed due to result being at or near the method reporting limit.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- # Value exceeds regulatory level for TCLP contaminant.
- X1 The motor oil elution pattern for the sample is not typical.
- X2 The sample appears to be a heavier hydrocarbon range than motor oil.
- X3 The sample appears to be a lighter hydrocarbon range than motor oil.
- * Value exceeds Maximum Contaminant Level or is outside the acceptable range.