



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 23, 2021

John Harding
Eagle Point School District #9
PO Box 548
Eagle Point, OR 97524
TEL: (541) 830-1240
FAX (541) 830-6375

RE: Lower Table Rock Elementary

Order No.: 21030684

Dear John Harding:

Neilson Research Corporation received 35 sample(s) on 3/11/2021 for the analyses presented in the following report.


The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 21030684
Date: 3/23/2021

CLIENT: Eagle Point School District #9
Project: Lower Table Rock Elementary

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-01 Client Sample ID: LOS
Collection Date: 3/11/2021 5:40:00 AM Collected By:
Matrix: Drinking Water Sample Location: LOS

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	523	*	1.03	ppb	10	3/15/2021	15.0	A	

Lab ID: 21030684-02 Client Sample ID: RM F
Collection Date: 3/11/2021 5:46:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	3.48		0.103	ppb	1	3/12/2021	15.0	A	

Lab ID: 21030684-03 Client Sample ID: RM 2S
Collection Date: 3/11/2021 5:49:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 2S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	2.20		0.103	ppb	1	3/12/2021	15.0	A	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-04 Client Sample ID: RM 2F
Collection Date: 3/11/2021 5:49:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 2F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.03		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-05 Client Sample ID: RM 3S
Collection Date: 3/11/2021 5:52:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 3S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	21.2	*	0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-06 Client Sample ID: RM 3F
Collection Date: 3/11/2021 5:52:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 3F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	23.3	*	0.103	ppb	1	3/12/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-07 Client Sample ID: RM 4S
Collection Date: 3/11/2021 5:55:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 4S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	36.4	*	0.100	ppb	1	3/13/2021	15.0	A	

Lab ID: 21030684-08 Client Sample ID: RM 4F
Collection Date: 3/11/2021 5:55:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 4F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	9.53		0.103	ppb	1	3/12/2021	15.0	A	

Lab ID: 21030684-09 Client Sample ID: RM 5S
Collection Date: 3/11/2021 6:00:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 5S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	6.51		0.100	ppb	1	3/13/2021	15.0	A	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-10 Client Sample ID: RM 9S
Collection Date: 3/11/2021 6:02:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 9S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.564		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-11 Client Sample ID: RM 9F
Collection Date: 3/11/2021 6:02:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 9F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.10		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-12 Client Sample ID: RM 10S
Collection Date: 3/11/2021 6:07:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 10S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.236		0.103	ppb	1	3/12/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-13 Client Sample ID: RM 13S
Collection Date: 3/11/2021 6:10:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 13S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.9		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-14 Client Sample ID: RM 13F
Collection Date: 3/11/2021 6:10:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 13F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.5		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-15 Client Sample ID: RM 14S
Collection Date: 3/11/2021 6:10:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 14S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.48		0.103	ppb	1	3/12/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-16 Client Sample ID: RM 14F
Collection Date: 3/11/2021 6:10:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 14F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.46		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-17 Client Sample ID: RM 16F
Collection Date: 3/11/2021 6:20:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 16F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.19		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-18 Client Sample ID: RM 17S
Collection Date: 3/11/2021 6:22:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 17S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.898		0.103	ppb	1	3/12/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-19 Client Sample ID: RM 17F
Collection Date: 3/11/2021 6:22:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 17F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.915		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-20 Client Sample ID: RM 18S
Collection Date: 3/11/2021 6:25:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 18S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.77		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-21 Client Sample ID: RM 18F
Collection Date: 3/11/2021 6:25:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 18F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.36		0.103	ppb	1	3/12/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-22 Client Sample ID: RM 19S
Collection Date: 3/11/2021 6:26:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 19S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.66		0.103	ppb	1	3/12/2021	15.0	A

Lab ID: 21030684-23 Client Sample ID: RM 20S
Collection Date: 3/11/2021 6:27:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 20S

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	71.1	*	0.100	ppb	1	3/13/2021	15.0	A

Lab ID: 21030684-24 Client Sample ID: RM 20F
Collection Date: 3/11/2021 6:27:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 20F

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.6		0.100	ppb	1	3/13/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-25 Client Sample ID: RM 21S
Collection Date: 3/11/2021 6:30:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 21S

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.85		0.103	ppb	1	3/13/2021	15.0	A

Lab ID: 21030684-26 Client Sample ID: RM 21F
Collection Date: 3/11/2021 6:30:00 AM Collected By:
Matrix: Drinking Water Sample Location: RM 21F

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.56		0.103	ppb	1	3/13/2021	15.0	A

Lab ID: 21030684-27 Client Sample ID: 2 GRR S2
Collection Date: 3/11/2021 6:38:00 AM Collected By:
Matrix: Drinking Water Sample Location: 2 GRR S2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.95		0.103	ppb	1	3/13/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-28

Client Sample ID: KKB

Collection Date: 3/11/2021 6:39:00 AM

Collected By:

Matrix: Drinking Water

Sample Location: KKB

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	ppb	1	3/13/2021	15.0	A

Lab ID: 21030684-29

Client Sample ID: KKG

Collection Date: 3/11/2021 6:40:00 AM

Collected By:

Matrix: Drinking Water

Sample Location: KKG

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.232		0.103	ppb	1	3/13/2021	15.0	A

Lab ID: 21030684-30

Client Sample ID: WRR RRS

Collection Date: 3/11/2021 6:45:00 AM

Collected By:

Matrix: Drinking Water

Sample Location: WRR RRS

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	29.0	*	0.100	ppb	1	3/13/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-31 Client Sample ID: HRS
Collection Date: 3/11/2021 6:49:00 AM Collected By:
Matrix: Drinking Water Sample Location: HRS

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	14.3		0.103	ppb	1	3/13/2021	15.0	A

Lab ID: 21030684-32 Client Sample ID: IAS
Collection Date: 3/11/2021 7:09:00 AM Collected By:
Matrix: Drinking Water Sample Location: IAS

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.675		0.103	ppb	1	3/13/2021	15.0	A

Lab ID: 21030684-33 Client Sample ID: TSS
Collection Date: 3/11/2021 7:15:00 AM Collected By:
Matrix: Drinking Water Sample Location: TSS

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	31.4	*	0.103	ppb	1	3/13/2021	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 21030684

Date Reported: 3/23/2021

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 21030684

Received Date: 3/11/2021 9:24:00 AM

Reported Date: 3/23/2021 2:47:44 PM

Sample Information:

Lab ID: 21030684-34 Client Sample ID: DFS
Collection Date: 3/11/2021 7:00:00 AM Collected By:
Matrix: Drinking Water Sample Location: DFS

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	38.4	*	0.100	ppb	1	3/13/2021	15.0	A	

Lab ID: 21030684-35 Client Sample ID: DFT
Collection Date: 3/11/2021 7:00:00 AM Collected By:
Matrix: Drinking Water Sample Location: DFT

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS			
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	51.3	*	0.100	ppb	1	3/13/2021	15.0	A	

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 21030684

23-Mar-21

Client: Eagle Point School District #9

Project: Lower Table Rock Elementary

TestCode: LEAD_DW

Sample ID: MB-11319	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854
Client ID: PBW	Batch ID: 11319	TestNo: E200.8	E200.8	Analysis Date: 3/12/2021	SeqNo: 298002
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.103			

Sample ID: LCS-11319	SampType: LCS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854
Client ID: LCSW	Batch ID: 11319	TestNo: E200.8	E200.8	Analysis Date: 3/12/2021	SeqNo: 298003
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	98.7	0.104	100	0	98.7 85 115

Sample ID: 21030684-22AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854
Client ID: RM 19S	Batch ID: 11319	TestNo: E200.8	E200.8	Analysis Date: 3/12/2021	SeqNo: 298026
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	97.4	0.104	100	2.66	94.7 70 130

Sample ID: 21030684-22AMSD	SampType: MSD	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854
Client ID: RM 19S	Batch ID: 11319	TestNo: E200.8	E200.8	Analysis Date: 3/13/2021	SeqNo: 298027
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	97.8	0.104	100	2.66	95.1 70 130 97.4 0.416 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit

CI Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit

E Value above quantitation range
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 21030684
23-Mar-21

Client: Eagle Point School District #9
Project: Lower Table Rock Elementary

TestCode: LEAD_DW

Sample ID: MB-11320	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854
Client ID: PBW	Batch ID: 11320	TestNo: E200.8	E200.8	Analysis Date: 3/13/2021	SeqNo: 298030
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.103			

Sample ID: LCS-11320	SampType: LCS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854
Client ID: LCSW	Batch ID: 11320	TestNo: E200.8	E200.8	Analysis Date: 3/13/2021	SeqNo: 298031
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	99.1	0.104	100	0	99.1 85 115

Sample ID: 21030684-33AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854
Client ID: TSS	Batch ID: 11320	TestNo: E200.8	E200.8	Analysis Date: 3/13/2021	SeqNo: 298040
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	125	0.104	100	31.4	93.7 70 130

Sample ID: 21030684-33AMSD	SampType: MSD	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854
Client ID: TSS	Batch ID: 11320	TestNo: E200.8	E200.8	Analysis Date: 3/13/2021	SeqNo: 298041
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	127	0.104	100	31.4	96.0 70 130 125 1.84 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit

CI Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit

E Value above quantitation range
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 21030684
23-Mar-21

Client: Eagle Point School District #9
Project: Lower Table Rock Elementary

TestCode: LEAD_DW

Sample ID: MB-11322		SampType: MBLK		TestCode: LEAD_DW		Units: ppb		Prep Date: 3/12/2021			RunNo: 19854		
Client ID: PBW		Batch ID: 11322		TestNo: E200.8		E200.8		Analysis Date: 3/13/2021			SeqNo: 298046		
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.100
------	----	-------

Sample ID: LCS-11322		SampType: LCS	TestCode: LEAD_DW		Units: ppb	Prep Date: 3/12/2021				RunNo: 19854	
Client ID: LCSW	Batch ID: 11322		TestNo: E200.8		E200.8	Analysis Date: 3/13/2021				SeqNo: 298047	
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	101	0.100	100	0	101	85	115
------	-----	-------	-----	---	-----	----	-----

Sample ID: 21030690-01AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/12/2021	RunNo: 19854						
Client ID: BatchQC	Batch ID: 11322	TestNo: E200.8	E200.8	Analysis Date: 3/13/2021	SeqNo: 298058						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.3	0.100	100	0.855	94.4	70	130
------	------	-------	-----	-------	------	----	-----

Sample ID: 21030690-01AMSD		SampType: MSD		TestCode: LEAD_DW		Units: ppb		Prep Date: 3/12/2021			RunNo: 19854		
Client ID: BatchQC		Batch ID: 11322		TestNo: E200.8		E200.8		Analysis Date: 3/13/2021			SeqNo: 298059		
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	95.6	0.100	100	0.855	94.7	70	130	95.3	0.330	20
------	------	-------	-----	-------	------	----	-----	------	-------	----

Qualifiers:

* Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit

CI Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit

E Value above quantitation range
ND Not Detected at the Reporting Limit

Original

Sample Log-In Check List

Client Name: **EAGLEPTSCHOOL**

Work Order Number: **21030684**

RcptNo: **1**

Logged by: **Ty Bryde** **3/11/2021 9:24:00 AM**

Completed By: **Krizzle Calip** **3/11/2021 6:23:30 PM**

Reviewed By: **Naomi Orr** **3/23/2021 1:58:37 PM**

TA
Krizzle Calip
Naomi Orr

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

The sample submitted was tan (samples 07, 23, and 34)/beige (sample 30) and grey (sample 09) in color. The sample contained visible sediments (samples 01, 05, 06, 07, 09, 23, 31 and 33).

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

Chain of Custody Record

Page 1 of 4

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Eagle Point S.D #9 (LRE)
Address: 2830 Maple Court
White City, OR 97503
Email: Harding.j@eaglepoint.k12.or.us
Phone: 541-830-6376 Fax: _____
Collected By (Print): _____
Collected By (Sign): _____
Email Report ☒ Yes ___ No ___ Mail Report ___ Yes ___ No
Fax Report ___ Yes ___ No

Section B

Required Project Information

Project Name: Lower Table Rock Chem
Project Number: _____
Report To: _____
Copy To: _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
___ 5 Business Days (50% surcharge)
___ 3 Business Days (75% surcharge)
___ 24 - 48 hours (100% surcharge)
___ Other _____
Authorized ___ Yes ___ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
<u>LOS</u>			<u>3-11-21</u>	<u>5:40</u>	<u>1</u>											<u>21030684</u>		<u>01</u>
<u>RM F</u>			<u>1</u>	<u>5:46</u>	<u>1</u>													<u>02</u>
<u>RM 2S</u>				<u>5:49</u>	<u>1</u>													<u>03</u>
<u>RM 2F</u>				<u>5:49</u>	<u>1</u>													<u>04</u>
<u>RM 3S</u>				<u>5:52</u>	<u>1</u>													<u>05</u>
<u>RM 3F</u>				<u>5:52</u>	<u>1</u>													<u>06</u>
<u>RM 4S</u>				<u>5:55</u>	<u>1</u>													<u>07</u>
<u>RM 4F</u>				<u>5:55</u>	<u>1</u>													<u>08</u>
<u>RM 5S</u>				<u>6:00</u>	<u>1</u>													<u>09</u>
<u>RM 9S</u>				<u>6:02</u>	<u>1</u>													<u>10</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By: [Signature] Sign _____ Print Steven Lambert Date 3/11/21 Time 9:24
Received By: _____
Relinquished By: _____
Received By: _____
Relinquished By: _____
Received By Laboratory: [Signature] Jay Byde 3/11/2021 924

Section G

Lab Use Only

Temp: Amb
4°C +/- 2°C: ___ Yes ___ No N.A.
Received on Ice: ___ Yes ___ No N.A.
Number of Bottles Received: 35
pH Checked: N.A.
COC Seals Intact: ___ Yes ___ No X NA
Field Blank Included: ___ Yes X No

Received Via ___ UPS ___ FedEx ___ Other Hand

Payment: Invoice Cash ___ VISA, M/C ___ Check # ___ Amount ___

Chain of Custody Record

Page 2 of 4

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Eagle Point S.D. #9 (LRE)
Address: 2830 Maple Court
White City, OR 97503
Email: Harding.j@eaglept.k12.or.us
Phone: 541-830-6376 Fax: _____
Collected By (Print): _____
Collected By (Sign): _____
Email Report ☒ Yes ___ No ___ Mail Report ___ Yes ___ No
Fax Report ___ Yes ___ No

Section B

Required Project Information

Project Name: Lower Table Rock Elem
Project Number: _____
Report To: _____
Copy To: _____
P.O. # _____

Section C

Invoice Information

Attention: _____
Company Name: _____
Address: _____
P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
___ 5 Business Days (50% surcharge)
___ 3 Business Days (75% surcharge)
___ 24 - 48 hours (100% surcharge)
___ Other _____
Authorized ___ Yes ___ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
RM9F			3-11-21	6:02	1	Lead										21030684	error	11
RM10S				6:07	1												TLS	12
RM13S				6:10	1												5/11/2021	13
RM13F				6:10	1													14
RM14S				6:10	1													15
RM14F				6:10	1													16
RM16F				6:20	1													17
RM17S				6:25	1													18
RM17F				6:25	1													19
RM18S				6:25	1													20

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By: Steven Lambert Sign: Steven Lambert Print: Steven Lambert Date: 3-11-21 Time: 9:24
Received By: _____
Relinquished By: _____
Received By: _____
Relinquished By: _____
Received By Laboratory: Eq. Dept Date: 5/11/2021 Time: 9:24

Section G

Lab Use Only

Temp: Am
4°C +/- 2°C: ___ Yes X No ___
Received on Ice: ___ Yes X No ___
Number of Bottles Received: 35
pH Checked: N/A
COC Seals Intact: ___ Yes ___ No X NA
Field Blank Included: ___ Yes X No ___

Received Via ___ UPS ___ FedEx ___ Other ___ Hand

Payment: ___ Invoice ___ Cash ___ VISA, M/C ___ Check # ___ Amount ___

Chain of Custody Record

Page 3 of 4

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: Eagle Point S.D.#9 (LRE)
 Address: 2830 Maple Court
White City, OR 97503
 Email: Hardingj@Eaglept.k12.or.us
 Phone: 541-830-6376 Fax: _____
 Collected By (Print): _____
 Collected By (Sign): _____
 Email Report ☒ Yes ___ No ___ Mail Report ___ Yes ___ No
 Fax Report ___ Yes ___ No

Section B

Required Project Information

Project Name: Lower Table Rock Elem
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C

Invoice Information

Attention: _____
 Company Name: _____
 Address: _____
 P.O. # _____

Section D

Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days
 ___ 5 Business Days (50% surcharge)
 ___ 3 Business Days (75% surcharge)
 ___ 24 - 48 hours (100% surcharge)
 ___ Other _____
 Authorized ___ Yes ___ No

Section E

Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										Remarks/Field Data	NRC Sample # (Lab Use Only)
RM18F			3-11-21	6:25	1	Lead											21
RM19S				6:26	1												22
RM20S				6:27	1												23
RM20F				6:27	1												24
RM21S				6:30	1												25
RM21F				6:30	1												26
2GBRS2				6:38	1												27
KKB				6:39	1												28
KKG				6:40	1												29
WRR RRS				6:45	1												30

Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F

Relinquish/Receive

Relinquished By: <u>Stan Lambert</u>	Sign	Print	Date	Time
Received By: _____		Steven Lambert	3-11-21	9:24
Relinquished By: _____				
Received By: _____				
Relinquished By: _____				
Received By Laboratory: <u>Ly/S</u>		Ty Bryde	3/11/2021	9:29


Section G

Lab Use Only

Temp: Amb
 4°C +/- 2°C: ___ Yes ☒ No ___
 Received on Ice: ___ Yes ☒ No ___
 Number of Bottles Received: 35
 pH Checked: N/A
 COC Seals Intact: ___ Yes ___ No ☒ NA
 Field Blank Included: ___ Yes ☒ No ___

Received Via ___ UPS ___ FedEx ___ Other Hand

Payment: ___ Invoice ___ Cash ___ VISA, M/C ___ Check # _____ Amount _____



Page 4 of 4

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Required Client Information

Company: Eagle Point S.D #9 (LIRE)	
Address: 2830 Maple Court White City OR 97503	
Email: Hardingj@Eaglept.k12.or.us	
Phone: 541-830-6376 Fax:	
Collected By (Print):	
Collected By (Sign):	
Email Report <input checked="" type="checkbox"/> Yes ___ No	Mail Report ___ Yes ___ No
Fax Report ___ Yes ___ No	

Required Project Information

Project Name:	Lump Sum Rock Clean
Project Number:	
Report To:	
Copy To:	

Invoice Information

Attention:	
Company Name:	
Address:	
P.O. #	

Rush Status (Subject to Scheduling)

<input checked="" type="checkbox"/>	Standard 10-14 Days		
<input type="checkbox"/>	5 Business Days (50% surcharge)		
<input type="checkbox"/>	3 Business Days (75% surcharge)		
<input type="checkbox"/>	24 - 48 hours (100% surcharge)		
<input type="checkbox"/>	Other _____		

	Authorized	Yes	No
--	------------	-----	----

Sample Information

[illegible]

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquish/Receive

Relinquished By: <i>[Signature]</i>	<i>Steven Lambert</i>	<i>3-11-21</i>	<i>9:24</i>
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: <i>6 N</i>	<i>E. Ardo</i>	<i>3/11/2021</i>	<i>9:24</i>

Lab Use Only

Temp: Amh
4°C +/- 2°C: ____ Yes X No
Received on Ice: ____ Yes X No
Number of Bottles Received: 35
pH Checked: N/A
COC Seals Intact: ____ Yes ____ No X NA
Field Blank Included: ____ Yes X No

Received Via	UPS	FedEX	Other	Hand
--------------	-----	-------	-------	------

Payment:	Invoice	Cash	VISA, M/C	Check #	Amount
----------	---------	------	-----------	---------	--------

-
- B Analyte detected in the associated method blank.
 - BA BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - D1 The diesel elution pattern for the sample is not typical.
 - D2 The sample appears to be a heavier hydrocarbon range than diesel.
 - D3 The sample appears to be a lighter hydrocarbon range than diesel.
 - D4 Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
 - D5 Detected hydrocarbons in the diesel range appear to be weathered diesel.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - G1 The gasoline elution pattern for the sample is not typical.
 - G2 The sample appears to be a heavier hydrocarbon range than gasoline.
 - G3 The sample appears to be a lighter hydrocarbon range than gasoline.
 - G4 Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT ☐ At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - NLR No Legionella Recovered.
 - PLR Presence of Legionella Recovered.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 Duplicate analysis failed due to result being at or near the method reporting limit.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - # Value exceeds regulatory level for TCLP contaminant.
 - X1 The motor oil elution pattern for the sample is not typical.
 - X2 The sample appears to be a heavier hydrocarbon range than motor oil.
 - X3 The sample appears to be a lighter hydrocarbon range than motor oil.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.