



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

December 30, 2020

John Harding  
Eagle Point School District #9  
PO Box 548  
Eagle Point, OR 97524  
TEL: (541) 830-1240  
FAX (541) 830-6375

RE: Shady Cove Schools

Order No.: 20120966

Dear John Harding:

Neilson Research Corporation received 65 sample(s) on 12/17/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Senior Project Manager  
245 S Grape St  
Medford, OR 97501



Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

## Case Narrative

WO#: 20120966  
Date: 12/30/2020

---

**CLIENT:** Eagle Point School District #9

**Project:** Shady Cove Schools

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-01 Client Sample ID: BL-1  
Collection Date: 12/17/2020 5:51:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: BL-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.160		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-02 Client Sample ID: BL-2  
Collection Date: 12/17/2020 5:52:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: BL-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.293		0.100	µg/L	1	12/22/2020	15.0	A

Lab ID: 20120966-03 Client Sample ID: GL-1  
Collection Date: 12/17/2020 5:54:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: GL-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.232		0.100	µg/L	1	12/22/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-04 Client Sample ID: GL-2  
Collection Date: 12/17/2020 5:54:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: GL-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-05 Client Sample ID: G-1  
Collection Date: 12/17/2020 5:56:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: G-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.82		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-06 Client Sample ID: K-1  
Collection Date: 12/17/2020 6:00:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: K-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.44		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-07 Client Sample ID: K-2  
Collection Date: 12/17/2020 6:01:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: K-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.18		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-08 Client Sample ID: K-3  
Collection Date: 12/17/2020 6:01:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: K-3

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-09 Client Sample ID: K-4  
Collection Date: 12/17/2020 6:19:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: K-4

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.80		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-10 Client Sample ID: K-5  
Collection Date: 12/17/2020 6:20:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: K-5

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.92		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-11 Client Sample ID: B-1  
Collection Date: 12/17/2020 6:22:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: B-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.80		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-12 Client Sample ID: B-2  
Collection Date: 12/17/2020 6:21:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: B-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.30		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-13 Client Sample ID: B-3  
Collection Date: 12/17/2020 6:23:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: B-3

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.50		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-14 Client Sample ID: B-4  
Collection Date: 12/17/2020 6:24:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: B-4

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	11.4		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-15 Client Sample ID: B-5  
Collection Date: 12/17/2020 6:25:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: B-5

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.73		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-16 Client Sample ID: B-6  
Collection Date: 12/17/2020 6:24:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: B-6

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.88		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-17 Client Sample ID: I-1  
Collection Date: 12/17/2020 6:28:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: I-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.927		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-18 Client Sample ID: I-2  
Collection Date: 12/17/2020 6:29:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: I-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.23		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-19 Client Sample ID: I-3  
Collection Date: 12/17/2020 6:29:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: I-3

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	13.3		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-20 Client Sample ID: I-4  
Collection Date: 12/17/2020 6:30:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: I-4

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.18		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-21 Client Sample ID: PD-1  
Collection Date: 12/17/2020 6:31:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: PD-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.536		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-22 Client Sample ID: PD-2  
Collection Date: 12/17/2020 6:32:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: PD-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.28		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-23 Client Sample ID: M-1  
Collection Date: 12/17/2020 6:35:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.747		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-24 Client Sample ID: M-2  
Collection Date: 12/17/2020 6:36:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.29		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-25 Client Sample ID: M-3  
Collection Date: 12/17/2020 6:36:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-3

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.140		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-26 Client Sample ID: M-4  
Collection Date: 12/17/2020 6:36:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-4

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.235		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-27 Client Sample ID: M-5  
Collection Date: 12/17/2020 6:35:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-5

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.737		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-28 Client Sample ID: M-6  
Collection Date: 12/17/2020 6:34:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-6

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.140		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-29 Client Sample ID: M-7  
Collection Date: 12/17/2020 6:34:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-7

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.208		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-30 Client Sample ID: M-8  
Collection Date: 12/17/2020 6:38:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-8

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.76		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-31 Client Sample ID: M-9  
Collection Date: 12/17/2020 6:38:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-9

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.341		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-32 Client Sample ID: M-10  
Collection Date: 12/17/2020 6:40:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-10

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.287		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-33 Client Sample ID: M-11  
Collection Date: 12/17/2020 6:39:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-11

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.04		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-34 Client Sample ID: M-12  
Collection Date: 12/17/2020 6:41:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-12

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.11		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-35 Client Sample ID: M-13  
Collection Date: 12/17/2020 6:41:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-13

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.355		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-36 Client Sample ID: M-14  
Collection Date: 12/17/2020 6:42:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-14

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.33		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-37 Client Sample ID: M-15  
Collection Date: 12/17/2020 6:42:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: M-15

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.981		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-38 Client Sample ID: R5-1  
Collection Date: 12/17/2020 6:57:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R5-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.00		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-39 Client Sample ID: BB-1  
Collection Date: 12/17/2020 6:59:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: BB-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.67		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9  
PO Box 548  
Eagle Point, OR 97524

**Lab Order:** 20120966  
**Received Date:** 12/17/2020 12:30:00 PM  
**Reported Date:** 12/30/2020 3:33:24 PM

Sample Information:

**Lab ID:** 20120966-40 **Client Sample ID:** BB-2  
**Collection Date:** 12/17/2020 6:58:00 AM **Collected By:** Ethan Kennelly  
**Matrix:** Drinking Water **Sample Location:** BB-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.42		0.103	µg/L	1	12/20/2020	15.0	A

**Lab ID:** 20120966-41 **Client Sample ID:** R3-1  
**Collection Date:** 12/17/2020 7:01:00 AM **Collected By:** Ethan Kennelly  
**Matrix:** Drinking Water **Sample Location:** R3-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	7.51		0.103	µg/L	1	12/20/2020	15.0	A

**Lab ID:** 20120966-42 **Client Sample ID:** R3-2  
**Collection Date:** 12/17/2020 7:00:00 AM **Collected By:** Ethan Kennelly  
**Matrix:** Drinking Water **Sample Location:** R3-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.79		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-43 Client Sample ID: O-1  
Collection Date: 12/17/2020 7:02:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: O-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	10.6		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-44 Client Sample ID: O-2  
Collection Date: 12/17/2020 7:03:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: O-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.17		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-45 Client Sample ID: O-3  
Collection Date: 12/17/2020 7:04:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: O-3

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.945		0.103	µg/L	1	12/20/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-46 Client Sample ID: GB-1  
Collection Date: 12/17/2020 7:05:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: GB-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.35		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-47 Client Sample ID: GB-2  
Collection Date: 12/17/2020 7:04:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: GB-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.344		0.103	µg/L	1	12/20/2020	15.0	A

Lab ID: 20120966-48 Client Sample ID: S-1  
Collection Date: 12/17/2020 7:07:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: S-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.525		0.103	µg/L	1	12/21/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-49 Client Sample ID: S-2  
Collection Date: 12/17/2020 7:08:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: S-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.460		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-50 Client Sample ID: S-3  
Collection Date: 12/17/2020 7:09:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: S-3

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.314		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-51 Client Sample ID: L-1  
Collection Date: 12/17/2020 7:13:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: L-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.58		0.103	µg/L	1	12/21/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-52 Client Sample ID: R6-1  
Collection Date: 12/17/2020 7:16:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R6-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.20		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-53 Client Sample ID: R6-4  
Collection Date: 12/17/2020 7:17:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R6-4

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.537		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-54 Client Sample ID: R1-1  
Collection Date: 12/17/2020 7:25:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R1-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.33		0.103	µg/L	1	12/21/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-55 Client Sample ID: R1-2  
Collection Date: 12/17/2020 7:26:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R1-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.69		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-56 Client Sample ID: R2-1  
Collection Date: 12/17/2020 7:28:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R2-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.01		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-57 Client Sample ID: R2-2  
Collection Date: 12/17/2020 7:29:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R2-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.58		0.103	µg/L	1	12/21/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-58 Client Sample ID: R7-1  
Collection Date: 12/17/2020 7:33:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R7-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.17		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-59 Client Sample ID: R7-2  
Collection Date: 12/17/2020 7:34:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R7-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.11		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-60 Client Sample ID: R8-1  
Collection Date: 12/17/2020 7:36:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R8-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.94		0.103	µg/L	1	12/21/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-61 Client Sample ID: R8-2  
Collection Date: 12/17/2020 7:36:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R8-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.99		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-62 Client Sample ID: R9-1  
Collection Date: 12/17/2020 7:38:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R9-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	5.00		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-63 Client Sample ID: R9-2  
Collection Date: 12/17/2020 7:39:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R9-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.59		0.103	µg/L	1	12/21/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 20120966

Date Reported: 12/30/2020

Eagle Point School District #9

PO Box 548

Eagle Point, OR 97524

Lab Order: 20120966

Received Date: 12/17/2020 12:30:00 PM

Reported Date: 12/30/2020 3:33:24 PM

Sample Information:

Lab ID: 20120966-64 Client Sample ID: R10-1  
Collection Date: 12/17/2020 7:41:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R10-1

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.962		0.103	µg/L	1	12/21/2020	15.0	A

Lab ID: 20120966-65 Client Sample ID: R10-2  
Collection Date: 12/17/2020 7:41:00 AM Collected By: Ethan Kennelly  
Matrix: Drinking Water Sample Location: R10-2

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.281		0.103	µg/L	1	12/21/2020	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Original





Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 20120966  
30-Dec-20

Client: Eagle Point School District #9

Project: Shady Cove Schools

TestCode: LEAD\_DW

Sample ID: <b>MB-10169</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>PBW</b>	Batch ID: <b>10169</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259935</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.103									

Sample ID: <b>LCS-10169</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>10169</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259936</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	98.9	0.104	100	0	98.9	85	115				

Sample ID: <b>20120902-01AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>10169</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259938</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.104	100	5.94	95.1	70	130				

Sample ID: <b>20120902-01AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>10169</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259939</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	101	0.104	100	5.94	95.5	70	130	101	0.393	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode  
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded  
PL Permit Limit

MI Recovery outside control limits due to Matrix Interference  
RL Reporting Detection Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 20120966  
30-Dec-20

Client: Eagle Point School District #9

Project: Shady Cove Schools

TestCode: LEAD\_DW

Sample ID: <b>MB-10170</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>PBW</b>	Batch ID: <b>10170</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259963</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.103									

Sample ID: <b>LCS-10170</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>10170</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259964</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	96.8	0.104	100	0	96.8	85	115				

Sample ID: <b>20120966-06AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>K-1</b>	Batch ID: <b>10170</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259966</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	94.0	0.104	100	3.44	90.5	70	130				

Sample ID: <b>20120966-06AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>K-1</b>	Batch ID: <b>10170</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259967</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	94.5	0.104	100	3.44	91.1	70	130	94.0	0.585	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode  
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded  
PL Permit Limit

MI Recovery outside control limits due to Matrix Interference  
RL Reporting Detection Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 20120966  
30-Dec-20

Client: Eagle Point School District #9

Project: Shady Cove Schools

TestCode: LEAD\_DW

Sample ID: <b>MB-10171</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>
Client ID: <b>PBW</b>	Batch ID: <b>10171</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259991</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.103			
------	----	-------	--	--	--

Sample ID: <b>LCS-10171</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>
Client ID: <b>LCSW</b>	Batch ID: <b>10171</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259992</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	97.8	0.104	100	0	97.8 85 115
------	------	-------	-----	---	-------------

Sample ID: <b>20120966-26AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>
Client ID: <b>M-4</b>	Batch ID: <b>10171</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259994</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	91.3	0.104	100	0.235	91.1 70 130
------	------	-------	-----	-------	-------------

Sample ID: <b>20120966-26AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>
Client ID: <b>M-4</b>	Batch ID: <b>10171</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>259995</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	90.6	0.104	100	0.235	90.4 70 130 91.3 0.783 20
------	------	-------	-----	-------	---------------------------

**Qualifiers:** C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Int  
ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 20120966  
30-Dec-20

Client: Eagle Point School District #9

Project: Shady Cove Schools

TestCode: LEAD\_DW

Sample ID: <b>MB-10172</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>PBW</b>	Batch ID: <b>10172</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>260019</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.103									

Sample ID: <b>LCS-10172</b>		SampType: <b>LCS</b>		TestCode: <b>LEAD_DW</b>		Units: <b>µg/L</b>		Prep Date: <b>12/20/2020</b>		RunNo: <b>17905</b>			
Client ID: <b>LCSW</b>		Batch ID: <b>10172</b>		TestNo: <b>E200.8</b>		<b>E200.8</b>		Analysis Date: <b>12/20/2020</b>		SeqNo: <b>260020</b>			
Analyte		Result		PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead		95.9		0.104	100	0	95.9	85	115				

Sample ID: <b>20120966-46AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>GB-1</b>	Batch ID: <b>10172</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>260022</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	97.1	0.104	100	5.35	91.8	70	130				

Sample ID: <b>20120966-46AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/20/2020</b>	RunNo: <b>17905</b>						
Client ID: <b>GB-1</b>	Batch ID: <b>10172</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/20/2020</b>	SeqNo: <b>260023</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	96.7	0.104	100	5.35	91.4	70	130	97.1	0.368	20	

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode  
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded  
PL Permit Limit

MI Recovery outside control limits due to Matrix Int  
RL Reporting Detection Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 20120966  
30-Dec-20

Client: Eagle Point School District #9

Project: Shady Cove Schools

TestCode: LEAD\_DW

Sample ID: <b>MB-10180</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/21/2020</b>	RunNo: <b>17959</b>
Client ID: <b>PBW</b>	Batch ID: <b>10180</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/22/2020</b>	SeqNo: <b>260835</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.100			

Sample ID: <b>LCS-10180</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/21/2020</b>	RunNo: <b>17959</b>
Client ID: <b>LCSW</b>	Batch ID: <b>10180</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/22/2020</b>	SeqNo: <b>260836</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	102	0.100	100	0	102 85 115

Sample ID: <b>20121073-01AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/21/2020</b>	RunNo: <b>17959</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>10180</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/22/2020</b>	SeqNo: <b>260838</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	99.4	0.100	100	0.0450	99.4 70 130

Sample ID: <b>20121073-01AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>µg/L</b>	Prep Date: <b>12/21/2020</b>	RunNo: <b>17959</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>10180</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>12/22/2020</b>	SeqNo: <b>260839</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	98.9	0.100	100	0.0450	98.9 70 130 99.4 0.481 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode  
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeded  
PL Permit Limit

MI Recovery outside control limits due to Matrix Int  
RL Reporting Detection Limit

Original

## Sample Log-In Check List

Client Name: **EAGLEPTSCHOOL**

Work Order Number: **20120966**

RcptNo: **1**

Logged by: **Jeri Stringer** **12/17/2020 12:30:00 PM**



Completed By: **Krizzle Calip** **12/17/2020 5:44:23 PM**



Reviewed By: **Naomi Orr** **12/30/2020 3:21:41 PM**



### Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐  
2. How was the sample delivered? Client

### Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒  
4. Shipping container/cooler in good condition? Yes ☒ No ☐  
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒  
No. Seal Date: Signed By:  
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒  
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒  
7. Sample(s) in proper container(s)? Yes ☒ No ☐  
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐  
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐  
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐  
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2  
No VOA Vials ☒  
12. Were any sample containers received broken? Yes ☐ No ☒  
13. Does paperwork match bottle labels? Yes ☒ No ☐  
(Note discrepancies on chain of custody)  
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐  
15. Is it clear what analyses were requested? Yes ☒ No ☐  
16. Were all holding times able to be met? Yes ☒ No ☐  
(If no, notify customer for authorization.)

### Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified:  Date:   
By Whom:  Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person  
Regarding:   
Client Instructions:

18. Additional remarks:

The sample submitted contained visible sediments (fraction 09, 14, 27, 30, 34, 38, 40, 41, 42, 52, and 60).

### Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

# Chain of Custody Record

Page \_\_\_\_ of \_\_\_\_

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

## Section A Required Client Information

Company: Eagle Point SD #9  
Address: 203 N. Platt  
Eagle Point, OR 97524  
Email: Harding J@eaglepoint.k12.or.us  
Phone: 541-830-6376 Fax: \_\_\_\_\_  
Collected By (Print): Ethan Kennelly  
Collected By (Sign): [Signature]  
Email Report ☒ Yes \_\_\_ No \_\_\_ Mail Report \_\_\_ Yes \_\_\_ No  
Fax Report \_\_\_ Yes \_\_\_ No

## Section B Required Project Information

Project Name: Shady Cove Schools  
Project Number: \_\_\_\_\_  
Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_

## Section C Invoice Information

Attention: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
P.O. # \_\_\_\_\_

## Section D Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days  
\_\_\_ 5 Business Days (50% surcharge)  
\_\_\_ 3 Business Days (75% surcharge)  
\_\_\_ 24 - 48 hours (100% surcharge)  
\_\_\_ Other \_\_\_\_\_  
Authorized \_\_\_ Yes \_\_\_ No

## Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
BL-1			12/17	5:51 A	1	X											01
BL-2				5:52 A	1	X											02
GL-1				5:54 A	1	X											03
GL-2				5:54 A	1	X											04
G-1				5:56 A	1	X											05
K-1				6:00 A	1	X											06
K-2				6:01 A	1	X											07
K-3				6:01 A	1	X											08
K-4				6:19 A	1	X											09
K-5				6:20 A	1	X											10

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

## Section F Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>Ethan Kennelly</u>		12/17	9:08
Received By: <u>John Harding</u>	<u>John Harding</u>		12/17	9:08
Relinquished By: <u>John Harding</u>	<u>John Harding</u>		12/17	12:30
Received By: _____				
Relinquished By: <u>[Signature]</u>				
Received By Laboratory: <u>[Signature]</u>	<u>Jeri Stringer</u>		12/17/20	12:30

## Section G Lab Use Only

Temp: Ambient  
4°C +/- 2°C: \_\_\_ Yes \_\_\_ No NA  
Received on Ice: \_\_\_ Yes \_\_\_ No  
Number of Bottles Received: \_\_\_\_\_  
pH Checked: NA  
COC Seals Intact: \_\_\_ Yes \_\_\_ No NA  
Field Blank Included: \_\_\_ Yes \_\_\_ No

Received Via \_\_\_ UPS \_\_\_ FedEX \_\_\_ Other ☒ Hand

Payment: Invoice Cash \_\_\_ VISA, M/C \_\_\_ Check # \_\_\_\_\_ Amount \_\_\_\_\_



# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page \_\_\_\_ of \_\_\_\_

## Section A

### Required Client Information

Company: Eagle Point SD #9  
Address: 203 W. Platt  
Eagle Point OR 97524  
Email: HardingJ@eaglept.k12.or.us  
Phone: 541-330-6376 Fax: \_\_\_\_\_  
Collected By (Print): Ethan Kennedy  
Collected By (Sign): [Signature]  
Email Report ☒ Yes \_\_\_ No \_\_\_ Mail Report \_\_\_ Yes \_\_\_ No  
Fax Report \_\_\_ Yes \_\_\_ No

## Section B

### Required Project Information

Project Name: Shady Cove Schools  
Project Number: \_\_\_\_\_  
Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_

## Section C

### Invoice Information

Attention: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
P.O. # \_\_\_\_\_

## Section D

### Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days  
\_\_\_ 5 Business Days (50% surcharge)  
\_\_\_ 3 Business Days (75% surcharge)  
\_\_\_ 24 - 48 hours (100% surcharge)  
\_\_\_ Other \_\_\_\_\_  
Authorized \_\_\_ Yes \_\_\_ No

## Section E

### Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
B-1			12/17	6:22 A	1	X										2030966	11
B-2				6:21 A	1	X											12
B-3				6:23 A	1	X											13
B-4				6:24 A	1	X											14
B-5				6:25 A	1	X											15
B-6				6:24 A	1	X											16
I-1				6:25 A	1	X											17
I-2				6:27 A	1	X											18
I-3				6:29 A	1	X											19
I-4				6:30 A	1	X											20

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

## Section F

### Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>Ethan Kennedy</u>		12/17	9:06
Received By: <u>John Harding</u>	<u>John Harding</u>		12/17	9:08
Relinquished By: <u>John Harding</u>	<u>John Harding</u>		12/17	12:30
Received By: _____				
Relinquished By: <u>[Signature]</u>				
Received By Laboratory: <u>John Stringer</u>	<u>John Stringer</u>		12/17/20	12:30

## Section G

### Lab Use Only

Temp: Ambient  
4°C +/- 2°C: \_\_\_ Yes \_\_\_ No NA  
Received on Ice: \_\_\_ Yes ☒ No  
Number of Bottles Received: \_\_\_\_\_  
pH Checked: NA  
COC Seals Intact: \_\_\_ Yes \_\_\_ No ☒ NA  
Field Blank Included: \_\_\_ Yes ☒ No

Received Via \_\_\_ UPS \_\_\_ FedEX \_\_\_ Other ☒ Hand

Payment: ☒ Invoice \_\_\_ Cash \_\_\_ VISA, M/C \_\_\_ Check # \_\_\_\_\_ Amount \_\_\_\_\_



# Chain of Custody Record

Page \_\_\_\_ of \_\_\_\_

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

## Section A

### Required Client Information

Company: Eagle Point SD #9  
Address: 203 N. Platt  
Eagle Point, OR 97524  
Email: Harding J. Deagaput. K12.05.015  
Phone: 541-830-6376 Fax: \_\_\_\_\_  
Collected By (Print): Ethan Kennelly  
Collected By (Sign): [Signature]  
Email Report ☒ Yes ☐ No Mail Report ☐ Yes ☐ No  
Fax Report ☐ Yes ☐ No

## Section B

### Required Project Information

Project Name: Shady Cove Schools  
Project Number: \_\_\_\_\_  
Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_

## Section C

### Invoice Information

Attention: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
P.O. # \_\_\_\_\_

## Section D

### Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days  
☐ 5 Business Days (50% surcharge)  
☐ 3 Business Days (75% surcharge)  
☐ 24 - 48 hours (100% surcharge)  
☐ Other \_\_\_\_\_  
Authorized ☐ Yes ☐ No

## Section E

### Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
PD-1			12/17	6:31A	1	X												21
PD-2				6:32A	1	X												22
M-1				6:35A	1	X												23
M-2				6:36A	1	X												24
M-3				6:36A	1	X												25
M-4				6:36A	1	X												26
M-5				6:35A	1	X												27
M-6				6:34A	1	X												28
M-7				6:31A	1	X												29
M-8				6:38A	1	X												30

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

## Section F

### Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>Ethan Kennelly</u>	<u>Ethan Kennelly</u>	<u>12/17</u>	<u>9:09</u>
Received By: <u>John Harding</u>	<u>John Harding</u>	<u>John Harding</u>	<u>12/17</u>	<u>9:08</u>
Relinquished By: <u>John Harding</u>	<u>John Harding</u>	<u>John Harding</u>	<u>12/17</u>	<u>12:30</u>
Received By: _____	_____	_____	_____	_____
Relinquished By: _____	_____	_____	_____	_____
Received By Laboratory: <u>[Signature]</u>	<u>Jeri Stringer</u>	<u>Jeri Stringer</u>	<u>12/17/20</u>	<u>12:30</u>

## Section G

### Lab Use Only

Temp: Ambient  
4°C +/- 2°C: ☐ Yes ☒ No NA  
Received on Ice: ☐ Yes ☒ No  
Number of Bottles Received: \_\_\_\_\_  
pH Checked: NA  
COC Seals Intact: ☐ Yes ☒ No NA  
Field Blank Included: ☐ Yes ☒ No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: ☐ Invoice ☐ Cash ☐ VISA, M/C ☐ Check # \_\_\_\_\_ Amount \_\_\_\_\_

# Chain of Custody Record

Page \_\_\_\_ of \_\_\_\_

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

## Section A Required Client Information

Company: Eagle Point SD #9  
Address: 708 N. Platt  
Eagle Point, OR 97524  
Email: Harding SD eaglept.k12.ors  
Phone: 541-830-6376 Fax: \_\_\_\_\_  
Collected By (Print): Ethan Kennelly  
Collected By (Sign): [Signature]  
Email Report ☒ Yes \_\_\_ No \_\_\_ Mail Report \_\_\_ Yes \_\_\_ No  
Fax Report \_\_\_ Yes \_\_\_ No

## Section B Required Project Information

Project Name: Shady Cove Sheds  
Project Number: \_\_\_\_\_  
Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_

## Section C Invoice Information

Attention: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
P.O. # \_\_\_\_\_

## Section D Reply Status (Subject to Scheduling)

☒ Standard 10-14 Days  
\_\_\_ 5 Business Days (50% surcharge)  
\_\_\_ 3 Business Days (75% surcharge)  
\_\_\_ 24 - 48 hours (100% surcharge)  
\_\_\_ Other \_\_\_\_\_  
Authorized \_\_\_ Yes \_\_\_ No

## Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
M-9			12/17	6:38 A	1	X												31
M-10				6:40 A	1	X												32
M-11				6:39 A	1	X												33
M-12				6:41 A	1	X												34
M-13				6:41 A	1	X												35
M-14				6:42 A	1	X												36
M-15				6:43 A	1	X												37
K5-1				6:57 A	1	X												38
B3-1				6:59 A	1	X												39
B3-2				6:58 A	1	X												40

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

## Section F Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>		<u>Ethan Kennelly</u>	<u>12/17</u>	<u>9:06</u>
Received By: <u>John Harding</u>		<u>John Harding</u>	<u>12/17</u>	<u>9:08</u>
Relinquished By: <u>John Harding</u>		<u>John Harding</u>	<u>12/17</u>	<u>12:30</u>
Received By: _____				
Relinquished By: <u>[Signature]</u>		<u>Jeri Stringer</u>	<u>12/17/20</u>	<u>12:30</u>
Received By Laboratory: _____				

## Section G Lab Use Only

Temp: Ambient  
4°C +/- 2°C: \_\_\_ Yes \_\_\_ No NA  
Received on Ice: \_\_\_ Yes ☒ No  
Number of Bottles Received: \_\_\_\_\_  
pH Checked: NA  
COC Seals Intact: \_\_\_ Yes \_\_\_ No ☒ NA  
Field Blank Included: \_\_\_ Yes ☒ No

Received Via \_\_\_ UPS \_\_\_ FedEx \_\_\_ Other ☒ Hand

Payment Invoice Cash \_\_\_ VISA, M/C \_\_\_ Check # \_\_\_\_\_ Amount \_\_\_\_\_



# Chain of Custody Record

Page \_\_\_\_ of \_\_\_\_

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

## Section A Required Client Information

Company: Eagle Point SD #9  
Address: 203 N. Platt  
Eagle Point, OR 97524  
Email: Harding SD eaglepnt.k12.or.us  
Phone: 541-830-6376 Fax: \_\_\_\_\_  
Collected By (Print): Ethan Kennedy  
Collected By (Sign): [Signature]  
Email Report ☒ Yes \_\_\_ No \_\_\_ Mail Report \_\_\_ Yes \_\_\_ No  
Fax Report \_\_\_ Yes \_\_\_ No

## Section B Required Project Information

Project Name: Sludgy Cove skunk  
Project Number: \_\_\_\_\_  
Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_

## Section C Invoice Information

Attention: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
P.O. # \_\_\_\_\_

## Section D Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days  
\_\_\_ 5 Business Days (50% surcharge)  
\_\_\_ 3 Business Days (75% surcharge)  
\_\_\_ 24 - 48 hours (100% surcharge)  
\_\_\_ Other \_\_\_\_\_  
Authorized \_\_\_ Yes \_\_\_ No

## Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
R3-1			12/17	7:01A	1	X												41
R3-2				7:00A	1	X												42
O-1				7:02A	1	X												43
O-2				7:03A	1	X												44
O-3				7:04A	1	X												45
GB-1				7:05A	1	X												46
GB-2				7:04A	1	X												47
S-1				7:07A	1	X												48
S-2				7:08A	1	X												49
S-3				7:09A	1	X												50

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

## Section F Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>Ethan Kennedy</u>	<u>Ethan Kennedy</u>	<u>12/17</u>	<u>9:08</u>
Received By: <u>John Harding</u>	<u>John Harding</u>	<u>John Harding</u>	<u>12/17</u>	<u>9:08</u>
Relinquished By: <u>John Harding</u>	<u>John Harding</u>	<u>John Harding</u>	<u>12/17</u>	<u>12:30</u>
Received By: _____	_____	_____	_____	_____
Relinquished By: _____	_____	_____	_____	_____
Received By Laboratory: _____	_____	_____	_____	_____

## Section G Lab Use Only

Temp: Ambient  
4°C +/- 2°C: \_\_\_ Yes \_\_\_ No NA  
Received on Ice: \_\_\_ Yes ☒ No  
Number of Bottles Received: \_\_\_\_\_  
pH Checked: NA  
COC Seals Intact: \_\_\_ Yes \_\_\_ No ☒ NA  
Field Blank Included: \_\_\_ Yes ☒ No

Received Via \_\_\_ UPS \_\_\_ FedEx \_\_\_ Other ☒ Hand

Payment: Invoice Cash \_\_\_ VISA, M/C \_\_\_ Check # \_\_\_\_\_ Amount \_\_\_\_\_

# Chain of Custody Record

Page \_\_\_\_ of \_\_\_\_

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

## Section A

### Required Client Information

Company: Eagle Point SD #9  
Address: 203 N. Platt  
Eagle Point, OR 97524  
Email: Harding.J@eaglepoint-OR.us  
Phone: 541-830-6376 Fax: \_\_\_\_\_  
Collected By (Print): Ethan Kennedy  
Collected By (Sign): [Signature]  
Email Report ☒ Yes \_\_\_ No \_\_\_ Mail Report \_\_\_ Yes \_\_\_ No  
Fax Report \_\_\_ Yes \_\_\_ No

## Section B

### Required Project Information

Project Name: Shady Cove Schools  
Project Number: \_\_\_\_\_  
Report To: \_\_\_\_\_  
Copy To: \_\_\_\_\_

## Section C

### Invoice Information

Attention: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
P.O. # \_\_\_\_\_

## Section D

### Rush Status (Subject to Scheduling)

☒ Standard 10-14 Days  
\_\_\_ 5 Business Days (50% surcharge)  
\_\_\_ 3 Business Days (75% surcharge)  
\_\_\_ 24 - 48 hours (100% surcharge)  
\_\_\_ Other \_\_\_\_\_  
Authorized \_\_\_ Yes \_\_\_ No

## Section E

### Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
L-1			12/17	7:13 A	1	X												51
R6-1				7:16 A	1	X												52
R6-2						X												
R6-3						X												
R6-4				7:17 A	1	X												53
R1-1				7:25 A	1	X												54
R1-2				7:26 A	1	X												55
R2-1				7:28 A	1	X												56
R2-2				7:29 A	1	X												57
R7-1				7:33 A	1	X												58

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

## Section F

### Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>Ethan Kennedy</u>		12/12	4:08
Received By: <u>John Harding</u>	<u>John Harding</u>		12/17	9:28
Relinquished By: <u>John Harding</u>	<u>John Harding</u>		12/17	12:38
Received By: _____				
Relinquished By: <u>[Signature]</u>				
Received By Laboratory: <u>John Stringer</u>	<u>John Stringer</u>		12/17/20	12:30

## Section G

### Lab Use Only

Temp: Ambient  
4°C +/- 2°C: \_\_\_ Yes \_\_\_ No N/A  
Received on Ice: \_\_\_ Yes ☒ No  
Number of Bottles Received: \_\_\_\_\_  
pH Checked: N/A  
COC Seals Intact: \_\_\_ Yes \_\_\_ No NA  
Field Blank Included: \_\_\_ Yes ☒ No

Received Via \_\_\_ UPS \_\_\_ FedEx \_\_\_ Other ☒ Hand

Payment: ☒ Invoice \_\_\_ Cash \_\_\_ VISA, M/C \_\_\_ Check # \_\_\_\_\_ Amount \_\_\_\_\_



# Chain of Custody Record

Page \_\_\_\_ of \_\_\_\_

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b> Required Client Information	<b>Section B</b> Required Project Information	<b>Section C</b> Invoice Information	<b>Section D</b> Rush Status (Subject to Scheduling)
Company: <u>Eagle Point SD #9</u>	Project Name: <u>Shady Cove Schools</u>	Attention:	<input checked="" type="checkbox"/> Standard 10-14 Days
Address: <u>202 N. Platt</u>	Project Number:	Company Name:	<input type="checkbox"/> 5 Business Days (50% surcharge)
<u>Eagle Point, OR 97524</u>	Report To:	Address:	<input type="checkbox"/> 3 Business Days (75% surcharge)
Email: <u>Harding J D eaglepnt.k12.or.us</u>	Copy To:	P.O. #	<input type="checkbox"/> 24 - 48 hours (100% surcharge)
Phone: <u>541-830-6376</u> Fax:			<input type="checkbox"/> Other _____
Collected By (Print): <u>Ethan Kennedy</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Collected By (Sign): <u>[Signature]</u>			
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

<b>Section E</b> Sample Information					<b>Analysis Requested</b>										<b>NRC Workorder #</b> (Lab Use Only) <u>2020966</u>				
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead												Remarks/Field Data	NRC Sample # (Lab Use Only)
R7-2			12/17	7:34A	1	X													59
R8-1				7:36A	1	X													60
R8-2				7:36A	1	X													61
R9-1				7:38A	1	X													62
R9-2				7:39A	1	X													63
R10-1				7:41am	1	X													64
R10-2				7:41am	1	X													65

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

<b>Section F</b> Relinquish/Receive		Sign	Print	Date	Time	<b>Section G</b> Lab Use Only	
Relinquished By:	<u>[Signature]</u>		<u>[Signature]</u>	12/17	9:06	Temp:	<u>Ambient</u>
Received By:	<u>[Signature]</u>		<u>John Harding</u>	12/17	9:08	4°C +/- 2°C:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>NA</u>
Relinquished By:	<u>[Signature]</u>		<u>John Harding</u>	12/17	12:30	Received on Ice:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received By:	<u>[Signature]</u>					Number of Bottles Received:	
Relinquished By:	<u>[Signature]</u>					pH Checked:	<u>NA</u>
Received By Laboratory:	<u>[Signature]</u>		<u>Jen Stringer</u>	12/17/20	12:30	COC Seals Intact:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>NA</u>
						Field Blank Included:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Received Via ☐ UPS ☐ FedEx ☐ Other ☒ Hand

Payment: Invoice Cash ☐ VISA, M/C ☐ Check # \_\_\_\_\_ Amount \_\_\_\_\_