



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Monday, February 3, 2025

Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 78009.

First Draw samples flushed by Martel on November 12, 2024 sampled by Martel on November 13, 2024.

Project Identification: MD HB 270

School: Berry Elementary

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



Certificate of Analysis

MARTEL NO. 78009 1 BES-1-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 04:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 19:46 BJ

MARTEL NO. 78009 2 BES-2-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 04:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 19:51 BJ

MARTEL NO. 78009 3 BES-3-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 04:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 19:53 BJ

MARTEL NO. 78009 4 BES-4-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 04:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.26	ug/l	EPA .200.8	2	01/28/2025 19:56 BJ

MARTEL NO. 78009 5 BES-5-IM CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 04:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 19:58 BJ

MARTEL NO. 78009 8 BES-8-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 04:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:01 BJ

MARTEL NO. 78009 9 BES-9-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 04:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:03 BJ

MARTEL NO. 78009 10 BES-10-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 04:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 11	BES-11-DB		11/13/2024 04:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 14	BES-14-FC		11/13/2024 04:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:10 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 15	BES-15-DB		11/13/2024 04:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:18 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 40	BES-40-DC		11/13/2024 04:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:25 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 41	BES-41-DC		11/13/2024 04:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:28 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 42	BES-42-DC		11/13/2024 04:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:30 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 43	BES-43-DC		11/13/2024 04:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:33 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 68	BES-68-FC		11/13/2024 04:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:35 BJ



MARTEL NO. 78009	69	CLIENT SAMPLE IDENTIFICATION BES-69-DB	Sample Date/Time 11/13/2024 04:38
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.38	ug/l	EPA .200.8	2	01/28/2025 20:38 BJ

MARTEL NO. 78009	70	CLIENT SAMPLE IDENTIFICATION BES-70-DC	Sample Date/Time 11/13/2024 04:41
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:40 BJ

MARTEL NO. 78009	71	CLIENT SAMPLE IDENTIFICATION BES-71-DC	Sample Date/Time 11/13/2024 04:41
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:43 BJ

MARTEL NO. 78009	72	CLIENT SAMPLE IDENTIFICATION BES-72-FC	Sample Date/Time 11/13/2024 04:45
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:45 BJ

MARTEL NO. 78009	73	CLIENT SAMPLE IDENTIFICATION BES-73-FC	Sample Date/Time 11/13/2024 04:45
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 20:55 BJ

MARTEL NO. 78009	74	CLIENT SAMPLE IDENTIFICATION BES-74-DB	Sample Date/Time 11/13/2024 04:45
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.13	ug/l	EPA .200.8	2	01/28/2025 21:00 BJ

MARTEL NO. 78009	75	CLIENT SAMPLE IDENTIFICATION BES-75-FC	Sample Date/Time 11/13/2024 04:45
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:02 BJ

MARTEL NO. 78009	76	CLIENT SAMPLE IDENTIFICATION BES-76-DB	Sample Date/Time 11/13/2024 04:45
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:05 BJ



MARTEL NO. 78009	77	CLIENT SAMPLE IDENTIFICATION BES-77-FC	Sample Date/Time 11/13/2024 04:49
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.45	ug/l	EPA .200.8	2	01/28/2025 21:07 BJ

MARTEL NO. 78009	78	CLIENT SAMPLE IDENTIFICATION BES-78-DB	Sample Date/Time 11/13/2024 04:49
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.25	ug/l	EPA .200.8	2	01/28/2025 21:10 BJ

MARTEL NO. 78009	79	CLIENT SAMPLE IDENTIFICATION BES-79-FC	Sample Date/Time 11/13/2024 04:49
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:12 BJ

MARTEL NO. 78009	80	CLIENT SAMPLE IDENTIFICATION BES-80-DB	Sample Date/Time 11/13/2024 04:49
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:15 BJ

MARTEL NO. 78009	81	CLIENT SAMPLE IDENTIFICATION BES-81-FC	Sample Date/Time 11/13/2024 04:49
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:17 BJ

MARTEL NO. 78009	82	CLIENT SAMPLE IDENTIFICATION BES-82-DB	Sample Date/Time 11/13/2024 04:49
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:19 BJ

MARTEL NO. 78009	85	CLIENT SAMPLE IDENTIFICATION BES-85-FC	Sample Date/Time 11/13/2024 04:51
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:27 BJ

MARTEL NO. 78009	86	CLIENT SAMPLE IDENTIFICATION BES-86-FC	Sample Date/Time 11/13/2024 04:54
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.26	ug/l	EPA .200.8	2	01/28/2025 21:34 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 87	BES-87-DB		11/13/2024 04:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:37 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 89	BES-89-BU		11/13/2024 04:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:39 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 90	BES-90-BU		11/13/2024 04:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:42 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 91	BES-91-BU		11/13/2024 04:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:44 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 92	BES-92-BU		11/13/2024 04:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:47 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 93	BES-93-BU		11/13/2024 04:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:49 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 94	BES-94-BU		11/13/2024 04:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:52 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
78009 95	BES-95-BU		11/13/2024 04:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 21:54 BJ

Martel Laboratories *JDS* Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 martel@martellabs.com

CHARPS

02/03/2025

P 06



MARTEL NO. 78009	96	CLIENT SAMPLE IDENTIFICATION BES-96-BU	Sample Date/Time 11/13/2024 04:32
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:04 BJ

MARTEL NO. 78009	1F	CLIENT SAMPLE IDENTIFICATION BES-1F-FC	Sample Date/Time 11/13/2024 05:07
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:09 BJ

MARTEL NO. 78009	2F	CLIENT SAMPLE IDENTIFICATION BES-2F-FC	Sample Date/Time 11/13/2024 05:07
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:12 BJ

MARTEL NO. 78009	3F	CLIENT SAMPLE IDENTIFICATION BES-3F-FC	Sample Date/Time 11/13/2024 05:07
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:14 BJ

MARTEL NO. 78009	4F	CLIENT SAMPLE IDENTIFICATION BES-4F-FC	Sample Date/Time 11/13/2024 05:07
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:17 BJ

MARTEL NO. 78009	85F	CLIENT SAMPLE IDENTIFICATION BES-85F-FC	Sample Date/Time 11/13/2024 04:59
---------------------	-----	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:19 BJ

MARTEL Chain of Custody Record

Martel Laboratoies JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/13/24 4:15am End Date/Time: 11/13/24 5:07am

Sampler/Relinquished By: Neverson Simms - Clark Received at Martel by: Date/Time: 11/15/24

22 Berry Elementary School

First Draw

10155 Berry Road Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78009

Martel #	Sample #	Location ID #	Fixture Type (Sink, bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb)	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush	Sample Time
							Flush Date	
1	1	BES-1-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	11/12	4:15
2	2	BES-2-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	11/12	4:15
3	3	BES-3-FC	sink	FC	kitchen sink	C	11/12	4:15
4	4	BES-4-FC	2 comp sink	FC	kitchen 2 comp sink	C	11/12	4:15
5	5	BES-5-IM	Ice Machine	IM	kitchen	C	11/12	4:15
6	8	BES-8-DC	water fountain	DC	corridor	C	11/12	4:23
7	9	BES-9-DC	water fountain	DC	corridor	C	11/12	4:23
8	10	BES-10-FC	sink	FC	Teachers lounge	C	11/12	4:26
9	11	BES-11-DB	bubbler	DB	Teachers lounge	C	11/12	4:26
10	14	BES-14-FC	sink	FC	CR 31 (Sp-Ed) Pull Out	C	11/12	4:28
11	15	BES-15-DB	bubbler	DB	CR 31 (Sp-Ed) Pull Out	C	11/12	4:28
12	40	BES-40-DC	water fountain - Left	DC	corridor	C	11/12	4:32
13	41	BES-41-DC	water fountain - Right	DC	corridor	C	11/12	4:32
14	42	BES-42-DC	water fountain - Left	DC	corridor	C	11/12	4:35
15	43	BES-43-DC	water fountain - Right	DC	corridor	C	11/12	4:35
16	68	BES-68-FC	sink	FC	CR K4 - K	C	11/12	4:38
17	69	BES-69-DB	bubbler	DB	CR K4 - K	C	11/12	4:38
18	70	BES-70-DC	water fountain	DC	corridor	C	11/12	4:41
19	71	BES-71-DC	water fountain	DC	corridor	C	11/12	4:41
20	72	BES-72-FC	sink	FC	New addition activity room	C	11/12	4:45
21	73	BES-73-FC	sink	FC	CR Pre-K 2 - Pre-K	C	11/12	4:45
22	74	BES-74-DB	bubbler	DB	CR Pre-K 2 - Pre-K	C	11/12	4:45
23	75	BES-75-FC	sink	FC	CR Pre-K 1 - Pre-K	C	11/12	4:45
24	76	BES-76-DB	bubbler	DB	CR Pre-K 1 - Pre-K	C	11/12	4:45

22 Berry Elementary School

First Draw

10155 Berry Road Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78009

							Flush	
25	77	BES-77-FC	sink	FC	CR K3 - K	C	11/12	4:49
26	78	BES-78-DB	bubbler	DB	CR K3 - K	C	11/12	4:49
27	79	BES-79-FC	sink	FC	CR K2 - K	C	11/12	4:49
28	80	BES-80-DB	bubbler	DB	CR K2 - K	C	11/12	4:49
29	81	BES-81-FC	sink	FC	CR K1 - K	C	11/12	4:49
30	82	BES-82-DB	bubbler	DB	CR K1 - K	C	11/12	4:49
31	83	BES-83-FC	sink	FC	Teachers lounge	C	NO SAMP	NO SAMP
32	85	BES-85-FC	sink	FC	nurse office	C	11/12	4:51
33	86	BES-86-FC	sink	FC	classroom 17	C	11/12	4:54
34	87	BES-87-DB	bubbler	DB	classroom 17	C	11/12	4:54
35	88	BES-88-DH	hot water dispenser	DH	Teachers lounge	C	NO SAMP	NO SAMP
36	89	BES-89-BU	Bottle Filler	BU	corridor	C	11/12	4:23
37	90	BES-90-BU	Bottle Filler	BU	corridor	C	11/12	4:23
38	91	BES-91-BU	Bottle Filler	BU	corridor	C	11/12	4:41
39	92	BES-92-BU	Bottle Filler	BU	corridor	C	11/12	4:41
40	93	BES-93-BU	Bottle Filler - Left	BU	corridor	C	11/12	4:35
41	94	BES-94-BU	Bottle Filler - Right	BU	corridor	C	11/12	4:35
42	95	BES-95-BU	Bottle Filler - Left	BU	corridor	C	11/12	4:32
43	96	BES-96-BU	Bottle Filler - Right	BU	corridor	C	11/12	4:32
44	1F	BES-1F-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C		FLUSH 5:07
45	2F	BES-2F-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C		FLUSH 5:07
46	3F	BES-3F-FC	sink	FC	kitchen sink	C		FLUSH 5:07
47	4F	BES-4F-FC	2 comp sink	FC	kitchen 2 comp sink	C		FLUSH 5:07
48	85F	BES-85F-FC	sink	FC	nurse office	C		FLUSH 4:59



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Monday, February 3, 2025

Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 78010.

First Draw samples flushed by Martel on November 12, 2024 sampled by Martel on November 13, 2024.

Project Identification: MD HB 270

School: Mattawoman Middle

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.

MARTEL NO. 78010 1 CLIENT SAMPLE IDENTIFICATION MMS-1-FC Sample Date/Time 11/13/2024 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:21 BJ

MARTEL NO. 78010 2 CLIENT SAMPLE IDENTIFICATION MMS-2-FC Sample Date/Time 11/13/2024 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.67	ug/l	EPA .200.8	2	01/28/2025 22:24 BJ

MARTEL NO. 78010 3 CLIENT SAMPLE IDENTIFICATION MMS-3-FC Sample Date/Time 11/13/2024 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:26 BJ

MARTEL NO. 78010 4 CLIENT SAMPLE IDENTIFICATION MMS-4-FC Sample Date/Time 11/13/2024 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/28/2025 22:29 BJ

MARTEL NO. 78010 7 CLIENT SAMPLE IDENTIFICATION MMS-7-FC Sample Date/Time 11/13/2024 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.31	ug/l	EPA .200.8	2	01/30/2025 17:05 BJ

MARTEL NO. 78010 8 CLIENT SAMPLE IDENTIFICATION MMS-8-DC Sample Date/Time 11/13/2024 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:17 BJ

MARTEL NO. 78010 9 CLIENT SAMPLE IDENTIFICATION MMS-9-DC Sample Date/Time 11/13/2024 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:19 BJ

MARTEL NO. 78010 11 CLIENT SAMPLE IDENTIFICATION MMS-11-DC Sample Date/Time 11/13/2024 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:21 BJ



Certificate of Analysis

MARTEL NO. 78010 13 MMS-13-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 05:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:24 BJ

MARTEL NO. 78010 14 MMS-14-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 05:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:26 BJ

MARTEL NO. 78010 15 MMS-15-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 05:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:29 BJ

MARTEL NO. 78010 16 MMS-16-FC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:31 BJ

MARTEL NO. 78010 17 MMS-17-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:34 BJ

MARTEL NO. 78010 18 MMS-18-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:36 BJ

MARTEL NO. 78010 19 MMS-19-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:46 BJ

MARTEL NO. 78010 20 MMS-20-DC CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/13/2024 05:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 17:51 BJ



Certificate of Analysis

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	21	MMS-21-DC				11/13/2024 05:44	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 17:54 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	22	MMS-22-DC				11/13/2024 05:44	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 17:56 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	24	MMS-24-FC				11/13/2024 05:32	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 17:58 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	28	MMS-28-FC				11/13/2024 05:27	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 18:01 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	29	MMS-29-BU				11/13/2024 05:34	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 18:03 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	30	MMS-30-BU				11/13/2024 05:23	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 18:06 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	31	MMS-31-BU				11/13/2024 05:29	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 18:08 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	1F	MMS-1F-FC				11/13/2024 05:53	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 18:11 BJ	



Certificate of Analysis

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	2F	MMS-2F-FC				11/13/2024 05:53	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 18:18 BJ	

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	4F	MMS-4F-FC				11/13/2024 05:53	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 18:25 BJ	

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78010	7F	MMS-7F-FC				11/13/2024 05:53	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 18:28 BJ	

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/13/24 5:19am End Date/Time: 11/13/24 5:53am

Sampler/Relinquished By: Neversen Simms-Clark Received at Martel by 11/13/24 Date/Time: 11/15/24

39 Mattawomen Middle School

First Draw

10145 Berry Road Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78010

Martel #	Sample #	Location ID #	Fixture Type (Sink, bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb)	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush	Sample Time
							Flush Date	
1	1	MMS-1-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C	11/12	5:19
2	2	MMS-2-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C	11/12	5:19
3	3	MMS-3-FC	Ice Machine	FC	Kitchen	C	11/12	5:19
4	4	MMS-4-FC	2 comp sink	FC	Kitchen	C	11/12	5:19
5	5	MMS-5-FC	Island sink next to kettle	FC	Kitchen	C	NO SAMP	NO SAMP
6	7	MMS-7-FC	Island sink	FC	Kitchen	C	11/12	5:19
7	8	MMS-8-DC	water fountain - Left	DC	corridor	C	11/12	5:23
8	9	MMS-9-DC	water fountain - Right	DC	corridor	C	11/12	5:23
9	11	MMS-11-DC	water fountain	DC	corridor	C	11/12	5:25
10	13	MMS-13-DC	water fountain	DC	cafeteria	C	11/12	5:29
11	14	MMS-14-FC	sink	FC	Nurse office	C	11/12	5:31
12	15	MMS-15-DC	water fountain	DC	corridor	C	11/12	5:34
13	16	MMS-16-FC	sink	FC	ILT	C	11/12	5:36
14	17	MMS-17-DC	water fountain	DC	ILT	C	11/12	5:36
15	18	MMS-18-DC	water fountain - Left	DC	corridor	C	11/12	5:38
16	19	MMS-19-DC	water fountain - Right	DC	corridor	C	11/12	5:38
17	20	MMS-20-DC	water fountain	DC	corridor	C	11/12	5:39
18	21	MMS-21-DC	water fountain	DC	corridor - (2nd Floor)	C	11/12	5:44
19	22	MMS-22-DC	water fountain	DC	corridor - (2nd Floor)	C	11/12	5:44
20	24	MMS-24-FC	sink	FC	work rm main office	C	11/12	5:32
21	25	MMS-25-FC	Sink	FC	Teacher's Lounge	C	NO SAMP	NO SAMP
22	26	MMS-26-FC	Sink	FC	Teacher's Lounge	C	NO SAMP	NO SAMP
23	27	MMS-27-FC	Sink	FC	Teacher's Lounge	C	NO SAMP	NO SAMP
24	28	MMS-28-FC	Sink	FC	Classroom 179 (Sp-Ed) Life Skills	C	11/12	5:27

PO

39 Mattawomen Middle School

First Draw

10145 Berry Road Waldorf, MD 20603

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

Flush

78010

25	29	MMS-29-BU	Bottle Filler	BU	Corridor	C	11/12	S:34
26	30	MMS-30-BU	Bottle Filler	BU	Corridor	C	11/12	S:23
27	31	MMS-31-BU	Bottle Filler	BU	cafeteria	C	11/12	S:24
49	1F	MMS-1F-FC	Sink - Left fixture	FC	Kitchen - Left Fixture on 3 Comp Sink	C		FLUSH S:53
50	2F	MMS-2F-FC	Sink - Right fixture	FC	Kitchen - Right Fixture on 3 Comp Sink	C		FLUSH S:53
51	4F	MMS-4F-FC	2 comp sink	FC	Kitchen	C		FLUSH S:53
52	5F	MMS-5F-FC	Island sink next to kettle	FC	Kitchen	C		FLUSH N/A
53	7F	MMS-7F-FC	Island sink	FC	Kitchen	C		FLUSH S:53



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Monday, February 3, 2025

Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 78011.

First Draw samples flushed by Martel on November 13, 2024 sampled by Martel on November 14, 2024.

Project Identification: MD HB 270

School: Nanjemoy Creek

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 78011	1	CLIENT SAMPLE IDENTIFICATION NCEEC-1-DC	Sample Date/Time 11/14/2024 04:32
---------------------	---	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 18:30 BJ

MARTEL NO. 78011	2	CLIENT SAMPLE IDENTIFICATION NCEEC-2-FC	Sample Date/Time 11/14/2024 04:32
---------------------	---	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 18:33 BJ

MARTEL NO. 78011	3	CLIENT SAMPLE IDENTIFICATION NCEEC-3-DC	Sample Date/Time 11/14/2024 04:44
---------------------	---	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 18:35 BJ

MARTEL NO. 78011	4	CLIENT SAMPLE IDENTIFICATION NCEEC-4-DC	Sample Date/Time 11/14/2024 04:44
---------------------	---	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 18:38 BJ

MARTEL NO. 78011	5	CLIENT SAMPLE IDENTIFICATION NCEEC-5-BU	Sample Date/Time 11/14/2024 04:32
---------------------	---	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 18:40 BJ

MARTEL NO. 78011	2F	CLIENT SAMPLE IDENTIFICATION NCEEC-2F-FC	Sample Date/Time 11/14/2024 04:37
---------------------	----	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/30/2025 18:42 BJ

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/14/24 4:32am End Date/Time: 11/14/24 4:44am

Sampler/Relinquished By: Neverson Simms-Clark Received at Martel by Date/Time: 11/15/24

75- Nanjemoy Creek

First Draw

5300 Turley Tayac Place Nanjemoy, MD 20662


ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78011

Martel #	Sample #	Location ID #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb)	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush	Sample Time
							Flush Date	
1	1	NCEEC-1-DC	water fountain	DC	pavillion	C	11/13	4:32
2	2	NCEEC-2-FC	kitchen sink	FC	pavillion lounge	C	11/13	4:32
3	3	NCEEC-3-DC	water fountain	DC	BS office bathroom (Girls) Left	C	11/13	4:44
4	4	NCEEC-4-DC	water fountain	DC	BS office bathroom (Boys) Right	C	11/13	4:44
5	5	NCEEC-5-BU	Bottle Filler	BU	Pavillion	C	11/13	4:32
6	2F	NCEEC-2F-FC	kitchen sink	FC	pavillion lounge	C		FLUSH 4:37

P03



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plata, MD 20646
Attention:

Monday, February 3, 2025

Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 78013.

First Draw samples flushed by Martel on November 14, 2024 sampled by Martel on November 15, 2024.

Project Identification: MD HB 270

School: PISOTA Middle School

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.



MARTEL NO. 78013	1	CLIENT SAMPLE IDENTIFICATION PIMS-1-DF-C	Sample Date/Time 11/15/2024 04:00
---------------------	---	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 20:42 BJ

MARTEL NO. 78013	2	CLIENT SAMPLE IDENTIFICATION PIMS-2-BF-C	Sample Date/Time 11/15/2024 04:00
---------------------	---	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 20:45 BJ

MARTEL NO. 78013	3	CLIENT SAMPLE IDENTIFICATION PIMS-3-FC	Sample Date/Time 11/15/2024 04:01
---------------------	---	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 20:47 BJ

MARTEL NO. 78013	4	CLIENT SAMPLE IDENTIFICATION PIMS-4-FC	Sample Date/Time 11/15/2024 04:01
---------------------	---	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 20:49 BJ

MARTEL NO. 78013	5	CLIENT SAMPLE IDENTIFICATION PIMS-5-FC	Sample Date/Time 11/15/2024 04:02
---------------------	---	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 20:52 BJ

MARTEL NO. 78013	6	CLIENT SAMPLE IDENTIFICATION PIMS-6-FC	Sample Date/Time 11/15/2024 04:03
---------------------	---	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 20:54 BJ

MARTEL NO. 78013	9	CLIENT SAMPLE IDENTIFICATION PIMS-9-DF-C	Sample Date/Time 11/15/2024 04:07
---------------------	---	---	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 21:04 BJ

MARTEL NO. 78013	10	CLIENT SAMPLE IDENTIFICATION PIMS-10-BF-C	Sample Date/Time 11/15/2024 04:07
---------------------	----	--	--------------------------------------

Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 21:09 BJ



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78013	12	PIMS-12-DF-C				11/15/2024 04:06	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 21:12 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78013	13	PIMS-13-BF-C				11/15/2024 04:06	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 21:14 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78013	3F	PIMS-3F-FC				11/15/2024 04:13	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 21:16 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78013	4F	PIMS-4F-FC				11/15/2024 04:18	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 21:19 BJ	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
78013	5F	PIMS-5F-FC				11/15/2024 04:18	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/30/2025 21:21 BJ	

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Charles County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Sample Start Date/Time: 11/15/24 4:00am End Date/Time: 11/15/24 4:18am

Sampler/Relinquished By: Neverson Simms-Glark Received at Martel by: Date/Time: 11/15/24

PISOTA Middle School

First Draw

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE SAMPLING BETWEEN THE HOURS OF 6 PM and 10 PM. WHEN SAMPLE TIMES ARE IDENTICAL, SAMPLING WAS PERFORMED IN LAB NUMBER ORDER

Martel NO:

78013

Martel #	Sample #	Location ID #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb)	Outlet Key Codes	Room/Location	Consumption C or NC?	Flush	Sample Time
							Flush Date	
1	1	PIMS-1-DF-C	Water Fountain	DF-C	Room 104 Café	C	11/14	4:00
2	2	PIMS-2-BF-C	Bottle Filler	BF-C	Room 104 Café	C	11/14	4:00
3	3	PIMS-3-FC	Sink	FC	Room 102A Kitchen	C	11/14	4:01
4	4	PIMS-4-FC	Sink	FC	Room 107 - Nurse	C	11/14	4:01
5	5	PIMS-5-FC	Sink	FC	Room 109 - Nurse	C	11/14	4:02
6	6	PIMS-6-FC	Sink	FC	Room 111 - Teacher Lounge	C	11/14	4:03
7	7	PIMS-7-DF-C	Water Fountain	DF-C	Corridor	C	NO SAMP	NO SAMP
8	8	PIMS-8-BF-C	Bottle Filler	BF-C	Corridor	C	NO SAMP	NO SAMP
9	9	PIMS-9-DF-C	Water Fountain	DF-C	Corridor - 2nd Floor	C	11/14	4:07
10	10	PIMS-10-BF-C	Bottle Filler	BF-C	Corridor - 2nd Floor	C	11/14	4:07
11	11	PIMS-11-FC	Sink	FC	Room 203 - Teacher Lounge - 2nd Floor	C	NO SAMP	NO SAMP
12	12	PIMS-12-DF-C	Water Fountain	DF-C	Corridor	C	11/14	4:06
13	13	PIMS-13-BF-C	Bottle Filler	BF-C	Corridor	C	11/14	4:06
14	3F	PIMS-3F-FC	Sink	FC	Room 102A Kitchen	C		FLUSH 4:13
15	4F	PIMS-4F-FC	Sink	FC	Room 107 - Nurse	C		FLUSH 4:18
16	5F	PIMS-5F-FC	Sink	FC	Room 109 - Nurse	C		FLUSH 4:18

P04