

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
RELEM 1	1/22/2025 05:56	1/28/2025 13:36	70334237001	Lead	<1.0	5	ug/L
RELEM 2	1/22/2025 05:58	1/28/2025 13:38	70334237002	Lead	2.9	5	ug/L
RELEM 3S	1/22/2025 05:59	1/28/2025 13:42	70334237003	Lead	<1.0	5	ug/L
RELEM 3DF	1/22/2025 05:59	1/28/2025 13:44	70334237004	Lead	<1.0	5	ug/L
RELEM 4S	1/22/2025 06:01	1/28/2025 13:46	70334237005	Lead	<1.0	5	ug/L
RELEM 4DF	1/22/2025 06:01	1/28/2025 13:47	70334237006	Lead	<1.0	5	ug/L
RELEM 5S	1/22/2025 06:02	1/28/2025 13:49	70334237007	Lead	<1.0	5	ug/L
RELEM 5DF	1/22/2025 06:03	1/28/2025 13:50	70334237008	Lead	<1.0	5	ug/L
RELEM 6S	1/22/2025 06:04	1/28/2025 13:52	70334237009	Lead	1.4	5	ug/L
RELEM 6DF	1/22/2025 06:04	1/28/2025 13:53	70334237010	Lead	<1.0	5	ug/L
RELEM 7S	1/22/2025 06:05	1/28/2025 13:55	70334237011	Lead	<1.0	5	ug/L
RELEM 7DF	1/22/2025 06:05	1/28/2025 13:57	70334237012	Lead	<1.0	5	ug/L
RELEM 8S	1/22/2025 06:07	1/28/2025 14:01	70334237013	Lead	<1.0	5	ug/L
RELEM 8DF	1/22/2025 06:07	1/28/2025 14:06	70334237014	Lead	<1.0	5	ug/L
RELEM 9S	1/22/2025 06:08	1/28/2025 14:10	70334237015	Lead	1.8	5	ug/L
RELEM 9DF	1/22/2025 06:08	1/28/2025 14:15	70334237016	Lead	<1.0	5	ug/L
RELEM 10S	1/22/2025 06:10	1/28/2025 14:20	70334237017	Lead	<1.0	5	ug/L
RELEM 11S	1/22/2025 06:11	1/28/2025 14:21	70334237018	Lead	<1.0	5	ug/L
RELEM 12S	1/22/2025 06:12	1/28/2025 14:23	70334237019	Lead	1.0	5	ug/L
RELEM 12DF	1/22/2025 06:12	1/28/2025 14:24	70334237020	Lead	<1.0	5	ug/L
RELEM 13S	1/22/2025 06:14	1/28/2025 14:26	70334237021	Lead	<1.0	5	ug/L
RELEM 15A	1/22/2025 06:16	1/28/2025 14:27	70334237022	Lead	1.2	5	ug/L
RELEM 15B	1/22/2025 06:16	1/28/2025 14:29	70334237023	Lead	14.0	5	ug/L
RELEM 17DF	1/22/2025 06:18	1/28/2025 14:31	70334237024	Lead	<1.0	5	ug/L
RELEM 17BF	1/22/2025 06:18	1/28/2025 14:32	70334237025	Lead	<1.0	5	ug/L
RELEM 20	1/22/2025 05:54	1/28/2025 14:34	70334237026	Lead	36.5	5	ug/L
RELEM 23	1/22/2025 06:20	1/28/2025 14:38	70334237027	Lead	<1.0	5	ug/L
RELEM 24	1/22/2025 06:21	1/28/2025 14:40	70334237028	Lead	<1.0	5	ug/L
RELEM 25	1/22/2025 06:22	1/28/2025 14:42	70334237029	Lead	<1.0	5	ug/L
RELEM 26	1/22/2025 06:23	1/28/2025 14:43	70334237030	Lead	<1.0	5	ug/L
RELEM 27	1/22/2025 06:24	1/28/2025 14:45	70334237031	Lead	1.9	5	ug/L
RELEM 28	1/22/2025 06:25	1/28/2025 14:46	70334237032	Lead	<1.0	5	ug/L
RELEM 29	1/22/2025 06:26	1/28/2025 11:40	70334237033	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb