

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:		1 = Damaged or significantly damaged TSI ACM 2 = Damaged friable surfacing ACM 3 = Significantly damaged friable surfacing ACM 4 = Damaged or significantly damaged friable miscellaneous ACM		5 = ACBM with potential for damage 6 = ACBM with potential for significant damage 7 = Remaining friable ACBM or friable suspect ACBM			
IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assessment Category
5 CAD #:	G1A	Sprayed-On Acoustical Finish 1974 Installation	THROUGHOUT 1974 ADDITION	160 Sq Ft	Y	>1 CH	5
Comments: RESIDUAL. INACCESSIBLE MATERIAL BETWEEN WALLS & CEILINGS.					Sample #: ACB-450W-A5; 2001-01112-5		
7 CAD #:	X0E	Miscellaneous Material Tackboard Adhesive (1974)	THROUGHOUT 1974 ADDITION	1000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
8 CAD #:	D1C	Boiler Gaskets Burner Gasket (Rope)	1974 ADDITION BASEMENT BOILER ROOM 0200	2 Sq Ft	Y	85 CH	5
Comments: TWO (2) GASKETS. FRAYED AROUND EDGES.					Sample #: 120208-MA-02		
10 CAD #:	D2C	Interior Boiler Insulation 1974 Addition	1974 ADDITION BASEMENT BOILER ROOM 0200	200 Sq Ft	N	ASSUMED	5
Comments: RECOMMEND SAMPLING PRIOR TO DISTURBANCE.					Sample #:		
12 CAD #:	X0A	Miscellaneous Material Incinerator Refractory	1974 ADDITION BASEMENT BOILER ROOM 0200	100 Sq Ft	N	ASSUMED	5
Comments: RECOMMEND SAMPLING PRIOR TO DISTURBANCE.					Sample #:		
13 CAD #:	X0B	Miscellaneous Material Incinerator Gaskets	1974 ADDITION BASEMENT BOILER ROOM 0200	1 Sq Ft	N	ASSUMED	5
Comments: TWO (2) GASKETS BETWEEN INCINERATOR & BURNERS.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
19 CAD #:	X0C	Miscellaneous Material Pipe Flange/Valve Gaskets (1974)	1974 ADDITION BASEMENT BOILER ROOM 0200	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
20 CAD #:	X0D	Miscellaneous Material Black AHU Seam Gaskets	1974 ADDITION BASEMENT BOILER ROOM 0200	10 Sq Ft	N	5 CH	5
Comments: ON "MCQUAY SEASONMASTER" AHU'S.					Sample #:		
24 CAD #:	X0D	Miscellaneous Material Black AHU Seam Gaskets	1974 ADDITION BASEMENT FAN ROOM 0203	50 Sq Ft	N	5 CH	5
Comments: ON "MCQUAY SEASONMASTER" AHU'S.					Sample #:		
29 CAD #:	X0D	Miscellaneous Material Black AHU Seam Gaskets	1974 ADDITION BASEMENT UNEXCAVATED AREA 0100	20 Sq Ft	N	5 CH	5
Comments: ON "MCQUAY SEASONMASTER" AHU'S.					Sample #:	120208-MA-12	
30 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	STAIRWELL 1399A (DOWN) EAST OF FACULTY LOUNGE 1302	16 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
31 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	STAIRWELL 1399A (DOWN) EAST OF FACULTY LOUNGE 1302	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		
34 CAD #:	V0A	Sink Undercoating Black	FACULTY LOUNGE 1302	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
43 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	MAINTENANCE OFFICE 1301	550 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
44 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1307	130 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:	2001-1501-AO-15	
45 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1307	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
47 CAD #:	V0C	Sink Undercoating Pink	ROOM 1315	3 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
48 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1308	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
49 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1308	4 Sq Ft	N	5 CH	5
Comments:					Sample #:		
50 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1309	200 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
51 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1309	4 Sq Ft	N	5 CH	5
Comments:					Sample #:		
52 CAD #:	V0C	Sink Undercoating Pink	ROOM 1313	3 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:	120308-MA-06	
56 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1310	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:	120308-MA-07	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
57 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1310	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
58 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	CLOSETS 1214 & 1215 OFF HALLWAY OUTSIDE POOL OFFICE	80 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #: 120308-MA-08		
59 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	HALLWAY 1210A OUTSIDE POOL OFFICE	100 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: CRACK NEAR DOOR ENTRY FROM HALL.					Sample #:		
60 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	POOL OFFICE 1210	170 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
63 CAD #:	X1I	Miscellaneous Material 2" Blue Ceramic Floor Tile System	POOL 1209	4000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
71 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	CUSTODIAL CLOSET 1205	40 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: CRACKED & CHIPPED TILE BY SINK.					Sample #: 310-WBSP-B		
73 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	STAIRWELL 1299A (DOWN) BY ROOM 1205	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		
74 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	STAIRWELL 1299A (DOWN) BY ROOM 1205	16 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
75 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	STAIRWELL 1299A (UP) BY ROOM 1206	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		
78 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	STAIRWELL 1299A (UP) BY ROOM 1206	45 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: INCLUDES ALL LANDINGS.					Sample #:		
82 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Brown Streaks	GYMNASIUM STORAGE 1207A	120 Sq Ft	N	8 CH (TILE), 12 CH (MASTIC)	5
Comments: CRACKING NEAR ENTRANCE.					Sample #: 120308-MA-10		
83 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Brown Streaks	GYMNASIUM STORAGE 1207B	120 Sq Ft	N	8 CH (TILE), 12 CH (MASTIC)	5
Comments: SMALL PIECE OF TILE MISSING BY ENTRANCE.					Sample #:		
84 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1204	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
85 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1204	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
86 CAD #:	V0D	Sink Undercoating Lavender w/Hook Faucets	ROOM 1321	16 Sq Ft	N	5 CH	5
Comments: TWO (2) DOUBLE SINKS.					Sample #: 120308-MA-09		
88 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1203	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
89 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1203	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
90 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1202	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
91 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1202	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
92 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	CUSTODIAL CLOSET 1142	15 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
94 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 1123 EAST STORAGE 1123C	75 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
96 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 1123 NORTH STORAGE 1123A	85 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
97 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1201	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
98 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1201	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
99 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	STAIRWELL 1201C (UP) BY ROOM 1201	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR. INSIDE EDGE CHIPPING. MONITOR.					Sample #:		
100 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	STAIRWELL 1201C (UP) BY ROOM 1201	250 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: INCLUDES ALL LANDINGS. TILE CHIPPED W/PIECES MISSING AT EXIT DOOR. INCLUDES REPLACEMENT TILES.					Sample #:		
102 CAD #:	S0C	Wood Floor Felt / Vapor Barrier 1974 Addition	SMALL GYMNASIUM 1122	820 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
105 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	SMALL GYMNASIUM 1122 STORAGE 1122A	60 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: ACCESS FROM SMALL GYMNASIUM.					Sample #:		
106 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1121	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments: TILE MISSING BY SMALL AHU W/EXPOSED MASTIC.					Sample #:		
107 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1121	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
108 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1120	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
109 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1120	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
110 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1119	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
111 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1119	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
112 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1116/1117 COMMON AREA	240 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
113 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1116/1117 COMMON AREA	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
114 CAD #:	V0C	Sink Undercoating Pink	ROOM 1116/1117 COMMON AREA	3 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
116 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1118	150 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
117 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1118	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
118 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 1114/1115 COMMON AREA	240 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:		
119 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1114/1115 COMMON AREA	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
120 CAD #:	V0C	Sink Undercoating Pink	ROOM 1114/1115 COMMON AREA	3 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
123 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1112/1113	8 Sq Ft	N	5 CH	5
Comments: TWO (2) SINKS.					Sample #:		
126 CAD #:	V0C	Sink Undercoating Pink	ROOM 1111	3 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
128 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1130 (SPEECH)	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
129 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1128	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
132 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 1103	200 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
137 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	SCIENCE ROOM STORAGE 1102B	80 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
138 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	SCIENCE ROOM STORAGE 1102A	42 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
139 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	STAIRWELL BY PLANETARIUM	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		
140 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	STAIRWELL BY PLANETARIUM	65 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: INCLUDES ALL LANDINGS.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
143 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	NURSE ROOMS 1134 & 1135	8 Sq Ft	N	5 CH	5
Comments: TWO (2) SINKS.					Sample #:		
144 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 1006 (CONFERENCE ROOM)	400 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
145 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 1318	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
147 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	CUSTODIAL CLOSET 1006A	20 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: INCLUDES REPLACEMENT TILES BY SINK.					Sample #:		
149 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ELEVATOR BY ROOM 1318	40 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: INCLUDES REPLACEMENT TILES.					Sample #:		
150 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	STORAGE ROOM 1140	45 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: ACROSS FROM ROOM 112.					Sample #:		
151 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	2ND FLOOR SOUTHWEST STAIRWELL 2299A	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR. TAG MISSING. CRACKED BUT REPAIRED.					Sample #:		
152 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 2108	15 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments: AT SINK.					Sample #:		
153 CAD #:	V0A	Sink Undercoating Black	ROOM 2108	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
154 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 2202	15 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments: AT SINK.					Sample #:		
155 CAD #:	V0A	Sink Undercoating Black	ROOM 2202	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
156 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 2313	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
157 CAD #:	V0A	Sink Undercoating Black	ROOM 2104	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:	120308-MA-14	
158 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 2104	15 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments: AT SINK.					Sample #:		
159 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	MEDIA CENTER STORAGE 2319 BY OFFICE	300 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments:					Sample #:	120308-MA-17	
160 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	MEDIA CENTER STORAGE 2319 BY OFFICE	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
161 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	STORAGE ROOM 2000B	30 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
163 CAD #:	V0A	Sink Undercoating Black	ROOM 2101	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
164 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	2ND FLOOR STAIRWELL 2099	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		
166 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 2004	15 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments: AT SINK.					Sample #:		
167 CAD #:	V0B	Sink Undercoating Lavender w/Gooseneck	ROOM 2004	4 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
168 CAD #:	V0A	Sink Undercoating Black	ROOM 2302	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
170 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 2308	15 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments: AT SINK. TILE CHIPPED IN CORNER W/PIECE MISSING.					Sample #:		
171 CAD #:	V0A	Sink Undercoating Black	ROOM 2308	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
172 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 2309	15 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments: AT SINK.					Sample #:		
173 CAD #:	V0A	Sink Undercoating Black	ROOM 2309	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
175 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	2ND FLOOR CUSTODIAL CLOSET 2212	80 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
176 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	2ND FLOOR STORAGE 2206A	25 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
177 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	2ND FLOOR STAIRWELL 2299B	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR. DOOR CRACKING AT HINGES.					Sample #:		
178 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	2ND FLOOR STAIRWELL 2299B	30 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
179 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Streaks & Dark Pits	ROOM 2210	15 Sq Ft	N	6 CH (TILE), 10 CH (MASTIC)	5
Comments: AT SINK.					Sample #:		
180 CAD #:	V0A	Sink Undercoating Black	ROOM 2210	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
181 CAD #:	V0A	Sink Undercoating Black	ROOM 2204	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #:		
182 CAD #:	P0A	Fire Doors Wood Composite - 1.5 Hr Rating (Weyerhaeuser)	2ND FLOOR STAIRWELL 2399	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
183 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	2ND FLOOR STAIRWELL 2399	120 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: 2ND FLOOR LANDING.					Sample #:		
187 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1924 Original Building (Elevated)	THROUGHOUT 1924 ORIGINAL BUILDING 2ND FLOOR	20000 Sq Ft	N	ASSUMED	5
Comments: MOST UNDER CARPET.					Sample #:		
193 CAD #:	W1B	1' x 1' Ceiling Tile Adhesive Associated w/I1B	ROOM 2506	150 Sq Ft	N	ASSUMED	5
Comments: ON WALLS.					Sample #:		
195 CAD #:	X1E	Miscellaneous Material Slate Chalkboard Adhesive (1924)	ROOM 2506	20 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARD.					Sample #:		
196 CAD #:	X1F	Miscellaneous Material Tackboard Adhesive (1924)	ROOM 2506	16 Sq Ft	N	ASSUMED	5
Comments: OUTSIDE WALL.					Sample #:		
199 CAD #:	X1E	Miscellaneous Material Slate Chalkboard Adhesive (1924)	ROOM 2505	20 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
200 CAD #:	X1F	Miscellaneous Material Tackboard Adhesive (1924)	ROOM 2505	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
202 CAD #:	X1E	Miscellaneous Material Slate Chalkboard Adhesive (1924)	ROOM 2504	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
204 CAD #:	X1F	Miscellaneous Material Tackboard Adhesive (1924)	ROOM 2504	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
205 CAD #:	X0K	Miscellaneous Material Metal Frame Corkboard (19xx)	ROOM 2504	36 Sq Ft	N	ASSUMED	5
Comments: THREE (3) BOARDS.					Sample #:		
206 CAD #:	X1A	Miscellaneous Material Pipe/Valve Flange Gaskets	1924 ORIGINAL BUILDING BOILER ROOM 0501	8 Sq Ft	N	65 CH	5
Comments: TWO (2) EXPOSED ON ABANDONED LINES.					Sample #:	120308-MA-02	
207 CAD #:	X1A	Miscellaneous Material Pipe/Valve Flange Gaskets	1924 ORIGINAL BUILDING WATER MAIN ROOM 0506	14 Sq Ft	N	65 CH	5
Comments:					Sample #:		
210 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 2601	75 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:	2001-1901-CPE-1C	
211 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 2602	75 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
213 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 2614	850 Sq Ft	N	4 CH (TILE), 5 CH (MASTIC)	5
Comments: UNDER CARPET. 3" X 15' STRIP OF CARPET MISSING W/TILE EXPOSED. PIECE OF TILE MISSING W/EXPOSED MASTIC.					Sample #:		
214 CAD #:	X1F	Miscellaneous Material Tackboard Adhesive (1924)	ROOM 2614	24 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
216 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Tan w/Brown & Beige Streaks	ROOM 2604	450 Sq Ft	N	12 CH (MASTIC)	5
Comments: UNDER CARPET. RECOMMEND ADDITIONAL SAMPLE OF TILE PRIOR TO DISTURBANCE.					Sample #:	120308-MA-22	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
219 CAD #:	X1E	Miscellaneous Material Slate Chalkboard Adhesive (1924)	ROOM 2604	10 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
220 CAD #:	X1F	Miscellaneous Material Tackboard Adhesive (1924)	ROOM 2604	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
224 CAD #:	X1E	Miscellaneous Material Slate Chalkboard Adhesive (1924)	ROOM 2605	20 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
225 CAD #:	X1F	Miscellaneous Material Tackboard Adhesive (1924)	ROOM 2605	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
227 CAD #:	X1E	Miscellaneous Material Slate Chalkboard Adhesive (1924)	ROOM 2606	30 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
228 CAD #:	X1F	Miscellaneous Material Tackboard Adhesive (1924)	ROOM 2606	80 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
233 CAD #:	S0B	Wood Floor Felt / Vapor Barrier 1925 Addition	1925 ADDITION CLASSROOMS	3000 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		