

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:	1 = Damaged or significantly damaged TSI ACM	5 = ACBM with potential for damage
	2 = Damaged friable surfacing ACM	6 = ACBM with potential for significant damage
	3 = Significantly damaged friable surfacing ACM	7 = Remaining friable ACBM or friable suspect ACBM
	4 = Damaged or significantly damaged friable miscellaneous ACM	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
9 CAD #:	X0D	Miscellaneous Material Green Duct Seam Caulk	THROUGHOUT BUILDING	100 Sq Ft	N	5 CH	5
Comments:					Sample #: 321-DC1-A		
10 CAD #:	X0E	Miscellaneous Material Dark Gray Duct Seam Caulk	THROUGHOUT BUILDING	100 Sq Ft	N	5 CH	5
Comments:					Sample #: 321-DC2-A		
11 CAD #:	X0F	Miscellaneous Material Dark Gray Duct Seam Putty	THROUGHOUT BUILDING	100 Sq Ft	N	10 CH	5
Comments:					Sample #: 321-DC3-A		
13 CAD #:	X0H	Miscellaneous Material Dark Brown Window Sill Caulk	THROUGHOUT BUILDING	200 Sq Ft	N	3 CH	5
Comments:					Sample #: 321-WS2-A		
14 CAD #:	X1B	Miscellaneous Material 1" x 1" Light Brown Ceramic Floor Tile System	THROUGHOUT BUILDING RESTROOMS	800 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
15 CAD #:	X1H	Miscellaneous Material 4" X 6" Beige Ceramic Baseboard System	THROUGHOUT BUILDING RESTROOMS	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
18 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1405 (CUSTODIAL OFFICE)	250 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: CRACKED TILE IN BACK OF ROOM UNDER SHELVES. WEARING UNDER DESK CHAIR. CHAIR MAT INSTALLED.					Sample #:		
19 CAD #:	V0A	Sink Undercoating Black	ROOM 1406	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
21 CAD #:	B3A	Pre-Formed Pipe Insulation	CRAWLSPACE	10 Lin Ft	Y	ASSUMED	1
Comments: MATERIAL IS INACCESSIBLE. DEBRIS ENCASED IN SOIL IN CONCRETE.					Sample #:		
32 CAD #:	X1A	Miscellaneous Material Pipe Flange Gaskets	BOILER ROOM 0406A	30 Sq Ft	N	25 CH	5
Comments: APPROXIMATELY THIRTY (30) FLANGES.					Sample #:	111708-MA-03	
33 CAD #:	X0W	Miscellaneous Material Black Dampproofing	BOILER ROOM 0406A	300 Sq Ft	N	ASSUMED	5
Comments: BEHIND PLASTER.					Sample #:		
38 CAD #:	X0W	Miscellaneous Material Black Dampproofing	ROOM 0406B (ELECTRICAL)	400 Sq Ft	N	ASSUMED	5
Comments: VISIBLE BEHIND PLASTER.					Sample #:		
44 CAD #:	X0X	Miscellaneous Material Tackboard Adhesive (1912)	ROOM 0404	50 Sq Ft	N	ASSUMED	5
Comments: THREE (3) BOARDS.					Sample #:		
46 CAD #:	T0A	Light Cord Insulation Fuzzy, White	ROOM 0202	6 Lin Ft	N	ASSUMED	5
Comments: MOUNTED AT CEILING. ONE (1) GRAY LIGHT FIXTURE.					Sample #:		
49 CAD #:	T0A	Light Cord Insulation Fuzzy, White	OFFICES 0204-0206	24 Lin Ft	N	ASSUMED	5
Comments: FOUR (4) MAROON FIXTURES STORED IN OFFICES. RECOMMEND REMOVAL IF NOT BEING USED.					Sample #:		
51 CAD #:	T0A	Light Cord Insulation Fuzzy, White	ROOM 0101	36 Lin Ft	N	ASSUMED	5
Comments: MOUNTED AT CEILING. SIX (6) LIGHT FIXTURES W/THREE (3) CORDS EACH. FOUR (4) COLORED GRAY, TWO (2) MAROON.					Sample #:		
52 CAD #:	I2A	2' x 2' Acoustical Ceiling Tile Gouges & Pin Holes	STAIRWELL TO OBSERVATION NORTH OFF ROOM 0101	96 Sq Ft	Y	ASSUMED	5
Comments:					Sample #:		
53 CAD #:	T0A	Light Cord Insulation Fuzzy, White	STAIRWELL TO OBSERVATION NORTH OFF ROOM 0101	18 Lin Ft	N	ASSUMED	5
Comments: THREE (3) FIXTURES. ONE (1) GRAY FIXTURE ON TOP OF METAL CABINET UNIT & TWO (2) MAROON FIXTURES INSIDE CABINET UNIT AT BOTTOM OF STAIRS. RECOMMEND REMOVAL IF NOT BEING USED.					Sample #:		
66 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1106	70 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
67 CAD #:	V0A	Sink Undercoating Black	ROOM 1106	10 Sq Ft	N	3 CH	5
Comments: ONE (1) DOUBLE SINK.					Sample #:		
70 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1201	210 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: TILE CHIPPED NEAR DOOR. TILE WEAR UNDER ROLLING CHAIR. RECOMMEND CHAIR MAT.					Sample #:		
74 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1202A	144 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
75 CAD #:	V0E	Sink Undercoating White	ROOM 1202A	5 Sq Ft	N	10 CH	5
Comments: ONE (1) SINK.					Sample #:		
78 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1203	15 Sq Ft	N	30 CH	5
Comments: CRACKED ON FRONT AT SOUTH END. PAINTED OVER.					Sample #:		
80 CAD #:	X1E	Miscellaneous Material 4" X 4" White Ceramic Wall Tile System	HANDWASH AREA OUTSIDE 2ND FLOOR RESTROOMS 1204 & 1205	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
82 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1318	720 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: CHIPPED TILE BEHIND TEACHER'S DESK. MONITOR. WEARING AT TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
83 CAD #:	V0E	Sink Undercoating White	ROOM 1318	8 Sq Ft	N	10 CH	5
Comments: DOUBLE SINK.					Sample #:		
86 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1303	25 Sq Ft	N	30 CH	5
Comments:					Sample #:		
88 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1304	25 Sq Ft	N	30 CH	5
Comments: CRACKED NEAR MIDDLE. MULTIPLE CHIPS ON TOP SURFACE.					Sample #:		
89 CAD #:	V0C	Sink Undercoating Deep Black	ROOM 1304	24 Sq Ft	N	5 CH	5
Comments: THREE (3) SINKS.					Sample #:		
93 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1308	25 Sq Ft	N	30 CH	5
Comments:					Sample #:		
94 CAD #:	J3C	Miscellaneous Cementitious Material Old Black Countertops	ROOM 1308	50 Sq Ft	N	25 CH	5
Comments: CHIPPED AT EAST END.					Sample #: 399-BLCK-A		
95 CAD #:	V0C	Sink Undercoating Deep Black	ROOM 1308	16 Sq Ft	N	5 CH	5
Comments: TWO (2) SINKS.					Sample #: 111808-MA-02		
100 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1317	30 Sq Ft	N	30 CH	5
Comments:					Sample #:		
103 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1407	500 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: TILE WEARING UNDER CHAIRS. CHAIR MATS INSTALLED. NINETEEN (19) TILES MISSING AT ENTRANCE, BLACK MASTIC EXPOSED. MONITOR.					Sample #:		
104 CAD #:	V0A	Sink Undercoating Black	ROOM 1407	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
106 CAD #:	V0A	Sink Undercoating Black	ROOM 1409	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
107 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1410	42 Sq Ft	N	30 CH	5
Comments:					Sample #:		
108 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1412	30 Sq Ft	N	30 CH	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
110 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1414	1200 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: TILE WEARING UNDER CHAIRS. CHAIR MATS INSTALLED. MONITOR.					Sample #:		
111 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1414	30 Sq Ft	N	30 CH	5
Comments:					Sample #:		
112 CAD #:	V0A	Sink Undercoating Black	ROOM 1414	45 Sq Ft	N	3 CH	5
Comments: FIVE (5) SINKS.					Sample #:		
114 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1415	60 Sq Ft	N	30 CH	5
Comments:					Sample #:		
115 CAD #:	V0A	Sink Undercoating Black	ROOM 1415	10 Sq Ft	N	3 CH	5
Comments: ONE (1) DOUBLE SINK.					Sample #:		
118 CAD #:	X1B	Miscellaneous Material 1" x 1" Light Brown Ceramic Floor Tile System	2ND FLOOR RESTROOMS 1417 & 1418	1250 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
120 CAD #:	K3D	Miscellaneous Flooring Old Membrane/Vapor Barrier (1977)	ROOM 1501 (GYMNASIUM)	12000 Sq Ft	N	ASSUMED	5
Comments: UNDER NEWER WOOD FLOOR (S0F).					Sample #:		
124 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1503 (PHY ED OFFICE)	290 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: WEARING AT DESK FROM CHAIR CASTERS. RECOMMEND CHAIR MAT.					Sample #:		
128 CAD #:	S0B	Wood Floor Felt / Vapor Barrier On Grade (1924)	ROOM 1505 (GYMNASTICS)	8000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
130 CAD #:	R0E	Baseboard/Mopboard Adhesive 4" Cream Baseboard	ROOM 1214	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
133 CAD #:	X1B	Miscellaneous Material 1" x 1" Light Brown Ceramic Floor Tile System	ROOM 1509 (MEN'S TEAM LOCKER ROOM)	3000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
135 CAD #:	X1B	Miscellaneous Material 1" x 1" Light Brown Ceramic Floor Tile System	ROOM 1510 (WOMEN'S TEAM LOCKER ROOM)	3000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
136 CAD #:	X1I	Miscellaneous Material 1" X 1" Cream Ceramic Floor Tile System	POOL 1512	3000 Sq Ft	N	ASSUMED	5
Comments: POOL DECK.					Sample #:		
137 CAD #:	X1J	Miscellaneous Material 1" X 1" White & Black Ceramic Pool Tile System	POOL 1512	4000 Sq Ft	N	ASSUMED	5
Comments: POOL.					Sample #:		
140 CAD #:	J3D	Miscellaneous Cementitious Material Thin, Black Tabletop	POOL MECHANICAL ROOM	12 Sq Ft	N	15 CH	5
Comments: ONE (1) TABLE. AT BACK WALL.					Sample #: 111708-MA-17		
141 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 1117 (WEIGHT ROOM)	30 Sq Ft	N	30 CH	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
145 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1116	430 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: LARGE CRACK THROUGH MIDDLE OF ROOM ON REPLACEMENT TILES. LOOSE TILES IN NORTH END. MONITOR. WEARING AT DESKS FROM CHAIR CASTERS. RECOMMEND CHAIR MAT.					Sample #: 111708-MA-19		
146 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1115	400 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: WEARING AT DESKS FROM CHAIR CASTERS. RECOMMEND CHAIR MAT. MONITOR.					Sample #:		
147 CAD #:	S0C	Wood Floor Felt / Vapor Barrier 1977 Addition (On Grade)	ROOM 1114	1550 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
150 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1119	600 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: WEARING UNDER CHAIRS.					Sample #:		
151 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1119A	220 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: SEVERAL TILES COMING LOOSE. MONITOR.					Sample #:		
154 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1119C	250 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: CRACKS IN TILE THROUGHOUT.					Sample #:		
155 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1120	600 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		
157 CAD #:	T0A	Light Cord Insulation Fuzzy, White	STORAGE CLOSET 2201C	6 Lin Ft	N	ASSUMED	5
Comments: ACCESS OFF SOUTH STAIRWELL TO AUDITORIUM. TWO (2) GRAY LIGHTS STORED. RECOMMEND REMOVAL IF NO LONGER USED.					Sample #:		
158 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 1215	400 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: CHIPPED AT DOOR W/EXPOSED MASTIC. MONITOR.					Sample #:		
159 CAD #:	K3B	Miscellaneous Flooring Black Floor Tile Mastic	STAIRWELL 1199A 2ND FLOOR LANDING	7 Sq Ft	N	5 CH	5
Comments: EXPOSED MATERIAL. POSSIBLY UNDER EPOXY.					Sample #: 312-FL-A, B, C		
169 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	CAFETERIA 2200	250 Sq Ft	N	30 CH	5
Comments:					Sample #:		
171 CAD #:	X1C	Miscellaneous Material 6" x 6" Light Brown Quarry Tile System	KITCHEN 2204/2302	1700 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
181 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 2102	250 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: WORN & SCRATCHED THROUGHOUT. BACK OF ROOM 2101.					Sample #: 2001-01108-11		
183 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2007	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
184 CAD #:	P1A	Safe Doors Metal	ROOM 2011 (VAULT)	20 Sq Ft	N	ASSUMED	5
Comments: APPEARS TO BE TRANSITE INSIDE.					Sample #:		
185 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 2011 (VAULT)	60 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
186 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2008	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
187 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2009 (PRINCIPAL)	20 Sq Ft	N	30 CH	5
Comments:					Sample #:		
188 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	OFFICE CONFERENCE ROOMS 2010A & 2010B	30 Sq Ft	N	30 CH	5
Comments:					Sample #:		
190 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2023	16 Sq Ft	N	30 CH	5
Comments:					Sample #:		
191 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2022	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
192 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2021	8 Sq Ft	N	30 CH	5
Comments:					Sample #:		
193 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2020	8 Sq Ft	N	30 CH	5
Comments:					Sample #:		
194 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2019	2 Sq Ft	N	30 CH	5
Comments:					Sample #:		
195 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2018	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
196 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2017	2 Sq Ft	N	30 CH	5
Comments:					Sample #:		
198 CAD #:	V0A	Sink Undercoating Black	OFFICE KITCHEN 2027	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
200 CAD #:	V0A	Sink Undercoating Black	OFFICE WORK ROOM 2001A	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
201 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	OFFICE COPY ROOM 2013	250 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: WEARING IN MIDDLE OF ROOM.					Sample #:		
203 CAD #:	V0A	Sink Undercoating Black	NURSE'S OFFICE - ROOM 2107	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #: 111808-MA-01		
204 CAD #:	X1F	Miscellaneous Material 4" X 4" Beige Ceramic Wall Tile System	NURSE'S RESTROOM 2107B	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
206 CAD #:	X1F	Miscellaneous Material 4" X 4" Beige Ceramic Wall Tile System	NURSE'S RESTROOM 2113A	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
208 CAD #:	X0L	Miscellaneous Material White Duct Seam Caulk	ROOM 2117 (MECHANICAL)	2 Sq Ft	N	8 CH	5
Comments: AT CORNERS.					Sample #: 111808-MA-03		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
228 CAD #:	X0W	Miscellaneous Material Black Dampproofing	ROOM 2510 (STORAGE/HALLWAY)	1000 Sq Ft	N	ASSUMED	5
Comments: <u>VISIBLE BEHIND PLASTER.</u>				Sample #:			
231 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 2510 (STORAGE/HALLWAY)	560 Sq Ft	N	8-10 CH (TILE & MASTIC)	5
Comments: <u>CHIPPED AND HEAVY WEAR THROUGHOUT W/EXPOSED MASTIC. MISSING TILE ON FAR END WITH EXPOSED MASTIC.</u>				Sample #: <u>310-TYPE-6-B</u>			
237 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 2511A	130 Sq Ft	N	8-10 CH (TILE & MASTIC)	5
Comments: <u>CRACKING TILE WITH EXPOSED MASTIC THROUGHOUT. MONITOR.</u>				Sample #: <u>310-TYPE-6-C</u>			
240 CAD #:	X0W	Miscellaneous Material Black Dampproofing	ROOM 2511C	500 Sq Ft	N	ASSUMED	5
Comments: <u>VISIBLE BEHIND PLASTER.</u>				Sample #:			
241 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Flecks	ROOM 2511C	160 Sq Ft	N	8-10 CH (TILE & MASTIC)	5
Comments: <u>CHIPPED TILE WITH EXPOSED MASTIC THROUGHOUT.</u>				Sample #: <u>310-TYPE-6-A</u>			
248 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 2403	1000 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: <u>SCRAPING NEAR DOOR. CHIPS & DENTS THROUGHOUT.</u>				Sample #:			
249 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2403	100 Sq Ft	N	30 CH	5
Comments:				Sample #:			
250 CAD #:	J3C	Miscellaneous Cementitious Material Old Black Countertops	ROOM 2403	75 Sq Ft	N	25 CH	5
Comments: <u>ALONG SOUTH WALL ONLY.</u>				Sample #: <u>399-BLCK-C</u>			
252 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 2304	1600 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: <u>TILE WEARING THROUGHOUT.</u>				Sample #:			
255 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2304	28 Sq Ft	N	30 CH	5
Comments:				Sample #:			
256 CAD #:	J3C	Miscellaneous Cementitious Material Old Black Countertops	ROOM 2304	100 Sq Ft	N	25 CH	5
Comments: <u>NORTH SIDE OF ROOM ONLY. INCLUDES FUME HOOD BASE.</u>				Sample #:			
258 CAD #:	J1A	Cementitious Panels Fume Hood - Gray Panels	ROOM 2304	40 Sq Ft	N	ASSUMED	5
Comments: <u>ONE (1) FUME HOOD.</u>				Sample #:			
259 CAD #:	J3D	Miscellaneous Cementitious Material Thin, Black Tabletop	ROOM 2305	12 Sq Ft	N	15 CH	5
Comments: <u>ONE (1) TABLE.</u>				Sample #:			
261 CAD #:	J3F	Miscellaneous Cementitious Material Black Sink/Counter w/Lip	ROOM 2305	30 Sq Ft	N	15 CH	5
Comments: <u>ON LIGHT TAN CABINETS.</u>				Sample #: <u>111808-MA-10</u>			
265 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2306	30 Sq Ft	N	30 CH	5
Comments:				Sample #:			
266 CAD #:	J3C	Miscellaneous Cementitious Material Old Black Countertops	ROOM 2306	36 Sq Ft	N	25 CH	5
Comments: <u>DEMONSTRATION TABLE.</u>				Sample #:			
267 CAD #:	J3D	Miscellaneous Cementitious Material Thin, Black Tabletop	ROOM 2306	12 Sq Ft	N	15 CH	5
Comments: <u>ONE (1) TABLE. PORTABLE.</u>				Sample #:			

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
268 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 2307	1600 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments:				Sample #:			
270 CAD #:	J3C	Miscellaneous Cementitious Material Old Black Countertops	ROOM 2307	140 Sq Ft	N	25 CH	5
Comments: DEMONSTRATION TABLE & COUNTERS ALONG SOUTH WALL.				Sample #:			
271 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2307	25 Sq Ft	N	30 CH	5
Comments:				Sample #:			
275 CAD #:	J1B	Cementitious Panels Chemical Storage Cabinet Lining	ROOM 2309 CHEMICAL STORAGE	45 Sq Ft	N	ASSUMED	5
Comments: USED AS LINING IN DARK WOODEN CHEMICAL STORAGE CABINET.				Sample #:			
276 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2309 CHEMICAL STORAGE	10 Sq Ft	N	30 CH	5
Comments: USED AS SHELVING IN WOODEN CHEMICAL STORAGE CABINET. ROOM INCORRECTLY LABELED "2308 MECH". CRACKED ON TOP SHELF.				Sample #:			
280 CAD #:	J3C	Miscellaneous Cementitious Material Old Black Countertops	ROOM 2311	325 Sq Ft	N	25 CH	5
Comments: ALL FIXED TABLES & COUNTERS. TWO (2) NEW SECTIONS & FUME HOOD INSTALLED 2011.				Sample #: 399-BLCK-B			
281 CAD #:	X0T	Miscellaneous Material Black Countertop Adhesive	ROOM 2311	5 Sq Ft	N	2 CH	5
Comments:				Sample #: 081011-JC-01			
282 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2311	24 Sq Ft	N	30 CH	5
Comments:				Sample #:			
283 CAD #:	X0U	Miscellaneous Material Window Caulk (1912)	ROOM 2311	4 Sq Ft	N	3 CH	5
Comments: AT WALL WITH ROOM 2312.				Sample #: 081011-JC-02			
285 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Beige w/Thin Tan Streaks	ROOM 2312	1120 Sq Ft	N	3 CH (TILE), 5 CH (MASTIC)	5
Comments: MULTIPLE CHIPPED AREAS SEALED WITH WAX.				Sample #:			
286 CAD #:	J3G	Miscellaneous Cementitious Material 1" Black Desk Tops	ROOM 2312	60 Sq Ft	N	15 CH	5
Comments: SIX (6) DESKS.				Sample #: 111808-MA-13			
289 CAD #:	J3C	Miscellaneous Cementitious Material Old Black Countertops	ROOM 2312	195 Sq Ft	N	25 CH	5
Comments: NORTH & WEST SIDE COUNTERS ONLY. ONE (1) NEW SECTION INSTALLED IN 2011.				Sample #:			
293 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2404	54 Sq Ft	N	30 CH	5
Comments:				Sample #:			
297 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2405	54 Sq Ft	N	30 CH	5
Comments:				Sample #:			
298 CAD #:	J3D	Miscellaneous Cementitious Material Thin, Black Tabletop	ROOM 2405	12 Sq Ft	N	15 CH	5
Comments: ONE (1) TABLE. PORTABLE. CHIPPED AT FRONT EDGE.				Sample #:			
301 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 2406	54 Sq Ft	N	30 CH	5
Comments:				Sample #:			
302 CAD #:	VOA	Sink Undercoating Black	ROOM 2407	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.				Sample #:			

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
304 CAD #:	V0A	Sink Undercoating Black	ROOM 2408	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
308 CAD #:	X0R	Miscellaneous Material Coarse White Proscenium Curtain	AUDITORIUM STAGE 2201A	600 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
314 CAD #:	V0A	Sink Undercoating Black	ROOM 3420	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
316 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3401	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
317 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3402	50 Sq Ft	N	30 CH	5
Comments: CHIPPED ON TOP AT SOUTH END.					Sample #:		
318 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3403	50 Sq Ft	N	30 CH	5
Comments: CHIPPED ON EDGE AT EAST END.					Sample #:		
319 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3404	40 Sq Ft	N	30 CH	5
Comments:					Sample #:		
321 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3405	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
322 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3406	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
323 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3407	40 Sq Ft	N	30 CH	5
Comments:					Sample #:		
325 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3408	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
326 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3409	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
331 CAD #:	V0A	Sink Undercoating Black	ROOM 3205	10 Sq Ft	N	3 CH	5
Comments: ONE (1) DOUBLE SINK.					Sample #:		
332 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3205	100 Sq Ft	N	30 CH	5
Comments:					Sample #:		
333 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3206	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
336 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3101	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
337 CAD #:	V0A	Sink Undercoating Black	ROOM 3118	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
338 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3102	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
339 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3103	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
340 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3104	40 Sq Ft	N	30 CH	5
Comments:					Sample #:		
341 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3105	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
343 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3106	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
344 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3107	40 Sq Ft	N	30 CH	5
Comments:					Sample #:		
346 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3108	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
347 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 3109/3110	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
354 CAD #:	S0E	Wood Floor Felt / Vapor Barrier 1912 Original Building (Elevated)	THROUGHOUT 5TH FLOOR CLASSROOMS 4101-4110	7000 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
360 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4101	50 Sq Ft	N	30 CH	5
Comments: CHIPPED AT MIDDLE OF FRONT EDGE.					Sample #:		
361 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4102	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
363 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4103	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
364 CAD #:	V0E	Sink Undercoating White	ROOM 4103	10 Sq Ft	N	10 CH	5
Comments: ONE (1) DOUBLE SINK.					Sample #: 502-GRA-B, C		
365 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown	ROOM 4104	480 Sq Ft	N	10 CH (TILE), 5 CH (MASTIC)	5
Comments: UNDER CARPET. WEST SIDE OF ROOM.					Sample #: 111908-MA-03		
366 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4104	50 Sq Ft	N	30 CH	5
Comments:					Sample #: 306-WS-A		
368 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown	ROOM 4105	300 Sq Ft	N	10 CH (TILE), 5 CH (MASTIC)	5
Comments: UNDER CARPET. EAST SIDE OF ROOM. ESTIMATED.					Sample #: 311-LB-A		
369 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4105	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
370 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Brown	ROOM 4106	330 Sq Ft	N	10 CH (TILE), 5 CH (MASTIC)	5
Comments: UNDER CARPET. EAST SIDE OF ROOM. ESTIMATED.					Sample #:		
371 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4106	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
372 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4107	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
374 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Gray	ROOM 4108	700 Sq Ft	N	10 CH (TILE)	5
Comments: UNDER CARPET. RECOMMEND ADDITIONAL SAMPLE OF MASTIC PRIOR TO DISTURBANCE.					Sample #: 311-GRA-A, B, C		
375 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4108	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
376 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Brown	ROOM 4109	600 Sq Ft	N	10 CH (TILE)	5
Comments: UNDER CARPET. RECOMMEND ADDITIONAL SAMPLE OF MASTIC PRIOR TO DISTURBANCE.					Sample #: 311-BRW-A, B, C		
377 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4109	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
378 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Dark Brown	ROOM 4110	960 Sq Ft	N	10 CH (TILE)	5
Comments: UNDER CARPET. RECOMMEND ADDITIONAL SAMPLE OF MASTIC PRIOR TO DISTURBANCE.					Sample #: 311-DB-A, B, C		
379 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4110	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
381 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4215	40 Sq Ft	N	30 CH	5
Comments:					Sample #:		
382 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4216	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
383 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4217	25 Sq Ft	N	30 CH	5
Comments:					Sample #:		
384 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4218	25 Sq Ft	N	30 CH	5
Comments:					Sample #:		
385 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4219	25 Sq Ft	N	30 CH	5
Comments:					Sample #:		
387 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4222	25 Sq Ft	N	30 CH	5
Comments:					Sample #:		
389 CAD #:	V0A	Sink Undercoating Black	MEDIA CENTER WORK ROOM 4202	10 Sq Ft	N	3 CH	5
Comments: ONE (1) DOUBLE SINK.					Sample #:		
394 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4401	50 Sq Ft	N	30 CH	5
Comments:					Sample #: 306-WS-B		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
395 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4402	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
396 CAD #:	K2J	12" x 12" Vinyl Floor Tile & Mastic Beige w/Tan Swirls	ROOM 4403	770 Sq Ft	N	10 CH (MASTIC)	5
Comments:					Sample #: 310-TYPE 2-A, B, C		
397 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4403	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
398 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4404	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
400 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4405	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
401 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4406	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
403 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4407	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
404 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4408	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
405 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4409	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
406 CAD #:	J3B	Miscellaneous Cementitious Material White Window Sills	ROOM 4410	50 Sq Ft	N	30 CH	5
Comments:					Sample #:		
408 CAD #:	P0B	Fire Doors Metal - .75 Hr Rating	JAMES GRIFFIN STADIUM CONFERENCE ROOM	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		
409 CAD #:	P0C	Fire Doors Metal - 1.5 Hr Rating	JAMES GRIFFIN STADIUM WEST TRAINER OFFICE	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		
410 CAD #:	P0B	Fire Doors Metal - .75 Hr Rating	JAMES GRIFFIN STADIUM NORTHEAST WOMEN'S RESTROOM ENTRYWAY	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		