

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:		1 = Damaged or significantly damaged TSI ACM 2 = Damaged friable surfacing ACM 3 = Significantly damaged friable surfacing ACM 4 = Damaged or significantly damaged friable miscellaneous ACM	5 = ACBM with potential for damage 6 = ACBM with potential for significant damage 7 = Remaining friable ACBM or friable suspect ACBM
-----------------------------------	--	--	--

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
10 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1932 Original Building (Elevated)	1932 ORIGINAL BUILDING ROOM 2204	615 Sq Ft	N	ASSUMED	5
Comments: <u>UNDER CARPET.</u>					Sample #:		
11 CAD #:	X0E	Miscellaneous Material Slate Chalkboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 2204	10 Sq Ft	N	ASSUMED	5
Comments: <u>BEHIND WHITEBOARDS.</u>					Sample #:		
12 CAD #:	X0F	Miscellaneous Material Wood Frame Tackboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 2204	60 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
13 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1932 Original Building (Elevated)	1932 ORIGINAL BUILDING ROOM 2205	615 Sq Ft	N	ASSUMED	5
Comments: <u>UNDER CARPET.</u>					Sample #:		
15 CAD #:	X0E	Miscellaneous Material Slate Chalkboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 2205	10 Sq Ft	N	ASSUMED	5
Comments: <u>BEHIND WHITEBOARDS.</u>					Sample #:		
16 CAD #:	X0F	Miscellaneous Material Wood Frame Tackboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 2205	60 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
17 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1932 Original Building (Elevated)	1932 ORIGINAL BUILDING ROOM 2206	615 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
18 CAD #:	X0E	Miscellaneous Material Slate Chalkboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 2206	10 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
19 CAD #:	X0F	Miscellaneous Material Wood Frame Tackboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 2206	60 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
20 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1932 Original Building (Elevated)	1932 ORIGINAL BUILDING ROOM 2203	615 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
21 CAD #:	X0E	Miscellaneous Material Slate Chalkboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 2203	10 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
22 CAD #:	X0F	Miscellaneous Material Wood Frame Tackboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 2203	60 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
24 CAD #:	X0F	Miscellaneous Material Wood Frame Tackboard Adhesive (1932)	1932 ORIGINAL BUILDING HALLWAY 2200	5 Sq Ft	N	ASSUMED	5
Comments: NEAR ROOM 2203.					Sample #:		
25 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Brown	1932 ORIGINAL BUILDING HALLWAY 2200	400 Sq Ft	N	8 CH (TILE), NONE DETECTED (MASTIC)	5
Comments: UNDER CARPET. CARPET IS WEARING NEAR NORTH STAIRWELL.					Sample #:		
26 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Black	1932 ORIGINAL BUILDING HALLWAY 2200	100 Sq Ft	N	8 CH (TILE), NONE DETECTED (MASTIC)	5
Comments: UNDER CARPET. BORDER TILE.					Sample #:		
28 CAD #:	X0Q	Miscellaneous Material Stone Panel Adhesive	GIRLS' RESTROOM 2207	80 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
32 CAD #:	X0N	Miscellaneous Material Slate Chalkboard Adhesive (1939)	1939 ADDITION ROOM 2201	10 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
33 CAD #:	X0O	Miscellaneous Material Tackboard Adhesive (1939)	1939 ADDITION ROOM 2201	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
36 CAD #:	X0N	Miscellaneous Material Slate Chalkboard Adhesive (1939)	1939 ADDITION ROOM 2208	10 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
37 CAD #:	X0O	Miscellaneous Material Tackboard Adhesive (1939)	1939 ADDITION ROOM 2208	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
45 CAD #:	X1P	Miscellaneous Material 1" X 1" Beige Ceramic Floor Tile System	1973 ADDITION LIBRARY 2100 & HALLWAYS	5 Sq Ft	N	ASSUMED	5
Comments: AT DRINKING FOUNTAIN.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
47 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 2104	45 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: SINK AREA. WEARING AT TEACHER'S DESK. SEALED WITH WAX. MONITOR.					Sample #:		
48 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2104	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
49 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 2103	45 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: NEAR SINK.					Sample #:		
50 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2103	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
52 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 2102	45 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: SINK AREA. WEARING AT TEACHER'S DESK. RECOMMEND WAX, CHAIR MAT, OR MOVE TEACHER'S DESK. MONITOR.					Sample #:		
53 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2102	5 Sq Ft	N	3 CH	5
Comments:					Sample #:		
56 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 2101	45 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: SINK AREA. MINIMAL WEARING NEAR CARPET EDGE. MONITOR.					Sample #:	2001-1901-ZZ-3C	
57 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2101	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
59 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION ROOM 2106	130 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments:					Sample #:		
61 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2107	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
63 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 2112	45 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: SINK AREA. WEAR AT CARPET EDGE, MONITOR.					Sample #:		
64 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2112	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
66 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 2111	45 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: SINK AREA.					Sample #:		
67 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2111	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
69 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 2110	45 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: SINK AREA. RUGS PLACED OVER TILE.					Sample #:		
70 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2110	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
71 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 2109	45 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: SINK AREA. WEARING AT TEACHER'S DESK. RECOMMEND CHAIR MAT.					Sample #:		
72 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 2109	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:		
73 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 1101 (CALMING ROOM)	50 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments: SINK AREA.					Sample #:	120108-MA-17	
74 CAD #:	V0C	Sink Undercoating Black (1973)	1973 ADDITION ROOM 1101 (CALMING ROOM)	5 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #:	120108-MA-18	
77 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION ROOM 1101A	100 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: TWO (2) TILES MISSING.					Sample #:		
80 CAD #:	X1Q	Miscellaneous Material 4" X 4" Yellow Ceramic Wall Tile System	GIRLS' RESTROOM 1122	176 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
81 CAD #:	X1R	Miscellaneous Material 1" X 1" Yellow Ceramic Floor Tile System	GIRLS' RESTROOM 1122	120 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
84 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION ROOM 1103	1100 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: UNDER CARPET EXCEPT IN SINK AREA.					Sample #:		
85 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION ROOM 1103	15 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: UNDER SINK.					Sample #:		
87 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION ROOM 1104	225 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments:					Sample #:		
89 CAD #:	K2F	12" x 12" Vinyl Floor Tile & Mastic Brown, Beige & Orange Mottle	1973 ADDITION ROOM 1102	30 Sq Ft	N	8 CH (TILE & MASTIC)	5
Comments:					Sample #:		
90 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION ROOM 1102A	215 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #:		
91 CAD #:	X1Q	Miscellaneous Material 4" X 4" Yellow Ceramic Wall Tile System	1973 ADDITION WOMEN'S STAFF RESTROOM 1110	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
92 CAD #:	X1R	Miscellaneous Material 1" X 1" Yellow Ceramic Floor Tile System	1973 ADDITION WOMEN'S STAFF RESTROOM 1110	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
94 CAD #:	X1S	Miscellaneous Material 4" X 4" Beige Ceramic Wall Tile System	1973 ADDITION MEN'S STAFF RESTROOM 1109	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
95 CAD #:	X1P	Miscellaneous Material 1" X 1" Beige Ceramic Floor Tile System	1973 ADDITION MEN'S STAFF RESTROOM 1109	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
96 CAD #:	V0D	Sink Undercoating Lavender	1973 ADDITION PHY ED OFFICE 1108	5 Sq Ft	N	5 CH	5
Comments: ONE (1) SINK.					Sample #: 120108-MA-19		
98 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION CUSTODIAL OFFICE 1105	150 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: CHAIR WEAR. CHAIR MAT INSTALLED. MONITOR.					Sample #:		
106 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION GYMNASIUM STORAGE 1100B BY SOUTHWEST STAIRWELL	15 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: WORN AT ENTRANCE. NO MASTIC EXPOSED.					Sample #:		
107 CAD #:	U0A	Light Pad Insulation Square (1973)	1973 ADDITION GYMNASIUM STORAGE 1100B BY SOUTHWEST STAIRWELL	1 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
110 CAD #:	X1S	Miscellaneous Material 4" X 4" Beige Ceramic Wall Tile System	1973 ADDITION GIRLS' LOCKER ROOM 1111	500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
111 CAD #:	X1P	Miscellaneous Material 1" X 1" Beige Ceramic Floor Tile System	1973 ADDITION GIRLS' LOCKER ROOM 1111	300 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
114 CAD #:	X1P	Miscellaneous Material 1" X 1" Beige Ceramic Floor Tile System	1973 ADDITION BOYS' LOCKER ROOM 1112	300 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
115 CAD #:	X1S	Miscellaneous Material 4" X 4" Beige Ceramic Wall Tile System	1973 ADDITION BOYS' LOCKER ROOM 1112	500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
119 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION RECREATION CENTER KITCHEN 1118	100 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: ASSUMED PRESENT UNDER NEWER QUARRY TILE.					Sample #: 120108-MA-20		
124 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1973 ADDITION DAYCARE OFFICE 1120	300 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: WEARING AT TEACHER'S DESK. COVERED W/CHAIR MAT. WEARING AT DOOR, USING A BRICK TO HOLD DOOR. REMOVE BRICK, USE A RUBBER OR WOOD STOP. MONITOR.					Sample #: 425-JJT-36		
125 CAD #:	X0L	Miscellaneous Material Slate Chalkboard Adhesive	1939 ADDITION ROOM 1214	3 Sq Ft	N	ASSUMED	5
Comments: ONE (1) CHALKBOARD. UNKNOWN INSTALLATION DATE.					Sample #:		
128 CAD #:	V0E	Sink Undercoating Black w/Hook Faucet	1939 ADDITION FACULTY LOUNGE 1209	6 Sq Ft	N	3 CH	5
Comments: ONE (1) SINK.					Sample #: 2001-1504-AA-3		
134 CAD #:	X0F	Miscellaneous Material Wood Frame Tackboard Adhesive (1932)	1932 ORIGINAL BUILDING HALLWAY 1200	5 Sq Ft	N	ASSUMED	5
Comments: ACROSS FROM DRINKING FOUNTAIN. NEAR ROOM 1204.					Sample #:		
136 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Tan w/Beige & Brown Streaks	1932 ORIGINAL BUILDING ROOM 1202	800 Sq Ft	N	8 CH (TILE), 10 CH (MASTIC)	5
Comments: MOST UNDER CARPET.					Sample #: 120108-MA-07		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
137 CAD #:	S0D	Wood Floor Felt / Vapor Barrier 1932 Original Building (On Grade)	1932 ORIGINAL BUILDING ROOM 1202	800 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET & FLOOR TILE. UNEXCAVATED AREA BELOW. MAY HAVE VAPOR BARRIER.					Sample #:		
138 CAD #:	X0E	Miscellaneous Material Slate Chalkboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 1202	10 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
139 CAD #:	X0F	Miscellaneous Material Wood Frame Tackboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 1202	60 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
140 CAD #:	V0A	Sink Undercoating Black w/Gooseneck Faucet	1932 ORIGINAL BUILDING ROOM 1202	6 Sq Ft	N	3 CH	5
Comments:					Sample #: 120108-MA-06		
142 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Tan w/Beige & Brown Streaks	1932 ORIGINAL BUILDING ROOM 1201	720 Sq Ft	N	8 CH (TILE), 10 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #:		
144 CAD #:	S0D	Wood Floor Felt / Vapor Barrier 1932 Original Building (On Grade)	1932 ORIGINAL BUILDING ROOM 1201	800 Sq Ft	N	ASSUMED	5
Comments: UNEXCAVATED AREA BELOW. MAY HAVE VAPOR BARRIER.					Sample #:		
145 CAD #:	X0E	Miscellaneous Material Slate Chalkboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 1201	10 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
146 CAD #:	X0F	Miscellaneous Material Wood Frame Tackboard Adhesive (1932)	1932 ORIGINAL BUILDING ROOM 1201	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
148 CAD #:	S0D	Wood Floor Felt / Vapor Barrier 1932 Original Building (On Grade)	1932 ORIGINAL BUILDING ROOMS 1001-1003	425 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET. UNEXCAVATED AREA BELOW. MAY HAVE VAPOR BARRIER.					Sample #:		
154 CAD #:	K3B	Miscellaneous Flooring Black Floor Tile Mastic (1953)	1953 ADDITION ROOM 1301	860 Sq Ft	N	8 CH	5
Comments: UNDER CARPET. TILE CODE WAS K0B.					Sample #: 120108-MA-10		
155 CAD #:	J1A	Cementitious Panels 1/8" Radiator Shields	1953 ADDITION ROOM 1301	18 Sq Ft	N	ASSUMED	5
Comments: BEHIND UNIVENT & SHORT SECTION OF CABINETS TO THE NORTH.					Sample #:		
158 CAD #:	K3B	Miscellaneous Flooring Black Floor Tile Mastic (1953)	1953 ADDITION ROOM 1302	860 Sq Ft	N	8 CH	5
Comments: UNDER CARPET.					Sample #:		
160 CAD #:	J1A	Cementitious Panels 1/8" Radiator Shields	1953 ADDITION ROOM 1302	18 Sq Ft	N	ASSUMED	5
Comments: BEHIND UNIVENT & SHORT SECTION OF CABINETS TO THE NORTH.					Sample #:		
163 CAD #:	K3C	Miscellaneous Flooring Black Floor Tile Mastic	1953 ADDITION ROOM 1303	860 Sq Ft	N	15 CH	5
Comments: UNDER CARPET. ASSOCIATED W/FORMER K0C TILE CODE.					Sample #: 425-JJT-27		
165 CAD #:	J1A	Cementitious Panels 1/8" Radiator Shields	1953 ADDITION ROOM 1303	18 Sq Ft	N	ASSUMED	5
Comments: BEHIND UNIVENT & SHORT SECTION OF CABINETS TO THE NORTH.					Sample #:		
168 CAD #:	K3B	Miscellaneous Flooring Black Floor Tile Mastic (1953)	1953 ADDITION ROOM 1304	860 Sq Ft	N	8 CH	5
Comments: UNDER CARPET.					Sample #:		
170 CAD #:	J1A	Cementitious Panels 1/8" Radiator Shields	1953 ADDITION ROOM 1304	18 Sq Ft	N	ASSUMED	5
Comments: BEHIND UNIVENT & SHORT SECTION OF CABINETS TO THE NORTH.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
173 CAD #:	K3B	Miscellaneous Flooring Black Floor Tile Mastic (1953)	1953 ADDITION ROOM 1305	1500 Sq Ft	N	8 CH	5
Comments: UNDER CARPET. ASSUMED TO BE UNDER 12" TILE.					Sample #:		
175 CAD #:	J1A	Cementitious Panels 1/8" Radiator Shields	1953 ADDITION ROOM 1305	175 Sq Ft	N	ASSUMED	5
Comments: BOTH WALL & CABINET SIDES.					Sample #:		
179 CAD #:	X1N	Miscellaneous Material 2" x 2" Brown Ceramic Floor Tile System	1953 ADDITION ROOM 1305 RESTROOM (1305A)	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
180 CAD #:	K3B	Miscellaneous Flooring Black Floor Tile Mastic (1953)	1953 ADDITION ROOM 1306	1500 Sq Ft	N	8 CH	5
Comments: UNDER CARPET. ASSUMED PRESENT UNDER 12" TILE.					Sample #:		
182 CAD #:	J1A	Cementitious Panels 1/8" Radiator Shields	1953 ADDITION ROOM 1306	175 Sq Ft	N	ASSUMED	5
Comments: BOTH WALL & CABINET SIDES.					Sample #:		
186 CAD #:	X1N	Miscellaneous Material 2" x 2" Brown Ceramic Floor Tile System	1953 ADDITION ROOM 1306 RESTROOM (1306A)	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
187 CAD #:	K2B	12" x 12" Vinyl Floor Tile & Mastic Light Gray w/White & Black Specks	1953 ADDITION DISHROOM 1308B	85 Sq Ft	N	2 CH (MASTIC ONLY)	5
Comments: MASTIC ONLY UNDER NEW QUARRY TILE SYSTEM.					Sample #: 425-JJT-31		
188 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Dark Gray w/White & Black Specks	1953 ADDITION DISHROOM 1308B	35 Sq Ft	N	3 CH (MASTIC ONLY)	5
Comments: MASTIC ONLY UNDER NEW QUARRY TILE SYSTEM.					Sample #: 425-JJT-32		
196 CAD #:	X1P	Miscellaneous Material 1" X 1" Beige Ceramic Floor Tile System	1953 ADDITION KITCHEN RESTROOM 1308A	16 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
198 CAD #:	T0A	Light Cord Insulation White, Fuzzy	1953 ADDITION CAFETERIA 1307	6 Lin Ft	N	ASSUMED	5
Comments: ONE (1) LIGHT W/TWO (2) CORDS.					Sample #:		
200 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Gray w/Beige Marbling	1953 ADDITION CAFETERIA STAGE BACK STAIR LANDING 1307	20 Sq Ft	N	ASSUMED	5
Comments: CRACKING NEAR DOOR.					Sample #:		
203 CAD #:	X1N	Miscellaneous Material 2" x 2" Brown Ceramic Floor Tile System	1953 ADDITION BOYS' RESTROOM 1309	200 Sq Ft	N	ASSUMED	5
Comments: INCLUDES CUSTODIAL CLOSET.					Sample #:		
206 CAD #:	X1N	Miscellaneous Material 2" x 2" Brown Ceramic Floor Tile System	1953 ADDITION GIRLS' RESTROOM 1310	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
209 CAD #:	X0K	Miscellaneous Material Dark Brown Caulk	1953 ADDITION HALLWAY 1300	2 Sq Ft	N	10 CH	5
Comments: AT EDGE OF PLASTER ABOVE LOCKERS.					Sample #: 120108-MA-14		
211 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1939 ADDITION BASEMENT STORAGE AREA 0208 OFF ELEVATOR	320 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: GO THROUGH ROOM 206					Sample #:		
212 CAD #:	R0E	Baseboard/Mopboard Adhesive 4' Dark Brown	1939 ADDITION BASEMENT STORAGE AREA 0208 OFF ELEVATOR	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
214 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown Streaks	1939 ADDITION BASEMENT ELECTRICAL ROOM 0207 BY STAIRWELL	100 Sq Ft	N	8-18 CH (TILE), 10-18 CH (MASTIC)	5
Comments: TWO (2) TILES MISSING, MASTIC REMOVED. CHIPPING AT DOOR W/EXPOSED MASTIC.					Sample #: 425-JJT-11		
215 CAD #:	X0D	Miscellaneous Material Dark Brown Tackboard Adhesive	1939 ADDITION BASEMENT ROOM 0205	40 Sq Ft	N	3 CH	5
Comments: TWO (2) TACKBOARDS.					Sample #: 120108-MA-04		
216 CAD #:	X0B	Miscellaneous Material Pipe/Valve Flange Gaskets	BOILER ROOM 0212	2 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
217 CAD #:	X0P	Miscellaneous Material White Paper Insulation Under & Above Fuses	ELECTRICAL ROOM 0210	20 Sq Ft	N	ASSUMED	5
Comments: LIMITED ACCESS. DO NOT EXAMINE UNLESS AN ELECTRICIAN IS PRESENT. ESTIMATED IN DISTRIBUTION PANEL DP-1.					Sample #:		